

DEC 03 1976

Docket No. 50-318

Baltimore Gas and Electric Company
ATTN: Mr. John W. Gore, Jr.
Vice President
Gas and Electric Building
Charles Center
Baltimore, Maryland 21203

Distribution

Docket File ✓	JPO'Reilly
NRC PDR	(Region I)
Local PDR	PKellogg
LWR #2 File	(Region I)
RSBoyd	FDreher
RCDeYoung	RShewmaker
DBVassallo	DEisenhut
HRood	LShao
KKniel	RBosnak
DZiemann	
RDiggs	
EReeves	

Gentlemen:

AUTHORIZATION TO OPERATE CALVERT CLIFFS UNIT NO. 2 IN MODE 1

Paragraph 2.C.5.a of Facility Operating License No. DPR-69, as amended, requires the resolution of two items relating to hydraulic snubbers, prior to operation of the plant in Operational Mode 1 (Power Operation). In your letter of December 2, 1976, you provided information addressing the two items. We have reviewed the information provided and conclude that, as required by the license, (1) you have acceptably demonstrated that the Hot Functional Testing conducted prior to fuel loading has not resulted in unacceptable overstressing of safety related systems due to improper restraint by inoperable snubbers, and (2) the snubber inspection and testing program required by Appendix A Technical Specification 3/4.7.8 provides adequate assurance that, during operation, inoperable snubbers will not cause unacceptable overstressing of safety related systems.

You are, therefore, authorized to operate the facility in Mode 1 in accordance with the conditions of the license as amended.

Sincerely,

Original signed by:
Roger S. Boyd
Roger S. Boyd, Director
Division of Project Management
Office of Nuclear Reactor Regulation

cc: See page 2

counter

OFFICE →	DPM:LWR #2	DPM:LWR #2	DOR:EE	DSS:MEB	DPM:AD/LWR	DPM
SURNAME →	HRood:mt	KKniel	LShao	RBosnak	DBVassallo	RSBoyd
DATE →	12/3/76	12/3/76	12/3/76	12/3/76	12/3/76	12/2/76

cc: Mr. James A. Biddison, Jr.
General Counsel
Gas and Electric Building
Charles Center
Baltimore, Maryland 21203

Mr. R. C. L. Olson
Room 922
Gas and Electric Building
Baltimore Gas and Electric Company
Charles Center
Baltimore, Maryland 21203

James C. Cawood, Jr., Esq.
Vice President
Chesapeake Environmental
Protection Association
4700 Auth Place
Camp Springs, Maryland 20023

George F. Trowbridge, Esq.
Shaw, Pittman, Potts & Trowbridge
910 17th Street, N. W.
Washington, D. C. 20006

Mr. R. L. Ashley
Chief Nuclear Engineer
Bechtel Power Corporation
P. O. Box 607
Gaithersburg, Maryland 20760

Mr. R. M. Douglas
Chief Engineer
Calvert Cliffs Nuclear Power Plant
Baltimore Gas and Electric Company
Lusby, Maryland 20657

Mr. J. A. Honey
Project Manager
Combustion Engineering, Inc.
P. O. Box 500
Windsor, Connecticut 06095

Dr. Steven Long
Power Plant Siting Program
Department of Natural Resources
B-3, Pawes
State Office Building
Annapolis, Maryland 21401

OFFICE ➤						
SURNAME ➤						
DATE ➤						