


# **Calvert Cliffs Containment Tendon Project**

**Presentation to the Nuclear Regulatory Commission  
Containment Tendon Project  
November 16, 2000**



**Calvert Cliffs Nuclear Power Plant, Inc.**

# Project Members

Mike Navin - Superintendent of Tech. Support  
Master Section

Joe Jaeger - System Manager

Donna Moeller - Senior Engineer - Nuclear  
Regulatory Matters

Jeff Poehler - Materials Engineer

Jon Woodfield - Civil Design Engineer

# Presentation Outline

## Purpose

- To discuss the corrective action plan


## Overview of Information

## Current Condition of Containment


## Corrective Actions

- Repair and Replacement
- Inspection Program


# Overview



# Original Design Grease Cap



# New Design Grease Cap



# Overview

## Future

### December Submittal Will Include:

- Response to questions received on 9/20/2000
- Number of tendons that will be replaced by end of 2002
- Actions to be taken on remaining tendon population
- Inspection Program

# Containment Tendon Project Goal

Ensure Containments Meet Design  
Requirements Until End of Life  
2034 and 2036




# Overview

## 2000 Activities

### Inspected Non-Corroded Tendons


- New Grease
- New End Caps
- No Additional Broken Wires

# Tendon Summary




2000-003

# U-1 Tendon Wire Summary



2000-003

# U-2 Tendon Wire Summary



# Planned Corrective Actions

Regrease Non-Corroded Vertical Tendons

Replace Vertical Tendon Caps and Gaskets

Replace Selected Vertical Tendons

Restress Vertical Tendons with Low  
Lift-Off

Enhance Inspection Plan

# Planned Corrective Action

## Selection Process for Vertical Tendon Replacement in 2002


Replace corroded tendons with at least 2 broken wires

Replace corroded tendons demonstrating lower liftoff forces


Replace corroded tendons to ensure uniform distribution of prestress

Replace corroded tendons to ensure uniform distribution after accounting for prestress loss of statistical model.

# Unit 1 1997 Running Force Distribution




# Unit 1 2034 Running Force Distribution w/ Tendon Replacement/Restressing and No Wire Breaks Considered







# Unit 1 2034 Running Force Distribution w/ Tendon Replacement/Restressing and Wire Breaks




# Unit 2 1997 Running Force Distribution



# Unit 2 2036 Running Force Distribution w/ Tendon Replacement/Restressing and No Wire Breaks Considered



# Unit 2 2036 Running Force Distribution w/Tendon Replacement/Restressing and Wire Breaks



2000-003

# Planned Corrective Action

Corroded Tendons

Number of Tendons Planned for Replacement

- Unit - 1 ~ 40
- Unit - 2 ~ 40

# Inspection Plan

## Code Required Inspections

- Lift-Offs
- Wire Examination and Testing
- Grease Composition Analysis
- Visual Inspections

## Enhanced Inspection

- Visual Inspections

# By End of 2001

## Project Work

- Regreasing Tendons
- Replacing End Caps
- Procuring Tendons
- Planning and Scheduling

# By End of 2002

## Code Inspection

- Complete Five-Year Tendon Surveillance
  - Increase sample size due to corrosion
  - Lift-offs on U-2 and visuals for U-1

## Enhanced Inspection

- Reinspect All Corroded Tendons For Broken Wires



# By End of 2005

## Enhanced Inspection

- Random sample of tendons visually inspected to verify that predictions of model are still bounding
- Correct statistical estimates for broken wires utilizing field results

# By End of 2007

## Code Inspection

- Complete Five-Year Tendon Surveillance
  - Increase sample size due to corrosion
  - Lift-offs on U-1 and visuals for U-2

## Enhanced Inspection

- Validate Statistical Model
  - Random sample of tendons visually inspected to verify that predictions of model are still bounding
  - Correct statistical estimates for broken wires utilizing field results

# At 5 Year Surveillance Intervals

## Code Inspection

- Complete Five-Year Tendon Surveillance
  - Increase sample size due to corrosion
  - Lift-offs and visuals inspections alternating between Units every Surveillance.

## Enhanced Inspection

- Validate Statistical Model
  - Random sample of tendons visually inspected to verify that predictions of model are still bounding
  - Correct statistical estimates for broken wires utilizing field results

# Conclusions

Combination of restressing and replacing containment tendons will ensure containment meets design requirements through 2034 (U-1) and 2036 (U-2)

Inspection program will ensure effectiveness of our corrective actions

## DRAFT

ADDITIONAL INFORMATION REQUEST  
PERTAINING TO THE MECHANICAL & CIVIL ENGINEERING BRANCH  
STAFF REVIEW OF THE "RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION  
CONCERNING THE CONTAINMENT TENDON LONG-TERM CORRECTIVE ACTION PLAN"  
SUBMITTED BY CALVERT CLIFFS NUCLEAR POWER PLANT, INC. DATED JULY 24, 2000  
(DOCKET NOS. 50-317 & 50-318)

References:

1. Calvert Cliffs Nuclear Power Plant, Inc. Letter to US NRC Titled, "Calvert Cliffs Nuclear Power Plant Unit Nos. 1 & 2; Docket Nos. 50-317 & 50-318, Response to Request for Additional Information Concerning the Containment Tendon Long-Term Corrective Action Plan (TAC Nos. MA7782 and MA7783), Dated July 24, 2000
2. BGE Letter to US NRC Titled, "Calvert Cliffs Nuclear Power Plant Unit Nos. 1 & 2; Docket Nos. 50-317 & 50-318, Revision to the Containment Tendon Long-Term Corrective Action Plan," dated December 7, 1999.

EMEB staff has completed its review of Calvert Cliffs Nuclear Power Plant, Inc.'s submittal dated July 24, 2000 (Ref. 1) and determined that additional information is needed in order to complete the review. The requested additional information is described in the following staff RAI:

1. Since the extended model for containment building vertical tendon degradation for Calvert Cliffs Units 1 and 2 discussed in attachment 1 to reference 1 is based on minimal data (i.e., limited data from 1997 and 1999 inspections) and several unverified assumptions, staff considers it is neither appropriate nor acceptable to rely solely upon the results of the model prediction in defining Calvert Cliffs' containment tendon long-term corrective action plan. The staff believes that it is essential for Calvert Cliffs Plant, Inc. to implement periodic future inspections of reasonable scope and frequency to verify that the model consistently predicts an upper bound to actual Calvert Cliffs' tendon degradation experience. Therefore, the licensee is requested to provide a periodic future inspection program with discussion of basis for the program contents which will amply fulfill the above noted need for verification.

As part of this information request, please indicate the completion status of your planned summer 2000 inspection which you expected to complete your evaluation by October 2000. As appropriate, discuss how did the latest inspection data verify the expected upper-bound characteristics of the model.

2. With respect to third paragraph, page 3 of reference 2, Calvert Cliffs Plant Inc. stated that, "...Depending on the results of the engineering analysis, replacement may be any number between 0 and 100 % of the 153 vertical tendons identified during the 1997 inspection to be severely corroded." Please discuss specific criteria to be used in deciding the final percentage of tendons to be replaced and the basis thereof. Also confirmed that the corrective action schedules described in the fourth paragraph of the same page will be maintained by Calvert Cliffs Plant, Inc.