

July 5, 1985

Docket No. 50-247

DISTRIBUTION

Mr. John D. O'Toole
Vice President
Nuclear Engineering and Quality Assurance
Consolidated Edison Company
of New York, Inc.
4 Irving Place
New York, New York 10003

Docket File	NRC PDR
LPDR	ORB#1Rdg
Gray File	HThompson
ORAB	MSlosson
JDNeighbors	CParrish
OELD	EJordan
BGrimes	JPartlow
TBarnhart 4	ACRS 10
CMiles	SECY
RDiggs	FRowsome

Dear Mr. O'Toole:

The Commission has issued the enclosed Rescission of Order for the Indian Point Nuclear Generating Unit No. 2. This rescission is based on the Commission's Decision CLI-85-06 dated May 7, 1985, and rescinds the requirements of the February 11, 1980, Order as set forth.

Sincerely,

/s/SAVarga

Steven A. Varga, Chief
Operating Reactors Branch #1
Division of Licensing

Enclosure:
As stated

cc w/enclosure:
See next page

ORB#1:DL
CParrish
6/16/85

ORB#1:DL
MSlosson
6/18/85

ORB#1:DL
JDNeighbors
6/18/85

BC-ORB#1:DL
SVarga
6/18/85

OELD
6/18/85

8507170251 850705
PDR ADOCK 05000247
PDR

Mr. John D. O'Toole
Consolidated Edison Company
of New York, Inc.

Indian Point Nuclear Generating
Station 1/2

cc:

Mayor, Village of Buchanan
236 Tate Avenue
Buchanan, New York 10511

Michael Blatt
Director Regulatory Affairs
Consolidated Edison Company
of New York, Inc.
Broadway and Bleakley Avenues
Buchanan, New York, 10511

Robert L. Spring
Nuclear Licensing Engineer
Consolidated Edison Company
of New York, Inc.
4 Irving Place
New York, New York 10003

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
Post Office Box 38
Buchanan, New York 10511

Brent L. Brandenburg
Assistant General Counsel
Consolidated Edison Company
of New York, Inc.
4 Irving Place - 1822
New York, New York 10003

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, Pennsylvania 19406

Carl R. D'Alvia, Esquire
Attorney for the Village of
Buchanan, New York
395 South Riverside Avenue
Croton-on-Hudson, New York 10520

Mr. Jay Dunkleberger
Office of Policy Analysis
and Planning
York State Energy Office
Building 2, Empire State Plaza
Albany, New York 12223

Ms. Ellyn Weiss
Sheldon, Harmon and Weiss
2001 S Street, NW, Suite 430
Washington, D.C. 20006

Director, Technical Development
Programs
State of New York Energy Office
Agency Building 2
Empire State Plaza
Albany, New York 12223

Mr. Peter Kokolakis, Director
Nuclear Licensing
New York Power Authority
123 Main Street
White Plains, New York 10601

Mr. Murray Selman
Vice President, Nuclear Power
Consolidated Edison Company of
New York, Inc.
Broadway and Bleakley Avenues
Buchanan, New York 10511

Mr. Frank Matra
Resident Construction Manager
Consolidated Edison Company
of New York, Inc.
Broadway and Bleakley Avenues
Buchanan, New York 10511

Ezra I. Bialik
Assistant Attorney General
Environmental Protection Bureau
New York State Department of Law
2 World Trade Center
New York, New York 10047

7590-01

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the Matter of

CONSOLIDATED EDISON COMPANY
OF NEW YORK, INC.

(Indian Point Nuclear Generating
Unit No. 2)

}
} Docket No. 50-247
}

RESCISSION OF ORDER

I.

In September of 1979, the Union of Concerned Scientists (UCS) filed a petition with the Commission pursuant to 10 C.F.R. § 2.206 requesting, among other things, that Indian Point Units 2 and 3 be shut down. The Director of the Office of Nuclear Reactor Regulation denied that part of the petition relating to the requested shutdown of the two Indian Point units.

Consolidated Edison Company of New York, Inc. (Indian Point, Units 1 and 2),
Power Authority of the State of New York (Indian Point, Unit 3), DD-80-5, 11
NRC 351 (1980). However, the Director imposed by Order certain interim requirements upon the Indian Point Units while an NRC Task Force determined what design changes should be made to further reduce the probability and/or consequences of a severe reactor accident. Id. at 370.

The Commission decided, in its discretion, to commence a special investigatory proceeding concerning the Indian Point plants in which one of the issues to be addressed was the risk reduction afforded by the requirements

8507170260 850705
PDR ADOCK 05000247
PDR

imposed by the Director in 1980. Consolidated Edison Company of New York, Inc. (Indian Point, Unit No. 2), Power Authority of the State of New York (Indian Point, Unit No. 3) CLI-81-1, 13 NRC 1 (1981). After hearing testimony on this issue the Licensing Board designated to preside over the proceeding concluded that the Director's Order resulted in some small positive benefit which was not amenable to quantification. Consolidated Edison Company of New York, Inc. (Indian Point, Unit No. 2), Power Authority of the State of New York (Indian Point, Unit No. 3), LBP-83-68, 18 NRC 811, 816 (1983).

The Commission, after reviewing the Licensing Board's recommendations, concluded that because the risk reduction effect of these measures is not sufficient to be termed substantial, the Director's measures should be rescinded unless they are required to fulfill generic requirements applicable to similar types of reactors, or are required to meet other license requirements for the Indian Point units. Consolidated Edison Company of New York (Indian Point, Unit No. 2), Power Authority of the State of New York (Indian Point, Unit No. 3) CLI-85-06 --NRC-- (1985) slip op at 26. This document implements the Commission's directive that these Orders be rescinded.

II.

Some of the requirements in Appendix A of the February 11, 1980 Order can be rescinded in full. Other items have been completed and the action is irreversible. In the case of the completed items, no further action is required. Items in these categories are:

<u>Rescind</u>	<u>Complete</u>
A.1	A.6
A.2	A.7
A.3	B.2
B.1	C.1
B.6	C.2
C.6	C.3
D.1.b	C.4
D.2	C.5
D.3	E.1.a
E.1.c	E.1.b
E.1.d	E.1.f
E.1.e	E.1.g
F.4	E.1.h
	E.1.i
	E.2
	F.1
	F.3
	F.5

Eight of the Order requirements are generic issues. In some cases, the specific Order requirement is rescinded when compliance with the generic issue is confirmed. These eight items and resolutions are:

1. Item A.4: The requirements for shift manning are set forth in 10 CFR 50.54. Therefore, the Order is rescinded for this item.

2. **Item A.5: LPI/RHR check valve operability.** Valve operability and leakage requirements are set forth in the NRC generic letter dated February 23, 1980. These requirements were imposed on most licensees other than the Indian Point licensees by Orders issued during April, 1981. The requirements of the generic letter set forth the staff's final position on this generic matter. Accordingly, the licensee shall follow the Order Item A.5 until Technical Specifications implementing the generic letter have been submitted to and approved by the NRC. Upon such approval the Order is rescinded with respect to this item.
3. **Item B.3: Requirements for notification for emergency action levels** are set forth in 10 CFR 50.72. Therefore, the Order is rescinded with respect to this item.
4. **Item B.4: Requirements for containment purge and vent operations in accordance with the staff's generic position on this matter** are set forth in the NRC Safety Evaluation Report dated September 29, 1983. Consistent with the actions taken generically with respect to other licensees, the SER calls for the submission of additional Technical Specifications. The licensee shall follow Order Item B.4 until Technical Specifications implementing the SER requirements have been submitted to and approved by the NRC. Upon such approval the Order is rescinded with respect to this item.
5. **Item B.5: Personnel training for the following items shall be in conformance with the requirements in NUREG-0737.** The requirements for these items are contained in an Order dated July 10, 1981. Similar Orders were issued generically to other licensees.

Containment and Degraded Core Sampling

Degraded Core - Training

Emergency Power for Pressurizer Heaters and Decay Heat Removal

Containment Isolation

Containment Purge/Purge Valve Operation

Subcooling Meter Operation

In-plant Area Radioiodine Monitors

Training requirements for the following four items shall conform to the training requirements of 10 CFR 50 Appendix E:

Technical Support Center

Onsite Operational Support Center

Near-Site Emergency Operations Center

Emergency Preparedness Plan

There are no generic requirements with respect to Surveillance Testing of non-ESF Filtration System Training.

For these reasons the Order is rescinded with respect to the above items.

6. Item B.7: Reactor operator qualifications shall conform to the requirements in NUREG-0737. This item is contained in an Order dated July 10, 1981. Similar Orders were issued generically to other licensees. Accordingly, this item is rescinded.
7. & 8. Item D.1.a: Emergency Preparedness manning levels and Item F.2: Meteorological acceptance criteria shall be in conformance with NUREG-0737, Supplement 1. Items D.1.a and F.2 are contained in an Order dated June 12, 1984, as supplemented March 11, 1985. Similar Orders were issued generically to other licensees. Accordingly, these items are rescinded.

III.

Accordingly, pursuant to the Commissioners Decision CLI-85-06 the requirements of the February 11, 1980 Order are rescinded in accordance with the terms set forth herein.

This rescission is effective upon issuance.

Original signed by
Darrell G. Eisenhut

Darrell G. Eisenhut, Deputy Director
Office of Nuclear Reactor Regulation

Dated in Bethesda, Maryland,
this 5th day of July, 1985.

*See previous white for concurrence

ORB#1:DL*	ORB#1:DL	ORB#1:DL*	BC-ORB#1:DL*	OELD*	AD-OR:DL*
CParrish	MSlosson;ps	JDNeighbors	SVarga		GLainas
6/18/85	6/ /85	6/24/85	6/24/85	6/28/85	6/26/85
AD/TECH*	D:DL*	DD NRR	D:DRD		
FRowsome	HThompson	DEisenhut	WBeitton		
6/24/85	6/27/85	7/5/85	6/15/85		

III.

Accordingly, pursuant to the Commissioners Decision CLI-85-06 the requirements of the February 11, 1980 Order are rescinded in accordance with the terms set forth herein.

This rescission is effective upon issuance.

Harold R. Denton, Director
Office of Nuclear Reactor Regulation

Dated in Bethesda, Maryland,
this day of

*See previous white for concurrence

ORB#1:DL*
CParrish
6/18/85

ORB#1:DL
MSTosson;ps
6/18/85

ORB#1:DL*
JDNeighbors
6/24/85

BC-ORB#1:DL*
SVarga
6/24/85

OELD* AD/OR:DL
GLainas
6/28 /85 6/9/85

AD/TECH*
FRowsome
6/24/85

D:DL
HThompson
6/21/85

D:NRR
DEisenhut
6/ /85

D:NRR
HDenton
6/ /85

III.

Accordingly, pursuant to the Commissioners Decision CLI-85-06 the requirements of the February 11, 1980 Order are rescinded except as noted in Section II.

This rescission is effective upon issuance.

Harold B. Denton, Director
Office of Nuclear Reactor Regulation

Dated in Bethesda, Maryland,
this day of

*See previous white for concurrence

ORB#1:DL*	ORB#1:DL	ORB#1:DL*	BC-ORB#1:DL*	OELD* AD-OR:DL
CParrish	MSlossonps	JDNeighbors	SVarga	GLainas
6/18/85	6/ /85	6/24/85	6/24/85	6/28 /85 6/ /85
AD/TECH*	D:DL	D:NRR		
FRowsome	DEisenhut	HDenton		
6/24/85	6/ /85	6/ /85	D:DL	D:NRR
HThompson	HDenton			
6/ /85	6/ /85			

Orders were issued generically to other licensees. Accordingly, these items are rescinded.

III.

Accordingly, pursuant to the Commissioners Decision CLI-85-06 the requirements of the February 11, 1980 Order are rescinded except as noted in Section II.

This rescission is effective upon issuance.

Harold R. Denton, Director
Office of Nuclear Reactor Regulation

Dated in Bethesda, Maryland,
this day of

*See previous white for concurrence

ORB#1:DL*
CParrish
6/ /85

ORB#1:DL
MSY
6/2/85

ORB#1:DL
Neighbors
6/4/85

BC-ORB#1:DL
SVarga
6/5/85

ORLD AD-OR:DL
GLainas
6/ /85

ADT
FRowsome
6/24/85

D:DL D:NRR
DEisenhut HDenton
6/ /85 6/ /85

[Handwritten signature]
[Handwritten notes: Clear with discussion with H.S.]

Near-Site Emergency Operations Center
Emergency Preparedness Plan

In-plant Area Airborne Radioidine Monitors Training shall be in conformance with NUREG-0737, Item III.D.3.3. This item was found acceptable by NRC letter dated February 19, 1982.

The above Order items as well as Surveillance Testing of non-ESF Filtration System Training are rescinded.

6. Item B.7: Reactor operator qualifications shall conform to the requirements in NUREG-0737. This item was found acceptable by letter dated August 24, 1982 and is rescinded.

7. & 8. Item D.1.a: Emergency Preparedness manning levels and Item F.2: Meteorological acceptance criteria shall be in conformance with NUREG-0737, Supplement 1. Items D.1.a and F.2 are contained in Orders dated June 12, 1984, as supplemented March 11, 1985. These items are rescinded.

III.

Accordingly, pursuant to the Commissioners Decision CLI-85-06 the requirements of the February 11, 1980 Order as rescinded except as noted in Section III.

This rescission is effective upon issuance.

Harold R. Denton, Director
Office of Nuclear Reactor Regulation

Dated in Bethesda, Maryland,
this day of

ORB#1:DL CParrish 6/1785	ORB#1:DL MSlosson;ps 6/ /85	ORB#1:DL JDNeighbors 6/ /85	OELD 6/ /85	BC-ORB#1:DL SVarga 6/ /85	AD-OR:DL GLainas 6/ /85
--------------------------------	-----------------------------------	-----------------------------------	----------------	---------------------------------	-------------------------------

D:DL HThompson 6/ /85	D:NRR HDenton 6/ /85
-----------------------------	----------------------------