

Distribution  
Docket File  
NRC PDR  
Local PDR  
ORB#1 Rdg.  
Gray file  
DEishnut  
CParrish  
PPolk  
MSlosson  
OELD  
ACRS (10)  
EJordan  
PMcKee

Docket No. 50-247

October 24, 1984

Mr. John D. O'Toole  
Vice President  
Consolidated Edison Company of New York  
4 Irving Place  
New York, New York 10003

Dear Mr. O'Toole:

SUBJECT: APPENDIX R EXEMPTION REQUEST REGARDING HEATING, VENTILATION AND AIR CONDITIONING (HVAC) EXHAUST FANS FOR THE INDIAN POINT NUCLEAR GENERATING PLANT, UNIT NO. 2 (IP-2)

By letter dated January 10, 1983 as supplemented by letters dated July 13, July 29 and September 9, 1983, you requested an exemption to Appendix R Section III.G with regard to HVAC exhaust fans. You proposed portable exhaust fans in charging and RHR pump rooms as an alternate cooling method. Additionally, you proposed to open a rollup door in order to provide the necessary cooling for safe shutdown equipment in the auxiliary feed pump room in the event the exhaust fan in this room fails due to fire. Based on our review of your exemption request, we find your proposed methods acceptable providing you: 1) store the portable exhaust fans onsite and provide the necessary procedures to instruct plant operators on the use of the exhaust fans in the charging and RHR pump rooms, and 2) provide instructions to the operators or plant operating procedures which specify when the rollup door in the auxiliary feed pump room should be opened.

Our review of your exemption request concerning HVAC exhaust fans will be completed upon receipt of your confirmation of compliance with the above stipulations. Your response is requested within 30 days of receipt of this letter.

Sincerely,

/s/SAVarga

Steven A. Varga, Chief  
Operating Reactors Branch #1  
Division of Licensing

cc:  
See next page

ORB#1:DL  
MSlosson/ts  
10/24/84

ORB#1:DL  
PPolk  
10/24/84

ORB#1:DL  
SVarga  
10/24/84

8411080643 841024  
PDR ADOCK 05000247  
PDR