

December 12, 2000  
PY-CEI/NRR-2532L

United States Nuclear Regulatory Commission  
Document Control Desk  
Washington, D.C. 20555


Perry Nuclear Power Plant  
Docket No. 50-440  
License No. NPF-58  
Monthly Operating Report

Ladies and Gentlemen:

Attached is the November 2000 Monthly Operating Report for Perry Unit 1. Page 1 is the Operating Data Report and page 2 is the Unit Shutdowns Chart. This report is submitted in accordance with Technical Specification 5.6.4 and Generic Letter 97-02, "Revised Contents of the Monthly Operating Report."

If you have questions or require additional information, please contact Ms. Toni Phelps at (440) 280-7660.

Very truly yours,



Gregory A. Dunn  
Manager - Regulatory Affairs

Attachment

cc: NRC Region III Administrator  
NRC Project Manager  
NRC Resident Inspector

IE24

# OPERATING DATA REPORT

UNIT: Perry  
DATE: 12/7/00

1. Docket: 50-440
2. Unit Name: Perry Nuclear Power Plant
3. Reporting Period: November 2000
4. Utility Contact: T. Phelps
5. Telephone: 440-280-7660
6. Design Electrical Rating (Net MWe): 1263\*
7. Maximum Dependable Capacity (Net MWe): 1223\*\*

	<u>This Month</u>	<u>Yr-to-Date</u>	<u>Cumulative</u>
8. Hours Reactor was Critical	<u>720.0</u>	<u>7,781.0</u>	<u>88,864.6</u>
9. Hours Generator On-Line	<u>720.0</u>	<u>7,762.7</u>	<u>86,618.2</u>
10. Unit Reserve Shutdown Hours	<u>0.0</u>	<u>0.0</u>	<u>0.0</u>
11. Net Electrical Energy (MWeH)	<u>888,814.0</u>	<u>9,209,849.0</u>	<u>97,945,130.0</u>

- \*The New Design Electrical Rating is based on the 105% uprate which will not be complete until March of 2001.
- \*\* The Maximum Dependable Capacity (Net MWe) is the lowest net capacity for the remainder of the year 2000, which included an uprate to 103.5% during June 2000. The new MDC was effective July 1, 2000.

## UNIT SHUTDOWNS REPORT MONTH – NOVEMBER 2000

DOCKET NO: 50-440  
 NAME: Perry Nuclear Power Plant  
 DATE: 12/7/00  
 CONTACT: T. Phelps  
 TELEPHONE: (440) 280-7660

No.	Date	Type 1	Duration Hours	Reason 2	Method 3	Cause and Corrective Action to Prevent Recurrence

**SUMMARY:** Perry Unit 1 was on-line for the entire month of November 2000.

- |  |   |   |
|--|---|---|
| <p>1. TYPE:<br/>         F: Forced<br/>         S: Scheduled</p> | <p>2. REASON:<br/>         A - Equipment Failure (explain)<br/>         B - Maintenance or Test<br/>         C - Refueling<br/>         D - Regulatory<br/>         E - Operating Training &amp;<br/>             License Examination<br/>         F - Administrative<br/>         G - Operational Error (explain)<br/>         H - Other (explain)</p> | <p>3. METHOD:<br/>         1 - Manual<br/>         2 - Manual Scram<br/>         3 - Automatic Scram<br/>         4 - Continuation<br/>         5 - Other</p> |
|--|---|---|