

August 5, 1988

Docket No. 50-247

DISTRIBUTION

~~Docket File~~
NRC PDR
Local PDR
PDI-1 Rdg.
SVarga
BBoger
CVogan

MSlosson
OGC
EJordan
BGrimes
PSwetland, RI
ACRS(10)
JCraig

Mr. Stephen B. Bram
Vice President, Nuclear Power
Consolidated Edison Company
of New York, Inc.
Broadway and Bleakley Avenue
Buchanan, New York 10511

Dear Mr. Bram:

SUBJECT: TEMPORARY WAIVER OF COMPLIANCE (TAC 69025)

In response to the Consolidated Edison (Con Ed) request dated August 4, 1988, as supplemented on August 5, 1988, the Commission herewith grants the following temporary waiver of compliance from 1) Technical Specification (TS) 5.2.C, "Containment Systems," TS Basis page 3.3-10 and 2) Table 9.6-1, "Essential Service Water Requirements at 75°F River Water Temperature," of the Updated Final Safety Analysis Report (UFSAR) to Facility Operating License No. DPR-26 for the Indian Point Nuclear Generating Unit No. 2.

This waiver is provided to permit Con Ed to operate at up to 100% rated thermal power with a service water temperature less than or equal to 87°F. Currently, the TS and plant design basis limit the maximum service water temperature limit to 85°F.

This waiver shall become effective upon Con Ed's completion of 1) the development of emergency operating procedures to maintain component cooling water heat exchanger outlet temperature at 150°F or less and 2) the training of the plant operators upon these emergency operating procedures.

Until the NRC staff completes the processing of the Con Ed emergency amendment request dated August 4, 1988, as supplemented on August 5, 1988, this waiver of compliance shall remain in effect.

Sincerely,

Original signed by

Bruce A. Boger, Assistant Director
for Region I Reactors
Division of Reactor Projects, I/II

cc: See next page

*SEE PREVIOUS CONCURRENCE

PDI-1
*CVogan
8/5/88

PDI-1 *Sam*
SMcNeil:dlg
8/5/88

SPLB
*JCraig
8/5/88

PDI-1 *Sam*
RCapra *for*
8/5/88

AD: PD1 *K*
BBoger
8/5/88

8808170288 880805
PDR ADOCK 05000247
PDC

PFO
1/1

Docket No. 50-247

DISTRIBUTION

Docket File
NRC PDR
Local PDR
PDI-1 Rdg.
SVarga
BBoger
CVogan

MSlosson
OGC
EJordan
BGrimes
PSwetland
ACRS(10)
JCraig

Mr. Stephen B. Bram
Vice President, Nuclear Power
Consolidated Edison Company
of New York, Inc.
Broadway and Bleakley Avenue
Buchanan, New York 10511

Dear Mr. Bram:

SUBJECT: WAIVER OF COMPLIANCE (TAC 69025)

In response to the Consolidated Edison (Con Ed) request dated August 4, 1988, as supplemented on August 5, 1988, the Commission herewith grants the following waiver of compliance from 1) Technical Specification (TS) 5.2.C, "Containment Systems," TS Basis page 3.3-10 and 2) Table 9.6-1, "Essential Service Water Requirements at 75°F River Water Temperature," of the Updated Final Safety Analysis Report (UFSAR) to Facility Operating License No. DPR-26 for the Indian Point Nuclear Generating Unit No. 2.

This waiver is provided to permit Con Ed to operate at up to 100% rated thermal power with a service water temperature less than or equal to 87°F. Currently, the TS and plant design basis limit the maximum service water temperature limit to 85°F.

This waiver shall become effective upon Con Ed's completion of 1) the development of emergency operating procedures to maintain component cooling water heat exchanger outlet temperature at 150°F or less and 2) the training of the plant operators upon these emergency operating procedures.

Until the NRC staff completes the processing of the Con Ed emergency amendment request dated August 4, 1988, as supplemented on August 5, 1988, this waiver of compliance shall remain in effect.

Sincerely,

Bruce A. Boger, Assistant Director
for Region I Reactors
Division of Reactor Projects, I/II

PDI-1
CVogan *CV*
8/5/88

PDI-1
SMcNeil:dlg
8/5/88

MSPLB
JCraig
8/5/88

PDI-1
RCapra
8/5/88

AD:PD1A
BBoger
8/5/88

Mr. Stephen B. Bram
Consolidated Edison Company
of New York, Inc.

Indian Point Nuclear Generating
Station 1/2

CC:

Mavor, Village of Buchanan
236 Tate Avenue
Buchanan, New York 10511

Ms. Donna Ross
New York State Energy Office
2 Empire State Plaza
16th Floor
Albany, New York 12223

Mr. Jude Del Percio
Manager of Regulatory Affairs
Consolidated Edison Company
of New York, Inc.
Broadway and Bleakley Avenue
Buchanan, New York 10511

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
Post Office Box 38
Buchanan, New York 10511

Mr. Brent L. Brandenburg
Assistant General Counsel
Consolidated Edison Company
of New York, Inc.
4 Irving Place - 1822
New York, New York 10003

Director, Technical Development
Programs
State of New York Energy Office
Agency Building 2
Empire State Plaza
Albany, New York 12223

Mr. Peter Kokolakis, Director
Nuclear Licensing
Power Authority of the State
of New York
123 Main Street
White Plains, New York 10601

Mr. Walter Stein
Secretary - NFSC
Consolidated Edison Company
of New York, Inc.
4 Irving Place - 1822
New York, New York 10003

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406