

December 8, 1994

Mr. Stephen E. Quinn  
Vice President, Nuclear Power  
Consolidated Edison Company of  
New York  
Broadway and Bleakley Avenue  
Buchanan, NY 10511

SUBJECT: ADMINISTRATIVE ERROR IN ISSUANCE OF AMENDMENT NO. 174,  
INDIAN POINT NUCLEAR GENERATING UNIT NO. 2 (TAC NO. M88862)

Dear Mr. Quinn:

By letter dated November 8, 1994, you advised us that Amendment No. 174, which was issued on July 29, 1994, and which addressed Technical Specification (TS) changes to extend containment isolation valve leak testing intervals to accommodate a 24-month fuel cycle, should have included a TS page which had been changed solely as a result of text spillover from the previous page. This page had inadvertently been omitted from the amendment application dated January 28, 1994. A corrected page was included with your November 8, 1994, letter.

To correct this administrative error, please substitute and distribute the corrected TS page which is enclosed.

Sincerely,

Original signed by

Francis J. Williams, Jr., Project Manager  
Project Directorate I-1  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Docket No. 50-247

Enclosure: As stated

cc w/encl: See next page

9412130116 941208  
PDR ADOCK 05000247  
P PDR

DOCUMENT NAME: H:\IP2\IP288862.COR

To receive a copy of this document, indicate in the box: "C" = Copy without enclosures "E" = Copy with enclosures "N" = No copy

OFFICE	LA:PDI-1	C	PM:PDI-1	E	D:PDI-1					
NAME	CVogan	CV	FWi/Trans:cn		MCaser					
DATE	12/5/94		12/6/94		12/6/94					

OFFICIAL RECORD COPY

120019

URG FILE CENTER COPY



UNITED STATES  
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

December 8, 1994

Mr. Stephen E. Quinn  
Vice President, Nuclear Power  
Consolidated Edison Company of  
New York  
Broadway and Bleakley Avenue  
Buchanan, NY 10511

SUBJECT: ADMINISTRATIVE ERROR IN ISSUANCE OF AMENDMENT NO. 174,  
INDIAN POINT NUCLEAR GENERATING UNIT NO. 2 (TAC NO. M88862)

Dear Mr. Quinn:

By letter dated November 8, 1994, you advised us that Amendment No. 174, which was issued on July 29, 1994, and which addressed Technical Specification (TS) changes to extend containment isolation valve leak testing intervals to accommodate a 24-month fuel cycle, should have included a TS page which had been changed solely as a result of text spillover from the previous page. This page had inadvertently been omitted from the amendment application dated January 28, 1994. A corrected page was included with your November 8, 1994, letter.

To correct this administrative error, please substitute and distribute the corrected TS page which is enclosed.

Sincerely,

A handwritten signature in cursive script, reading "Francis J. Williams, Jr.", is written over the typed name.

Francis J. Williams, Jr., Project Manager  
Project Directorate I-1  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Docket No. 50-247

Enclosure: As stated

cc w/encl: See next page

Stephen E. Quinn  
Consolidated Edison Company  
of New York, Inc.

cc:

Mayor, Village of Buchanan  
236 Tate Avenue  
Buchanan, NY 10511

Ms. Donna Ross  
New York State Energy Office  
2 Empire State Plaza  
16th Floor  
Albany, NY 12223

Mr. Charles W. Jackson  
Manager of Nuclear Safety and  
Licensing  
Consolidated Edison Company  
of New York, Inc.  
Broadway and Bleakley Avenue  
Buchanan, NY 10511

Senior Resident Inspector  
U. S. Nuclear Regulatory Commission  
P.O. Box 38  
Buchanan, NY 10511

Mr. Brent L. Brandenburg  
Assistant General Counsel  
Consolidated Edison Company  
of New York, Inc.  
4 Irving Place - 1822  
New York, NY 10003

Indian Point Nuclear Generating  
Station Units 1/2

Charles Donaldson, Esquire  
Assistant Attorney General  
New York Department of Law  
120 Broadway  
New York, NY 10271

Mr. Peter Kokolakis, Director  
Nuclear Licensing  
Power Authority of the State  
of New York  
123 Main Street  
White Plains, NY 10601

Mr. Walter Stein  
Secretary - NFSC  
Consolidated Edison Company  
of New York, Inc.  
4 Irving Place - 1822  
New York, NY 10003

Regional Administrator, Region I  
U. S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

The maximum permissible inleakage rate from the containment isolation valves sealed with service water for the full 12-month period of post-accident recirculation without flooding the internal recirculation pumps is 0.36 gpm per fan-cooler.

#### References

- (1) UFSAR - Section 5
- (2) UFSAR - Section 5.1.6
- (3) UFSAR - Section 14.3.6
- (4) UFSAR - Section 6.6
- (5) UFSAR - Section 6.5

9412140164 941208  
PDR ADDCK 05000247  
P PDR

DATED: December 8, 1994

CORRECTION TO AMENDMENT NO. 174 TO FACILITY OPERATING LICENSE NO. DPR-26-  
INDIAN POINT UNIT 2

Docket File

PUBLIC

PDI-1 Reading

S. Varga, 14/E/4

J. Zwolinski, 14/H/3

M. Case

C. Vogan

F. Williams

OGC

G. Hill (2), T-5 C3

C. Grimes, 11/E/22

ACRS (4)

OPA

OC/LFDCB

PD plant-specific file

C. Cowgill, Region I

R. Barrett, 8/H/7

cc: Plant Service list