

REGULATORY DOCKET FILE COPY

MAY 23 1980

Docket No. 50-247

DISTRIBUTION

Docket File 50-247

NRC PDR

Local PDR

TERA

NSIC

NRR Reading

ORBL Reading

H. Denton

D. Eisenhut

T. Novak

S. Varga

L. Olshan

C. Parrish

I&E (5)

B. Jones (4)

B. Scharf (10)

ACRS (16)

C. Miles

R. Diggs

C. Stephens

Mr. William J. Cahill, Jr.
Vice President
Consolidated Edison Company
of New York, Inc.
4 Irving Place
New York, New York 10003

Dear Mr. Cahill:

The Commission has issued the enclosed Amendment No. 61 to Facility Operating License No. DPR-26 for the Indian Point Nuclear Generating Unit No. 2. This amendment consists of changes to the Technical Specifications in response to your application transmitted by letter dated December 31, 1979.

The amendment revises the Technical Specifications to increase the staffing of the Station Nuclear Safety Committee and incorporates Standard Technical Specification provisions allowing the shift crew composition to be less than the minimum requirements for up to two hours provided immediate action is taken to restore the shift crew composition to within the minimum requirements.

Copies of the Safety Evaluation and the Notice of Issuance are also enclosed.

Sincerely,

Original signed by:

S. A. Varga

Steven A. Varga, Chief
Operating Reactors Branch #1
Division of Licensing

Enclosures:

1. Amendment No. 61 to DPR-26
2. Safety Evaluation
3. Notice of Issuance

cc: w/enclosures
See next page

8 0061 30 208 P

13285-complete

*SEE PREVIOUS YELLOW FOR CONCURRENCE

OFFICE	DL:ORB1	DL:ORB1	DL:ORB1	DL:AD ORP	OELD
SURNAME	LNolshan:jb*	CSParrish*	SAVarga*	TNovak	S.H. Lewis
DATE	05/ /80	05/ /80	05/ /80	05/15/80	05/19/80

DISTRIBUTION

Docket File 50-28847

NRC PDR

Local PDR

TERA

NSIC

NRR Reading

ORB1 Reading

H. Denton

D. Eisenhut

T. Novak

S. Varga

L. Olshan

C. Parrish

I&E (5)

B. Jones (4)

B. Scharf (10)

ACRS (16)

C. Miles

R. Diggs

C. Stephens

Docket No. 50-247

Mr. William J. Cahill, Jr.
Vice President
Consolidated Edison Company
of New York, Inc.
4 Irving Place
New York, New York 10003

Dear Mr. Cahill:

The Commission has issued the enclosed Amendment No. to Facility Operating License No. DPR-26 for the Indian Point Nuclear Generating Unit No. 2. This amendment consists of changes to the Technical Specifications in response to your application transmitted by letter dated December 31, 1979.

The amendment revises the Technical Specification to increase the staffing of the Station Nuclear Safety Committee and to allow the shift crew composition to be less than the minimum requirements for up to two hours.

Copies of the Safety Evaluation and the Notice of Issuance are also enclosed.

Sincerely,

Steven A. Varga, Chief
Operating Reactors Branch #1
Division of Licensing

Enclosures:

1. Amendment No. to DPR-26
2. Safety Evaluation
3. Notice of Issuance

cc: w/enclosures
See next page

13285-complete

SAV
5/14/80

OFFICE >	DL:ORB1	DL:ORB1 <i>gp</i>	DL:ORB1	DL:AD:ORP	OELD
BURNAME >	LOlshan:jb	CSParrish	SAVarga	TNovak	
DATE >	05/8/80	05/8/80	05/12/80	05/ /80	05/ /80



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

Docket No. 50-247

May 23, 1980

Mr. William J. Cahill, Jr.
Vice President
Consolidated Edison Company
of New York, Inc.
4 Irving Place
New York, New York 10003

Dear Mr. Cahill:

The Commission has issued the enclosed Amendment No. 61 to Facility Operating License No. DPR-26 for the Indian Point Nuclear Generating Unit No. 2. This amendment consists of changes to the Technical Specifications in response to your application transmitted by letter dated December 31, 1979.

The amendment revises the Technical Specifications to increase the staffing of the Station Nuclear Safety Committee and incorporates Standard Technical Specification provisions allowing the shift crew composition to be less than the minimum requirements for up to two hours provided immediate action is taken to restore the shift crew composition to within the minimum requirements.

Copies of the Safety Evaluation and the Notice of Issuance are also enclosed.

Sincerely,

A handwritten signature in dark ink, appearing to read "Steven A. Varga".

Steven A. Varga, Chief
Operating Reactors Branch #1
Division of Licensing

Enclosures:

1. Amendment No. 61 to DPR-26
2. Safety Evaluation
3. Notice of Issuance

cc: w/enclosures.
See next page

Mr. William J. Cahill, Jr.
Consolidated Edison Company of New York, Inc. - 2 - May 23, 1980

cc: White Plains Public Library
100 Martine Avenue
White Plains, New York 10601

Joseph D. Block, Esquire
Executive Vice President
Administrative
Consolidated Edison Company
of New York, Inc.
4 Irving Place
New York, New York 10003

Richard Remshaw
Nuclear Licensing Engineer
Consolidated Edison Company
of New York, Inc.
4 Irving Place
New York, New York 10003

Ms. Ellyn Weiss
Sheldon, Harmon and Weiss
1725 I Street, N.W., Suite 506
Washington, D. C. 20006

Dr. Lawrence R. Quarles
Apartment 51
Kendal at Longwood
Kennett Square, Pennsylvania 19348

Theodore A. Rebelowski
Resident Inspector
U. S. Nuclear Regulatory Commission
P. O. Box 38
Buchanan, New York 10511

John D. O'Toole
Assistant Vice President
Consolidated Edison Company
of New York, Inc.
4 Irving Place
New York, New York 10003

Carl R. D'Alvia, Esquire
Attorney for the Village of
Buchanan, New York
395 South Riverside Avenue
Croton-on-Hudson, New York 10520

Jeffrey C. Cohen, Esquire
New York State Energy Office
Swan Street Building
CORE 1 - Second Floor
Empire State Plaza
Albany, New York 12223

Director, Technical Development
Programs
State of New York Energy Office
Agency Building 2
Empire State Plaza
Albany, New York 12223

Director, Technical Assessment Division
Office of Radiation Programs (AW-459)
U. S. Environmental Protection Agency
Crystal Mall #2
Arlington, Virginia 20460

U. S. Environmental Protection Agency
Region II Office
ATTN: EIS COORDINATOR
26 Federal Plaza
New York, New York 10007

Joyce P. Davis, Esquire
Law Department
Consolidated Edison Company
of New York, Inc.
4 Irving Place
New York, New York 10003



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC.

DOCKET NO. 50-247

INDIAN POINT NUCLEAR GENERATING UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 61
License No. DPR-26

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Consolidated Edison Company of New York, Inc. (the licensee) dated December 31, 1979, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

8006130214 P

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-26 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 61, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Steven A. Varga, Chief
Operating Reactors Branch #1
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: May 23, 1980

ATTACHMENT TO LICENSE AMENDMENT NO. 61

FACILITY OPERATING LICENSE NO. DPR-26

DOCKET NO. 50-247

Revise Appendix A as follows:

Remove Pages

6-4
6-5
6-6

Insert Pages

6-4
6-5
6-6

Table 6.2-1

Minimum Shift Crew Composition**

License Category	During Operations Involving Core Alterations	During Cold Shutdown or Refueling Periods	At All Other Times
Senior Operator License	2*	1	1
Operator License	1	1	2
Non-Licensed	(As Required)	1	2

*Includes individual with SRO license supervising fuel movement as per Section 6.2.2(e).

**Shift crew composition may be one less than the minimum requirements for a period of time not to exceed 2 hours in order to accommodate unexpected absence of on duty shift crew members provided immediate action is taken to restore the shift crew composition to within the minimum requirements of Table 6.2-1.

6.3.2 The Department Manager shall meet or exceed the minimum qualifications specified for Plant Manager in ANSI N18.1-1971.

6.4 TRAINING

6.4.1 A retraining and replacement training program for the facility staff shall be maintained under the direction of the Nuclear Training Director and shall meet or exceed the requirements and recommendations of Section 5.5 of ANSI N18.1-1971 and Appendix "A" of 10 CFR Part 55.

6.4.2 A training program for the Fire Brigade shall be maintained under the direction of the Nuclear Training Director and shall meet or exceed the requirements of Section 27 of the NFPA Code-1976 with the exception of the training program schedule.

6.5 REVIEW AND AUDIT

6.5.1 STATION NUCLEAR SAFETY COMMITTEE (SNSC)

FUNCTION

6.5.1.1 The Station Nuclear Safety Committee shall function to advise the Department Manager on all matters related to nuclear safety.

COMPOSITION

6.5.1.2 The Station Nuclear Safety Committee shall, as a minimum, be composed as follows:

Chairman:	Plant Manager
Member:	Technical Engineering Director
Member:	Quality Assurance Engineer
Member:	Chief Operations Engineer
Member:	Security Supervisor
Member:	Test and Performance Engineer
Member:	Instrument and Control Engineer
Member:	Maintenance Engineer
Member:	Chemistry and Radiation Safety Director
Member:	Reactor Engineer
Member:	Department Manager
Member:	Refueling Engineer
Member:	Assistant Chief Field Engineer (Eng. Dept.)
Member:	QA Field Office Manager (QA & R Dept.)

6.5.1.2.1 In addition, other technically competent individuals may be appointed by the SNSC Chairman to serve as SNSC members.

ALTERNATES

6.5.1.3 Alternate members shall be appointed in writing by the SNSC Chairman to serve on a temporary basis.

MEETING FREQUENCY

6.5.1.4 The SNSC shall meet at least once per calendar month and as convened by the SNSC Chairman.

QUORUM

6.5.1.5 A quorum of the SNSC shall consist of the Chairman or Vice Chairman and a majority of the committee members including no more than two alternates.

RESPONSIBILITIES

6.5.1.6 The Station Nuclear Safety Committee shall be responsible for:

- a. Review of 1) all procedures required by Specification 6.8 and changes thereto, and 2) any other proposed procedures or changes thereto as determined by the Department Manager to affect nuclear safety.
- b. Review of all proposed tests and experiments that affect nuclear safety.
- c. Review of all proposed changes to the Technical Specifications.
- d. Review of all proposed changes or modifications to plant systems or equipment that affect nuclear safety.
- e. Investigation of all violations of the Technical Specifications and preparation and forwarding of a report covering evaluation and recommendations to prevent recurrence to the Manager, Nuclear Power Generation Department and to the Chairman of the Nuclear Facilities Safety Committee.
- f. Review of facility operations to detect potential safety hazards.
- g. Performance of special reviews and investigations and the issuance of reports thereon as required by the Chairman of the Nuclear Facilities Safety Committee.
- h. Review of the Plant Security Plan and implementing procedures and submission of recommended changes to the Chairman of the Nuclear Facilities Safety Committee.
- i. Review of the Emergency Plan and implementing procedures and submission of recommended changes to the Chairman of the Nuclear Facilities Safety Committee.

AUTHORITY

6.5.1.7 The Station Nuclear Safety Committee shall:

- a. Recommend to the Department Manager, in writing, approval or disapproval of items considered under 6.5.1.6(a) through (d) above.
- b. Render determinations in writing with regard to whether or not each item considered under 6.5.1.6(a) through (e) above constitutes an unreviewed safety question.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION
RELATED TO AMENDMENT NO. 61 TO FACILITY OPERATING LICENSE NO. DPR-26

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC.

INDIAN POINT NUCLEAR GENERATING UNIT NO. 2

DOCKET NO. 50-247

Introduction

By letter dated December 31, 1979, Consolidated Edison Company of New York (the licensee) requested amendment of Facility Operating License DPR-26 for Indian Point Nuclear Generating Unit No. 2 to increase the membership of the Station Nuclear Safety Committee (SNSC). In addition, the licensee verbally requested a change that would allow the shift crew composition to be less than the minimum requirements for a period of time not to exceed two hours.

Evaluation

The proposed change adds the Assistant Chief Field Engineer and the Quality Assurance Field Office Manager to the SNSC and allows the SNSC Chairman to appoint other technically competent individuals to serve as SNSC members. The licensee has proposed this change in recognition of a recommendation of the Kemeny Commission (Recommendation B.5) that "substantially more attention and care must be devoted to the writing, reviewing, and monitoring of plant procedures."

In addition, the proposed change allows the shift crew composition to be less than the minimum requirement for up to two hours provided immediate action is taken to restore the shift crew composition to within the minimum requirements. This proposed change is consistent with the provision incorporated in Standard Technical Specifications and therefore, we find it acceptable.

Environmental Consideration

We have determined that the amendment does not authorize a change in effluent types or total amounts nor an increase in power level and will not result in any significant environmental impact. Having made this determination, we have further concluded that the amendment involves an action which is insignificant from the standpoint of environmental impact and, pursuant to 10 CFR §51.5(d)(4), that an environmental impact statement or negative declaration and environmental impact appraisal need not be prepared in connection with the issuance of this amendment.

Conclusion

We have concluded, based on the considerations discussed above, that: (1) because the amendment does not involve a significant increase in the probability or consequences of accidents previously considered and does not involve a significant decrease in a safety margin, the amendment does not involve a significant hazards consideration, (2) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (3) such activities will be conducted in compliance with the Commission's regulations and the issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public.

Date: May 23, 1980

UNITED STATES NUCLEAR REGULATORY COMMISSIONDOCKET NO. 50-247CONSOLIDATED EDISON COMPANY OF NEW YORK, INC.NOTICE OF ISSUANCE OF AMENDMENT TO FACILITY
OPERATING LICENSE

The U. S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. 61 to Facility Operating License No. DPR-26, issued to the Consolidated Edison Company of New York, Inc. (the licensee), which revised Technical Specifications for operation of the Indian Point Nuclear Generating Unit No. 2 (the facility) located in Buchanan, Westchester County, New York. The amendment is effective as of the date of issuance.

The amendment revises the Technical Specification to increase the membership of the Station Nuclear Safety Committee and to allow the shift crew composition to be less than the minimum requirements for up to two hours.

The application for the amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendment. Prior public notice of this amendment was not required since the amendment does not involve a significant hazards consideration.

- 2 -

The Commission has determined that the issuance of this amendment will not result in any significant environmental impact and that pursuant to 10 CFR §51.5(d)(4) an environmental impact statement or negative declaration and environmental impact appraisal need not be prepared in connection with issuance of this amendment.

For further details with respect to this action, see (1) the application for amendment dated December 31, 1979, (2) Amendment No. 61 to License No. DPR-26, and (3) the Commission's related Safety Evaluation. All of these items are available for public inspection at the Commission's Public Document Room, 1717 H Street, N.W., Washington, D.C. and at the White Plains Public Library, 100 Martine Avenue, White Plains, New York. A copy of items (2) and (3) may be obtained upon request addressed to the U. S. Nuclear Regulatory Commission, Washington, D.C. 20555, Attention: Director, Division of Licensing.

Dated at Bethesda, Maryland, this 23rd day of May, 1980.

FOR THE NUCLEAR REGULATORY COMMISSION



Steven A. Varga, Chief
Operating Reactors Branch #1
Division of Licensing