

VERMONT YANKEE NUCLEAR POWER STATION

P.O. Box 157, Governor Hunt Road
Vernon, Vermont 05354-0157
(802) 257-7711

December 08, 2000
BVY-00-110

United States Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Reference: (a) License No. DPR-28 (Docket No. 50-271)

In accordance with section 6.6.B of the Vermont Yankee Technical Specifications, submitted herewith is the Monthly Statistical Report for the Vermont Yankee Nuclear Power Station for the month of November, 2000.

Sincerely,

VERMONT YANKEE NUCLEAR POWER STATION



Kevin H. Bronson
Plant Manager

cc: USNRC Region I Administrator
USNRC Resident Inspector - VYNPS
USNRC Project Manager – VYNPS

JE24

VERMONT YANKEE NUCLEAR POWER STATION

MONTHLY STATISTICAL REPORT 00-11

FOR THE MONTH OF NOVEMBER 2000

OPERATING DATA REPORT

DOCKET NO. 50-271
 DATE 001210
 COMPLETED BY G.A. WALLIN
 TELEPHONE (802)258-5414

OPERATING STATUS

1. Unit Name: Vermont Yankee
2. Reporting Period: November
3. Licensed Thermal Power (Mwt): 1593
4. Nameplate Rating (Gross MWe): 540
5. Design Electrical Rating (Net MWe): 522
6. Maximum Dependable Capacity (Gross MWe): 535
7. Maximum Dependable Capacity (Net MWe): 510
8. If changes, occur in capacity ratings (Items Number 3 through 7) since last report, give reasons:



9. Power level to which restricted, if any (Net MWe): N/A
10. Reasons for restrictions, if any: N/A

	This Month	Yr-to-Date	Cumulative
11. Hours in Reporting Period	720.00	8040.00	244704.00
12. Number Of Hours Reactor was Critical	720.00	8006.84	206181.30
13. Reactor Reserve Shutdown Hours	0.00	0.00	0.00
14. Hours Generator On-Line	720.00	7995.00	202656.00
15. Unit Reserve Shutdown Hours	0.00	0.00	0.00
16. Gross Thermal Energy Generated (MWH)	1146371.95	12653942.80	306215126.90
17. Gross Electrical Energy Generated (MWH)	395161.00	4344415.00	102646983.00
18. Net Electrical Energy Generated (MWH)	379976.00	4154636.00	97655194.00
19. Unit Service Factor	100.00	99.40	81.80
20. Unit Availability Factor	100.00	99.40	81.80
21. Unit Capacity Factor (Using MDC Net)	103.50	101.30	78.00
22. Unit Capacity Factor (Using DER Net)	101.10	99.00	76.40
23. Unit Forced Outage Rate	0.00	0.56	4.23

24. Shutdowns scheduled over next 6 months (Type, Date, and Duration of Each): 2001 Refueling Outage scheduled to begin on April 27, 2001 and end on May 19, 2001.
25. If shut down at end of report period, estimated date of startup: N/A
26. Units In Test Status (prior to commercial operation): N/A

INITIAL CRITICALITY
 INITIAL ELECTRICITY
 COMMERCIAL OPERATION

Forecast Achieved

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-271
 UNIT Vermont Yankee
 DATE 001210
 COMPLETED BY G.A. WALLIN
 TELEPHONE (802)258-5414

MONTH November

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1.	<u>529</u>	17.	<u>526</u>
2.	<u>528</u>	18.	<u>528</u>
3.	<u>527</u>	19.	<u>528</u>
4.	<u>527</u>	20.	<u>528</u>
5.	<u>527</u>	21.	<u>528</u>
6.	<u>527</u>	22.	<u>528</u>
7.	<u>527</u>	23.	<u>529</u>
8.	<u>527</u>	24.	<u>529</u>
9.	<u>527</u>	25.	<u>529</u>
10.	<u>527</u>	26.	<u>529</u>
11.	<u>528</u>	27.	<u>529</u>
12.	<u>528</u>	28.	<u>527</u>
13.	<u>527</u>	29.	<u>528</u>
14.	<u>527</u>	30.	<u>528</u>
15.	<u>527</u>	31.	<u>---</u>
16.	<u>525</u>		

INSTRUCTIONS:

On this format, list the average daily unit power level in MWE-Net for each day in the reporting month. Compute to the nearest whole megawatt.

VYDPF 0411.02 (Sample)
 DP 0411 Rev. 7
 Page 1 of 1
 RT No. 13.F01.18V

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH NOVEMBER

DOCKET NO 50-271
 UNIT NAME Vermont Yankee
 DATE 001210
 COMPLETED BY G.A. Wallin
 TELEPHONE (802)258-5414

No.	Date	1 Type	Duration (hours)	2 Reason	3 Method of Shutting Down Reactor	License Event Report #	4 System Code	5 Component Code	Cause and Corrective Action to Prevent Recurrence
(None)									

1 F: Forced
S: Scheduled

2 Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training and
 License Examination
 F-Administrative
 G-Operational Error (Explain)
 H-(Explain) -

3 Method:
 1 - Manual
 2 - Manual Scram
 3 - Automatic Scram
 4 - Other (Explain)

4 Exhibit G- Instructions
 for Preparation of Data
 Entry Sheets for License
 Event Report (LER) File
 (NUREG 0161)

5 Exhibit I - Same Source

DOCKET NO. 50-271
DATE 001210
COMPLETED BY G.A. WALLIN
TELEPHONE (802)258-5414

REPORT MONTH November

SUMMARY OF OPERATING EXPERIENCES

Highlights

Vermont Yankee operated at 99.9% of rated thermal power for the month. Gross electrical generation was 395,161 MWh or 100.5% design electrical capacity.

Operating Summary

The following is a chronological description of plant operations including other pertinent items of interest for the month:

At the beginning of the reporting period the plant was operating at 99.9% of rated thermal power.

There were no items of interest to report for this month.

At the end of the reporting period the plant was operating at 99.9% of rated thermal power.

VYDPF 0411.04 (Sample)
DP 0411 Rev. 7
Page 1 of 1
RT No. 13.F01.18X