

REGULATORY DOCKET FILE COPY

JUNE 30 1980

Distribution
 Docket File 50-286
 NRC PDR
 Local PDR
 TERA
 NSIC
 NRR Reading
 ORB1 Reading
 D. Eisenhut
 T. Novak
 S. Varga
 L. Olshan
 C. Parrish
 I&E (3)
 Attorney, OELD
 A. Thadani

Docket No. 50-286

Mr. George T. Berry, President
 and Chief Operating Officer
 Power Authority of the State of New York
 10 Columbus Circle
 New York, New York 10019

Dear Mr. Berry:

Item C.4 of Appendix A to the February 11, 1980 Confirmatory Order required you to submit a schedule for implementing the Anticipated Transient Without Scram (ATWS) instrumentation modification justified in the December 30, 1979 letter from T. N. Anderson to S. H. Hanauer. You proposed, in your letter of April 11, 1980, to complete installation of the ATWS modification in the fall of 1982.

The date for completing ATWS modifications recommended by the staff in NUREG-0460, Volume 4, was July 1, 1981. As a result of public comments, we are considering extension of this date. However, we would like Indian Point, because of the risk we believe it represents, to improve upon the schedule required of other plants. With this in mind, re-evaluate your original proposal and submit, within 30 days of receipt of this letter, a revised schedule and justification for this schedule.

Sincerely,

Original signed by:
 S. A. Varga

Steven A. Varga, Chief
 Operating Reactors Branch #1
 Division of Licensing

cc: See next page

*SEE PREVIOUS YELLOW FOR CONCURRENCES

OFFICE	DL:ORB1*	DL:ORB1*	DST*			
SURNAME	LN01shan:jb	SAVarga	RJMattson			
DATE	06/11/80	06X/16/80	06/20/80			

Distribution
 Docket File 50-286
 NRC PDR
 Local PDR
 TERA
 NSIC
 NRR Reading
 ORBI Reading
 D. Eisenhut
 T. Novak
 S. Varga
 L. Olshan
 I&E (3)
 Attorney, OELD
 A. Thadani

Docket No. 50-286

Mr. George T. Berry, President
 and Chief Operating Officer
 Power Authority of the State of New York
 10 Columbus Circle
 New York, New York 10019

Dear Mr. Berry:

Item C.4 of Appendix A to the February 11, 1980 Confirmatory Order required you to submit a schedule for implementing the Anticipated Transient Without Scram (ATWS) instrumentation modification justified in the December 30, 1979 letter from T. N. Anderson to S. H. Hanauer. You proposed, in your letter of April 11, 1980, to complete installation of the ATWS modification in the fall of 1982.

The date for completing ATWS modifications ~~identified~~ ^{public recommended by the staff} in NUREG-0460, Volume 4, was July 1, 1981. As a result of ~~industry~~ comments, we are considering extension of this date, ~~to January 1, 1982.~~ However, we would like Indian Point, because of the risk we believe it represents, to improve upon the schedule required of other plants. With this in mind, re-evaluate your original proposal and submit, within 30 days of receipt of this letter, a revised schedule and justification for this schedule.

Sincerely,

Steven A. Varga, Chief
 Operating Reactors Branch #1
 Division of Licensing

cc: See next page

SV
6/23/80

with changes marked above

OFFICE →	DL:ORB1	DL:ORB1	DST			
SURNAME →	ENOlshan:jb	SAVarga	RMattson			
DATE →	06/11/80	06/16/80	06/19/80			



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

June 30, 1980

Docket No. 50-286


Mr. George T. Berry, President
and Chief Operating Officer
Power Authority of the State of New York
10 Columbus Circle
New York, New York 10019

Dear Mr. Berry:

Item C.4 of Appendix A to the February 11, 1980 Confirmatory Order required you to submit a schedule for implementing the Anticipated Transient Without Scram (ATWS) instrumentation modification justified in the December 30, 1979 letter from T. N. Anderson to S. H. Hanauer. You proposed, in your letter of April 11, 1980, to complete installation of the ATWS modification in the fall of 1982.

The date for completing ATWS modifications recommended by the staff in NUREG-0460, Volume 4, was July 1, 1981. As a result of public comments, we are considering extension of this date. However, we would like Indian Point, because of the risk we believe it represents, to improve upon the schedule required of other plants. With this in mind, re-evaluate your original proposal and submit, within 30 days of receipt of this letter, a revised schedule and justification for this schedule.

Sincerely,


Steven A. Varga, Chief
Operating Reactors Branch #1
Division of Licensing

cc: See next page

Mr. George T. Berry
Power Authority of the State of New York - 2 - June 30, 1980

cc: White Plains Public Library
100 Martine Avenue
White Plains, New York 10601

Mr. Charles M. Pratt
Assistant General Counsel
Power Authority of the
State of New York
10 Columbus Circle
New York, New York 10019

Ms. Eilyn Weiss
Sheldon, Harmon and Weiss
1725 I Street, N.W., Suite 506
Washington, D. C. 20006

Dr. Lawrence D. Quarles
Apartment 51
Kendal at Longwood
Kennett Square, Pennsylvania 19348

Mr. George M. Wilverding
Licensing Supervisor
Power Authority of the
State of New York
10 Columbus Circle
New York, New York 10019

Mr. P. W. Lyon, Senior Vice
President - Nuclear Generation
Power Authority of the
State of New York
10 Columbus Circle
New York, New York 10019

Mr. J. P. Bayne, Resident Manager
Indian Point 3 Nuclear Power Plant
P. O. Box 215
Buchanan, New York 10511

Mr. J. W. Blake, Ph.D., Director
Environmental Programs
Power Authority of the
State of New York
10 Columbus Circle
New York, New York 10019

Theodore A. Rebelowski
Resident Inspector
Indian Point Nuclear Generating
U. S. Nuclear Regulatory Commission
Post Office Box 38
Buchanan, New York 10511