

John K. Wood
Vice President, Nuclear

440-280-5224
Fax: 440-280-8029

December 12, 2000
PY-CEI/LCDU-0060L


Attention: Robert Shelby, Mentor Waste Facility
Lake County Department of Utilities
P.O. Box 490
Painesville, Ohio 44077-0490

Ladies and Gentlemen:

Enclosed are the results of an isotopic analysis performed for industrial wastewater from the Perry Nuclear Power Plant. No radioactive material attributable to the Perry Nuclear Power Plant was detected.

If you have questions or require additional information, please contact Ms. Donna Benz at (440) 280-5514.

Very truly yours,



DGB:sc

Enclosures

cc: NRC Region III
NRC Resident Inspector Office
NRC Project Manager
NRC Document Control Desk (Docket No. 50-440)

COOL

8:23:26

Perry Computer Automated Laboratory System (CAL) 11/29/2000

Note: Test by Sample Screen Qualify OK:

System Name: ENVIRONMEN	Desc: Environmental Sample
MPL Number : SEWAGE	Desc: Sewage Lift Station
Reason/Freq: Q	Desc: Quarterly
Mode Number: 6	Desc: At All Times
Sample ID : 304787	Date Collected: 13:00:00 11/28/00

Status: P

Isotopic by Gamma Spectroscopy

Limit: 0.00 to 0.00 0.00E+00 uCi/ml

MCA: 1001

NOTE: A numeric result of zero indicates 'None Detected'