

November 9, 1984

MEMORANDUM FOR: James R. Miller, Chief
Operating Reactors Branch #3
Division of Licensing

FROM: Steven A. Varga, Chief
Operating Reactors Branch #1
Division of Licensing

Distribution
Docket file
NRC PDR Local PDR
ORB#1 Rdg.
CParrish
JNeighbors
memo file

SUBJECT: REQUEST FOR PUBLICATION IN MONTHLY FR NOTICE -
NOTICE OF ISSUANCE OF AMENDMENT TO FACILITY
OPERATING LICENSE AND FINAL DETERMINATION OF NO
SIGNIFICANT HAZARDS CONSIDERATION AND OPPORTUNITY
FOR HEARING (EXIGENT OR EMERGENCY CIRCUMSTANCES)

Power Authority of The State of New York, Docket No. 50-286, Indian Point
Nuclear Generating Plant, Unit No. 3, Westchester County, New York

Date of amendment request: November 1, 1984, as supplemented November 6,
1984

Description of amendment request: This amendment revises the Technical
Specifications, Section 4.9.A.1.f to change the steam generator tube
plugging limit for pitting from an imperfection plugging depth of 50% to
63%.

Date of Issuance: November 9, 1984

Amendment No. 50

Effective Date: November 9, 1984

Facility Operating License No. DPR-64

Amendment revised the Technical Specifications.

Press release issued requesting comments as to proposed no significant
hazards consideration: No

Comments received: No

The Commission's related evaluation is contained in a Safety Evaluation
dated November 6, 1984

8411200366 841109
PDR ADDCK 05000286
P PDR

Mr. Miller

-2-

Local Public Document Room location: White Plains Public Library, 100
Martine Avenue, White Plains, New York 10601

Attorney for licensee: Mr. Charles M. Pratt, 10 Columbus Circle, New York,
New York 10019

NRC Branch Chief: Steven A. Varga

Steven A. Varga, Chief
Operating Reactors Branch #1
Division of Licensing

ORB#1:DL
CParrish
11/9/84

ORB#1:DL
DNeighbors/ts
11/8/84

ORB#1:DL
SVarga
11/8/84

ORB#1:DL
11/9/84