

April 26, 1984

Docket No. 50-286

Mr. J. P. Bayne
Executive Vice President - Nuclear Generation
Power Authority of the State of New York
123 Main Street
White Plains, New York 10601

Dear Mr. Bayne:

SUBJECT: CATEGORY "A" LESSONS LEARNED REQUIREMENTS FOR THE INDIAN
POINT NUCLEAR GENERATING PLANT, UNIT NO. 3 (IP-3)

On October 7, 1981 the Commission issued Amendment No. 38 to Facility
Operating License No. DPR-84. The amendment consisted of changes to the
IP-3 Technical Specifications to incorporate certain of the TMI-2 Lessons
Learned Category "A" requirements.

Through an administrative error an incorrect page for Technical Specification
Table 3.5-3 were forwarded. In order to properly correct this table as
intended, enclosed is Table 3.5-3.

Please accept our apologies for any inconvenience this error may have
caused.

Sincerely,

ORIGINAL SIGNED BY

Pjillip Polk, Project Manager
Operating Reactors Branch #1
Division of Licensing

Enclosure:
Corrected Table 3.5-3

cc w/enclosure
See next page

ORB#1:DL
CParrish
4/29/84

ORB#1:DL
PPolk;ps
4/27/84

ORB#1:DL
SVara
4/26/84

8405170096 840426
PDR ADOCK 05000286
P PDR

DISTRIBUTION
Docket File
NRC PDR
L PDR
ORB#1:RDG
Gray File
DEisenhut
CParrish
PPolk
OELD
SECY
LHarmon

EJordan
JNGrace
TBarnhart (4)
WJones
DBrinkman
ACRS 10
OPA CMiles
RDiggs
RBallard

TABLE 3.5-3 (SHEET 1 of 3)

INSTRUMENTATION OPERATING CONDITION FOR ENGINEERED SAFETY FEATURES

<u>NO. FUNCTIONAL UNIT</u>	<u>1</u> <u>NO. OF</u> <u>CHANNELS</u>	<u>2</u> <u>NO. OF</u> <u>CHANNELS</u> <u>TO TRIP</u>	<u>3</u> <u>MIN.</u> <u>NUMBER OF</u> <u>OPERABLE</u> <u>CHANNELS</u>	<u>4</u> <u>MIN.</u> <u>DEGREE OF</u> <u>REDUNDANCY</u>	<u>5</u> <u>OPERATOR</u> <u>ACTION IF CONDI-</u> <u>TIONS OF COL. 3</u> <u>OR 4 CANNOT BE</u> <u>MET*****</u>
1. SAFETY INJECTION					
a. Manual	2	1	1	0	Cold Shutdown
b. High Containment Pressure (Hi Level)	3	2	2	1	Cold Shutdown
c. High Differential Pressure Between Steam Lines	3/steam line	2/steam line	2/steam line	1/steam line	Cold Shutdown
d. Pressurizer Low Pressure*	3	2	2	1	Cold Shutdown
e. High Steam Flow in 2/4 Steam Lines Coincident with Low Tavg or Low Steam Line Pressure	2/steam line	1/2 in any 2 steam lines	2 channels in each of 3 steam lines	2	Cold Shutdown or main steam isolation valves closed
	4 Tavg Signals	2	3	2	
	4 Pressure Signals	2	3	2	
f. Pressurizer Low Pressure (Automatic Unblock)	3	2	2****	1****	Cold Shutdown

Amendment No. 26-38

8405170099 840426
PDR ADOCK 05000286
PDR

Mr. J. P. Bayne
Power Authority of the State
of New York

Indian Point Nuclear Generating Unit 3

cc: Mr. John C. Brons
Indian Point 3 Nuclear Power Plant
Post Office Box 215
Buchanan, New York 10511

Mr. Charles M. Pratt
Assistant General Counsel
Power Authority of the State
of New York
10 Columbus Circle
New York, NY 10019

Ms. Ellyn Weiss
Sheldon, Harmon and Weiss
1725 I Street, N.W., Suite 506
Washington, DC 20006

Dr. Lawrence R. Quarles
Apartment 51
Kendal at Longwood
Kennett Square, PA 19348

Mr. George M. Wilverding, Manager
Nuclear Safety Evaluation
Power Authority of the State
of New York
123 Main Street
White Plains, NY 10601

Director, Technical Development
Programs
State of New York Energy Office
Agency Building 2
Empire State Plaza
Albany, New York 12223

Honorable George Begany
Mayor, Village of Buchanan
236 Tate Avenue
Buchanan, New York 10511

Mr. Leroy W. Sinclair
Power Authority of the State
of New York
123 Main Street
White Plains, New York 10601

Resident Inspector
Indian Point Nuclear Generating
U.S. Nuclear Regulatory Commission
Post Office Box 66
Buchanan, New York 10511

Thomas J. Farrelly, Esquire.
Law Department
Consolidated Edison Company
of New York, Inc.
4 Irving Place
New York, New York 10003

Mr. A. Klausmann, Vice President
Quality Assurance
Power Authority of the State
of New York
10 Columbus Circle
New York, New York 10019

Regional Radiation Representative
EPA Region II
26 Federal Plaza
New York, New York 10007

Mr. D. Halama
Quality Assurance Superintendent
Indian Point 3 Nuclear Power Plant
Post Office Box 215
Buchanan, New York 10511

S. S. Zulla, Vice President
Nuclear Support
Power Authority of the State
of New York
123 Main Street
White Plains, New York 10601

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

cc: Ezra I. Bialik
Assistant Attorney General
Environmental Protection Bureau
New York State Department of Law
2 World Trade Center
New York, New York 10047

P. Kokolakis, Director
Nuclear Licensing
Power Authority of the State
of New York
123 Main Street
White Plains, New York 10601