

August 13, 1990

Docket No. 50-286

DISTRIBUTION:

Mr. John C. Brons
Executive Vice President - Nuclear Generation
Power Authority of the State of New York
123 Main Street
White Plains, New York 10601

Docket Files
NRC/Local PDRs
PDI-1 Reading
SVarga
RWessman
CVogan
DNeighbors
OGC
DHagan

EJordan
GHill
WJones
JCalvo
CMcCracken
ACRS(10)
GPA/PA
OC/LFMB
PDI-1 Gray
JLinville
RACapra

Dear Mr. Brons:

SUBJECT: ISSUANCE OF AMENDMENT (TAC NO. 66510)

The Commission has issued the enclosed Amendment No. 102 to Facility Operating License No. DPR-64 for the Indian Point Nuclear Generating Unit No. 3. The amendment consists of changes to the Technical Specifications in response to your application transmitted by letter dated October 13, 1987.

The amendment revises the Technical Specification Tables 3.6-1 and 4.4-1 to reflect modifications to certain containment isolation valves. Also, the appropriate valve identification prefix and suffix have been added to valves listed in Tables 3.6-1 and 4.4-1.

The parts of this amendment request related to Sections 3.3 and 3.4 (increase in calculated peak containment LOCA pressure) were withdrawn by letter dated March 6, 1989. The NRC granted the request for withdrawal on March 31, 1989.

A copy of the related Safety Evaluation is enclosed. A Notice of Issuance will be included in the Commission's next regular bi-weekly Federal Register notice.

Sincerely,

ORIGINAL SIGNED BY:

Joseph D. Neighbors, Project Manager
Project Directorate I-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosures:

- 1. Amendment No. 102 to DPR-64
- 2. Safety Evaluation

cc w/enclosures:

See next page

LA:PDI-1
CVogan
7/11/90

PM:PDI-1
DNeighbors:sam
7/11/90

C.R.
SPLB:NRR
CMcCracken
7/13/90

216
OGC
E. HOLLER
8/7/90

200
D:PDI-1
RCapra
8/13/90

9008170086 900813
PDR ADDCK 05000286
P FDC

QF01
11

Mr. John C. Brons
Power Authority of the State
of New York

Indian Point 3 Nuclear Power Plant

cc:

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406

Resident Inspector
Indian Point 3 Nuclear Power Plant
U.S. Nuclear Regulatory Commission
Post Office Box 337
Buchanan, New York 10511

Mr. Gerald C. Goldstein
Assistant General Counsel
Power Authority of the State
of New York
1633 Broadway
New York, New York 10019

Mr. Charles W. Jackson
Manager, Nuclear Safety and Licensing
Consolidated Edison Company
of New York, Inc.
Broadway and Bleakley Avenues
Buchanan, New York 10511

Mr. Phillip Bayne, President
Power Authority of the State
of New York
123 Main Street
White Plains, New York 10601

Mr. A. Klausmann, Vice President
Quality Assurance
Power Authority of the State of New York
1633 Broadway
New York, New York 10019

Mr. Joseph E. Russell
Resident Manager
Indian Point 3 Nuclear Power Plant
Post Office Box 215
Buchanan, New York 10511

Mayor, Village of Buchanan
236 Tate Avenue
Buchanan, New York 10511

Mr. George M. Wilverding, Manager
Nuclear Safety Evaluation
Power Authority of the State of New York
123 Main Street
White Plains, New York 10601

Mr. F. X. Pindar
Quality Assurance Superintendent
Indian Point 3 Nuclear Power Plant
Post Office Box 215
Buchanan, New York 10511

Mr. Peter Kokolakis, Director
Nuclear Licensing
Power Authority of the State
of New York
123 Main Street
White Plains, New York 10601

Mr. R. Beedle, Vice President
Nuclear Support
Power Authority of the State
of New York
123 Main Street
White Plains, New York 10601

Ms. Donna Ross
New York State Energy Office
2 Empire State Plaza
16th Floor
Albany, New York 12223

Mr. S. S. Zulla, Vice President
Nuclear Engineering
Power Authority of the State
of New York
123 Main Street
White Plains, New York 10601

Mr. William Josiger, Vice President
Operations and Maintenance
Power Authority of the State
of New York
123 Main Street
White Plains, New York 10601

Charles Donaldson, Esquire
Assistant Attorney General
New York Department of Law
120 Broadway
New York, New York 10271



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

POWER AUTHORITY OF THE STATE OF NEW YORK

DOCKET NO. 50-286

INDIAN POINT NUCLEAR GENERATING UNIT NO. 3

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 102
License No. DPR-64

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Power Authority of the State of New York (the licensee) dated October 13, 1987, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-64 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 102, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Robert A. Capra, Director
Project Directorate I-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: August 13, 1990

ATTACHMENT TO LICENSE AMENDMENT NO. 102

FACILITY OPERATING LICENSE NO. DPR-64

DOCKET NO. 50-286

Revise Appendix A as follows:

Remove Pages

Table 3.6-1

Table 4.4-1 (Page 1 of 7)

Table 4.4-1 (Page 2 of 7)

Table 4.4-1 (Page 3 of 7)

Table 4.4-1 (Page 4 of 7)

Table 4.4-1 (Page 5 of 7)

Table 4.4-1 (Page 6 of 7)

Table 4.4-1 (Page 7 of 7)

Insert Pages

Table 3.6-1

Table 4.4-1 (Page 1 of 7)

Table 4.4-1 (Page 2 of 7)

Table 4.4-1 (Page 3 of 7)

Table 4.4-1 (Page 4 of 7)

Table 4.4-1 (Page 5 of 7)

Table 4.4-1 (Page 6 of 7)

Table 4.4-1 (Page 7 of 7)

TABLE 3.6-1

NON-AUTOMATIC CONTAINMENT ISOLATION VALVES
OPEN CONTINUOUSLY OR INTERMITTENTLY FOR PLANT OPERATION

| | | |
|-------------|-------------|---------------|
| AC-MOV-744 | SI-MOV-850C | SWN-51-4 |
| AC-MOV-1870 | SI-1833A | SWN-44-5 |
| AC-MOV-743 | SI-1833B | SWN-51-5 |
| SP-990C | SI-859A | SWN-71-1 |
| AC-732 | SI-859C | SWN-71-2 |
| SI-MOV-885A | AC-752F | SWN-71-3 |
| SI-MOV-885B | AC-753F | SWN-71-4 |
| SI-MOV-888A | AC-752J | SWN-71-5 |
| SI-MOV-888B | AC-753J | SA-24-1 |
| CH-MOV-205 | SWN-41-1 | SA-24-2 |
| CH-MOV-226 | SWN-43-1 | PS-PCV-1111-1 |
| CH-227 | SWN-41-2 | PS-PCV-1111-2 |
| CH-MOV-250A | SWN-43-2 | UH-37 |
| CH-MOV-441 | SWN-41-3 | UH-38 |
| CH-MOV-250B | SWN-43-3 | SP-MOV-990A |
| CH-MOV-442 | SWN-41-4 | SP-MOV-990B |
| CH-MOV-250C | SWN-43-4 | SI-1814A |
| CH-MOV-443 | SWN-41-5 | SI-1814B |
| CH-MOV-250D | SWN-43-5 | SI-1814C |
| CH-MOV-444 | SWN-44-1 | HR-MOV-1882A |
| SI-869A | SWN-51-1 | HR-MOV-1875A |
| SI-869B | SWN-44-2 | HR-MOV-1875B |
| SI-878A | SWN-51-2 | HR-MOV-1876A |
| SI-878B | SWN-44-3 | HR-MOV-1876B |
| SI-MOV-851A | SWN-51-3 | PS-7 |
| SI-MOV-850A | SWN-44-4 | PS-8 |
| | | PS-9 |
| | | PS-10 |

TABLE 4.4-1 (Page 1 of 7)

| CONTAINMENT ISOLATION VALVES | | | |
|-------------------------------------|--|----------------------------------|--|
| <u>Valve No.</u> | <u>Penetration Number</u> ⁽¹⁾ | <u>Test Fluid</u> ⁽²⁾ | <u>Minimum Test Pressure</u> (PSIG) ⁽⁸⁾ |
| RC-AOV-549 | 1 | Water ⁽⁴⁾ | 47 |
| RC-AOV-548 | 1 | Water ⁽⁴⁾ | 47 |
| RC-518 | 2 | Gas | 43 |
| RC-AOV-550 | 2 | Gas | 43 |
| RC-AOV-552 | 3 | Water ⁽⁴⁾ | 47 |
| RC-AOV-519 | 3 | Water ⁽⁴⁾ | 47 |
| AC-741 | 4 | Water ⁽⁵⁾ | 47 ⁽³⁾ |
| AC-MOV-744 | 4 | Nitrogen ⁽⁴⁾ | 43 ⁽³⁾ |
| SI-MOV-888A | 5 | Nitrogen ⁽⁴⁾ | 43 |
| SI-MOV-888B | 5 | Nitrogen ⁽⁴⁾ | 43 |
| AC-AOV-958 | 5 | Nitrogen ⁽⁴⁾ | 43 |
| SP-AOV-959 | 5 | Nitrogen ⁽⁴⁾ | 43 |
| SP-990C | 5 | Nitrogen ⁽⁴⁾ | 43 |
| AC-MOV-1870 | 5 | Nitrogen ⁽⁴⁾ | 43 |
| AC-MOV-743 | 5 | Nitrogen ⁽⁴⁾ | 43 |
| AC-732 | 6 | Nitrogen ⁽⁴⁾ | 43 ⁽³⁾ |
| SI-MOV-885A | 7 | Water ⁽⁵⁾ | 47 |
| SI-MOV-885B | 7 | Water ⁽⁵⁾ | 47 |
| CH-AOV-201 | 8 | Water ⁽⁴⁾ | 47 |
| CH-AOV-202 | 8 | Water ⁽⁴⁾ | 47 |
| CH-MOV-205 | 9 | Water ⁽⁴⁾ | 47 |
| CH-MOV-226 | 9 | Water ⁽⁴⁾ | 47 |
| CH-227 | 9 | Water ⁽⁴⁾ | 47 |
| CH-MOV-250A | 10 | Water ⁽⁴⁾ | 47 |
| CH-MOV-441 | 10 | Water ⁽⁴⁾ | 47 |
| CH-MOV-250B | 10 | Water ⁽⁴⁾ | 47 |
| CH-MOV-442 | 10 | Water ⁽⁴⁾ | 47 |
| CH-MOV-250C | 10 | Water ⁽⁴⁾ | 47 |

TABLE 4.4-1 (Page 2 of 7)

| CONTAINMENT ISOLATION VALVES | | | |
|-------------------------------------|--|----------------------------------|--|
| <u>Valve No.</u> | <u>Penetration Number</u> ⁽¹⁾ | <u>Test Fluid</u> ⁽²⁾ | <u>Minimum Test Pressure (PSIG)</u> ⁽⁸⁾ |
| CH-MOV-443 | 10 | Water ⁽⁴⁾ | 47 |
| CH-MOV-250D | 10 | Water ⁽⁴⁾ | 47 |
| CH-MOV-444 | 10 | Water ⁽⁴⁾ | 47 |
| CH-MOV-222 | 11 | Water ⁽⁴⁾ | 47 |
| SP-AOV-956E | 12 | Water ⁽⁴⁾ | 47 |
| SP-AOV-956F | 12 | Water ⁽⁴⁾ | 47 |
| SI-869A | 14 | Water ⁽⁴⁾ | 47 |
| SI-867A | 14 | Gas | 43 |
| SI-878A | 14 | Gas | 43 |
| SI-869B | 14 | Water ⁽⁴⁾ | 47 |
| SI-867B | 14 | Gas | 43 |
| SI-878B | 14 | Gas | 43 |
| SI-MOV-1835A | 15 | Nitrogen ⁽⁴⁾ | 43 |
| SI-MOV-1835B | 15 | Nitrogen ⁽⁴⁾ | 43 |
| SI-1833A | 15 | Water ⁽⁴⁾ | 47 |
| SI-1833B | 15 | Water ⁽⁴⁾ | 47 |
| SI-MOV-851A | 15 | Water ⁽⁴⁾ | 47 |
| SI-MOV-850A | 15 | Water ⁽⁴⁾ | 47 |
| SI-MOV-850C | 15 | Water ⁽⁴⁾ | 47 |
| SI-859A | 16 | Water ⁽⁴⁾ | 47 |
| SI-859C | 16 | Water ⁽⁴⁾ | 47 |
| NNE-1610 | 17 | Gas | 43 |
| NNE-AOV-863 | 17 | Gas | 43 |
| SP-AOV-956G | 18 | Water ⁽⁴⁾ | 47 |
| SP-AOV-956H | 18 | Water ⁽⁴⁾ | 47 |
| WD-AOV-1786 | 19 | Water ⁽⁴⁾ | 47 |
| WD-AOV-1787 | 19 | Water ⁽⁴⁾ | 47 |

TABLE 4.4-1 (Page 3 of 7)

| CONTAINMENT ISOLATION VALVES | | | |
|-------------------------------------|-----------------------------------|----------------------|--|
| <u>Valve No.</u> | <u>Penetration Number (1)</u> | <u>Test Fluid(2)</u> | <u>Minimum Test Pressure(PSIG) (8)</u> |
| WD-AOV-1610 | 19 | Gas | 43 |
| WD-1616 | 19 | Gas | 43 |
| WD-AOV-1788 | 20 | Water(4) | 47 |
| WD-AOV-1789 | 20 | Water(4) | 47 |
| WD-AOV-1702 | 21 | Water(4) | 47 |
| WD-AOV-1705 | 21 | Water(4) | 47 |
| AC-MOV-797 | 22 | Water(4) | 47 |
| AC-MOV-769 | 22 | Water(4) | 47 |
| AC-MOV-784 | 23 | Water(4) | 47 |
| AC-MOV-786 | 23 | Water(4) | 47 |
| AC-FCV-625 | 24 | Water(4) | 47 |
| AC-MOV-789 | 24 | Water(4) | 47 |
| AC-AOV-791 | 29 | Water(4) | 47 |
| AC-AOV-798 | 29 | Water(4) | 47 |
| AC-AOV-796 | 30 | Water(4) | 47 |
| AC-AOV-793 | 30 | Water(4) | 47 |
| WD-AOV-1728 | 31 | Water(4) | 47 |
| WD-AOV-1723 | 31 | Water(4) | 47 |
| VS-PCV-1234 | 32 | Gas(7) | 43 |
| VS-PCV-1235 | 32 | Gas(7) | 43 |
| VS-PCV-1236 | 33 | Gas(7) | 43 |
| VS-PCV-1237 | 33 | Gas(7) | 43 |
| CA-PCV-1229 | 34 | Gas(7) | 43 |
| CA-PCV-1230 | 34 | Gas(7) | 43 |
| BD-PCV-1215 | 37 | Water(4) | 47 |
| BD-PCV-1215A | 37 | Water(4) | 47 |
| BD-PCV-1214 | 37 | Water(4) | 47 |
| BD-PCV-1214A | 37 | Water(4) | 47 |
| BD-PCV-1216 | 37 | Water(4) | 47 |
| BD-PCV-1216A | 37 | Water(4) | 47 |
| BD-PCV-1217 | 37 | Water(4) | 47 |
| BD-PCV-1217A | 37 | Water(4) | 47 |

TABLE 4.4-1 (Page 4 of 7)

| CONTAINMENT ISOLATION VALVES | | | |
|-------------------------------------|--|----------------------------------|---|
| <u>Valve No.</u> | <u>Penetration Number</u> ⁽¹⁾ | <u>Test Fluid</u> ⁽²⁾ | <u>Minimum Test Pressure(PSIG)</u> ⁽⁸⁾ |
| BD-PCV-1224 | 38 | Water ⁽⁴⁾ | 47 |
| BD-PCV-1224A | 38 | Water ⁽⁴⁾ | 47 |
| BD-PCV-1223 | 38 | Water ⁽⁴⁾ | 47 |
| BD-PCV-1223A | 38 | Water ⁽⁴⁾ | 47 |
| BD-PCV-1225 | 38 | Water ⁽⁴⁾ | 47 |
| BD-PCV-1225A | 38 | Water ⁽⁴⁾ | 47 |
| BD-PCV-1226 | 38 | Water ⁽⁴⁾ | 47 |
| BD-PCV-1226A | 38 | Water ⁽⁴⁾ | 47 |
| SWN-41-1 | 39 | Water ⁽⁶⁾ | 47 |
| SWN-43-1 | 39 | Water ⁽⁶⁾ | 47 |
| SWN-42-1 | 39 | Water ⁽⁶⁾ | 47 |
| SWN-41-2 | 39 | Water ⁽⁶⁾ | 47 |
| SWN-43-2 | 39 | Water ⁽⁶⁾ | 47 |
| SWN-42-2 | 39 | Water ⁽⁶⁾ | 47 |
| SWN-41-3 | 39 | Water ⁽⁶⁾ | 47 |
| SWN-43-3 | 39 | Water ⁽⁶⁾ | 47 |
| SWN-42-3 | 39 | Water ⁽⁶⁾ | 47 |
| SWN-41-4 | 39 | Water ⁽⁶⁾ | 47 |
| SWN-43-4 | 39 | Water ⁽⁶⁾ | 47 |
| SWN-42-4 | 39 | Water ⁽⁶⁾ | 47 |
| SWN-41-5 | 39 | Water ⁽⁶⁾ | 47 |
| SWN-43-5 | 39 | Water ⁽⁶⁾ | 47 |
| SWN-42-5 | 39 | Water ⁽⁶⁾ | 47 |
| SWN-44-1 | 40 | Water ⁽⁶⁾ | 47 |
| SWN-51-1 | 40 | Water ⁽⁶⁾ | 47 |
| SWN-44-2 | 40 | Water ⁽⁶⁾ | 47 |
| SWN-51-2 | 40 | Water ⁽⁶⁾ | 47 |
| SWN-44-3 | 40 | Water ⁽⁶⁾ | 47 |
| SWN-51-3 | 40 | Water ⁽⁶⁾ | 47 |
| SWN-44-4 | 40 | Water ⁽⁶⁾ | 47 |
| SWN-51-4 | 40 | Water ⁽⁶⁾ | 47 |

TABLE 4.4-1 (Page 5 of 7)

| CONTAINMENT ISOLATION VALVES | | | |
|-------------------------------------|-----------------------------------|-----------------------|--|
| <u>Valve No.</u> | <u>Penetration Number</u> (1) | <u>Test Fluid</u> (2) | <u>Minimum Test Pressure(PSIG)</u> (3) |
| SWN-44-5 | 40 | Water(6) | 47 |
| SWN-51-5 | 40 | Water(6) | 47 |
| SWN-71-1 | 40 | Water(6) | 47 |
| SWN-71-2 | 40 | Water(6) | 47 |
| SWN-71-3 | 40 | Water(6) | 47 |
| SWN-71-4 | 40 | Water(6) | 47 |
| SWN-71-5 | 40 | Water(6) | 47 |
| SA-24-1 | 41 | Water(4) | 47 |
| SA-24-2 | 41 | Water(4) | 47 |
| UH-37 | 45 | Water(4) | 47 |
| UH-38 | 46 | Water(4) | 47 |
| VS-FCV-1170 | 48 | Gas(7) | 43 |
| VS-FCV-1171 | 48 | Gas(7) | 43 |
| VS-FCV-1172 | 49 | Gas(7) | 43 |
| VS-FCV-1173 | 49 | Gas(7) | 43 |
| VS-FCV-1190 | 50 | Gas(7) | 43 |
| VS-FCV-1191 | 50 | Gas(7) | 43 |
| VS-FCV-1192 | 50 | Gas(7) | 43 |
| SP-MOV-990A | 51 | Nitrogen(4) | 43 |
| SP-MOV-990B | 51 | Nitrogen(4) | 43 |
| SP-AOV-956A | 52 | Water(4) | 47 |
| SP-AOV-956B | 52 | Water(4) | 47 |
| SP-AOV-956C | 53 | Water(4) | 47 |
| SP-AOV-956D | 53 | Water(4) | 47 |
| SI-1814A | 54 | Gas | 43 |
| SI-1814B | 55 | Gas | 43 |
| SI-1814C | 56 | Gas | 43 |
| SP-SOV-506 | 57 | Gas | 43 |
| SP-SOV-507 | 57 | Gas | 43 |

TABLE 4.4-1 (Page 6 of 7)

| CONTAINMENT ISOLATION VALVES | | | |
|------------------------------|-----------------------------------|----------------------|--|
| <u>Valve No.</u> | <u>Penetration Number (1)</u> | <u>Test Fluid(2)</u> | <u>Minimum Test Pressure(PSIG) (8)</u> |
| SP-SOV-508 | 57 | Gas (7) | 43 |
| SP-SOV-509 | 57 | Gas (7) | 43 |
| SP-SOV-510 | 57 | Gas (7) | 43 |
| SP-SOV-511 | 57 | Gas (7) | 43 |
| SP-SOV-512 | 57 | Gas (7) | 43 |
| SP-SOV-513 | 57 | Gas (7) | 43 |
| SP-SOV-514 | 57 | Gas (7) | 43 |
| SP-SOV-515 | 57 | Gas (7) | 43 |
| SP-SOV-516 | 57 | Gas (7) | 43 |
| HR-MOV-1882A | 58 | Gas | 43 |
| HR-IV-2A | 58 | Gas | 43 |
| HR-IV-2B | 58 | Gas | 43 |
| HR-MOV-1875A | 59 | Gas | 43 |
| HR-IV-3A | 59 | Gas | 43 |
| HR-MOV-1876A | 60 | Gas | 43 |
| HR-IV-5A | 60 | Gas | 43 |
| HR-MOV-1875B | 61 | Gas | 43 |
| HR-IV-3B | 61 | Gas | 43 |
| HR-MOV-1876B | 62 | Gas | 43 |
| HR-IV-5B | 62 | Gas | 43 |
| IA-39 | 64 | Gas | 43 |
| IA-PCV-1228 | 64 | Gas | 43 |
| PS-7 | 65 | Gas (7) | 43 |
| PS-10 | 65 | Gas (7) | 43 |
| PS-8 | 65 | Gas (7) | 43 |
| PS-9 | 65 | Gas (7) | 43 |
| CB-1 | 69 | Gas | 43 |
| CB-2 | 69 | Gas | 43 |
| CB-3 | 69 | Gas (7) | 43 |
| CB-4 | 69 | Gas (7) | 43 |
| DW-AOV-1 | 70 | Water (4) | 47 |
| DW-AOV-2 | 70 | Water (4) | 47 |

TABLE 4.4-1 (Page 7 of 7)
CONTAINMENT ISOLATION VALVES

NOTES:

1. Reference: FSAR Table 5.2-1, Penetration No.
2. Gas Test Fluid indicates either nitrogen or air as test medium.
3. Testable only when at cold shutdown.
4. Isolation Valve Seal Water System.
5. Sealed by Residual Heat Removal System fluid.
6. Sealed by Service Water System.
7. Sealed by Weld Channel and Penetration Pressurization System.
8. The minimum test pressure may be reduced by 2 psig until the current requirements associated with the Boron Injection Tank are removed (see Tech Spec 3.3.A.3.b).



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION
RELATED TO AMENDMENT NO. 102 TO FACILITY OPERATING LICENSE NO. DPR-64
POWER AUTHORITY OF THE STATE OF NEW YORK
INDIAN POINT NUCLEAR GENERATING UNIT NO. 3
DOCKET NO. 50-286

INTRODUCTION

By letter dated October 13, 1987, the Power Authority of the State of New York (the licensee) requested an amendment to Facility Operating License No. DPR-64 for Indian Point Nuclear Generating Unit No. 3. This proposed amendment would revise Technical Specification Tables 3.6-1 and 4.4-1 to reflect modifications to certain containment isolation valves. Sections 3.3 and 4.4 would have been revised to reflect an increase in the calculated peak containment LOCA pressure.

The parts of the amendment request related to Sections 3.3 and 4.4 (increase in calculated peak containment LOCA pressure) were withdrawn by letter dated March 6, 1989. The NRC granted the request for withdrawal on March 31, 1989.

DESCRIPTION

Table 3.6-1 has been revised to reflect the:

- addition of containment isolation valves CH-MOV-441 thru 444
- deletion of valves 1890 A thru H, J
- deletion of valves 241 A thru D
- deletion of valves 580 A, B

Table 4.4-1 has been revised to reflect the:

- addition of containment isolation valves SP-SOV-506 thru 516
- addition of containment isolation valves CH-MOV-441 thru 444
- deletion of valves 1890 A thru H, J
- deletion of valves 241 A thru D
- deletion of valves 580 A, B

Additionally, the appropriate valve identification prefix and suffix have been added to those valves listed in Tables 3.6-1 and 4.4-1.

9008170090 900813
FDR DOCK 05000286
P FDC

EVALUATION

Containment isolation valves CH-MOV-441 thru 444 were installed in the four reactor coolant pump seal water supply lines between the existing two containment isolation valves. This modification obviated the containment isolation function of the upstream valves, 241 A thru D.

The manual containment isolation valves, 1890 A thru H, J, for the post accident hydrogen sampling system, were replaced with solenoid operated valves, SP-SOV-506 thru 516.

Valves CH-MOV-441 thru 444 and SP-SOV-506 thru 516 were treated as containment isolation valves subject to appropriate Technical Specification requirements as of the date of their installation.

Containment isolation valves 580 A, B were removed from the pressurizer deadweight transmitter line. The line was capped and is no longer in use.

The appropriate valve identification prefix and suffix have been added to the listed valves. The valve identification prefix identifies the valve operator and the system in which the valve is located. The valve suffix distinguishes those valves which otherwise would have the same valve identification.

Table 4.4-1 reflects the minimum leak-rate test pressures which were approved by Amendment No. 98 dated May 7, 1990. The pressures approved by Amendment 98 supercede those in the licensee's submittal dated October 13, 1987.

ENVIRONMENTAL CONSIDERATION

This amendment involves a change to a requirement with respect to the installation of use of a facility component located within the restricted area as defined in 10 CFR Part 20. The staff has determined that the amendment involves no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that this amendment involves no significant hazards consideration and there has been no public comment on such finding. Accordingly, this amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR Sec 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of this amendment.

CONCLUSION

We have concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (2) such activities will be conducted in compliance with the Commission's regulations and the issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public.

Date: August 13, 1990

PRINCIPAL CONTRIBUTOR:

Joseph D. Neighbors, PDI-1