



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

PSEG NUCLEAR LLC
PHILADELPHIA ELECTRIC COMPANY
ATLANTIC CITY ELECTRIC COMPANY

DOCKET NO. 50-272

SALEM NUCLEAR GENERATING STATION, UNIT NO. 1

FACILITY OPERATING LICENSE

Amendment No.
License No. DPR-70

1. The Nuclear Regulatory Commission (the Commission) having found that:
 - A. The application for license filed by the Public Service Electric and Gas Company, Philadelphia Electric Company, Delmarva Power and Light Company, and Atlantic City Electric Company and the application for license amendment dated November 8, 1976, filed by Public Service Electric and Gas Company comply with the standards and requirements of the Atomic Energy Act (the Act) of 1954, as amended, and the Commission's rules and regulations set forth in 10 CFR Chapter I and all required notifications to other agencies or bodies have been duly made;
 - B. Construction of the Salem Nuclear Generating Station, Unit No. 1 (facility) has been substantially completed in conformity with Provisional Construction Permit No. CPPR-52 and the application, as amended, the provisions of the Act and the rules and regulations of the Commission;
 - C. The facility will operate in conformity with the application, as amended, the provisions of the Act, and the rules and regulations of the Commission;
 - D. There is reasonable assurance: (i) that the activities authorized by this amended operating license can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the rules and regulations of the Commission;
 - E. PSEG Nuclear LLC is technically qualified and the licensees are financially qualified to engage in the activities authorized by this amended operating license in accordance with the rules and regulations of the Commission;

- F. The licensees have satisfied the applicable provisions of 10 CFR Part 140, "Financial Protection Requirements and Indemnity Agreements," of the Commission's regulations;
 - G. The issuance of this amended operating license will not be inimical to the common defense and security or to the health and safety of the public;
 - H. After weighing the environmental, economic, technical, and other benefits of the facility against environmental and other costs and considering available alternatives, the issuance of Amendment No. 3 to Facility Operating License No. DPR-70 subject to the conditions for protection of the environment set forth in the Technical Specifications, Appendix B is in accordance with 10 CFR Part 51 (and with former Appendix D to 10 CFR Part 50) of the Commission's regulations and all applicable requirements have been satisfied; and
 - I. The receipt, possession, and use of source, byproduct and special nuclear material as authorized by this amended license will be in accordance with the Commission's regulations in 10 CFR Parts 30, 40, and 70, including 10 CFR Sections 30.33, 40.32, and 70.23 and 70.31.
2. Facility Operating License No. DPR-70, issued to PSEG Nuclear LLC, Philadelphia Electric Company, and Atlantic City Electric Company (the licensees), is hereby amended in its entirety, to read as follows:
- A. This amended license applies to the Salem Nuclear Generating Station, Unit No. 1, a pressurized water nuclear reactor and associated equipment (the facility), owned by PSEG Nuclear LLC, Philadelphia Electric Company, and Atlantic City Electric Company and operated by PSEG Nuclear LLC. The facility is located on the applicants' site in Salem County, New Jersey, on the southern end of Artificial Island on the east bank of the Delaware River in Lower Alloways Creek Township, and is described in the "Final Safety Analysis Report" as supplemented and amended (Amendments 10 through 39) and the Environmental Report as supplemented and amended (Amendments 1 through 3).
 - B. Subject to the conditions and requirements incorporated herein, the Commission hereby licenses

- (1) PSEG Nuclear LLC, Philadelphia Electric Company, and Atlantic City Electric Company to possess the facility at the designated location in Salem County, New Jersey, in accordance with the procedures and limitations set forth in this amended license;
- (2) PSEG Nuclear LLC, pursuant to Section 104b of the Act and 10 CFR Part 50, "Licensing of Production and Utilization Facilities," to possess, use and operate the facility;
- (3) PSEG Nuclear LLC, pursuant to the Act and 10 CFR Part 70, to receive, possess and use at any time special nuclear material as reactor fuel, in accordance with the limitations for storage and amounts required for reactor operation, as described in the Final Safety Analysis Report, as supplemented and amended;
- (4) PSEG Nuclear LLC, pursuant to the Act and 10 CFR Parts 30, 40 and 70 to receive, possess and use at any time any byproduct, source and special nuclear material as sealed neutron sources for reactor startup, sealed sources for reactor instrumentation and radiation monitoring equipment calibration, and as fission detectors in amounts as required;
- (5) PSEG Nuclear LLC, pursuant to the Act and 10 CFR Parts 30, 40 and 70 to receive, possess and use in amounts as required any byproduct, source or special nuclear material without restriction to chemical or physical form, for sample analysis or instrument calibration or associated with radioactive apparatus or components; and
- (6) PSEG Nuclear LLC, pursuant to the Act and 10 CFR Parts 30 and 70, to possess, but not separate, such byproduct and special nuclear materials as may be produced by the operation of the facility.

C. This amended license shall be deemed to contain and is subject to the conditions specified in the following Commission regulations in 10 CFR Chapter I: Part 20, Section 30.34 of Part 30, Section 40.41 of Part 40, Sections 50.54 and 50.59 of Part 50, and Section 70.32 of Part 70; and is subject to all applicable provisions of the Act and to the rules, regulations, and orders of the Commission now or hereafter in effect; and is subject to the additional conditions specified or incorporated below:

APPENDIX C
ADDITIONAL CONDITIONS
OPERATING LICENSE NO. DPR-70

PSEG Nuclear LLC, Philadelphia Electric Company, and Atlantic City Electric Company shall comply with the following conditions on the schedules noted below:

Amendment Number	Additional Condition	Implementation Date
192	The licensee is authorized to relocate certain Technical Specification requirements to licensee-controlled documents. Implementation of this amendment shall include the relocation of these technical specification requirements to the appropriate documents, as described in the licensee's application dated January 11, 1996, as supplemented by letters dated February 26, May 22, June 27, July 12, December 23, 1996, and March 17, 1997, and evaluated in the staff's safety evaluation attached to this amendment.	The amendment shall be implemented within 60 days from March 21, 1997.
194	The licensee is authorized to upgrade the initiation circuitry for the power operated relief valves, as described in the licensee's application dated January 31, 1997, as supplemented by letters dated March 14, April 8, and April 28, 1997, and evaluated in the staff's safety evaluation attached to this amendment.	The amendment shall be implemented prior to entry into Mode 3 from the current outage for Salem Unit 1.
196	<p>Containment Fan Cooler Units</p> <p>The licensee shall complete all modifications associated with the amendment request concerning Containment Fan Cooler Units (CFCU) response time dated October 25, 1996, as described in the letters supplementing the amendment request dated December 11, 1996, January 28, March 27, April 24, June 3, and June 12, 1997, prior to entry into Mode 3 following refueling outage 12. All modifications made in support of this amendment request and described in the referenced submittals shall be in conformance with the existing design basis for Salem Unit 1, and programmatic controls for tank monitoring instrumentation shall be as described in the letter dated April 24, 1997. Post modification testing and confirmatory analyses shall be as described in the letter dated March 27, 1997. Future changes to the design described in these submittals may be made in accordance with the provisions of 10 CFR 50.59. Further, the administrative controls associated with CFCU operability and containment integrity described in the letters dated March 27, and April 24, 1997 shall not be relaxed or changed without prior staff review until such time as the license has been amended to include the administrative controls as technical specification requirements.</p>	The amendment shall be implemented prior to entry into Mode 3 from the current outage for Salem Unit 1.
198	The licensee shall perform an evaluation of the containment liner anchorage by November 30, 1997, for the loading induced on the containment liner during a Main Steam Line Break event to confirm the assumptions provided in the Preliminary Safety Analysis Report and Updated Final Safety Analysis Report.	The amendment shall be implemented within 30 days from July 17, 1997.

Amendment No.



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

PSEG NUCLEAR LCC
PHILADELPHIA ELECTRIC COMPANY
ATLANTIC CITY ELECTRIC COMPANY

DOCKET NO. 50-311

SALEM NUCLEAR GENERATING STATION, UNIT NO. 2

FACILITY OPERATING LICENSE

Amendment No.
License No. DPR-75

1. The Nuclear Regulatory Commission (the Commission) having found that:
 - A. The application for license filed by Public Service Electric and Gas Company for itself and the Philadelphia Electric Company, Delmarva Power and Light Company and Atlantic City Electric Company complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I and all required notifications to other agencies or bodies have been duly made;
 - B. Construction of the Salem Nuclear Generating Station. Unit No. 2 (facility) has been substantially completed in conformity with Construction Permit No. CPPR-53 and the application, as amended, the provisions of the Act and the regulations of the Commission;
 - C. The facility will operate in conformity with the application, as amended, the provisions of the Act, and the regulations of the Commission;
 - D. There is reasonable assurance: (i) that the activities authorized by this operating license can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - E. PSEG Nuclear LLC is technically qualified to engage in the activities authorized by this operating license in accordance with the Commission's regulations set forth in 10 CFR Chapter I;

- F. The licensees are financially qualified to engage in the activities authorized by this license in accordance with the Commission's regulations set forth in 10 CFR Chapter I;
 - G. The licensees have satisfied the applicable provisions of 10 CFR Part 140, "Financial Protection Requirements and Indemnity Agreements," of the Commission's regulations;
 - H. The issuance of this operating license will not be inimical to the common defense and security or to the health and safety of the public;
 - I. After weighing the environmental, economic, technical and other benefits of the facility against environmental and other costs and considering available alternatives, the issuance of Facility Operating License No. DPR-75 subject to the conditions for protection of the environment set forth herein is in accordance with 10 CFR Part 50 Appendix D of the Commission's regulations and all applicable requirements have been satisfied; and
 - J. The receipt, possession, and use of source, byproduct and special nuclear material as authorized by this license will be in accordance with the Commission's regulations in 10 CFR Parts 30, 40 and 70.
2. Pursuant to approval by the Nuclear Regulatory Commission at meetings on January 14, 1981, April 28, 1981, and May 19, 1981, the License for Fuel-Loading and Low-Power Testing issued on April 18, 1980 is superseded by Facility Operating License No. DPR-75 hereby issued to PSEG Nuclear LLC, Philadelphia Electric Company, and Atlantic City Electric Company (licensees) to read as follows:
- A. This license applies to the Salem Nuclear Generating Station, Unit No. 2, a pressurized water nuclear reactor and associated equipment (the facility), owned by the licensees. The facility is located on the southern end of Artificial Island on the east bank of the Delaware River in Lower Alloways Creek Township in Salem County, New Jersey and is described in the Final Safety Analysis Report as supplemented and amended and the Environmental Report as supplemented and amended.
 - B. Subject to the conditions and requirements incorporated herein, the Commission hereby licenses:
 - (1) PSEG Nuclear LLC, Philadelphia Electric Company, and Atlantic City Electric Company to possess the facility at the designated location in Salem County, New Jersey, in accordance with the procedures and limitations set forth in the license;

APPENDIX C
ADDITIONAL CONDITIONS
OPERATING LICENSE NO. DPR-75

PSEG Nuclear LLC, Philadelphia Electric Company, and Atlantic City Electric Company shall comply with the following conditions on the schedules noted below:

Amendment Number	Additional Condition	Implementation Date
175	The licensee is authorized to relocate certain Technical Specification requirements to licensee-controlled documents. Implementation of this amendment shall include the relocation of these technical specification requirements to the appropriate documents, as described in the licensee's application dated January 11, 1996, as supplemented by letters dated February 26, May 22, June 27, July 12, December 23, 1996, and March 17, 1997, and evaluated in the staff's safety evaluation attached to this amendment.	The amendment shall be implemented within 60 days from March 21, 1997.
177	The licensee is authorized to upgrade the initiation circuitry for the power operated relief valves, as described in the licensee's application dated January 31, 1997, as supplemented by letters dated March 14, April 8, and April 28, 1997, and evaluated in the staff's safety evaluation attached to this amendment.	The amendment shall be implemented prior to entry into Mode 3 from the current outage for Salem Unit 2.
179	Containment Fan Cooler Units The licensee shall complete all modifications associated with the amendment request concerning Containment Fan Cooler Units (CFCU) response time dated October 25, 1996, as described in the letters supplementing the amendment request dated December 11, 1996, January 28, March 27, April 24, June 3, and June 12, 1997, prior to entry into Mode 3 following refueling outage 12. All modifications made in support of this amendment request and described in the referenced submittals shall be in conformance with the existing design basis for Salem Unit 1, and programmatic controls for tank monitoring instrumentation shall be as described in the letter dated April 24, 1997. Post modification testing and confirmatory analyses shall be as described in the letter dated March 27, 1997. Future changes to the design described in these submittals may be made in accordance with the provisions of 10 CFR 50.59. Further, the administrative controls associated with CFCU operability and containment integrity described in the letters dated March 27, and April 24, 1997 shall not be relaxed or changed without prior staff review until such time as the license has been amended to include the administrative controls as technical specification requirements.	The amendment shall be implemented prior to entry into Mode 3 from the current outage for Salem Unit 2.
181	The licensee shall perform an evaluation of the containment liner anchorage by November 30, 1997, for the loading induced on the containment liner during a Main Steam Line Break event to confirm the assumptions provided in the Preliminary Safety Analysis Report and Updated Final Safety Analysis Report.	The amendment shall be implemented within 30 days from July 17, 1997.

Amendment No.



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

PSEG NUCLEAR LLC
PHILADELPHIA ELECTRIC COMPANY

DOCKET NO. 50-272

SALEM NUCLEAR GENERATING STATION, UNIT NO. 1

FACILITY OPERATING LICENSE

Amendment No.
License No. DPR-70

1. The Nuclear Regulatory Commission (the Commission) having found that:
 - A. The application for license filed by the Public Service Electric and Gas Company, Philadelphia Electric Company, Delmarva Power and Light Company, and Atlantic City Electric Company and the application for license amendment dated November 8, 1976, filed by Public Service Electric and Gas Company comply with the standards and requirements of the Atomic Energy Act (the Act) of 1954, as amended, and the Commission's rules and regulations set forth in 10 CFR Chapter I and all required notifications to other agencies or bodies have been duly made;
 - B. Construction of the Salem Nuclear Generating Station, Unit No. 1 (facility) has been substantially completed in conformity with Provisional Construction Permit No. CPPR-52 and the application, as amended, the provisions of the Act and the rules and regulations of the Commission;
 - C. The facility will operate in conformity with the application, as amended, the provisions of the Act, and the rules and regulations of the Commission;
 - D. There is reasonable assurance: (i) that the activities authorized by this amended operating license can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the rules and regulations of the Commission;
 - E. PSEG Nuclear LLC is technically qualified and the licensees are financially qualified to engage in the activities authorized by this amended operating license in accordance with the rules and regulations of the Commission;

- F. The licensees have satisfied the applicable provisions of 10 CFR Part 140, "Financial Protection Requirements and Indemnity Agreements," of the Commission's regulations;
 - G. The issuance of this amended operating license will not be inimical to the common defense and security or to the health and safety of the public;
 - H. After weighing the environmental, economic, technical, and other benefits of the facility against environmental and other costs and considering available alternatives, the issuance of Amendment No. 3 to Facility Operating License No. DPR-70 subject to the conditions for protection of the environment set forth in the Technical Specifications, Appendix B is in accordance with 10 CFR Part 51 (and with former Appendix D to 10 CFR Part 50) of the Commission's regulations and all applicable requirements have been satisfied; and
 - I. The receipt, possession, and use of source, byproduct and special nuclear material as authorized by this amended license will be in accordance with the Commission's regulations in 10 CFR Parts 30, 40, and 70, including 10 CFR Sections 30.33, 40.32, and 70.23 and 70.31.
2. Facility Operating License No. DPR-70, issued to PSEG Nuclear LLC and Philadelphia Electric Company (the licensees), is hereby amended in its entirety, to read as follows:
- A. This amended license applies to the Salem Nuclear Generating Station, Unit No. 1, a pressurized water nuclear reactor and associated equipment (the facility), owned by PSEG Nuclear LLC and Philadelphia Electric Company, and operated by PSEG Nuclear LLC. The facility is located on the applicants' site in Salem County, New Jersey, on the southern end of Artificial Island on the east bank of the Delaware River in Lower Alloways Creek Township, and is described in the "Final Safety Analysis Report" as supplemented and amended (Amendments 10 through 39) and the Environmental Report as supplemented and amended (Amendments 1 through 3).
 - B. Subject to the conditions and requirements incorporated herein, the Commission hereby licenses

- (1) PSEG Nuclear LLC, and Philadelphia Electric Company, to possess the facility at the designated location in Salem County, New Jersey, in accordance with the procedures and limitations set forth in this amended license;
- (2) PSEG Nuclear LLC, pursuant to Section 104b of the Act and 10 CFR Part 50, "Licensing of Production and Utilization Facilities," to possess, use and operate the facility;
- (3) PSEG Nuclear LLC, pursuant to the Act and 10 CFR Part 70, to receive, possess and use at any time special nuclear material as reactor fuel, in accordance with the limitations for storage and amounts required for reactor operation, as described in the Final Safety Analysis Report, as supplemented and amended;
- (4) PSEG Nuclear LLC, pursuant to the Act and 10 CFR Parts 30, 40 and 70 to receive, possess and use at any time any byproduct, source and special nuclear material as sealed neutron sources for reactor startup, sealed sources for reactor instrumentation and radiation monitoring equipment calibration, and as fission detectors in amounts as required;
- (5) PSEG Nuclear LLC, pursuant to the Act and 10 CFR Parts 30, 40 and 70 to receive, possess and use in amounts as required any byproduct, source or special nuclear material without restriction to chemical or physical form, for sample analysis or instrument calibration or associated with radioactive apparatus or components; and
- (6) PSEG Nuclear LLC, pursuant to the Act and 10 CFR Parts 30 and 70, to possess, but not separate, such byproduct and special nuclear materials as may be produced by the operation of the facility.

C. This amended license shall be deemed to contain and is subject to the conditions specified in the following Commission regulations in 10 CFR Chapter I: Part 20, Section 30.34 of Part 30, Section 40.41 of Part 40, Sections 50.54 and 50.59 of Part 50, and Section 70.32 of Part 70; and is subject to all applicable provisions of the Act and to the rules, regulations, and orders of the Commission now or hereafter in effect; and is subject to the additional conditions specified or incorporated below:

APPENDIX C
ADDITIONAL CONDITIONS
OPERATING LICENSE NO. DPR-70

PSEG Nuclear LLC and Philadelphia Electric Company shall comply with the following conditions on the schedules noted below:

Amendment Number	Additional Condition	Implementation Date
192	The licensee is authorized to relocate certain Technical Specification requirements to licensee-controlled documents. Implementation of this amendment shall include the relocation of these technical specification requirements to the appropriate documents, as described in the licensee's application dated January 11, 1996, as supplemented by letters dated February 26, May 22, June 27, July 12, December 23, 1996, and March 17, 1997, and evaluated in the staff's safety evaluation attached to this amendment.	The amendment shall be implemented within 60 days from March 21, 1997.
194	The licensee is authorized to upgrade the initiation circuitry for the power operated relief valves, as described in the licensee's application dated January 31, 1997, as supplemented by letters dated March 14, April 8, and April 28, 1997, and evaluated in the staff's safety evaluation attached to this amendment.	The amendment shall be implemented prior to entry into Mode 3 from the current outage for Salem Unit 1.
196	Containment Fan Cooler Units The licensee shall complete all modifications associated with the amendment request concerning Containment Fan Cooler Units (CFCU) response time dated October 25, 1996, as described in the letters supplementing the amendment request dated December 11, 1996, January 28, March 27, April 24, June 3, and June 12, 1997, prior to entry into Mode 3 following refueling outage 12. All modifications made in support of this amendment request and described in the referenced submittals shall be in conformance with the existing design basis for Salem Unit 1, and programmatic controls for tank monitoring instrumentation shall be as described in the letter dated April 24, 1997. Post modification testing and confirmatory analyses shall be as described in the letter dated March 27, 1997. Future changes to the design described in these submittals may be made in accordance with the provisions of 10 CFR 50.59. Further, the administrative controls associated with CFCU operability and containment integrity described in the letters dated March 27, and April 24, 1997 shall not be relaxed or changed without prior staff review until such time as the license has been amended to include the administrative controls as technical specification requirements.	The amendment shall be implemented prior to entry into Mode 3 from the current outage for Salem Unit 1.
198	The licensee shall perform an evaluation of the containment liner anchorage by November 30, 1997, for the loading induced on the containment liner during a Main Steam Line Break event to confirm the assumptions provided in the Preliminary Safety Analysis Report and Updated Final Safety Analysis Report.	The amendment shall be implemented within 30 days from July 17, 1997.

Amendment No.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

PSEG NUCLEAR LCC
PHILADELPHIA ELECTRIC COMPANY

DOCKET NO. 50-311

SALEM NUCLEAR GENERATING STATION, UNIT NO. 2

FACILITY OPERATING LICENSE

Amendment No.
License No. DPR-75

1. The Nuclear Regulatory Commission (the Commission) having found that:
 - A. The application for license filed by Public Service Electric and Gas Company for itself and the Philadelphia Electric Company, Delmarva Power and Light Company and Atlantic City Electric Company complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I and all required notifications to other agencies or bodies have been duly made;
 - B. Construction of the Salem Nuclear Generating Station. Unit No. 2 (facility) has been substantially completed in conformity with Construction Permit No. CPPR-53 and the application, as amended, the provisions of the Act and the regulations of the Commission;
 - C. The facility will operate in conformity with the application, as amended, the provisions of the Act, and the regulations of the Commission;
 - D. There is reasonable assurance: (i) that the activities authorized by this operating license can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - E. PSEG Nuclear LLC is technically qualified to engage in the activities authorized by this operating license in accordance with the Commission's regulations set forth in 10 CFR Chapter I;

Amendment No.

- F. The licensees are financially qualified to engage in the activities authorized by this license in accordance with the Commission's regulations set forth in 10 CFR Chapter I;
 - G. The licensees have satisfied the applicable provisions of 10 CFR Part 140, "Financial Protection Requirements and Indemnity Agreements," of the Commission's regulations;
 - H. The issuance of this operating license will not be inimical to the common defense and security or to the health and safety of the public;
 - I. After weighing the environmental, economic, technical and other benefits of the facility against environmental and other costs and considering available alternatives, the issuance of Facility Operating License No. DPR-75 subject to the conditions for protection of the environment set forth herein is in accordance with 10 CFR Part 50 Appendix D of the Commission's regulations and all applicable requirements have been satisfied; and
 - J. The receipt, possession, and use of source, byproduct and special nuclear material as authorized by this license will be in accordance with the Commission's regulations in 10 CFR Parts 30, 40 and 70.
2. Pursuant to approval by the Nuclear Regulatory Commission at meetings on January 14, 1981, April 28, 1981, and May 19, 1981, the License for Fuel-Loading and Low-Power Testing issued on April 18, 1980 is superseded by Facility Operating License No. DPR-75 hereby issued to PSEG Nuclear LLC and Philadelphia Electric Company (licensees) to read as follows:
- A. This license applies to the Salem Nuclear Generating Station, Unit No. 2, a pressurized water nuclear reactor and associated equipment (the facility), owned by the licensees. The facility is located on the southern end of Artificial Island on the east bank of the Delaware River in Lower Alloways Creek Township in Salem County, New Jersey and is described in the Final Safety Analysis Report as supplemented and amended and the Environmental Report as supplemented and amended.
 - B. Subject to the conditions and requirements incorporated herein, the Commission hereby licenses:
 - (1) PSEG Nuclear LLC and Philadelphia Electric Company to possess the facility at the designated location in Salem County, New Jersey, in accordance with the procedures and limitations set forth in the license;

APPENDIX C
ADDITIONAL CONDITIONS
OPERATING LICENSE NO. DPR-75

PSEG Nuclear LLC and Philadelphia Electric Company, shall comply with the following conditions on the schedules noted below:

Amendment Number	Additional Condition	Implementation Date
175	The licensee is authorized to relocate certain Technical Specification requirements to licensee-controlled documents. Implementation of this amendment shall include the relocation of these technical specification requirements to the appropriate documents, as described in the licensee's application dated January 11, 1996, as supplemented by letters dated February 26, May 22, June 27, July 12, December 23, 1996, and March 17, 1997, and evaluated in the staff's safety evaluation attached to this amendment.	The amendment shall be implemented within 60 days from March 21, 1997.
177	The licensee is authorized to upgrade the initiation circuitry for the power operated relief valves, as described in the licensee's application dated January 31, 1997, as supplemented by letters dated March 14, April 8, and April 28, 1997, and evaluated in the staff's safety evaluation attached to this amendment.	The amendment shall be implemented prior to entry into Mode 3 from the current outage for Salem Unit 2.
179	Containment Fan Cooler Units The licensee shall complete all modifications associated with the amendment request concerning Containment Fan Cooler Units (CFCU) response time dated October 25, 1996, as described in the letters supplementing the amendment request dated December 11, 1996, January 28, March 27, April 24, June 3, and June 12, 1997, prior to entry into Mode 3 following refueling outage 12. All modifications made in support of this amendment request and described in the referenced submittals shall be in conformance with the existing design basis for Salem Unit 1, and programmatic controls for tank monitoring instrumentation shall be as described in the letter dated April 24, 1997. Post modification testing and confirmatory analyses shall be as described in the letter dated March 27, 1997. Future changes to the design described in these submittals may be made in accordance with the provisions of 10 CFR 50.59. Further, the administrative controls associated with CFCU operability and containment integrity described in the letters dated March 27, and April 24, 1997 shall not be relaxed or changed without prior staff review until such time as the license has been amended to include the administrative controls as technical specification requirements.	The amendment shall be implemented prior to entry into Mode 3 from the current outage for Salem Unit 2.
181	The licensee shall perform an evaluation of the containment liner anchorage by November 30, 1997, for the loading induced on the containment liner during a Main Steam Line Break event to confirm the assumptions provided in the Preliminary Safety Analysis Report and Updated Final Safety Analysis Report.	The amendment shall be implemented within 30 days from July 17, 1997.

Amendment No.