Duke Power
A Duke Energy Company

W. R. McCollum, Jr.
Vice President

Duke Power
Oconee Nuclear Site
7800 Rochester Highway
Seneca, SC 29672
(864) 885-3107 OFFICE
(864) 885-3564 FAX

December 14, 2000

U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Attention: Document Control Desk

Subject: Oconee Nuclear Station
Docket Numbers 50-269, 270, and 287
Technical Specification Bases Changes

Please find attached revision to Tech Spec Bases B 3.3.8. which was approved by Station Management on November 30, 2000 and implemented on December 5, 2000. The change revised the Core Exit Temperature section to clarify that the unit computer is the primary display for 47 Core Exit Thermocouples (CET). Five CETs are displayed on the corresponding SSF unit console. The change will also reflect the deletion of the LPSW flow to LPI Decay Heat Cooler Recorder. The recorder was removed per minor modification OE-13892.

Attachment 1 contains the new Technical Specification Bases page and Attachment 2 contains the markup version of the Bases page.

If any additional information is needed, please contact Larry E. Nicholson, (864-885-3292)

Very truly yours,

W. R. McCollum, Jr., Vice President
Oconee Nuclear Site

A001

cc: Mr. D. E. LaBarge, Project Manager
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Mail Stop O-14 H25
Washington, D. C. 20555

Mr. L. A. Reyes, Regional Administrator
U. S. Nuclear Regulatory Commission - Region II
Atlanta Federal Center
61 Forsyth St., SW, Suite 23T85
Atlanta, Georgia 30303

M. C. Shannon
Senior Resident Inspector
Oconee Nuclear Station

Virgil R. Autry, Director
Division of Radioactive Waste Management
Bureau of Land and Waste Management
Department of Health & Environmental Control
2600 Bull Street
Columbia, SC 29201

Attachment 1

BASES

LCO

16. Core Exit Temperature (continued)

There are a total of 52 Core Exit Thermocouples (CETs) per Oconee Unit. Twenty-four (12 per train) meet seismic and environmental qualification requirements (Category 1). The unit computer is the primary display for 47 CETs. Five CETs are displayed on the corresponding SSF Unit console. The CETs are distributed to provide monitoring of four or more in each quadrant for each train. The ICCM plasma displays (1 per train) located in the Control Room serve as safety related backup displays for the twenty-four Category 1 CETs. The range of the readouts is 50°F to 2300°F.

The ICCM CET function uses inputs from twelve incore thermocouples per train to calculate and display temperatures of the reactor coolant as it exits the core and to provide indication of thermal conditions across the core at the core exit. Each of the twelve qualified thermocouples per train is displayed on a spatially oriented core map on the plasma display. Trending of CET temperature is available continuously on the plasma display. The average of the five hottest CETs is trendable for the past forty minutes.

An evaluation was made of the minimum number of valid core exit thermocouples (CETs) necessary for inadequate core cooling detection. The evaluation determined the reduced complement of CETs necessary to detect initial core recovery and to trend the ensuing core heatup. The evaluations account for core nonuniformities and cold leg injection. Based on these evaluations, adequate or inadequate core cooling detection is ensured with two sets of five valid CETs.

Table 3.3.8-1 Note (d) indicates that the subcooling margin monitor takes the average of the five highest

CETs for each of the ICCM trains. Two channels ensure that a single failure will not disable the ability to determine the representative core exit temperature.

BASES

LCO (continued)

22. Low Pressure Service Water (LPSW) flow to LPI Coolers

LPSW flow to LPI Coolers is a Type A, Category 1 variable which is provided to prevent LPSW pump runout and inadequate NPSH. LPSW flow to LPI Coolers is throttled to maintain proper flow balance in the LPSW System.

Flow measurement is provided by one channel per train with readout on an indicator and the plant computer via a qualified signal isolator. The channels provide flow indication over a range from 0-8000 gpm.

APPLICABILITY

The PAM instrumentation LCO is applicable in MODES 1, 2, and 3. These variables are related to the diagnosis and preplanned actions required to mitigate accidents and transients. The applicable accidents and transients are assumed to occur in MODES 1, 2, and 3. In MODES 4, 5, and 6, unit conditions are such that the likelihood of an event occurring that would require PAM instrumentation is low; therefore, the PAM instrumentation is not required to be OPERABLE in these MODES.

ACTIONS

The ACTIONS are modified by two Notes. Note 1 is added to the ACTIONS to exclude the MODE change restriction of LCO 3.0.4. This exception allows entry into an applicable MODE while relying on the ACTIONS even though the ACTIONS may eventually require a unit shutdown. This exception is acceptable due to the passive function of the instruments, the operator's ability to respond to an accident utilizing alternate instruments and methods, and the low probability of an event requiring these instruments.

Note 2 is added to the ACTIONS to clarify the application of Completion Time rules. The Conditions of this Specification may be entered independently for each Function listed in Table 3.3.8-1. When the Required Channels for a function in Table 3.3.8-1 are specified on a "per" basis (e.g., per loop, per SG, per penetration flow path), then the Condition may be entered separately for each loop, SG, penetration flow path, etc., as appropriate. The Completion Time(s) of the inoperable channels of a Function are tracked separately for each Function starting from the time the Condition is entered for that Function.

Attachment 2

BASES

LCO

16. Core Exit Temperature (continued)

There are a total of 52 Core Exit Thermocouples (CETs) per Oconee Unit. Twenty-four (12 per train) meet seismic and environmental qualification requirements (Category 1). The unit computer is the primary display for ~~all 52~~ 11 CETs. The CETs are distributed to provide monitoring of four or more in each quadrant for each train. The ICCM plasma displays (1 per train) located in the Control Room serve as safety related backup displays for the twenty-four Category 1 CETs. The range of the readouts is 50°F to 2300°F.

Five CETs are displayed on the corresponding SSF unit console.

The ICCM CET function uses inputs from twelve incore thermocouples per train to calculate and display temperatures of the reactor coolant as it exits the core and to provide indication of thermal conditions across the core at the core exit. Each of the twelve qualified thermocouples per train is displayed on a spatially oriented core map on the plasma display. Trending of CET temperature is available continuously on the plasma display. The average of the five hottest CETs is trendable for the past forty minutes.

An evaluation was made of the minimum number of valid core exit thermocouples (CETs) necessary for inadequate core cooling detection. The evaluation determined the reduced complement of CETs necessary to detect initial core recovery and to trend the ensuing core heatup. The evaluations account for core nonuniformities and cold leg injection. Based on these evaluations, adequate or inadequate core cooling detection is ensured with two sets of five valid CETs.

Table 3.3.8-1 Note (d) indicates that the subcooling margin monitor takes the average of the five highest

CETs for each of the ICCM trains. Two channels ensure that a single failure will not disable the ability to determine the representative core exit temperature.

BASES

LCO (continued)

22. Low Pressure Service Water (LPSW) flow to LPI Coolers

LPSW flow to LPI Coolers is a Type A, Category 1 variable which is provided to prevent LPSW pump runout and inadequate NPSH. LPSW flow to LPI Coolers is throttled to maintain proper flow balance in the LPSW System.

Flow measurement is provided by one channel per train with readout on an indicator and ~~recorder~~. The channels provide flow indication over a range from 0-8000 gpm. the plant computer via a qualified signal isolator.

APPLICABILITY

The PAM instrumentation LCO is applicable in MODES 1, 2, and 3. These variables are related to the diagnosis and preplanned actions required to mitigate accidents and transients. The applicable accidents and transients are assumed to occur in MODES 1, 2, and 3. In MODES 4, 5, and 6, unit conditions are such that the likelihood of an event occurring that would require PAM instrumentation is low; therefore, the PAM instrumentation is not required to be OPERABLE in these MODES.

ACTIONS

The ACTIONS are modified by two Notes. Note 1 is added to the ACTIONS to exclude the MODE change restriction of LCO 3.0.4. This exception allows entry into an applicable MODE while relying on the ACTIONS even though the ACTIONS may eventually require a unit shutdown. This exception is acceptable due to the passive function of the instruments, the operator's ability to respond to an accident utilizing alternate instruments and methods, and the low probability of an event requiring these instruments.

Note 2 is added to the ACTIONS to clarify the application of Completion Time rules. The Conditions of this Specification may be entered independently for each Function listed in Table 3.3.8-1. When the Required Channels for a function in Table 3.3.8-1 are specified on a "per" basis (e.g., per loop, per SG, per penetration flow path), then the Condition may be entered separately for each loop, SG, penetration flow path, etc., as appropriate. The Completion Time(s) of the inoperable channels of a Function are tracked separately for each Function starting from the time the Condition is entered for that Function.