

JAN 31 1983

DISTRIBUTION:

Docket File  
NRC PDR  
Local PDR  
NSIC  
PRC

Docket No.: 50-387

Mr. Norman W. Curtis  
Vice President  
Engineering and Construction - Nuclear  
Pennsylvania Power & Light Company  
2 North Ninth Street  
Allentown, Pennsylvania 18101

LB#2 File  
RPerch  
EHylton  
Cutchin, OELD  
DEisenhut/RPurple  
ELJordan, DEQA:IE  
JMTaylor, DRP:IE  
LJHarmon, IE File (2)  
JSauder  
WMiller  
IDinitz  
WJones, QA  
TBarnhart (4)  
BPCotter, ASLBP  
ARosenhtal, ASLAP  
ACRS (16)  
RPagano, IE

Dear Mr. Curtis:

Subject: Amendment No. 7 to Facility Operating License No. NPF-14 -  
Susquehanna Steam Electric Station, Unit 1

The Nuclear Regulatory Commission has issued the enclosed Amendment No. 7 to Facility Operating License No. NPF-14 for the Susquehanna Steam Electric Station, Unit 1. The amendment is in response to your letter dated December 10, 1982. This amendment revises Technical Specifications 3.4.3.2 and 4.4.3.2.1 to be consistent with the intent of NUREG-0313, Revision 1 and Standard Technical Specifications as noted by the sua sponte question raised by the Atomic Safety and Licensing Appeal Board Order dated October 26, 1982.

A copy of the related safety evaluation supporting Amendment No. 7 to Facility Operating License NPF-14 is enclosed. Also enclosed is a copy of a related notice which has been forwarded to the Office of the Federal Register for publication.

As discussed with and agreed to by your staff on January 28, 1983, this amendment also contains a condition regarding implementation of certain aspects of the recently signed Public Law 97-425, January 7, 1983 (Nuclear Waste Policy Act of 1982).

Sincerely,

A. Schwencer, Chief  
Licensing Branch No. 2  
Division of Licensing

8302080406 830131  
PDR ADOCK 05000387  
PDR

Enclosures:

1. Amendment No. 7 to NPF-14
2. Safety Evaluation
3. Federal Register Notice

\*SEE ATTACHED PAGES FOR PREVIOUS CONCURRENCES

OFFICE	cc w/ enclosures See next page	DL:LB#2/PM*	DL:LB#2/LA*	OELD*	DL:LB#2/BC*	DL:AD/L*	
SURNAME		RPerch:pt	EHylton	MCutchin	ASchwencer	TNovak	
DATE		12/28/82	1/7/83	1/24/83	1/2/83	1/27/83	

**DISTRIBUTION:**

Docket File  
NRC PDR  
Local PDR  
NSIC  
PRC

Docket No.: 50-387

LB#2 File  
RPerch  
EHylton  
Cutchin, OELD  
DEisenhut/RPurple  
ELJordan, DEQA:IE  
MTaylor, DRP:IE  
LJHarmon, IE File (2)  
JSauder  
WMiller  
IDinitz  
WJones, QA  
TBarnhart (4)

BPCotter, ASLBP  
ARosenthal, ASLAP  
ACRS (16)  
FPagano, IE

Mr. Norman W. Curtis  
Vice President  
Engineering and Construction - Nuclear  
Pennsylvania Power & Light Company  
2 North Ninth Street  
Allentown, Pennsylvania 18101

Dear Mr. Curtis:

Subject: Amendment No. 7 to Facility Operating License No. NPF-14 -  
Susquehanna Steam Electric Station, Unit 1

The Nuclear Regulatory Commission has issued the enclosed Amendment No. 7 to Facility Operating License No. NPF-14 for the Susquehanna Steam Electric Station, Unit 1. The amendment is in response to your letter dated December 10, 1982. This amendment revises Technical Specifications 3.4.3.2 and 4.4.3.2.1 to be consistent with the intent of NUREG-0313, Revision 1 and Standard Technical Specifications as noted by the sua sponte question raised by the Atomic Safety and Licensing Appeal Board Order dated October 26, 1982.

A copy of the related safety evaluation supporting Amendment No. 7 to Facility Operating License NPF-14 is enclosed. Also enclosed is a copy of a related notice which has been forwarded to the Office of the Federal Register for publication.

Your attention is also directed to page 2, paragraph 3 of this amendment with regard to R.L. 97-425, January 7, 1983 (Nuclear Waste Policy Act of 1982).

Sincerely,

A. Schwencer, Chief  
Licensing Branch No. 2  
Division of Licensing

**Enclosures:**

- 1. Amendment No. 7 to NPF-14
- 2. Safety Evaluation
- 3. Federal Register Notice \*see attached pages for previous concurrences

OFFICE ▶	cc w/ enclosures: See next page	DL:LB#2/PM*	DL:LB#2/LA*	OELD *	DL:LB#2/BC*	DL:AD/L*
SURNAME ▶		RPerch:pt	EHylton	MCutchin	ASchwencer	TNovak
DATE ▶		12/28/82	1/7/83	1/24/83	1/6/83	1/27/83

Docket No.: 50-387

Mr. Norman W. Curtis  
Vice President  
Engineering and Construction - Nuclear  
Pennsylvania Power & Light Company  
2 North Ninth Street  
Allentown, Pennsylvania 18101

Dear Mr. Curtis:

Subject: Amendment No.        to Facility Operating License No. NPF-14 -  
Susquehanna Steam Electric Station, Unit 1

The Nuclear Regulatory Commission has issued the enclosed Amendment No.        to Facility Operating License No. NPF-14 for the Susquehanna Steam Electric Station, Unit 1. The amendment is in response to your letter dated December 10, 1982. This amendment revises Technical Specifications 3.4.3.2 and 4.4.3.2.1 to be consistent with the intent of NUREG-0313, Revision 1 and Standard Technical Specifications as noted by the sua sponte question raised by the Atomic Safety and Licensing Appeal Board Order dated October 26, 1982.

A copy of the related safety evaluation supporting Amendment No.        to Facility Operating License NPF-14 is enclosed. Also enclosed is a copy of a related notice which has been forwarded to the Office of the Federal Register for publication.

Your attention is also directed to page 2, paragraph 3 of this amendment with regard to P.L. 97-425, January 7, 1983 (Nuclear Waste Policy Act of 1982).

Sincerely,

Darrell G. Eisenhut, Director  
Division of Licensing  
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No.        to NPF-14
2. Safety Evaluation
3. Federal Register Notice

\*SEE ATTACHED PAGE FOR PREVIOUS CONCURRENCES

OFFICE	cc w/ enclosures	DL:LB2/PM	DL:LB#2/LA	OELD	DL:LB#2/BC	DL:AD/L	DL:DIR
SURNAME	See next page	RPerch:pt	EHylton	*	ASchwencer*	TNovak*	DEisenhut
DATE		12/28/82	1/7/83	1/24/83	1/6/83	1/27/83	/ /83

Docket No.: 50-387

Mr. Norman W. Curtis  
Vice President  
Engineering and Construction - Nuclear  
Pennsylvania Power & Light Company  
2 North Ninth Street  
Allentown, Pennsylvania 18101

Dear Mr. Curtis:

Subject: Amendment No.        to Facility Operating License No. NPF-14 -  
Susquehanna Steam Electric Station, Unit 1

The Nuclear Regulatory Commission has issued the enclosed Amendment No.        to Facility Operating License No. NPF-14 for the Susquehanna Steam Electric Station, Unit 1. The amendment is in response to your letter dated December 10, 1982. This amendment revises Technical Specifications 3.4.3.2 and 4.4.3.2.1 to be consistent with the intent of NUREG-0313, Revision 1 and Standard Technical Specifications as noted by the sua sponte question raised by the Atomic Safety and Licensing Appeal Board Order dated October 26, 1982.

A copy of the related safety evaluation supporting Amendment No.        to Facility Operating License NPF-14 is enclosed. Also enclosed is a copy of a related notice which has been forwarded to the Office of the Federal Register for publication.

Sincerely,

A. Schwencer, Chief  
Licensing Branch No. 2  
Division of Licensing

Enclosures:

1. Amendment No.        to NPF-14
2. Safety Evaluation
3. Federal Register Notice

cc w/ enclosures:  
See next page

OFFICE	DL:LB#2/PM	DL:LB#2/LA	OELD	DL:LB#2/BC	DL:AD/L		
SURNAME	RPerch:pt	EHylton	CUTCHIN	ASchwencer	Novak		
DATE	12/28/82	1/7/83	1/24/83	1/16/83	1/18		

Susquehanna

Mr. Norman W. Curtis  
Vice President  
Engineering and Construction  
Pennsylvania Power & Light Company  
Allentown, Pennsylvania 18101

ccs: Jay Silberg, Esquire  
Shaw, Pittman, Potts & Trowbridge  
1800 M Street, N. W.  
Washington, D. C. 20036

Edward M. Nagel, Esquire  
General Counsel and Secretary  
Pennsylvania Power & Light Company  
2 North Ninth Street  
Allentown, Pennsylvania 18101

Mr. William E. Barberich  
Nuclear Licensing Group Supervisor  
Pennsylvania Power & Light Company  
2 North Ninth Street  
Allentown, Pennsylvania 18101

Mr. G. Rhodes  
Resident Inspector  
P. O. Box 52  
Shickshinny, Pennsylvania 18655

Gerald R. Schultz, Esquire  
Susquehanna Environmental Advocates  
P. O. Box 1560  
Wilkes-Barre, Pennsylvania 18703

Mr. E. B. Poser  
Project Engineer  
Bechtel Power Corporation  
P. O. Box 3965  
San Francisco, California 94119

Dr. Judith H. Johnsrud  
Co-Director  
Environmental Coalition on Nuclear Power  
433 Orlando Avenue  
State College, Pennsylvania 16801

Mr. Thomas M. Gerusky, Director  
Bureau of Radiation Protection Resources  
Commonwealth of Pennsylvania  
P. O. Box 2063  
Harrisburg, Pennsylvania 17120

Ms. Colleen Marsh  
P. O. Box 538A, RD #4  
Mountain Top, Pennsylvania 18707

Mr. Thomas J. Halligan  
Correspondent  
The Citizens Against Nuclear Dangers  
P. O. Box 5  
Scranton, Pennsylvania 18501

Mr. J. W. Millard  
Project Manager  
Mail Code 395  
General Electric Company  
175 Curtner Avenue  
San Jose, California 95125

Robert W. Adler, Esquire  
Office of Attorney General  
505 Executive House  
P. O. Box 2357  
Harrisburg, Pennsylvania 17120

PENNSYLVANIA POWER & LIGHT COMPANY  
ALLEGHENY ELECTRIC COOPERATIVE, INC.  
DOCKET NO. 50-387  
SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1  
AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 7  
 License No. NPF-14

1. The Nuclear Regulatory Commission (the Commission or the NRC) having found that:
  - A. The application for an amendment filed by the Pennsylvania Power & Light Company, dated December 10, 1982, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the regulations of the Commission;
  - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
  
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of the Facility Operating License No. NPF-14 is hereby amended to read as follows:

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 7, and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. PP&L shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

OFFICE							
SURNAME							
DATE							
	8302080409 830131 PDR ADOCK 05000387 P PDR						

PENNSYLVANIA POWER & LIGHT COMPANY  
ALLEGHENY ELECTRIC COOPERATIVE, INC.  
DOCKET NO. 50-387  
SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1  
AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No.  
 License No. NPF-14

1. The Nuclear Regulatory Commission (the Commission or the NRC) having found that:
  - A. The application for an amendment filed by the Pennsylvania Power & Light Company, dated December 10, 1982, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the regulations of the Commission;
  - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
  
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of the Facility Operating License No. NPF-14 is hereby amended to read as follows:

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. , and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. PP&L shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

OFFICE ▶							
SURNAME ▶							
DATE ▶							

3. Within 90 days after the effective date of this amendment, or such later time as the Commission may specify, PP&L shall satisfy any applicable requirement of P.L. 97-425 related to pursuing an agreement with the Secretary of Energy for the disposal of high-level radioactive waste and spent nuclear fuel.
4. This amendment is effective as of the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



A. Schwencer, Chief  
Licensing Branch No. 2  
Division of Licensing

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: **JAN 31 1983**

\*SEE ATTACHED PAGES FOR PREVIOUS CONCURRENCES

OFFICE ▶	DL:LB#2/PM*	DL:LB#2/LA*	OELD*	DL:LB#2/BC*	DL:AD/L*		
SURNAME ▶	RPerch:pt	EHylton	MCutchin	ASchwencer	TNovak		
DATE ▶	12/28/82	1/7/83	1/24/83	1/6/83	1/27/83		

3. Within 90 days after the effective date of this amendment, or such later time as the Commission may specify, PP&L shall satisfy any applicable requirement of P.L. 97-425 related to pursuing an agreement with the Secretary of Energy for the disposal of high-level radioactive waste and spent nuclear fuel.
4. This amendment is effective as of the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

Darrell G. Eisenhut, Director  
 Division of Licensing  
 Office of Nuclear Reactor Regulation

Attachment:  
 Changes to the Technical  
 Specifications

Date of Issuance:

\*SEE ATTACHED PAGE FOR PREVIOUS CONCURRENCES

OFFICE	DL:LB#2/PM*	DL:LB#2/LA *	OELD *	DL:LB#2/BC*	<del>ORR</del>	DL:AD/L*	DL:DIR
SURNAME	RPerch:pt	EHy1ton		ASchwencer		TNovak	DEisenhut
DATE	12/28/82	1/7/83	1/24/83	1/6/83		1/27/83	

3. This amendment is effective as of the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

A. Schwencer, Chief  
Licensing Branch No. 2  
Division of Licensing

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance:

OFFICE	DL:LB#2/PT	DL:LB#2/LA	OELD <i>MS</i>	DL:LB#2/BC	DL:AD/b		
SURNAME	RPerch:pt	EHilton	CUTCHIN	ASchwencer	Novak		
DATE	12/29/82	1/17/87	1/24/83	1/16/8	1/15/8		

ATTACHMENT TO LICENSE AMENDMENT NO. 7  
FACILITY OPERATING LICENSE NO. NPF-14  
DOCKET NO. 50-387

Replace the following pages of the Appendix "A" Technical Specifications with enclosed pages. The revised pages are identified by Amendment number and contain vertical lines indicating the area of change.

REMOVE

3/4 4-7  
3/4 4-8

INSERT

3/4 4-7  
3/4 4-8

## REACTOR COOLANT SYSTEM

### OPERATIONAL LEAKAGE

#### LIMITING CONDITION FOR OPERATION

---

3.4.3.2 Reactor coolant system leakage shall be limited to:

- a. No PRESSURE BOUNDARY LEAKAGE.
- b. 5 gpm UNIDENTIFIED LEAKAGE.
- c. 25 gpm total leakage averaged over any 24-hour period.
- d. 1 gpm leakage at a reactor coolant system pressure of  $1000 \pm 10$  psig from any reactor coolant system pressure isolation valve specified in Table 3.4.3.2-1.
- e. 2 gpm increase in UNIDENTIFIED LEAKAGE within any 4-hour period.

APPLICABILITY: OPERATIONAL CONDITIONS 1, 2 and 3.

#### ACTION:

- a. With any PRESSURE BOUNDARY LEAKAGE, be in at least HOT SHUTDOWN within 12 hours and in COLD SHUTDOWN within the next 24 hours.
- b. With any reactor coolant system leakage greater than the limits in b and/or c, above, reduce the leakage rate to within the limits within 4 hours or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.
- c. With any reactor coolant system pressure isolation valve leakage greater than the above limit, isolate the high pressure portion of the affected system from the low pressure portion within 4 hours by use of at least two closed manual or deactivated automatic valves, or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.
- d. With one or more of the high/low pressure interface valve leakage pressure monitors shown in Table 3.4.3.2-1 inoperable, restore the inoperable monitor(s) to OPERABLE status within 7 days or verify the pressure to be less than the alarm pressure at least once per 12 hours; restore the inoperable monitor(s) to OPERABLE status within 30 days or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.
- e. With any reactor coolant system UNIDENTIFIED LEAKAGE increase greater 2 gpm within any 4-hour period, identify the source of leakage increase as not service sensitive Type 304 or 316 austenitic stainless steel within 4 hours or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.

## REACTOR COOLANT SYSTEM

### SURVEILLANCE REQUIREMENTS

---

4.4.3.2.1 The reactor coolant system leakage shall be demonstrated to be within each of the above limits by:

- a. Monitoring the primary containment atmospheric particulate and gaseous radioactivity at least once per 4 hours, and
- b. Monitoring the drywell floor drain sump level at least once per 4 hours.

4.4.3.2.2 Each reactor coolant system pressure isolation valve specified in Table 3.4.3.2-1 shall be demonstrated OPERABLE by leak testing pursuant to Specification 4.0.5 and verifying the leakage of each valve to be within the specified limit:

- a. At least once per 18 months, and
- b. Prior to returning the valve to service following maintenance, repair or replacement work on the valve which could affect its leakage rate.

The provisions of Specification 4.0.4 are not applicable for entry into OPERATIONAL CONDITION 3.

4.4.3.2.3 The high/low pressure interface valve leakage pressure monitors shall be demonstrated OPERABLE with the alarm setpoints per Table 3.4.3.2-1 by performance of a:

- a. CHANNEL FUNCTIONAL TEST at least once per 31 days, and
- b. CHANNEL CALIBRATION at least once per 18 months.



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

SAFETY EVALUATION  
AMENDMENT NO. 7 TO NPF-14  
SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1  
DOCKET NO. 50-387

Introduction

The licensee in a letter dated December 10, 1982, proposed changes to the Technical Specifications of the operating license for Susquehanna Steam Electric Station, Unit 1 which are as follows:

- a) Under Limiting Condition for Operation (LCO) of Technical Specification 3.4.3.2, the addition of a statement that reactor coolant system leakage shall be limited to 2 gpm increase in UNIDENTIFIED LEAKAGE within a 4-hour period, and the addition of an action statement for this LCO, and
- b) In surveillance requirements under Technical Specification 4.4.3.2.1, modify the monitoring of primary containment atmospheres particulate and gaseous activity, and drywell floor drain sump level at least once per 4 hours vice at least once per 12 hours.

In response to an Atomic Safety and Licensing Appeal Board (ASLAB) Order dated October 26, 1982 regarding reactor coolant leakage, the licensee informed the board that a limit on the increase in unidentified leakage was appropriate for Susquehanna, Unit 1, in order to be consistent with NUREG-0313, Rev. 1, and committed to effect a change in Unit 1 Technical Specifications which would include a limitation on the increase in unidentified reactor coolant system leakage of 2 gpm within a four-hour period. The licensee formally requested such a change, among others, in a letter to the NRC dated December 10, 1982.

In response to the ASLAB Order dated October 26, 1982 and in view of the licensee's response dated November 2, 1982 to that order, the NRC staff concluded that amendment of Section 3.4.3.2 of the Technical Specifications for Susquehanna Unit 1 to include a Limiting Condition for Operation (LCO) that limits increases in unidentified leakage to no more than 2 gpm in any four-hour period was appropriate to resolve this matter.

Evaluation

Incorporation of the General Electric - Standard Technical Specification for BWR/4 plants requiring an LCO for periodic monitoring of incremental increases in unidentified leakage and its associated action statement are appropriate for Susquehanna Steam Electric Station, Unit 1. The surveillance requirements under Section 4.4.3.2.1 which require monitoring at least once per 4 hours vice at least once per 12 hours is also appropriate and consistent with NUREG-0313, Rev. 1.

### Environmental Consideration

We have determined that this amendment does not authorize a change in effluent types or total amount nor an increase in power level and will not result in any significant environmental impact. Having made this determination, we have further concluded that this amendment involves action which is insignificant from the standpoint of environmental impact, and, pursuant to 10 CFR Section 51.5(d)(4), that an environmental impact statement or negative declaration and environmental impact appraisal need not be prepared in connection with the issuance of this statement.

### Conclusion

We have concluded, based on the considerations discussed above, that: (1) because the amendment does not involve a significant increase in the probability or consequences of accidents previously considered, does not create the possibility of an accident of a type different from any evaluated previously, and does not involve a significant decrease in a safety margin, the amendment does not involve a significant hazards consideration, (2) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (3) such activities will be conducted in compliance with the Commission's regulations and the issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public.

- Dated: **JAN 31** 1983

UNITED STATES NUCLEAR REGULATORY COMMISSION

DOCKET NO. 50-387

PENNSYLVANIA POWER & LIGHT COMPANY

ALLEGHENY ELECTRIC COOPERATIVE, INC.

NOTICE OF ISSUANCE OF AMENDMENT TO FACILITY

OPERATING LICENSE

The U. S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. 7 to Facility Operating License No. NPF-14, issued to Pennsylvania Power & Light Company and Allegheny Electric Cooperative, Inc., for Susquehanna Steam Electric Station, Unit 1 (the facility) located in Luzerne County, Pennsylvania. This amendment grants changes to Technical Specifications to modify monitoring intervals and reactor coolant leakage measurements to be consistent with NUREG-0313, Rev. 1 and Standard Technical Specifications and adds a license condition regarding implementation of certain aspects of P. L. 97-425, January 7, 1983 (Nuclear Waste Policy Act of 1982). This amendment is effective as of the date of issuance.

The application for the amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations. The Commission has made appropriate findings as required by the Act and the Commissions' regulations in 10 CFR Chapter I, which are set forth in the license amendment. Prior public notice of this amendment was not required since the amendment does not involve a significant hazards consideration.

The Commission has determined that the issuance of this amendment will not result in any significant environmental impact and that pursuant to 10 CFR Section 51.5(d)(4) and environmental impact statement, or negative declaration and environmental impact appraisal need not be prepared in connection with issuance of this amendment.

OFFICE	.....	.....	.....	.....	.....	.....	.....
SURNAME	8302080417	830131	.....	.....	.....	.....	.....
DATE	PDR	ADOCK	05000387	.....	.....	.....	.....
	P	PDR	.....	.....	.....	.....	.....

UNITED STATES NUCLEAR REGULATORY COMMISSION

DOCKET NO. 50-387

PENNSYLVANIA POWER & LIGHT COMPANY

ALLEGHENY ELECTRIC COOPERATIVE, INC.

NOTICE OF ISSUANCE OF AMENDMENT TO FACILITY

OPERATING LICENSE

The U. S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. 7 to Facility Operating License No. NPF-14, issued to Pennsylvania Power & Light Company and Allegheny Electric Cooperative, Inc., for Susquehanna Steam Electric Station, Unit 1 (the facility) located in Luzerne County, Pennsylvania. This amendment grants changes to Technical Specifications to modify monitoring intervals and reactor coolant leakage measurements to be consistent with NUREG-0313, Rev. 1 and Standard Technical Specifications. This amendment is effective as of the date of issuance.

The application for the amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations. The Commission has made appropriate findings as required by the Act and the Commissions' regulations in 10 CFR Chapter I, which are set forth in the license amendment. Prior public notice of this amendment was not required since the amendment does not involve a significant hazards consideration.

The Commission has determined that the issuance of this amendment will not result in any significant environmental impact and that pursuant to 10 CFR Section 51.5(d)(4) and environmental impact statement, or negative declaration and environmental impact appraisal need not be prepared in connection with issuance of this amendment.

OFFICE ▶	.....	.....	.....	.....	.....	.....	.....
SURNAME ▶	.....	.....	.....	.....	.....	.....	.....
DATE ▶	.....	.....	.....	.....	.....	.....	.....

UNITED STATES NUCLEAR REGULATORY COMMISSION

DOCKET NO. 50-387

PENNSYLVANIA POWER & LIGHT COMPANY

ALLEGHENY ELECTRIC COOPERATIVE, INC.

NOTICE OF ISSUANCE OF AMENDMENT TO FACILITY

OPERATING LICENSE

The U. S. Nuclear Regulatory Commission (the Commission) has issued Amendment No.     to Facility Operating License No. NPF-14, issued to Pennsylvania Power & Light Company and Allegheny Electric Cooperative, Inc., for Susquehanna Steam Electric Station, Unit 1 (the facility) located in Luzerne County, Pennsylvania. This amendment grants changes to Technical Specifications to modify monitoring intervals and reactor coolant leakage measurements to be consistent with NUREG-0313, Rev. 1 and Standard Technical Specifications. This amendment is effective as of the date of issuance.

The application for the amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations. The Commission has made appropriate findings as required by the Act and the Commission's regulations in 10 CFR Chapter I, which are set forth in the license amendment. Prior public notice of this amendment was not required since the amendment does not involve a significant hazards consideration.

The Commission has determined that the issuance of this amendment will not result in any significant environmental impact and that pursuant to 10 CFR Section 51.5(d)(4) and environmental impact statement, or negative declaration and environmental impact appraisal need not be prepared in connection with issuance of this amendment.

OFFICE ▶	.....	.....	.....	.....	.....	.....	.....
SURNAME ▶	.....	.....	.....	.....	.....	.....	.....
DATE ▶	.....	.....	.....	.....	.....	.....	.....

For further details with respect to this action, see (1) the application for the amendment dated December 10, 1982; (2) Amendment No. 7 to License NPF-14 dated JAN 31 1983 ; and (3) the Commission's evaluation dated January 31, 1983. All of these items are available for public inspection at the Commission's Public Document Room 1717 H Street, N. W. , Washington, D. C. 20555, and at the Osterhout Free Library, Reference Department, 71 South Franklin Street, Wilkes-Barre, Pennsylvania 18701. A copy of items (1), (2) and (3) may be obtained upon request addressed to the U. S. Nuclear Regulatory Commission, Washington, D. C. 20555, Attention: Director, Division of Licensing.

Dated at Bethesda, Maryland, this 31st day of January 1983.

FOR THE NUCLEAR REGULATORY COMMISSION

A. Schwencer, Chief  
Licensing Branch No. 2  
Division of Licensing

\*SEE ATTACHED PAGE FOR PREVIOUS CONCURRENCES

OFFICE	DL:LB#2/PM *	DL:LB#2/LA*	OELD *	DL:LB#2/ABC*	DL:AD/L*		
SURNAME	RPerch:pt	EHylton	MCutchin	ASchwencer	TNovak		
DATE	12/29/82	1/ 7/83	1/24/83	1/31/83	1/27/83		

For further details with respect to this action, see (1) the application for the amendment dated December 10, 1982; (2) Amendment No. to License NPF-14 dated \_\_\_\_\_; and (3) the Commission's evaluation dated 1983. All of these items are available for public inspection at the Commission's Public Document Room 1717 H Street, N. W. , Washington, D. C. 20555, and at the Osterhout Free Library, Reference Department, 71 South Franklin Street, Wilkes-Barre, Pennsylvania 18701. A copy of items (1), (2) and (3) may be obtained upon request addressed to the U. S. Nuclear Regulatory Commission, Washington, D. C. 20555, Attention: Director, Division of Licensing.

Dated at Bethesda, Maryland, this \_\_\_\_\_ day of \_\_\_\_\_

FOR THE NUCLEAR REGULATORY COMMISSION

*AS*

OFFICE	DL:LB#2/BC	DL:LB#2/LA	OELD	DL:LB#2/BC	DL:AD/1		
SURNAME	RPerch:pt	EHylton	CUTCHIN	ASchwencer	TNovak		
DATE	12/29/82	1/17/83	1/24/83	1/1/83	1/2/83		