

Braidwood Generating Station
35100 S. Rt. 53 Suite 84
Braceville, IL 60407

December 13, 2000
BW000118

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D. C. 20555-0001

Braidwood Station, Units 1 and 2
Facility Operating License Nos. NPF-72 and NPF-77
NRC Docket Nos. STN 50-456 and STN 50-457

Subject: Monthly Operating Report

In accordance with Technical Specification 5.6.4, "Monthly Operating Reports," we are submitting the Monthly Operating Report for Braidwood Station, Units 1 and 2. This report covers the period November 1, 2000, to November 30, 2000.

If you have any questions regarding this letter, please contact Mr. T. W. Simpkin, Regulatory Assurance Manager, at (815) 458-2801 extension 2980.

Respectfully,


G. K. Schwartz
Station Manager
Braidwood Station

Attachment

cc: Regional Administrator – NRC Region III
NRC Senior Resident Inspector – Braidwood Station

IE24

ATTACHMENT

BRAIDWOOD STATION UNITS 1 AND 2
MONTHLY OPERATING REPORT

COMMONWEALTH EDISON COMPANY

FACILITY OPERATING LICENSE NOS. NPF-72 AND NPF-77

NRC DOCKET NOS. STN 50-456 AND STN 50-457

A. OPERATING DATA REPORT

Docket No: 50-456
Unit: Braidwood 1
Date: 12/06/2000
Completed by: Don Hildebrant
Telephone: 815-458-2801x2173

REPORTING PERIOD: November 2000

1) Design Electrical Rating (MWe Net) 1120
2) Maximum Dependable Capacity (MWe Net) 1100

	<u>Month</u>	<u>Year To Date</u>	<u>Cumulative</u>
3) Hours Reactor Critical (Hours)	720.0	7,602.3	88,712.8
4) Hours Generator on Line (Hours)	720.0	7,591.0	87,791.2
5) Unit Reserve Shutdown Hours (Hours)	0.0	0.0	0.0
6) Net Electrical Energy (Mwh)	830,356	8,452,694	92,068,678

B. UNIT SHUTDOWNS

Docket No.: 50 - 456
Unit: Braidwood 1
Date: 12/06/2000
Completed by: Don Hildebrant
Telephone: 815-458-2801x2173

REPORT PERIOD: November 2000

<u>No.</u>	<u>Date</u>	<u>Type</u>	<u>Duration</u> <u>Hours</u>	<u>Reason</u>	<u>Method</u>	<u>Cause and Corrective Actions</u> <u>and Comments</u>
------------	-------------	-------------	---------------------------------	---------------	---------------	--

None

*****SUMMARY*****

Unit performed normally for the entire month.

<u>TYPE</u>	<u>REASON</u>	<u>METHOD</u>
F - Forced	A - Equipment Failure (explain)	1 - Manual
S - Scheduled	B - Maintenance or Test	2 - Manual Trip / Scram
	C - Refueling	3 - Automatic Trip / Scram
	D - Regulatory Restriction	4 - Continuation
	E - Operator Training / Licensee Examination	5 - Other (explain)
	F - Administrative	
	G - Operator Error (explain)	
	H - Other (explain)	

C. SAFETY / RELIEF VALVE OPERATIONS

Docket No.: 50 - 456
Unit: Braidwood 1
Date: 12/06/2000
Completed by: Don Hildebrant
Telephone: 815-458-2801x2173

<u>Date</u>	<u>Valves Actuated</u>	<u>No. & Type Actuation</u>	<u>Plant Condition</u>	<u>Description of Event</u>
None				

A. OPERATING DATA REPORT

Docket No: 50-457
Unit: Braidwood 2
Date: 12/06/2000
Completed by: Don Hildebrant
Telephone: 815-458-2801x2173

REPORTING PERIOD: November 2000

1) Design Electrical Rating (Mwe Net) 1120
2) Maximum Dependable Capacity (Mwe Net) 1100

	<u>Month</u>	<u>Year To Date</u>	<u>Cumulative</u>
3) Hours Reactor Critical (Hours)	618.2	7,581.4	92,617.2
4) Hours Generator on Line (Hours)	609.0	7,559.5	92,122.4
5) Unit Reserve Shutdown Hours (Hours)	0.0	0.0	0.0
6) Net Electrical Energy (Mwh)	673,694	8,646,534	97,244,880

B. UNIT SHUTDOWNS

Docket No.: 50 - 457
Unit: Braidwood 2
Date: 12/06/2000
Completed by: Don Hildebrant
Telephone: 815-458-2801x2173

REPORT PERIOD: November 2000

<u>No.</u>	<u>Date</u>	<u>Type</u>	<u>Duration Hours</u>	<u>Reason</u>	<u>Method</u>	<u>Cause and Corrective Actions and Comments</u>
3	11/01/00	S	101.8	C	4	Normal Refueling Outage A2R08

*****SUMMARY*****

Unit was returned to service on 11/05/2000 following its 8th refueling outage. Following return to service, the Unit operated normally for the remainder of the month.

<u>TYPE</u>	<u>REASON</u>	<u>METHOD</u>
F - Forced	A - Equipment Failure (explain)	1 - Manual
S - Scheduled	B - Maintenance or Test	2 - Manual Trip / Scram
	C - Refueling	3 - Automatic Trip / Scram
	D - Regulatory Restriction	4 - Continuation
	E - Operator Training / Licensee Examination	5 - Other (explain)
	F - Administrative	
	G - Operator Error (explain)	
	H - Other (explain)	

C. SAFETY / RELIEF VALVE OPERATIONS

Docket No.: 50 - 457
Unit: Braidwood 2
Date: 12/06/2000
Completed by: Don Hildebrant
Telephone: 815-458-2801x2173

<u>Date</u>	<u>Valves Actuated</u>	<u>No. & Type Actuation</u>	<u>Plant Condition</u>	<u>Description of Event</u>
None				

ATTACHMENT 1
Regulatory Correspondence Approval Form
Page 1 of 1

Organizational review denotes explicit affirmation of the accuracy of the information provided in the document and explicit concurrence with the commitments made, if any, in the document.

Correspondence Number: BW 000118

Location from which the Correspondence will be submitted: BRAIDWOOD

Subject: MONTHLY OPERATING REPORT

Prepared By: DON HILDEBRANT Date: 12/4/00

Reference: TECH SPEC 5.6.4

Organization Review or Concurrence

	Due Date	Print Name/Signature	Date
<input type="checkbox"/>	_____	Operations _____	/ _____
<input type="checkbox"/>	_____	Maintenance _____	/ _____
<input type="checkbox"/>	_____	Engineering _____	/ _____
<input type="checkbox"/>	_____	Radiation Protection _____	/ _____
<input type="checkbox"/>	_____	Training _____	/ _____
<input type="checkbox"/>	_____	Security _____	/ _____
<input checked="" type="checkbox"/>	_____	Regulatory Services <u>K.M. Rood</u>	/ <u>12/13/00</u>
<input type="checkbox"/>	_____	Independent Technical Review _____	/ _____
<input type="checkbox"/>	_____	PORC _____	/ _____
<input type="checkbox"/>	_____	Other _____	/ _____

Final Review and Approval

RAM: [Signature] Date: _____

Station Manager: [Signature] Date: 12-13-00

Site Vice President: _____ Date: _____

Comments: _____

cc: completed Attachment 1 to Regulatory Services