



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

FEB 14 1986

Docket Nos: 50-387
and 50-388

Mr. Harold W. Keiser
Vice President
Nuclear Operations
Pennsylvania Power and Light Company
2 North Ninth Street
Allentown, Pennsylvania 18101

Dear Mr. Keiser:

Subject: Amendment Nos. 54 and 22 to Facility Operating License Nos.
NPF-14 and NPF-22 Susquehanna Steam Electric Station,
Units 1 and 2

The Nuclear Regulatory Commission has issued the enclosed Amendment Nos. 54 and 22 to Facility Operating License Nos. NPF-14 and NPF-22 for the Susquehanna Steam Electric Station, Units 1 and 2 respectively. These amendments are in response to your letter dated November 26, 1985, as supplemented on January 15, 1986. These amendments revise the Unit 1 and Unit 2 Technical Specifications to include operational control of refueling floor radiation monitors only when Unit 1 and/or Unit 2 are in condition "*".

A copy of the related safety evaluation supporting Amendment Nos. 54 and 22 to Facility Operating License Nos. NPF-14 and NPF-22 is enclosed.

Sincerely,

Elinor G. Adensam, Director
BWR Project Directorate No. 3
Division of BWR Licensing

Enclosures:

1. Amendment Nos. 54 and 22
to NPF-14 and NPF-22
2. Safety Evaluation

cc w/enclosures:
See next page

8602250150 860214
PDR ADOCK 05000387
P PDR

Mr. Harold W. Keiser
Pennsylvania Power & Light Company

Susquehanna Steam Electric Station
Units 1 & 2

cc:
Jay Silberg, Esq.
Shaw, Pittman, Potts, & Trowbridge
1800 M Street, N. W.
Washington, D.C. 20036

Robert W. Alder, Esquire
Office of Attorney General
P.O. Box 2357
Harrisburg, Pennsylvania 17120

Bryan A. Snapp, Esq.
Assistant Corporate Counsel
Pennsylvania Power & Light Company
2 North Ninth Street
Allentown, Pennsylvania 18101

Mr. William Matson
Allegheny Elec. Cooperative, Inc.
212 Locust Street
P. O. Box 1266
Harrisburg, Pennsylvania 17108-1266

Mr. William E. Barberich
Manager-Nuclear Licensing
Pennsylvania Power & Light Company
2 North Ninth Street
Allentown, Pennsylvania 18101

Mr. Anthony J. Pietrofitta,
General Manager
Power Production Engineering
and Construction
Atlantic Electric
1199 Black Horse Pike
Pleasantville, New Jersey 08232

Mr. R. Jacobs
Resident Inspector
P.O. Box 52
Shickshinny, Pennsylvania 18655

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, Pennsylvania 19406

Mr. R. J. Benich
Services Project Manager
General Electric Company
1000 First Avenue
King of Prussia, Pennsylvania 19406

Mr. Thomas M. Gerusky, Director
Bureau of Radiation Protection
Resources
Commonwealth of Pennsylvania
P. O. Box 2063
Harrisburg, Pennsylvania 17120

DISTRIBUTION:

Docket Files (50-387/388)

NRC PDR

Local PDR

PD#3 Reading Files

HDenton/DEisenhut

RBernero

ORAS

EHylton (2)

MCampagnone (4)

OELD (Goldberg)

EJordan

BGrimes

JPartlow

TBarnhart (8)

~~XXXXXXXXXX~~

OPA

LFMB

PRC System

NSIC

R. Diggs, LFMB

L. Harmon, I+E

CONFIDENTIAL
Certified By *eghylton*



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

PENNSYLVANIA POWER & LIGHT COMPANY

ALLEGHENY ELECTRIC COOPERATIVE, INC.

DOCKET NO. 50-387

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 54
License No. NPF-14

1. The Nuclear Regulatory Commission (the Commission or the NRC) having found that:
 - A. The application for the amendment filed by the Pennsylvania Power & Light Company, dated November 26, 1985, as supplemented on January 15, 1986, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of Facility Operating License No. NPF-14 is hereby amended to read as follows:

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 54 and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. PP&L shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This amendment is effective as of the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Elinor G. Adensam, Director
BWR Project Directorate No. 3
Division of BWR Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: FEB 14 1986

ATTACHMENT TO LICENSE AMENDMENT NO. 54

FACILITY OPERATING LICENSE NO. NPF-14

DOCKET NO. 50-387

Replace the following pages of the Appendix "A" Technical Specifications with enclosed pages. The revised pages are identified by Amendment number and contain vertical lines indicating the area of change. The corresponding overleaf page is also provided to maintain document completeness.

REMOVE

3/4 3-11
3/4 3-12

3/4 3-23
3/4 3-24

INSERT

3/4 3-11
3/4 3-12 (overleaf)

3/4 3-23
3/4 3-24 (overleaf)

TABLE 3.3.2-1

ISOLATION ACTUATION INSTRUMENTATION

<u>TRIP FUNCTION</u>	<u>ISOLATION SIGNAL(S)^(a)</u>	<u>MINIMUM OPERABLE CHANNELS PER TRIP SYSTEM (b)</u>	<u>APPLICABLE OPERATIONAL CONDITION</u>	<u>ACTION</u>
1. <u>PRIMARY CONTAINMENT ISOLATION</u>				
a. Reactor Vessel Water Level				
1) Low, Level 3	A	2	1, 2, 3	20
2) Low Low, Level 2	B	2	1, 2, 3	20
3) Low Low Low, Level 1	X	2	1, 2, 3	20
b. Drywell Pressure - High	Y,Z,X	2	1, 2, 3	20
c. Manual Initiation	NA	1	1, 2, 3	24
d. SGTS Exhaust Radiation-High	R	1	1, 2, 3,4***,5***	20
e. Main Steam Line Radiation-High	C	2	1, 2, 3	20
2. <u>SECONDARY CONTAINMENT ISOLATION</u>				
a. Reactor Vessel Water Level - Low Low, Level 2	**	2	1, 2, 3 and *	25
b. Drywell Pressure - High	**	2	1, 2, 3	25
c. Refuel Floor High Exhaust Duct Radiation - High	**	2	*	25
d. Railroad Access Shaft Exhaust Duct Radiation - High	**	2	*	25
e. Refuel Floor Wall Exhaust Duct Radiation - High	**	2	*	25
f. Manual Initiation	NA	1	1, 2, 3 and *	24

TABLE 3.3.2-1 (Continued)

ISOLATION ACTUATION INSTRUMENTATION

<u>TRIP FUNCTION</u>	<u>ISOLATION SIGNAL(S)^(a)</u>	<u>MINIMUM OPERABLE CHANNELS PER TRIP SYSTEM (b)</u>	<u>APPLICABLE OPERATIONAL CONDITION</u>	<u>ACTION</u>
3. MAIN STEAM LINE ISOLATION				
a. Reactor Vessel Water Level - Low, Low, Low, Level 1	X	2	1, 2, 3	21
b. Main Steam Line Radiation - High	C	2	1, 2, 3	21
c. Main Steam Line Pressure - Low	P	2	1	22
d. Main Steam Line Flow - High	D	2/line	1, 2, 3	20
e. Condenser Vacuum - Low	UA	2	1, 2, 3	21
f. Reactor Building Main Steam Line Tunnel Temperature - High	E	2	1, 2, 3	21
g. Reactor Building Main Steam Line Tunnel Δ Temperature - High	E	2	1, 2, 3	21
h. Manual Initiation	NA	1	1, 2, 3	24
i. Turbine Building Main Steam Line Tunnel Temperature-High	E	2	1, 2, 3	21
4. REACTOR WATER CLEANUP SYSTEM ISOLATION				
a. RWCU Δ Flow - High	J	1	1, 2, 3	23
b. RWCU Area Temperature - High	W	3	1, 2, 3	23
c. RWCU Area Ventilation Δ Temp. - High	W	3	1, 2, 3	23
d. SLCS Initiation	I	2	1, 2, 3	23
e. Reactor Vessel Water Level - Low Low, Level 2	B	2	1, 2, 3	23
f. RWCU Flow - High	J	1	1, 2, 3	23
g. Manual Initiation	NA	1	1, 2, 3	24

TABLE 4.3.2.1-1

ISOLATION ACTUATION INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>TRIP FUNCTION</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>CHANNEL CALIBRATION</u>	<u>OPERATIONAL CONDITIONS FOR WHICH SURVEILLANCE REQUIRED</u>
1. <u>PRIMARY CONTAINMENT ISOLATION</u>				
a. Reactor Vessel Water Level -				
1) Low, Level 3	S	M	R	1, 2, 3
2) Low Low, Level 2	S	M	R	1, 2, 3
3) Low Low Low, Level 1	S	M	R	1, 2, 3
b. Drywell Pressure - High	NA	M	R	1, 2, 3
c. Manual Initiation	NA	R	NA	1, 2, 3
d. SGTS Exhaust Radiation - High	S	M	R	1, 2, 3, 4, 5,
e. Main Steam Line Radiation - High	S	M	R	1, 2, 3
2. <u>SECONDARY CONTAINMENT ISOLATION</u>				
a. Reactor Vessel Water Level - Low Low, Level 2	S	M	R	1, 2, 3 and *
b. Drywell Pressure - High	NA	M	Q	1, 2, 3
c. Refuel Floor High Exhaust Duct Radiation - High	S	M	R	*
d. Railroad Access Shaft Exhaust Duct Radiation - High	S	M	R	*
e. Refuel Floor Wall Exhaust Duct Radiation - High	S	M	R	*
f. Manual Initiation	NA	R	NA	1, 2, 3 and *

TABLE 4.3.2.1-1 (Continued)

ISOLATION ACTUATION INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>TRIP FUNCTION</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>CHANNEL CALIBRATION</u>	<u>OPERATIONAL CONDITIONS FOR WHICH SURVEILLANCE REQUIRED</u>
3. <u>MAIN STEAM LINE ISOLATION</u>				
a. Reactor Vessel Water Level - Low, Low Low, Level 1	S	M	R	1, 2, 3
b. Main Steam Line Radiation - High	S	M	R	1, 2, 3
c. Main Steam Line Pressure - Low	NA	M	Q	1
d. Main Steam Line Flow - High	S	M	R	1, 2, 3
e. Condenser Vacuum - Low	NA	M	Q	1, 2**, 3**
f. Reactor Building Main Steam Line Tunnel Temperature - High	NA	M	Q	1, 2, 3
g. Reactor Building Main Steam Line Tunnel Δ Temperature - High	NA	M	Q	1, 2, 3
h. Manual Initiation	NA	R	NA	1, 2, 3
i. Turbine Building Main Steam Line Tunnel Temperature - High	NA	M	Q	1, 2, 3
4. <u>REACTOR WATER CLEANUP SYSTEM ISOLATION</u>				
a. RWCU Δ Flow - High	S	M	R	1, 2, 3
b. RWCU Area Temperature - High	NA	M	Q	1, 2, 3
c. RWCU Area Ventilation Δ Temperature - High	NA	M	Q	1, 2, 3
d. SLCS Initiation	NA	R	NA	1, 2, 3
e. Reactor Vessel Water Level - Low Low, Level 2	S	M	R	1, 2, 3
f. RWCU Flow - High	S	M	R	1, 2, 3
g. Manual Initiation	NA	R	NA	1, 2, 3

SUSQUEHANNA - UNIT 1

3/4 3-24

Amendment No. 3R



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

PENNSYLVANIA POWER & LIGHT COMPANY

ALLEGHENY ELECTRIC COOPERATIVE, INC.

DOCKET NO. 50-388

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 22
License No. NPF-22

1. The Nuclear Regulatory Commission (the Commission or the NRC) having found that:
 - A. The application for the amendment filed by the Pennsylvania Power & Light Company, dated November 26, 1985, as supplemented on January 15, 1986, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of Facility Operating License No. NPF-22 is hereby amended to read as follows:

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 22 and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. PP&L shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This amendment is effective as of the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Elinor G. Adensam, Director
BWR Project Directorate No. 3
Division of BWR Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: FEB 14 1986

ATTACHMENT TO LICENSE AMENDMENT NO. 22

FACILITY OPERATING LICENSE NO. NPF-22

DOCKET NO. 50-388

Replace the following pages of the Appendix "A" Technical Specifications with enclosed pages. The revised pages are identified by Amendment number and contain vertical lines indicating the area of change. The corresponding overleaf page is also provided to maintain document completeness.

REMOVE

3/4 3-11
3/4 3-12

3/4 3-23
3/4 3-24

INSERT

3/4 3-11
3/4 3-12 (overleaf)

3/4 3-23
3/4 3-24 (overleaf)

TABLE 3.3.2-1
ISOLATION ACTUATION INSTRUMENTATION

<u>TRIP FUNCTION</u>	<u>ISOLATION SIGNAL(S)(a)</u>	<u>MINIMUM OPERABLE CHANNELS PER TRIP SYSTEM (b)</u>	<u>APPLICABLE OPERATIONAL CONDITION</u>	<u>ACTION</u>
1. <u>PRIMARY CONTAINMENT ISOLATION</u>				
a. Reactor Vessel Water Level				
1) Low, Level 3	A	2	1, 2, 3	20
2) Low Low, Level 2	B	2	1, 2, 3	20
3) Low Low Low, Level 1	X	2	1, 2, 3	20
b. Drywell Pressure - High	Y,Z	2	1, 2, 3	20
c. Manual Initiation	NA	1	1, 2, 3	24
d. SGTS Exhaust Radiation - High	R	1	1, 2, 3, 4***, 5***	20
e. Main Steam Line Radiation - High	C	2	1, 2, 3	20
2. <u>SECONDARY CONTAINMENT ISOLATION</u>				
a. Reactor Vessel Water Level - Low Low, Level 2	**	2	1, 2, 3 and *	25
b. Drywell Pressure - High	**	2	1, 2, 3	25
c. Refuel Floor High Exhaust Duct Radiation - High	**	2	*	25
d. Railroad Access Shaft Exhaust Duct Radiation - High	**	2	*	25
e. Refuel Floor Wall Exhaust Duct Radiation - High	**	2	*	25
f. Manual Initiation	NA	1	1, 2, 3 and *	24

TABLE 3.3.2-1 (Continued)

ISOLATION ACTUATION INSTRUMENTATION

<u>TRIP FUNCTION</u>	<u>ISOLATION SIGNAL(S)(a)</u>	<u>MINIMUM OPERABLE CHANNELS PER TRIP SYSTEM (b)</u>	<u>APPLICABLE OPERATIONAL CONDITION</u>	<u>ACTION</u>
3. MAIN STEAM LINE ISOLATION				
a. Reactor Vessel Water Level - Low, Low, Level 2	B	2	1, 2, 3	21
b. Main Steam Line Radiation - High	C	2	1, 2, 3	21
c. Main Steam Line Pressure - Low	P	2	1	22
d. Main Steam Line Flow - High	D	2/line	1, 2, 3	20
e. Condenser Vacuum - Low	UA	2	1, 2, 3	21
f. Reactor Building Main Steam Line Tunnel Temperature - High	E	2	1, 2, 3	21
g. Reactor Building Main Steam Line Tunnel Δ Temperature - High	E	2	1, 2, 3	21
h. Manual Initiation	NA	1	1, 2, 3	24
i. Turbine Building Main Steam Line Tunnel Temperature - High	E	2	1, 2, 3	21
4. REACTOR WATER CLEANUP SYSTEM ISOLATION				
a. RWCU Δ Flow - High	J	1	1, 2, 3	23
b. RWCU Area Temperature - High	W	3	1, 2, 3	23
c. RWCU Area Ventilation Δ Temperature - High	W	3	1, 2, 3	23
d. SLCS Initiation	I	2	1, 2, 3	23
e. Reactor Vessel Water Level - Low Low, Level 2	B	2	1, 2, 3	23
f. RWCU Flow - High	J	1	1, 2, 3	23
g. Manual Initiation	NA	1	1, 2, 3	24

TABLE 4.3.2.1-1

ISOLATION ACTUATION INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>TRIP FUNCTION</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>CHANNEL CALIBRATION</u>	<u>OPERATIONAL CONDITIONS FOR WHICH SURVEILLANCE REQUIRED</u>
1. <u>PRIMARY CONTAINMENT ISOLATION</u>				
a. Reactor Vessel Water Level -				
1) Low, Level 3	S	M	R	1, 2, 3
2) Low Low, Level 2	S	M	R	1, 2, 3
3) Low Low Low, Level 1	S	M	R	1, 2, 3
b. Drywell Pressure - High	NA	M	R	1, 2, 3
c. Manual Initiation	NA	R	NA	1, 2, 3
d. SGTS Exhaust Radiation - High	S	M	R	1, 2, 3, 4, 5
e. Main Steam Line Radiation - High	S	M	R	1, 2, 3
2. <u>SECONDARY CONTAINMENT ISOLATION</u>				
a. Reactor Vessel Water Level - Low Low, Level 2	S	M	R	1, 2, 3 and *
b. Drywell Pressure - High	NA	M	Q	1, 2, 3
c. Refuel Floor High Exhaust Duct Radiation - High	S	M	R	*
d. Railroad Access Shaft Exhaust Duct Radiation - High	S	M	R	*
e. Refuel Floor Wall Exhaust Duct Radiation - High	S	M	R	*
f. Manual Initiation	NA	R	NA	1, 2, 3 and *

TABLE 4.3.2.1-1 (Continued)

ISOLATION ACTUATION INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>TRIP FUNCTION</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>CHANNEL CALIBRATION</u>	<u>OPERATIONAL CONDITIONS FOR WHICH SURVEILLANCE REQUIRED</u>
3. MAIN STEAM LINE ISOLATION				
a. Reactor Vessel Water Level - Low Low, Level 2	S	M	R	1, 2, 3
b. Main Steam Line Radiation - High	S	M	R	1, 2, 3
c. Main Steam Line Pressure - Low	NA	M	Q	1
d. Main Steam Line Flow - High	S	M	R	1, 2, 3
e. Condenser Vacuum - Low	NA	M	Q	1, 2**, 3**
f. Reactor Building Main Steam Line Tunnel Temperature - High	NA	M	Q	1, 2, 3
g. Reactor Building Main Steam Line Tunnel Δ Temperature - High	NA	M	Q	1, 2, 3
h. Manual Initiation	NA	R	NA	1, 2, 3
i. Turbine Building Main Steam Line Tunnel Temperature - High	NA	M	Q	1, 2, 3
4. REACTOR WATER CLEANUP SYSTEM ISOLATION				
a. RWCU Δ Flow - High	S	M	R	1, 2, 3
b. RWCU Area Temperature - High	NA	M	Q	1, 2, 3
c. RWCU Area Ventilation Δ Temperature - High	NA	M	Q	1, 2, 3
d. SLCS Initiation	NA	R	NA	1, 2, 3
e. Reactor Vessel Water Level - Low Low, Level 2	S	M	R	1, 2, 3
f. RWCU Flow - High	S	M	R	1, 2, 3
g. Manual Initiation	NA	R	NA	1, 2, 3



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

SAFETY EVALUATION

AMENDMENT NOS. 54 AND 22 TO NPF-14 AND NPF-22

SUSQUEHANNA STEAM ELECTRIC STATION, UNITS 1 AND 2

DOCKET NOS. 50-387 AND 388

INTRODUCTION

By letter dated November 26, 1985, as supplemented on January 15, 1986, the licensee requested a change to the Susquehanna Steam Electric Station Unit 1 and Unit 2 Technical Specifications. The change requested by the licensee would delete the requirement for the refueling floor wall exhaust duct radiation monitoring system, the refueling floor high exhaust duct radiation monitoring system and the railroad access exhaust duct radiation monitoring system to be OPERABLE during OPERATIONAL CONDITIONS 1, 2, and 3. However, the Technical Specifications will still require the above mentioned monitors to be OPERABLE during condition "**", which is defined as "when handling irradiated fuel in the secondary containment and during CORE ALTERATIONS and operations with a potential for draining the reactor vessel."

EVALUATION

The NRC staff has evaluated the Technical Specification change, as requested by the licensee, for SSES Unit 1 and Unit 2. The staff finds that the purpose of the requirement for the isolation actuation function of the three aforementioned refueling floor radiation effluent monitors is to mitigate the consequences of a radiation source release in Zone III of the secondary containment. The staff's review of the licensee's request indicates that the above radiological effluent monitors are required to support design assumptions and accident analyses only when irradiated fuel is being handled in the secondary containment. This requirement is covered in the Technical Specifications by OPERATIONAL CONDITION "**". By definition, this special condition covers fuel handling regardless of mode switch position; therefore, the postulated incident that would drive OPERATIONAL CONDITIONS 1, 2, and 3 would have to be independent of a fuel handling problem as a radiation source.

As a separate matter the staff requested the licensee to respond to questions pertaining to the handling of heavy loads and retaining the monitors' alarm and recorder functions when the trip function has been disabled. The licensee on January 15, 1986, supplemented their November 26, 1985, submittal per the staff's request. This submittal addressed the staff's concerns regarding control of heavy loads to prevent a fuel damaging accident when the monitors' trip functions are disabled. The staff was concerned that the dropping of a heavy load into the core or the spent fuel pool could cause fuel damage when the licensee was outside of condition "**". The licensee identified two heavy loads, the refueling jib crane, and the fuel transfer canal watertight gate and strongback, which could require operation of the Standby Gas Treatment System (SGTS - which can be activated by the aforementioned monitors) and has committed to administratively control the moving of heavy loads when these monitors are not OPERABLE. The

8602250160 860214
PDR ADDOCK 05000387
P PDR

licensee has additionally committed to revise their procedures to require that the aforementioned monitors be OPERABLE when handling the heavy loads identified above. The licensee states that no other analyzed components, including major vessel internals such as the steam dryer and steam separators require SGTS and/or the aforementioned monitors to be OPERABLE. The staff is satisfied with the licensee's commitment to administratively control the handling of heavy loads and their commitment to deal with the heavy loads issue in their procedures. It has not been the staff's practice in the past to require that the Technical Specifications cover the issue of heavy loads. Additionally, it is noted that this change to the Technical Specifications does not change or affect the licensee's previous requirements for dealing with the heavy loads issue. The staff finds that the deletion of the requirement to have the aforementioned monitors OPERABLE during OPERATIONAL CONDITION 1, 2, and 3 is an acceptable change and that the heavy loads issue has no direct bearing on the approval of removing the requirement to have the monitors OPERABLE during condition 1, 2, and 3.

The January 15, 1986, submittal additionally addressed the staff's question, "When the trip functions of the subject radiation monitors are disabled, will the monitoring function be retained?" The licensee has stated that it is their intent to keep the alarm and recorder channels associated with subject monitors functioning during situations where the trip function has been disabled to avoid an anticipated spurious ESF actuation. The situations in which the licensee intends to keep only the alarm and recorder function operational are for situations in which the monitors have been determined not to serve any safety function. The staff believes that, as a good practice, the licensee should keep the alarm and recorder function operational, but sees no safety or regulatory basis for doing so. As a result, the staff finds it acceptable for the licensee to keep the alarm and recorder function operational per their own best judgement. Whether or not the alarm and recorder function remains operational when the trip function is disabled has no bearing on the staff's acceptance of this Technical Specification change. Based on our review of the licensee's requested Technical Specification change for Units 1 and 2, the staff finds these changes acceptable.

ENVIRONMENTAL CONSIDERATION

These amendments involve a change in the installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20. The staff has determined that the amendments involve no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that these amendments involve no significant hazards consideration and there has been no public comment on such finding. Accordingly, these amendments meet the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement nor environmental assessment need be prepared in connection with the issuance of these amendments.

CONCLUSION

The Commission made a proposed determination that the amendments involve no significant hazards consideration which was published in the Federal Register (51 FR 1879) January 15, 1986, and consulted with the State of Pennsylvania. No public comments were received, and the State of Pennsylvania did not have any comments.

The staff has concluded, based on the considerations discussed above, that:
(1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (2) such activities will be conducted in compliance with the Commission's regulations and the issuance of these amendments will not be inimical to the common defense and security nor to the health and safety of the public.

Principal contributor: M. J. Campagnone, PD#3, DBL.
M. Lamastra, PSB, DBL

Dated: FEB 14 1986