

LaSalle County Station
2601 N. 21st Road
Marseilles, IL. 61341-9757
Tel 815-357-6761

December 22, 2000

United States Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

LaSalle County Station, Units 1 and 2
Facility Operating License Nos. NPF-11 and NPF-18
NRC Docket Nos. 50-373 and 50-374

Subject: Inspection Report 50-373/374-99020
Non-Cited Violation

- References:
- (1) Letter from J. A. Grobe to O. D. Kingsley, transmitting NRC Inspection Report 50-373/374-99020, dated, November 2, 1999.
 - (2) Letter from J. A. Benjamin to U.S. NRC, "Reply to Non-Cited Violation for NRC Inspection Report 50-373/99020; 50-374/99020," dated December 21, 1999.
 - (3) Letter from C. G. Pardee to U.S. NRC, "Response to Request for Additional Information, NRC Inspection Report 50-373/99020, 50-374/99020," dated July 21, 2000.

The NRC, in Reference 1, transmitted Non-Cited Violation 50-373/374-99020-02, which identified a failure to verify the adequacy of design with respect to the stiffness value used for concrete expansion anchors. In Reference 2, Commonwealth Edison (ComEd) Company stated that it did not believe it violated regulations in this matter, and that it intended to contest the violation.

On June 8, 2000, a meeting was held at NRC Headquarters to discuss this matter. Based on the results of this meeting as documented in Reference 3, ComEd will no longer contest the subject non-cited violation.

TEC1

December 22, 2000
U.S. Nuclear Regulatory Commission
Page 2

In Reference 3, ComEd committed to include the results of the extent of condition review of this issue in our corrective action program. The results of the review and corrective actions taken as a result of this issue were included in our corrective action program. No new corrective actions were identified as a result of the extent of condition review.

Should you have any questions concerning this letter, please contact Mr. William Riffer, Regulatory Assurance Manager, at (815) 357-6761, extension 2383.

Respectfully,

A handwritten signature in black ink, appearing to read "Charles G. Pardee". The signature is fluid and cursive, with a large loop at the end.

Charles G. Pardee
Site Vice President
LaSalle County Station

cc: Regional Administrator - NRC Region III
NRC Senior Resident Inspector - LaSalle County Station