



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

APR 23 1985

Docket No.: 50-387

Mr. Norman W. Curtis  
Vice President  
Engineering and Construction - Nuclear  
Pennsylvania Power and Light Company  
2 North Ninth Street  
Allentown, Pennsylvania 18101

Dear Mr. Curtis:

SUBJECT: AMENDMENT NO. 38 TO FACILITY OPERATING LICENSE NO. NPF-14,  
SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1

The Nuclear Regulatory Commission has issued the enclosed Amendment No. 38 to Facility Operating License No. NPF-14 for the Susquehanna Steam Electric Station, Unit 1. The amendment is in response to your letter dated October 31, 1984. This amendment revises the Technical Specifications to change the setpoint for main steam isolation valve (MSIV) closure on reactor vessel water low level from Level 2 to Level 1.

A copy of the related safety evaluation supporting Amendment No. 38 to Facility Operating License NPF-14 is enclosed.

Sincerely,

A. Schwencer, Chief  
Licensing Branch No. 2  
Division of Licensing

Enclosures:

1. Amendment No. 38 to NPF-14
2. Safety Evaluation

cc w/enclosures:  
See next page

8504300041 850423  
PDR ADOCK 05000387  
P PDR

Docket No.: 50-387

APR 23 1985

Mr. Norman W. Curtis  
Vice President  
Engineering and Construction - Nuclear  
Pennsylvania Power and Light Company  
2 North Ninth Street  
Allentown, Pennsylvania 18101

Dear Mr. Curtis:

SUBJECT: AMENDMENT NO. 38 TO FACILITY OPERATING LICENSE NO. NPF-14,  
SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1

The Nuclear Regulatory Commission has issued the enclosed Amendment No. 38 to Facility Operating License No. NPF-14 for the Susquehanna Steam Electric Station, Unit 1. The amendment is in response to your letter dated October 31, 1984. This amendment revises the Technical Specifications to change the setpoint for main steam isolation valve (MSIV) closure on reactor vessel water low level from Level 2 to Level 1.

A copy of the related safety evaluation supporting Amendment No. 38 to Facility Operating License NPF-14 is enclosed.

Sincerely,

Original signed by:

A. Schwencer, Chief  
Licensing Branch No. 2  
Division of Licensing

Enclosures:

1. Amendment No. 38 to NPF-14
2. Safety Evaluation

cc w/enclosures:  
See next page

DL:LB#2\* DL:LB#2\* OELD\*  
EHylton MCompagnone:pob JGray  
01/28/85 01/28/85 01/25/85

DL:LB#2\* AD/L:DL\*  
ASchwencer TNovak  
04/23/85 04/11/85

\* previously concurred

Susquehanna

Mr. Norman W. Curtis  
Vice President  
Engineering and Construction  
Pennsylvania Power & Light Company  
2 North Ninth Street  
Allentown, Pennsylvania 18101

Jay Silberg, Esq.  
Shaw, Pittman, Potts, & Trowbridge  
1800 M Street, N. W.  
Washington, D.C. 20036

Edward M. Nagel, Esq.  
General Counsel and Secretary  
Pennsylvania Power & Light Company  
2 North Ninth Street  
Allentown, Pennsylvania 18101

Mr. William E. Barberich  
Manager-Nuclear Licensing  
Pennsylvania Power & Light Company  
2 North Ninth Street  
Allentown, Pennsylvania 18101

Mr. R. Jacobs  
Resident Inspector  
P.O. Box 52  
Shickshinny, Pennsylvania 18655

Mr. E. B. Poser  
Project Engineer  
Bechtel Power Corporation  
P. O. Box 3965  
San Francisco, California 94119

Mr. Thomas M. Gerusky, Director  
Bureau of Radiation Protection Resources  
Commonwealth of Pennsylvania  
P. O. Box 2063  
Harrisburg, Pennsylvania 17120

Mr. N. D. Weiss, Project Manager  
Maile Code 391  
General Electric Company  
175 Curtner Avenue  
San Jose, California 95125

Robert W. Alder, Esquire  
Office of Attorney General  
P.O. Box 2357  
Harrisburg, Pennsylvania 17120

Mr. William Matson  
Allegheny Elec. Cooperative, Inc.  
212 Locust Street  
P. O. Box 1266  
Harrisburg, PA 17108-1266

Mr. Anthony J. Pietrofitta,  
General Manager  
Power Production Engineering  
and Construction  
Atlantic Electric  
1199 Black Horse Pike  
Pleasantville, NJ 08232

Susquehanna

cc: Governor's Office of State Planning & Development  
Attn: Coordinator, State Clearinghouse  
P O. Box 1323  
Harrisburg, Pennsylvania 17120

Mr. Bruce Thomas, President  
Board of Supervisors  
R. D. #1  
Berwick, Pennsylvania 18603

U. S. Environmental Protection Agency  
Attn: EIS Coordinator  
Region III Office  
Curtis Building  
6th and Walnut Streets  
Philadelphia, Pennsylvania 19106

AMENDMENT NO. 38 TO FACILITY OPERATING LICENSE NO. NPF-14 - SUSQUEHANNA STEAM  
ELECTRIC STATION, UNIT 1

DISTRIBUTION:

Docket File  
NRC PDR  
Local PDR  
PRC System  
NSIC  
LB#2 Reading  
EHylton  
MJCampagnone  
TNovak  
JSaltzman, SAB  
OELD, Attorney  
CMiles  
HDenton  
JRutberg  
AToalston  
WMiller, LFMB  
NGrace  
EJordan  
LHarmon  
DBrinkman, SSPB  
TBarnhart(4)



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

PENNSYLVANIA POWER & LIGHT COMPANY  
ALLEGHENY ELECTRIC COOPERATIVE, INC.  
DOCKET NO. 50-387  
SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1  
AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 38  
License No. NPF-14

1. The Nuclear Regulatory Commission (the Commission or the NRC) having found that:
  - A. The application for the amendment filed by the Pennsylvania Power & Light Company, dated October 31, 1984, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the regulations of the Commission;
  - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of the Facility Operating License No. NPF-14 is hereby amended to read as follows:

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 38 and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. The licensee shall operate the facilities in accordance with the Technical Specifications and the Environmental Protection Plan.

8504300046 850423  
PDR ADOCK 05000387  
P PDR

3. This amendment is effective upon startup following the first refueling outage.

FOR THE NUCLEAR REGULATORY COMMISSION



A. Schwencer, Chief  
Licensing Branch No. 2  
Division of Licensing

Enclosure:  
Changes to the Technical  
Specifications

Date of Issuance: APR 23 1985

ATTACHMENT TO LICENSE AMENDMENT NO. 38  
FACILITY OPERATING LICENSE NO. NPF-14  
DOCKET NO. 50-387

Replace the following pages of the Appendix "A" Technical Specifications with enclosed pages. The revised pages are identified by Amendment number and contain vertical lines indicating the area of change.

<u>REMOVE</u>	<u>INSERT</u>
3/4 3-11	3/4 3-11
3/4 3-12	3/4 3-12
3/4 3-17	3/4 3-17
3/4 3-18	3/4 3-18
3/4 3-21	3/4 3-21
3/4 3-22	3/4 3-22
3/4 3-23	3/4 3-23
3/4 3-24	3/4 3-24
3/4 6-19	3/4 6-19
3/4 6-20	3/4 6-20
B 3/4 3-7	B 3/4 3-7
B 3/4 3-8	B 3/4 3-8



TABLE 3.3.2-1

ISOLATION ACTUATION INSTRUMENTATION

<u>TRIP FUNCTION</u>	<u>ISOLATION SIGNAL(s)<sup>(a)</sup></u>	<u>MINIMUM OPERABLE CHANNELS PER TRIP SYSTEM (b)</u>	<u>APPLICABLE OPERATIONAL CONDITION</u>	<u>ACTION</u>
1. <u>PRIMARY CONTAINMENT ISOLATION</u>				
a. Reactor Vessel Water Level				
1) Low, Level 3	A	2	1, 2, 3	20
2) Low Low, Level 2	B	2	1, 2, 3	20
3) Low Low Low, Level 1	X	2	1, 2, 3	20
b. Drywell Pressure - High	Y,Z,X	2	1, 2, 3	20
c. Manual Initiation	NA	1	1, 2, 3	24
d. SGTS Exhaust Radiation-High	R	1	1, 2, 3,4***,5***	20
e. Main Steam Line Radiation-High	C	2	1, 2, 3	20
2. <u>SECONDARY CONTAINMENT ISOLATION</u>				
a. Reactor Vessel Water Level - Low Low, Level 2	**	2	1, 2, 3 and *	25
b. Drywell Pressure - High	**	2	1, 2, 3	25
c. Refuel Floor High Exhaust Duct Radiation - High	**	2	1, 2, 3 and *	25
d. Railroad Access Shaft Exhaust Duct Radiation - High	**	2	1, 2, 3 and *	25
e. Refuel Floor Wall Exhaust Duct Radiation - High	**	2	1, 2, 3 and *	25
f. Manual Initiation	NA	1	1, 2, 3 and *	24

4/23

6

TABLE 3.3.2-1 (Continued)

ISOLATION ACTUATION INSTRUMENTATION

<u>TRIP FUNCTION</u>	<u>ISOLATION SIGNAL(s)<sup>(a)</sup></u>	<u>MINIMUM OPERABLE CHANNELS PER TRIP SYSTEM (b)</u>	<u>APPLICABLE OPERATIONAL CONDITION</u>	<u>ACTION</u>
3. <u>MAIN STEAM LINE ISOLATION</u>				
a. Reactor Vessel Water Level - Low, Low, Low, Level 1	X	2	1, 2, 3	21
b. Main Steam Line Radiation - High	C	2	1, 2, 3	21
c. Main Steam Line Pressure - Low	P	2	1	22
d. Main Steam Line Flow - High	D	2/line	1, 2, 3	20
e. Condenser Vacuum - Low	UA	2	1, 2, 3	21
f. Reactor Building Main Steam Line Tunnel Temperature - High	E	2	1, 2, 3	21
g. Reactor Building Main Steam Line Tunnel $\Delta$ Temperature - High	E	2	1, 2, 3	21
h. Manual Initiation	NA	1	1, 2, 3	24
i. Turbine Building Main Steam Line Tunnel Temperature-High	E	2	1, 2, 3	21
4. <u>REACTOR WATER CLEANUP SYSTEM ISOLATION</u>				
a. RWCU $\Delta$ Flow - High	J	1	1, 2, 3	23
b. RWCU Area Temperature - High	W	3	1, 2, 3	23
c. RWCU Area Ventilation $\Delta$ Temp. - High	W	3	1, 2, 3	23
d. SLCS Initiation	I	2	1, 2, 3	23
e. Reactor Vessel Water Level - Low Low, Level 2	B	2	1, 2, 3	23
f. RWCU Flow - High	J	1	1, 2, 3	23
g. Manual Initiation	NA	1	1, 2, 3	24

TABLE 3.3.2-2

ISOLATION ACTUATION INSTRUMENTATION SETPOINTS

<u>TRIP FUNCTION</u>	<u>TRIP SETPOINT</u>	<u>ALLOWABLE VALUE</u>
1. <u>PRIMARY CONTAINMENT ISOLATION</u>		
a. Reactor Vessel Water Level		
1) Low, Level 3	> 13.0 inches*	> 11.5 inches
2) Low Low, Level 2	> -38.0 inches*	> -45.0 inches
3) Low Low Low, Level 1	> -129 inches*	> -136 inches
b. Drywell Pressure - High	< 1.72 psig	< 1.88 psig
c. Manual Initiation	NA	NA
d. SGTS Exhaust Radiation - High	< 23.0 mR/hr	< 31.0 mR/Hr
e. Main Steam Line Radiation - High	≤ 3 x full power background	≤ 3.6 x full power background
2. <u>SECONDARY CONTAINMENT ISOLATION</u>		
a. Reactor Vessel Water Level - Low Low, Level 2	≥ -38.0 inches*	≥ -45.0 inches
b. Drywell Pressure - High	≤ 1.72 psig	≤ 1.88 psig
c. Refuel Floor High Exhaust Duct Radiation - High	≤ 2.5 mR/hr.**	≤ 4.0 mR/hr.**
d. Railroad Access Shaft Exhaust Duct Radiation - High	≤ 2.5 mR/hr.**	≤ 4.0 mR/hr.**
e. Refuel Floor Wall Exhaust Duct Radiation - High	< 2.5 mR/hr.**	< 4.0 mR/hr.**
f. Manual Initiation	NA	NA
3. <u>MAIN STEAM LINE ISOLATION</u>		
a. Reactor Vessel Water Level - Low, Low Low, Level 1	≥ -129 inches*	≥ -136 inches
b. Main Steam Line Radiation - High	< 3 X full power background	< 3.6 X full power background
c. Main Steam Line Pressure - Low	≥ 861 psig	≥ 841 psig
d. Main Steam Line Flow - High	≤ 107 psid	≤ 110 psid

TABLE 3.3.2-2 (Continued)

ISOLATION ACTUATION INSTRUMENTATION SETPOINTS

<u>TRIP FUNCTION</u>	<u>TRIP SETPOINT</u>	<u>ALLOWABLE VALUE</u>
<u>MAIN STEAM LINE ISOLATION (Continued)</u>		
e. Condenser Vacuum - Low	$\geq 9.0$ inches Hg vacuum	$\geq 8.8$ inches Hg vacuum
f. Reactor Building Main Steam Line Tunnel Temperature - High	$\leq 177^{\circ}\text{F}$	$\leq 184^{\circ}\text{F}$
g. Reactor Building Main Steam Line Tunnel $\Delta$ Temperature - High	$\leq 99^{\circ}\text{F}$	$\leq 108^{\circ}\text{F}$
h. Manual Initiation	NA	NA
i. Turbine Building Main Steam Line Tunnel Temperature-High	$\leq 177^{\circ}\text{F}$	$\leq 184^{\circ}\text{F}$
4. <u>REACTOR WATER CLEANUP SYSTEM ISOLATION</u>		
a. RWCU $\Delta$ Flow - High	$\leq 60$ gpm	$\leq 80$ gpm
b. RWCU Area Temperature - High	$\leq 147^{\circ}\text{F}$ or $118.3^{\circ}\text{F}\#$	$\leq 154^{\circ}\text{F}$ or $125.3^{\circ}\text{F}\#$
c. RWCU/Area Ventilation $\Delta$ Temperature - High	$\leq 69^{\circ}\text{F}$ or $35.3^{\circ}\text{F}\#$	$\leq 78^{\circ}\text{F}$ or $44.3^{\circ}\text{F}\#$
d. SLCS Initiation	NA	NA
e. Reactor Vessel Water Level - Low Low, Level 2	$\geq -38$ inches*	$\geq -45$ inches
f. RWCU Flow - High	$\leq 426$ gpm	$\leq 436$ gpm
g. Manual Initiation	NA	NA
5. <u>REACTOR CORE ISOLATION COOLING SYSTEM ISOLATION</u>		
a. RCIC Steam Line $\Delta$ Pressure - High	$\leq 177'' \text{H}_2\text{O}^{**}$	$\leq 189'' \text{H}_2\text{O}^{**}$
b. RCIC Steam Supply Pressure - Low	$\geq 60$ psig	$\geq 53$ psig
c. RCIC Turbine Exhaust Diaphragm Pressure - High	$\leq 10.0$ psig	$\leq 20.0$ psig

TABLE 3.6.3-1

PRIMARY CONTAINMENT ISOLATION VALVES

<u>VALVE FUNCTION AND NUMBER</u>	<u>MAXIMUM ISOLATION TIME (Seconds)</u>	<u>ISOLATION SIGNAL(s)<sup>(a)</sup></u>
a. Automatic Isolation Valves		
<u>MSIV</u>		
HV-141F022 A,B,C,D	5	X,C,D,E,P,UA
HV-141F028 A,B,C,D	5	X,C,D,E,P,UA
<u>MSL Drain</u>		
HV-141F016	10	X,C,D,E,P,UA
HV-141F019	10	X,C,D,E,P,UA
<u>RCIC Steam Supply</u>		
HV-149F007	20	K,KB
HV-149F008	20	K,KB
HV-149F088	3	K,KB
<u>HPCI Steam Supply</u>		
HV-155F002	50	L,LB
HV-155F003	50	L,LB
HV-155F100	3	L,LB
<u>RHR - Shutdown Cooling Suction</u>		
HV-151F008	52	A,M,UB
HV-151F009	52	A,M,UB
<u>RWCU Suction<sup>(b)</sup></u>		
HV-144F001	30	B,J,W
HV-144F004	30	I,B,J,W
<u>RHR - Reactor Vessel Head Spray</u>		
HV-151F022	30	A,M,UB,Z
HV-151F023	20	A,M,UB,Z

TABLE 3.6.3-1 (Continued)  
PRIMARY CONTAINMENT ISOLATION VALVES

<u>VALVE FUNCTION AND NUMBER</u>	<u>MAXIMUM ISOLATION TIME (Seconds)</u>	<u>ISOLATION SIGNAL(s)<sup>(a)</sup></u>
<u>Automatic Isolation Valves (Continued)</u>		
<u>Containment Instrument Gas</u>		
HV-12603	20	X,Z
SV-12605	N/A	X,Z
SV-12651	N/A	X,Z
SV-12661	N/A	Y,B
SV-12671	N/A	Y,B
<u>RBCCW</u>		
HV-11313	30	X,Z
HV-11314	30	X,Z
HV-11345	30	X,Z
HV-11346	30	X,Z
<u>Containment Purge</u>		
HV-15703	15	B,Y,R
HV-15704	15	B,Y,R
HV-15705	15	B,Y,R
HV-15711	15	B,Y,R
HV-15713	15	B,Y,R
HV-15714	15	B,Y,R
HV-15721	15	B,Y,R
HV-15722	15	B,Y,R
HV-15723	15	B,Y,R
HV-15724	15	B,Y,R
HV-15725	15	B,Y,R
<u>RHR - Drywell Spray<sup>(c)</sup></u>		
HV-151F016 A,B	90	X,Z
<u>RB Chilled Water</u>		
HV-18781 A1,A2,B1,B2	40	X,Z
HV-18782 A1,A2,B1,B2	6	X,Z
HV-18791 A1,A2,B1,B2	15	Y,B
HV-18792 A1,A2,B1,B2	4	Y,B

TABLE 3.3.2-3

ISOLATION SYSTEM INSTRUMENTATION RESPONSE TIME

<u>TRIP FUNCTION</u>	<u>RESPONSE TIME (Seconds)#</u>
<b>1. <u>PRIMARY CONTAINMENT ISOLATION</u></b>	
a. Reactor Vessel Water Level	
1) Low, Level 3	<10(a)
2) Low Low, Level 2	<1.0*/<10(a)**
3) Low Low Low, Level 1	<10(a)
b. Drywell Pressure - High	<10(a)
c. Manual Initiation	NA
d. SGTS Exhaust Radiation - High(b)	<10(a)
e. Main Steam Line Radiation - High(b)	<10(a)
<b>2. <u>SECONDARY CONTAINMENT ISOLATION</u></b>	
a. Reactor Vessel Water Level-Low Low, Level 2	<10(a)
b. Drywell Pressure - High	<10(a)
c. Refuel Floor High Exhaust Duct Radiation - High(b)	<10(a)
d. Railroad Access Shaft Exhaust Duct Radiation - High(b)	<10(a)
e. Refuel Floor Wall Exhaust Duct Radiation -High(b)	<10(a)
f. Manual Initiation	NA
<b>3. <u>MAIN STEAM LINE ISOLATION</u></b>	
a. Reactor Vessel Water Level- Low Low Low, Level 1	<10(a)
b. Main Steam Line Radiation - High(b)	<1.0*/<10(a)**
c. Main Steam Line Pressure - Low	<1.0*/<10(a)**
d. Main Steam Line Flow-High	<0.5*/<10(a)**
e. Condenser Vacuum - Low	NA
f. Reactor Building Main Steam Line Tunnel Temperature - High	NA
g. Reactor Building Main Steam Line Tunnel Δ Temperature - High	NA
h. Manual Initiation	NA
i. Turbine Building Main Steam Line Tunnel Temperature - High	NA
<b>4. <u>REACTOR WATER CLEANUP SYSTEM ISOLATION</u></b>	
a. RWCU Δ Flow - High	<10(a)##
b. RWCU Area Temperature - High	NA
c. RWCU Area Ventilation Temperature ΔT - High	NA
d. SLCS Initiation	NA
e. Reactor Vessel Water Level - Low Low, Level 2	<10(a)
f. RWCU Flow - High	NA
g. Manual Initiation	NA
<b>5. <u>REACTOR CORE ISOLATION COOLING SYSTEM ISOLATION</u></b>	
a. RCIC Steam Line Δ Pressure - High	<10(a)###
b. RCIC Steam Supply Pressure - Low	<10(a)
c. RCIC Turbine Exhaust Diaphragm Pressure - High	NA
d. RCIC Equipment Room Temperature - High	NA

TABLE 3.3.2-3 (Continued)

ISOLATION SYSTEM INSTRUMENTATION RESPONSE TIME

<u>TRIP FUNCTION</u>	<u>RESPONSE TIME (Seconds)#</u>
e. RCIC Equipment Room $\Delta$ Temperature - High	NA
f. RCIC Pipe Routing Area Temperature - High	NA
g. RCIC Pipe Routing Area $\Delta$ Temperature - High	NA
h. RCIC Emergency Area Cooler Temperature - High	NA
i. Manual Initiation	NA
j. Drywell Pressure - High	$\leq 10$ (a)
6. <u>HIGH PRESSURE COOLANT INJECTION SYSTEM ISOLATION</u>	
a. HPCI Steam Flow - High	$\leq 10$ (a)####
b. HPCI Steam Supply Pressure - Low	$\leq 10$ (a)
c. HPCI Turbine Exhaust Diaphragm Pressure - High	NA
d. HPCI Equipment Room Temperature - High	NA
e. HPCI Equipment Room $\Delta$ Temperature - High	NA
f. HPCI Emergency Area Cooler Temperature - High	NA
g. HPCI Pipe Routing Area Temperature - High	NA
h. HPCI Pipe Routing Area $\Delta$ Temperature - High	NA
i. Manual Initiation	NA
j. Drywell Pressure - High	$\leq 10$ (a)
7. <u>RHR SYSTEM SHUTDOWN COOLING/HEAD SPRAY MODE ISOLATION</u>	
a. Reactor Vessel Water Level - Low, Level 3	$\leq 10$ (a)
b. Reactor Vessel (RHR Cut-in Permissive) Pressure - High	NA
c. RHR Equipment Area $\Delta$ Temperature - High	NA
d. RHR Equipment Area Temperature - High	NA
e. RHR Flow - High	NA
f. Manual Initiation	NA
g. Drywell Pressure - High	$\leq 10$ (a)

(a) The isolation system instrumentation response time shall be measured and recorded as a part of the ISOLATION SYSTEM RESPONSE TIME. Isolation system instrumentation response time specified includes the delay for diesel generator starting assumed in the accident analysis.

(b) Radiation detectors are exempt from response time testing. Response time shall be measured from detector output or the input of the first electronic component in the channel.

\*Isolation system instrumentation response time for MSIVs only. No diesel generator delays assumed for MSIV Valves.

\*\*Isolation system instrumentation response time for associated valves except MSIVs.

#Isolation system instrumentation response time specified for the Trip Function actuating each valve group shall be added to isolation time shown in Table 3.6.3-1 and 3.6.5.2-1 for valves in each valve group to obtain ISOLATION SYSTEM RESPONSE TIME for each valve.

##With time delay of 45 seconds.

###With time delay of 3 seconds.

####With time delay of 3 seconds.



TABLE 4.3.2.1-1

ISOLATION ACTUATION INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>TRIP FUNCTION</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>CHANNEL CALIBRATION</u>	<u>OPERATIONAL CONDITIONS FOR WHICH SURVEILLANCE REQUIRED</u>
1. <u>PRIMARY CONTAINMENT ISOLATION</u>				
a. Reactor Vessel Water Level -				
1) Low, Level 3	S	M	R	1, 2, 3
2) Low Low, Level 2	S	M	R	1, 2, 3
3) Low Low Low, Level 1	S	M	R	1, 2, 3
b. Drywell Pressure - High	NA	M	R	1, 2, 3
c. Manual Initiation	NA	R	NA	1, 2, 3
d. SGTS Exhaust Radiation - High	S	M	R	1, 2, 3, 4, 5,
e. Main Steam Line Radiation - High	S	M	R	1, 2, 3
2. <u>SECONDARY CONTAINMENT ISOLATION</u>				
a. Reactor Vessel Water Level - Low Low, Level 2	S	M	R	1, 2, 3 and *
b. Drywell Pressure - High	NA	M	Q	1, 2, 3
c. Refuel Floor High Exhaust Duct Radiation - High	S	M	R	1, 2, 3 and *
d. Railroad Access Shaft Exhaust Duct Radiation - High	S	M	R	1, 2, 3 and *
e. Refuel Floor Wall Exhaust Duct Radiation - High	S	M	R	1, 2, 3 and *
f. Manual Initiation	NA	R	NA	1, 2, 3 and *

TABLE 4.3.2.1-1 (Continued)

ISOLATION ACTUATION INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>TRIP FUNCTION</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>CHANNEL CALIBRATION</u>	<u>OPERATIONAL CONDITIONS FOR WHICH SURVEILLANCE REQUIRED</u>
3. <u>MAIN STEAM LINE ISOLATION</u>				
a. Reactor Vessel Water Level - Low, Low Low, Level 1	S	M	R	1, 2, 3
b. Main Steam Line Radiation - High	S	M	R	1, 2, 3
c. Main Steam Line Pressure - Low	NA	M	Q	1
d. Main Steam Line Flow - High	S	M	R	1, 2, 3
e. Condenser Vacuum - Low	NA	M	Q	1, 2**, 3**
f. Reactor Building Main Steam Line Tunnel Temperature - High	NA	M	Q	1, 2, 3
g. Reactor Building Main Steam Line Tunnel $\Delta$ Temperature - High	NA	M	Q	1, 2, 3
h. Manual Initiation	NA	R	NA	1, 2, 3
i. Turbine Building Main Steam Line Tunnel Temperature - High	NA	M	Q	1, 2, 3
4. <u>REACTOR WATER CLEANUP SYSTEM ISOLATION</u>				
a. RWCU $\Delta$ Flow - High	S	M	R	1, 2, 3
b. RWCU Area Temperature - High	NA	M	Q	1, 2, 3
c. RWCU Area Ventilation $\Delta$ Temperature - High	NA	M	Q	1, 2, 3
d. SLCS Initiation	NA	R	NA	1, 2, 3
e. Reactor Vessel Water Level - Low Low, Level 2	S	M	R	1, 2, 3
f. RWCU Flow - High	S	M	R	1, 2, 3
g. Manual Initiation	NA	R	NA	1, 2, 3

## INSTRUMENTATION

### BASES


---

#### 3/4.3.8 TURBINE OVERSPEED PROTECTION SYSTEM

This specification is provided to ensure that the turbine overspeed protection system instrumentation and the turbine speed control valves are OPERABLE and will protect the turbine from excessive overspeed. Protection from turbine excessive overspeed is required since excessive overspeed of the turbine could generate potentially damaging missiles which could impact and damage safety related components, equipment or structures.

#### 3/4.3.9 FEEDWATER/MAIN TURBINE TRIP SYSTEM ACTUATION INSTRUMENTATION

The feedwater/main turbine trip system actuation instrumentation is provided to initiate action of the feedwater system/main turbine trip system in the event of failure of feedwater controller under maximum demand.



BASES FIGURE B 3/4 3-1  
REACTOR VESSEL WATER LEVEL



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

SAFETY EVALUATION

AMENDMENT NO. 38 TO NPF-14

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1

DOCKET NO. 50-387

Introduction

The licensee proposed changes to the Technical Specifications of the operating license for Susquehanna Steam Electric Station, Unit 1 to lower the setpoint for main steam isolation valve (MSIV) closure from low water level 2 (Level 2) to low water level 1 (Level 1).

Evaluation

The purpose of lowering the setpoint for MSIV closure is to reduce the number of challenges to the safety-relief valves (SRVs). This modification is consistent with staff recommendations for resolving Action Plan Item II.K.3.16 "Reduction of Challenges and Failures of Relief Valves-Feasibility Study and System Modifications." The licensee reviewed the FSAR transient and accident analyses to assess the impact of the setpoint change on the events. Thermal safety limits for those transients involving MSIV closure on low water level are not affected because the limiting thermal conditions are reached and reduced well before water level falls to Level 2. For loss-of-coolant accidents involving loss of offsite power, MSIV closure will occur on the loss of power signal regardless of water level. For loss-of-coolant accident where offsite power is available, lowering the setpoint will delay closing of the MSIVs. This will result in a more rapid depressurization which leads to earlier injection into the vessel by the low pressure Emergency Core Cooling (ECC) systems.

The proposed modification will eliminate MSIV closures for many transient events where water level falls below Level 2 but is recovered prior to reaching Level 1. This will reduce challenges to the safety-relief valves. As discussed above, previously analyzed transients and accidents are not adversely impacted by the change.

For the above reasons, the proposed technical specification change is acceptable.

Environmental Consideration

This amendment involves a change in the installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20. The staff has determined that the amendment involves no significant increase in the amounts, and no significant change in the types, of any effluents that

may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that this amendment involves no significant hazards consideration and there has been no public comment on such finding. Accordingly, this amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of this amendment.

#### Conclusion

We have concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (2) such activities will be conducted in compliance with the Commission's regulations and the issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public.

Dated: APR 23 ~~1955~~