

September 14, 1987

Docket Nos. 50-387/388

Mr. Harold W. Keiser
Vice President
Nuclear Operations
Pennsylvania Power and Light Company
2 North Ninth Street
Allentown, Pennsylvania 18101

DISTRIBUTION

Docket File	OGC - Beth.	BClayton
NRC PDR	DHagan	SCollins
LPDR	EJordan	
PDI-2 Rdg.	JPartlow	
SVarga	TBarnhart (8)	
BBoger	Wanda Jones	
WButler	EButcher	
MThadani		
DFischer	ACRS (10)	
MO'Brien	CMiles, GPA/PA	
	RDiggs, ARM/LFMB	

Dear Mr. Keiser:

SUBJECT: REVISED TECHNICAL SPECIFICATIONS FOR STANDBY GAS EXHAUST RADIATION
MONITOR SURVEILLANCE (TAC NOS. 65167 AND 65168)

RE: SUSQUEHANNA STEAM ELECTRIC STATION, UNITS 1 AND 2

The Commission has issued the enclosed Amendment No. 70 to Facility Operating License No. NPF-14 and Amendment No. 39 to Facility Operating License No. NPF-22 for the Susquehanna Steam Electric Station, Units 1 and 2. These amendments are in response to your letter dated April 13, 1987.

These amendments revise the Susquehanna Steam Electric Station Units 1 and 2 Technical Specifications for surveillance of the Standby Gas Treatment System Exhaust Radiation-High instrumentation.

A copy of our Safety Evaluation is also enclosed. Notice of Issuance will be included in the Commission's Biweekly Federal Register Notice.

Sincerely,

/s/

8709180435 870914
PDR ADOCK 05000387
P PDR

Walter R. Butler, Director
Project Directorate I-2
Division of Reactor Projects I/II
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 70 to License No. NPF-14
2. Amendment No. 39 to License No. NPF-22
3. Safety Evaluation

cc w/enclosures:
See next page

PDI-MBA
MO'Brien
9/2/87

PDI-2/PM
MThadani:ca
9/2/87

PDI-2/D
WButler
9/14/87

OGC
9/17/87



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

September 14, 1987

Docket Nos. 50-387/388

Mr. Harold W. Keiser
Vice President
Nuclear Operations
Pennsylvania Power and Light Company
2 North Ninth Street
Allentown, Pennsylvania 18101

Dear Mr. Keiser:

SUBJECT: REVISED TECHNICAL SPECIFICATIONS FOR STANDBY GAS EXHAUST RADIATION
MONITOR SURVEILLANCE (TAC NOS. 65167 AND 65168)

RE: SUSQUEHANNA STEAM ELECTRIC STATION, UNITS 1 AND 2

The Commission has issued the enclosed Amendment No. 70 to Facility Operating License No. NPF-14 and Amendment No. 39 to Facility Operating License No. NPF-22 for the Susquehanna Steam Electric Station, Units 1 and 2. These amendments are in response to your letter dated April 13, 1987.

These amendments revise the Susquehanna Steam Electric Station Units 1 and 2 Technical Specifications for surveillance of the Standby Gas Treatment System Exhaust Radiation-High instrumentation.

A copy of our Safety Evaluation is also enclosed. Notice of Issuance will be included in the Commission's Biweekly Federal Register Notice.

Sincerely,

Walter R. Butler
Walter R. Butler, Director
Project Directorate I-2
Division of Reactor Projects I/II
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 70 to License No. NPF-14
2. Amendment No. 39 to License No. NPF-22
3. Safety Evaluation

cc w/enclosures:
See next page

Mr. Harold W. Keiser
Pennsylvania Power & Light Company

Susquehanna Steam Electric Station
Units 1 & 2

cc:

Jay Silberg, Esq.
Shaw, Pittman, Potts & Trowbridge
2300 N Street N.W.
Washington, D.C. 20037

Bryan A. Snapp, Esq.
Assistant Corporate Counsel
Pennsylvania Power & Light Company
2 North Ninth Street
Allentown, Pennsylvania 18101

Mr. E. A. Heckman
Licensing Group Supervisor
Pennsylvania Power & Light Company
2 North Ninth Street
Allentown, Pennsylvania 18101

Mr. Loren Plisco
Resident Inspector
P.O. Box 52
Shickshinny, Pennsylvania 18655

Mr. R. J. Benich
Services Project Manager
General Electric Company
1000 First Avenue
King of Prussia, Pennsylvania 19406

Mr. Thomas M. Gerusky, Director
Bureau of Radiation Protection
Resources
Commonwealth of Pennsylvania
P. O. Box 2063
Harrisburg, Pennsylvania 17120

Robert W. Alder, Esquire
Office of Attorney General
P.O. Box 2357
Harrisburg, Pennsylvania 17120

Mr. Jesse C. Tilton, III
Allegheny Elec. Cooperative, Inc.
212 Locust Street
P.O. Box 1266
Harrisburg, Pennsylvania 17108-1266

Mr. W. H. Hirst, Manager
Joint Generation
Projects Department
Atlantic Electric
P.O. Box 1500
1199 Black Horse Pike
Pleasantville, New Jersey 08232

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, Pennsylvania 19406



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

PENNSYLVANIA POWER & LIGHT COMPANY
ALLEGHENY ELECTRIC COOPERATIVE, INC.

DOCKET NO. 50-387

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1
AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 70
License No. NPF-14

1. The Nuclear Regulatory Commission (the Commission or the NRC) having found that:
 - A. The application for the amendment filed by the Pennsylvania Power & Light Company, dated April 13, 1987 complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of the Facility Operating License No. NPF-14 is hereby amended to read as follows:

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 70 and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. PP&L shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

8709180452 870914
PDR ADOCK 05000387
P PDR

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

/s/

Walter R. Butler, Director
Project Directorate I-2
Division of Reactor Projects I/II

Attachment:
Changes to the Technical
Specifications

Date of Issuance: ~~September~~ 14, 1987

PDI-2/A
MThadani
9/2/87

ML2
PDI-2/PM
MThadani:ca
9/2/87

OGC
Woodward
9/8/87

PDI-2/D
WButler
9/14/87

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Walter R. Butler, Director
Project Directorate I-2
Division of Reactor Projects I/II

Attachment:
Changes to the Technical
Specifications

Date of Issuance: ~~September~~ 14, 1987

ATTACHMENT TO LICENSE AMENDMENT NO. 70

FACILITY OPERATING LICENSE NO. NPF-14

DOCKET NO. 50-387

Replace the following pages of the Appendix A Technical Specifications with enclosed pages. The revised pages are identified by Amendment number and contain vertical lines indicating the area of change. The overleaf pages are provided to maintain document completeness.*

REMOVE

3/4 3-23
3/4 3-24*

3/4 3-25*
3/4 3-26

INSERT

3/4 3-23
3/4 3-24*

3/4 3-25*
3/4 3-26

TABLE 4.3.2.1-1

ISOLATION ACTUATION INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>TRIP FUNCTION</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>CHANNEL CALIBRATION</u>	<u>OPERATIONAL CONDITIONS FOR WHICH SURVEILLANCE REQUIRED</u>
<u>1. PRIMARY CONTAINMENT ISOLATION</u>				
a. Reactor Vessel Water Level -				
1) Low, Level 3	S	M	R	1, 2, 3
2) Low Low, Level 2	S	M	R	1, 2, 3
3) Low Low Low, Level 1	S	M	R	1, 2, 3
b. Drywell Pressure - High	NA	M	R	1, 2, 3
c. Manual Initiation	NA	R	NA	1, 2, 3
d. SGTS Exhaust Radiation - High	S	M	R	1, 2, 3, 4***, 5***
e. Main Steam Line Radiation - High	S	M	R	1, 2, 3
<u>2. SECONDARY CONTAINMENT ISOLATION</u>				
a. Reactor Vessel Water Level - Low Low, Level 2	S	M	R	1, 2, 3 and *
b. Drywell Pressure - High	NA	M	Q	1, 2, 3
c. Refuel Floor High Exhaust Duct Radiation - High	S	M	R	*
d. Railroad Access Shaft Exhaust Duct Radiation - High	S	M	R	*
e. Refuel Floor Wall Exhaust Duct Radiation - High	S	M	R	*
f. Manual Initiation	NA	R	NA	1, 2, 3 and *

TABLE 4.3.2.1-1 (Continued)
ISOLATION ACTUATION INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>TRIP FUNCTION</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>CHANNEL CALIBRATION</u>	<u>OPERATIONAL CONDITIONS FOR WHICH SURVEILLANCE REQUIRED</u>
3. <u>MAIN STEAM LINE ISOLATION</u>				
a. Reactor Vessel Water Level - Low, Low Low, Level 1	S	M	R	1, 2, 3
b. Main Steam Line Radiation - High	S	M	R	1, 2, 3
c. Main Steam Line Pressure - Low	NA	M	Q	1
d. Main Steam Line Flow - High	S	M	R	1, 2, 3
e. Condenser Vacuum - Low	NA	M	Q	1, 2**, 3**
f. Reactor Building Main Steam Line Tunnel Temperature - High	NA	M	Q	1, 2, 3
g. Reactor Building Main Steam Line Tunnel Δ Temperature - High	NA	M	Q	1, 2, 3
h. Manual Initiation	NA	R	NA	1, 2, 3
i. Turbine Building Main Steam Line Tunnel Temperature - High	NA	M	Q	1, 2, 3
4. <u>REACTOR WATER CLEANUP SYSTEM ISOLATION</u>				
a. RWCU Δ Flow - High	S	M	R	1, 2, 3
b. RWCU Area Temperature - High	NA	M	Q	1, 2, 3
c. RWCU Area Ventilation Δ Temperature - High	NA	M	Q	1, 2, 3
d. SLCS Initiation	NA	R	NA	1, 2, 3
e. Reactor Vessel Water Level - Low Low, Level 2	S	M	R	1, 2, 3
f. RWCU Flow - High	S	M	R	1, 2, 3
g. Manual Initiation	NA	R	NA	1, 2, 3

TABLE 4.3.2.1-1 (Continued)

ISOLATION ACTUATION INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>TRIP FUNCTION</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>CHANNEL CALIBRATION</u>	<u>OPERATIONAL CONDITIONS FOR WHICH SURVEILLANCE REQUIRED</u>
5. <u>REACTOR CORE ISOLATION COOLING SYSTEM ISOLATION</u>				
a. RCIC Steam Line Δ Pressure - High	NA	M	Q	1, 2, 3
b. RCIC Steam Supply Pressure - Low	NA	M	Q	1, 2, 3
c. RCIC Turbine Exhaust Diaphragm Pressure - High	NA	M	Q	1, 2, 3
d. RCIC Equipment Room Temperature - High	NA	M	Q	1, 2, 3
e. RCIC Equipment Room Δ Temperature - High	NA	M	Q	1, 2, 3
f. RCIC Pipe Routing Area Temperature - High	NA	M	Q	1, 2, 3
g. RCIC Pipe Routing Area Δ Temperature - High	NA	M	Q	1, 2, 3
h. RCIC Emergency Area Cooler Temperature - High	NA	M	Q	1, 2, 3
i. Manual Initiation	NA	R	NA	1, 2, 3
j. Drywell Pressure - High	NA	M	R	1, 2, 3
6. <u>HIGH PRESSURE COOLANT INJECTION SYSTEM ISOLATION</u>				
a. HPCI Steam Line Δ Pressure - High	NA	M	Q	1, 2, 3
b. HPCI Steam Supply Pressure - Low	NA	M	Q	1, 2, 3
c. HPCI Turbine Exhaust Diaphragm Pressure - High	NA	M	Q	1, 2, 3

TABLE 4.3.2.1-1 (Continued)

ISOLATION ACTUATION INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>TRIP FUNCTION</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>CHANNEL CALIBRATION</u>	<u>OPERATIONAL CONDITIONS FOR WHICH SURVEILLANCE REQUIRED</u>
<u>HIGH PRESSURE COOLANT INJECTION SYSTEM ISOLATION (Continued)</u>				
d. HPCI Equipment Room Temperature - High	NA	M	Q	1, 2, 3
e. HPCI Equipment Room Δ Temperature - High	NA	M	Q	1, 2, 3
f. HPCI Emergency Area Cooler Temperature - High	NA	M	Q	1, 2, 3
g. HPCI Pipe Routing Area Temperature - High	NA	M	Q	1, 2, 3
h. HPCI Pipe Routing Area Δ Temperature - High	NA	M	Q	1, 2, 3
i. Manual Initiation	NA	R	NA	1, 2, 3
j. Drywell Pressure - High	NA	M	R	1, 2, 3
<u>7. RHR SYSTEM SHUTDOWN COOLING/HEAD SPRAY MODE ISOLATION</u>				
a. Reactor Vessel Water Level - Low, Level 3	S	M	R	1, 2, 3
b. Reactor Vessel (RHR Cut-in Permissive) Pressure - High	NA	M	Q	1, 2, 3
c. RHR Equipment Area Δ Temperature - High	NA	M	Q	1, 2, 3
d. RHR Equipment Area Temperature - High	NA	M	Q	1, 2, 3
e. RHR Flow - High	S	M	R	1, 2, 3
f. Manual Initiation	NA	R	NA	1, 2, 3
g. Drywell Pressure - High	NA	M	R	1, 2, 3

* When handling irradiated fuel in the secondary containment and during CORE ALTERATIONS and operations with a potential for draining the reactor vessel.

** When reactor steam dome pressure > 1043 psig and/or any turbine stop valve is open.

*** When VENTING or PURGING the drywell per Specification 3.11.2.8.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

PENNSYLVANIA POWER & LIGHT COMPANY

ALLEGHENY ELECTRIC COOPERATIVE, INC.

DOCKET NO. 50-388

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 39
License No. NPF-22

1. The Nuclear Regulatory Commission (the Commission or the NRC) having found that:
 - A. The application for the amendment filed by the Pennsylvania Power & Light Company, dated April 13, 1987 complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of the Facility Operating License No. NPF-22 is hereby amended to read as follows:

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 39 and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. PP&L shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

/s/

Walter R. Butler, Director
Project Directorate I-2
Division of Reactor Projects I/II

Attachment:
Changes to the Technical
Specifications

Date of Issuance: ~~September~~ 14, 1987

PDI-2/D
MThadani:ca
9/2/87

MThadani
PDI-2/PM
MThadani:ca
9/2/87

OGC
WButler
9/8/87

PDI-2/D
WButler
9/14/87

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Walter R. Butler, Director
Project Directorate I-2
Division of Reactor Projects I/II

Attachment:
Changes to the Technical
Specifications

Date of Issuance: ~~September~~ 14, 1987

ATTACHMENT TO LICENSE AMENDMENT NO. 39

FACILITY OPERATING LICENSE NO. NPF-22

DOCKET NO. 50-388

Replace the following pages of the Appendix A Technical Specifications with enclosed pages. The revised pages are identified by Amendment number and contain vertical lines indicating the area of change. The overleaf pages are provided to maintain document completeness.*

REMOVE

3/4 3-23
3/4 3-24*

3/4 3-25*
3/4 3-26

INSERT

3/4 3-23
3/4 3-24*

3/4 3-25*
3/4 3-26

TABLE 4.3.2.1-1

ISOLATION ACTUATION INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>TRIP FUNCTION</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>CHANNEL CALIBRATION</u>	<u>OPERATIONAL CONDITIONS FOR WHICH SURVEILLANCE REQUIRED</u>
1. <u>PRIMARY CONTAINMENT ISOLATION</u>				
a. Reactor Vessel Water Level -				
1) Low, Level 3	S	M	R	1, 2, 3
2) Low Low, Level 2	S	M	R	1, 2, 3
3) Low Low Low, Level 1	S	M	R	1, 2, 3
b. Drywell Pressure - High	NA	M	R	1, 2, 3
c. Manual Initiation	NA	R	NA	1, 2, 3
d. SGTS Exhaust Radiation - High	S	M	R	1, 2, 3, 4***, 5***
e. Main Steam Line Radiation - High	S	M	R	1, 2, 3
2. <u>SECONDARY CONTAINMENT ISOLATION</u>				
a. Reactor Vessel Water Level - Low Low, Level 2	S	M	R	1, 2, 3 and *
b. Drywell Pressure - High	NA	M	Q	1, 2, 3
c. Refuel Floor High Exhaust Duct Radiation - High	S	M	R	*
d. Railroad Access Shaft Exhaust Duct Radiation - High	S	M	R	*
e. Refuel Floor Wall Exhaust Duct Radiation - High	S	M	R	*
f. Manual Initiation	NA	R	NA	1, 2, 3 and *

TABLE 4.3.2.1-1 (Continued)

ISOLATION ACTUATION INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>TRIP FUNCTION</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>CHANNEL CALIBRATION</u>	<u>OPERATIONAL CONDITIONS FOR WHICH SURVEILLANCE REQUIRED</u>
3. MAIN STEAM LINE ISOLATION				
a. Reactor Vessel Water Level - Low Low Low, Level 1	S	M	R	1, 2, 3
b. Main Steam Line Radiation - High	S	M	R	1, 2, 3
c. Main Steam Line Pressure - Low	NA	M	Q	1
d. Main Steam Line Flow - High	S	M	R	1, 2, 3
e. Condenser Vacuum - Low	NA	M	Q	1, 2**, 3**
f. Reactor Building Main Steam Line Tunnel Temperature - High	NA	M	Q	1, 2, 3
g. Reactor Building Main Steam Line Tunnel Δ Temperature - High	NA	M	Q	1, 2, 3
h. Manual Initiation	NA	R	NA	1, 2, 3
i. Turbine Building Main Steam Line Tunnel Temperature - High	NA	M	Q	1, 2, 3
4. REACTOR WATER CLEANUP SYSTEM ISOLATION				
a. RWCU Δ Flow - High	S	M	R	1, 2, 3
b. RWCU Area Temperature - High	NA	M	Q	1, 2, 3
c. RWCU Area Ventilation Δ Temperature - High	NA	M	Q	1, 2, 3
d. SLCS Initiation	NA	R	NA	1, 2, 3
e. Reactor Vessel Water Level - Low Low, Level 2	S	M	R	1, 2, 3
f. RWCU Flow - High	S	M	R	1, 2, 3
g. Manual Initiation	NA	R	NA	1, 2, 3

SUSQUEHANNA - UNIT 2

3/4 3-24

*Amendment No. 25
 reflecting the unit's
 response during
 the unit's first
 start-up*

TABLE 4.3.2.1-1 (Continued)

ISOLATION ACTUATION INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>TRIP FUNCTION</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>CHANNEL CALIBRATION</u>	<u>OPERATIONAL CONDITIONS FOR WHICH SURVEILLANCE REQUIRED</u>
5. <u>REACTOR CORE ISOLATION COOLING SYSTEM ISOLATION</u>				
a. RCIC Steam Line Δ Pressure - High	NA	M	Q	1, 2, 3
b. RCIC Steam Supply Pressure - Low	NA	M	Q	1, 2, 3
c. RCIC Turbine Exhaust Diaphragm Pressure - High	NA	M	Q	1, 2, 3
d. RCIC Equipment Room Temperature - High	NA	M	Q	1, 2, 3
e. RCIC Equipment Room Δ Temperature - High	NA	M	Q	1, 2, 3
f. RCIC Pipe Routing Area Temperature - High	NA	M	Q	1, 2, 3
g. RCIC Pipe Routing Area Δ Temperature - High	NA	M	Q	1, 2, 3
h. RCIC Emergency Area Cooler Temperature - High	NA	M	Q	1, 2, 3
i. Manual Initiation	NA	R	NA	1, 2, 3
j. Drywell Pressure - High	NA	M	R	1, 2, 3
6. <u>HIGH PRESSURE COOLANT INJECTION SYSTEM ISOLATION</u>				
a. HPCI Steam Line Δ Pressure - High	NA	M	Q	1, 2, 3
b. HPCI Steam Supply Pressure - Low	NA	M	Q	1, 2, 3
c. HPCI Turbine Exhaust Diaphragm Pressure - High	NA	M	Q	1, 2, 3

SUSQUEHANNA - UNIT 2

3/4 3-26

Amendment No. 39

TABLE 4.3.2.1-1 (Continued)
ISOLATION ACTUATION INSTRUMENTATION SURVEILLANCE REQUIREMENTS

TRIP FUNCTION	CHANNEL CHECK	CHANNEL FUNCTIONAL TEST	CHANNEL CALIBRATION	OPERATIONAL CONDITIONS FOR WHICH SURVEILLANCE REQUIRED
<u>HIGH PRESSURE COOLANT INJECTION SYSTEM ISOLATION (Continued)</u>				
d. HPCI Equipment Room Temperature - High	NA	M	Q	1, 2, 3
e. HPCI Equipment Room Δ Temperature - High	NA	M	Q	1, 2, 3
f. HPCI Emergency Area Cooler Temperature - High	NA	M	Q	1, 2, 3
g. HPCI Pipe Routing Area Temperature - High	NA	M	Q	1, 2, 3
h. HPCI Pipe Routing Area Δ Temperature - High	NA	M	Q	1, 2, 3
i. Manual Initiation	NA	M	Q	1, 2, 3
j. Drywell Pressure - High	NA	R	NA	1, 2, 3
		M	R	1, 2, 3
<u>7. RHR SYSTEM SHUTDOWN COOLING/HEAD SPRAY MODE ISOLATION</u>				
a. Reactor Vessel Water Level - Low, Level 3	S	M	R	1, 2, 3
b. Reactor Vessel (RHR Cut-in Permissive) Pressure - High	NA	M	Q	1, 2, 3
c. RHR Equipment Area Δ Temperature - High	NA	M	Q	1, 2, 3
d. RHR Equipment Area Temperature - High	NA	M	Q	1, 2, 3
e. RHR Flow - High	S	M	Q	1, 2, 3
f. Manual Initiation	NA	R	R	1, 2, 3
g. Drywell Pressure - High	NA	M	NA	1, 2, 3
			R	1, 2, 3

*When handling irradiated fuel in the secondary containment and during CORE ALTERATIONS and operations with a potential for draining the reactor vessel.
 **When reactor steam dome pressure > 1043 psig and/or any turbine stop valve is open.
 ***When VENTING or PURGING the drywell per Specification 3.11.2.8.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

SUPPORTING AMENDMENT NO. 70 TO FACILITY OPERATING LICENSE NO. NPF-14 AND

AMENDMENT NO. 39 TO FACILITY OPERATING LICENSE NO. NPF-22

PENNSYLVANIA POWER & LIGHT COMPANY

ALLEGHENY ELECTRIC COOPERATIVE, INC.

DOCKET NOS. 50-387 AND 50-388

SUSQUEHANNA STEAM ELECTRIC STATION, UNITS 1 AND 2

1.0 INTRODUCTION

By letter dated April 13, 1987, Pennsylvania Power and Light Company (the licensee) submitted Change Request No. 93 to NPF-14 and Change Request No. 46 to NPF-22 requesting that the Technical Specifications (TS) Table 4.3.2.1-1, Isolation Actuation Instrumentation Surveillance Requirements, be amended to revise the applicable operational modes requiring surveillance of the Standby Gas Treatment System (SGTS) Exhaust Radiation-High instrumentation. These changes are proposed to be consistent with the SGTS Exhaust Radiation-High instrumentation operability requirement specified in TS Table 3.3.2-1, Isolation Actuation Instrumentation.

The proposed changes consist of modifying the surveillance requirement on the SGTS Exhaust Radiation-High, instrumentation Item 1.d (both units) of TS Table 4.3.2.1-1 such that the surveillance is performed in modes 4 and 5 only when venting or purging is planned. The current TS requires the surveillance to be performed and maintained while in modes 4 and 5.

2.0 EVALUATION

The SGTS Exhaust Radiation-High instrument is designed to provide automatic closure of the primary containment purge and nitrogen makeup isolation valves when high radiation is detected in the SGTS exhaust vent during containment purge. This is done to prevent the release of radioactivity to the environment should a reactor coolant leak occur. The existing TS requires performing and maintaining surveillance of the SGTS Exhaust Radiation-High monitoring instrument during modes 4 and 5. However, in Table 3.3.2-1, under the "Applicable Operational Condition" column, the SGTS Exhaust Radiation-High instrument is required to be operable in modes 4 and 5 only when venting or purging the drywell per TS 3.11.2.8. The licensee has requested that the TS Table 4.3.2.1-1 for both units be amended to make it consistent with TS Table 3.3.2-1 (operability) and require surveillance consistent with TS 3.11.2.8, when venting or purging the drywell.

8709180454 870914
PDR ADDCK 05000387
P PDR

The staff finds that this change does not conflict with current guidance provided in NUREG-0123, Standard Technical Specifications (STS) for General Electric Boiling Water Reactors or the staff Technical Position CSB 6-4. The licensee's approach is, therefore, acceptable.

The staff therefore concludes that the licensee's proposal to modify TS Table 4.3.2.1-1, Item 1.d to require surveillance in modes 4 and 5 only when venting or purging the drywell is acceptable.

3.0 ENVIRONMENTAL CONSIDERATION

This amendment involves a change to a requirement with respect to the installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20 and changes to the surveillance requirements. The staff has determined that the amendment involves no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that this amendment involves no significant hazards consideration and there has been no public comment on such finding. Accordingly, this amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement nor environmental assessment need be prepared in connection with the issuance of this amendment.

4.0 CONCLUSION

The Commission made a proposed determination that the amendment involves no significant hazards consideration which was published in the Federal Register (52 FR 26594) on July 15, 1987 and consulted with the State of Pennsylvania. No public comments were received, and the State of Pennsylvania did not have any comments.

The staff has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (2) such activities will be conducted in compliance with the Commission's regulations and the issuance of this amendment will not be inimical to the common defense and security nor to the health and safety of the public.

Principal Contributor: Larry E. Briggs

Dated: **September 14, 1987**