

Docket No.: 50-387

May 22, 1987

Mr. Harold W. Keiser
Vice President
Nuclear Operations
Pennsylvania Power and Light Company
2 North Ninth Street
Allentown, Pennsylvania 18101

Dear Mr. Keiser:

SUBJECT: CONFIRMATION OF CHANGE TO TECHNICAL SPECIFICATIONS

RE: SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1

This confirms our telephone authorization given on May 22, 1987, for the change to the Technical Specifications for Susquehanna Steam Electric Station, Unit 1, as requested in your letter dated May 14, 1987 and supplemented with additional information in letters dated May 19 and 21, 1987. Facility Operating License NPF-14 is amended on May 22, 1987, by permitting valve, HV-155F002, located on the steamline for the HPCI system to be considered operable for the Technical Specification Section 3.6.3, with its current minimum torque switch setting for the period beginning May 23, 1987, until the next refueling outage, scheduled to begin on or about September 12, 1987. The corrected Technical Specification page, 3/4 6-19, and the overleaf page, 3/4 6-20, are enclosed.

The formal license amendment, our completed safety evaluation, and the Federal Register Notice of this change to the Technical Specifications for Susquehanna Steam Electric Station, Unit 1, are being processed and copies of these documents will be sent to you in the near future.

Sincerely,

/s/

Bruce A. Boger, Assistant Director
for Region I Reactors
Division of Reactor Projects I/II

Enclosures:
Technical Specification Pages

cc w/enclosures:
See next page

8705290129 870522
PDR ADOCK 05000387
P PDR

DISTRIBUTION:

Docket File	EJordan	BClayton
NRC PDR	JPartlow	JWiggins
Local PDR	TBarnhart (4)	RGallo
PDI-2 Rdg.	Wanda Jones	
SVarga	EButcher	
BBoger	Tech Branch	
WButler	ACRS (10)	
MThadani/DFischer	CMiles, GPA/PA	
MO'Brien	RDiggs, ARM/LFMB	

PDI-2/PM
MThadani:ca
5/24/87

PDI-2/PM
MThadani:ca
5/24/87

PDI-2/D
WButler
5/24/87

AD/RA
BBoger
5/22/87



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

May 22, 1987

Packet No.: 50-387

Mr. Harold W. Keiser
Vice President
Nuclear Operations
Pennsylvania Power and Light Company
2 North Ninth Street
Allentown, Pennsylvania 18101

Dear Mr. Keiser:

SUBJECT: CONFIRMATION OF CHANGE TO TECHNICAL SPECIFICATIONS

RE: SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1

This confirms our telephone authorization given on May 22, 1987, for the change to the Technical Specifications for Susquehanna Steam Electric Station, Unit 1, as requested in your letter dated May 14, 1987 and supplemented with additional information in letters dated May 19 and 21, 1987. Facility Operating License NPF-14 is amended on May 22, 1987, by permitting valve, HV-155F002, located on the steamline for the HPCI system to be considered operable for the Technical Specification Section 3.6.3, with its current minimum torque switch setting for the period beginning May 23, 1987, until the next refueling outage, scheduled to begin on or about September 12, 1987. The corrected Technical Specification page, 3/4 6-19, and the overleaf page, 3/4 6-20, are enclosed.

The formal license amendment, our completed safety evaluation, and the Federal Register Notice of this change to the Technical Specifications for Susquehanna Steam Electric Station, Unit 1, are being processed and copies of these documents will be sent to you in the near future.

Sincerely,

A handwritten signature in dark ink, appearing to read "BA Boger", is written over the signature line.

Bruce A. Boger, Assistant Director
for Region I Reactors
Division of Reactor Projects I/II

Enclosures:
Technical Specification Pages

cc w/enclosures:
See next page

Mr. Harold W. Keiser
Pennsylvania Power & Light Company

Susquehanna Steam Electric Station
Units 1 & 2

cc:

Jay Silberg, Esq.
Shaw, Pittman, Potts & Trowbridge
2300 N Street N.W.
Washington, D.C. 20037

Bryan A. Snapp, Esq.
Assistant Corporate Counsel
Pennsylvania Power & Light Company
2 North Ninth Street
Allentown, Pennsylvania 18101

Mr. E. A. Heckman
Licensing Group Supervisor
Pennsylvania Power & Light Company
2 North Ninth Street
Allentown, Pennsylvania 18101

Mr. Loren Plisco
Resident Inspector
P.O. Box 52
Shickshinny, Pennsylvania 18655

Mr. R. J. Benich
Services Project Manager
General Electric Company
1000 First Avenue
King of Prussia, Pennsylvania 19406

Mr. Thomas M. Gerusky, Director
Bureau of Radiation Protection
Resources
Commonwealth of Pennsylvania
P. O. Box 2063
Harrisburg, Pennsylvania 17120

Robert W. Alder, Esquire
Office of Attorney General
P.O. Box 2357
Harrisburg, Pennsylvania 17120

Mr. Jesse C. Tilton, III
Allegheny Elec. Cooperative, Inc.
212 Locust Street
P.O. Box 1266
Harrisburg, Pennsylvania 17108-1266

Mr. W. H. Hirst, Manager
Joint Generation
Projects Department
Atlantic Electric
P.O. Box 1500
1199 Black Horse Pike
Pleasantville, New Jersey 08232

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, Pennsylvania 19406

TABLE 3.6.3-1
PRIMARY CONTAINMENT ISOLATION VALVES

<u>VALVE FUNCTION AND NUMBER</u>	<u>MAXIMUM ISOLATION TIME (Seconds)</u>	<u>ISOLATION SIGNAL(s)^(a)</u>
<u>a. Automatic Isolation Valves</u>		
<u>MSIV</u>		
HV-141F022 A,B,C,D	5	X,C,D,E,P,UA
HV-141F028 A,B,C,D	5	X,C,D,E,P,UA
<u>MSL Drain</u>		
HV-141F016	10	X,C,D,E,P,UA
HV-141F019	10	X,C,D,E,P,UA
<u>RCIC Steam Supply</u>		
HV-149F007	20	K,KB
HV-149F008	20	K,KB
HV-149F088	3	K,KB
<u>HPCI Steam Supply</u>		
HV-155F002*	50	L,LB
HV-155F003	50	L,LB
HV-155F100	3	L,LB
<u>RHR - Shutdown Cooling Suction</u>		
HV-151F008	52	A,M,UB
HV-151F009	52	A,M,UB
<u>RWCU Suction^(b)</u>		
HV-144F001	30	B,J,W
HV-144F004	30	I,B,J,W
<u>RHR - Reactor Vessel Head Spray</u>		
HV-151F022	30	A,M,UB,Z
HV-151F023	20	A,M,UB,Z

*The HPCI HV-155F002 valve may be considered OPERABLE with its current minimum torque switch setting for the period beginning May 23, 1987 until an outage of sufficient duration to revise the setting occurs but no later than the next refueling outage scheduled on or about September 12, 1987.