



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

FEB 15 1985

Docket Nos.: 50-387  
and 50-388

Mr. Norman W. Curtis  
Vice President  
Engineering and Construction - Nuclear  
Pennsylvania Power and Light Company  
2 North Ninth Street  
Allentown, Pennsylvania 18101

Dear Mr. Curtis:

SUBJECT: AMENDMENT NOS. 35 AND 8 TO FACILITY OPERATING LICENSE  
NOS. NPF-14 AND NPF-22, SUSQUEHANNA STEAM ELECTRIC STATION,  
UNITS 1 AND 2 RESPECTIVELY

The Nuclear Regulatory Commission has issued the enclosed Amendment Nos. 35 and 8 to Facility Operating License Nos. NPF-14 and NPF-22 for the Susquehanna Steam Electric Station, Units 1 and 2 respectively. These amendments are in response to your letter dated September 28, 1984. These amendments change the Susquehanna Unit 1 and Unit 2 Technical Specifications 4.6.5.3 and 4.7.2 regarding HEPA filters and charcoal adsorber units to incorporate clarifications discussed in NRC Generic Letter No. 83-13 dated March 2, 1983.

A copy of the related safety evaluation supporting Amendment Nos. 35 and 8 to Facility Operating License Nos. NPF-14 and NPF-22 is enclosed.

Sincerely,

A handwritten signature in cursive script, appearing to read "A. Schwencer".

A. Schwencer, Chief  
Licensing Branch No. 2  
Division of Licensing

Enclosures:

1. Amendment No. 35 to NPF-14
2. Amendment No. 8 to NPF-22
3. Safety Evaluation

cc w/enclosures:  
See next page

8502250870 850215  
PDR ADOCK 05000387  
P PDR

FEB 15 1985

Docket Nos.: 50-387  
and 50-388

Mr. Norman W. Curtis  
Vice President  
Engineering and Construction - Nuclear  
Pennsylvania Power and Light Company  
2 North Ninth Street  
Allentown, Pennsylvania 18101

Dear Mr. Curtis:

SUBJECT: AMENDMENT NOS. *35* AND *8* TO FACILITY OPERATING LICENSE  
NOS. NPF-14 AND NPF-22, SUSQUEHANNA STEAM ELECTRIC STATION,  
UNITS 1 AND 2 RESPECTIVELY

The Nuclear Regulatory Commission has issued the enclosed Amendment Nos. *35* and *8* to Facility Operating License Nos. NPF-14 and NPF-22 for the Susquehanna Steam Electric Station, Units 1 and 2 respectively. These amendments are in response to your letter dated September 28, 1984. These amendments change the Susquehanna Unit 1 and Unit 2 Technical Specifications 4.6.5.3 and 4.7.2 regarding HEPA filters and charcoal adsorber units to incorporate clarifications discussed in NRC Generic Letter No. 83-13 dated March 2, 1983.

A copy of the related safety evaluation supporting Amendment Nos. *35* and *8* to Facility Operating License Nos. NPF-14 and NPF-22 is enclosed.

Sincerely,

Original signed by:

A. Schwencer, Chief  
Licensing Branch No. 2  
Division of Licensing

Enclosures:

1. Amendment No. *35* to NPF-14
2. Amendment No. *8* to NPF-22
3. Safety Evaluation

cc w/enclosures:  
See next page

DL:LB#2  
EB/ston  
1/21/85

DL:LB#2  
MCarb...:pob  
1/21/85

DL:LB#2  
ASchwencer  
1/31/85

OELD  
J. Goldberg  
2/1/85

AD/LDL  
TNovak  
2/13/85

*with notes  
change to  
material*

Susquehanna

Mr. Norman W. Curtis  
Vice President  
Engineering and Construction  
Pennsylvania Power & Light Company  
2 North Ninth Street  
Allentown, Pennsylvania 18101

Jay Silberg, Esq.  
Shaw, Pittman, Potts, & Trowbridge  
1800 M Street, N. W.  
Washington, D.C. 20036

Edward M. Nagel, Esq.  
General Counsel and Secretary  
Pennsylvania Power & Light Company  
2 North Ninth Street  
Allentown, Pennsylvania 18101

Mr. William E. Barberich  
Manager-Nuclear Licensing  
Pennsylvania Power & Light Company  
2 North Ninth Street  
Allentown, Pennsylvania 18101

Mr. R. Jacobs  
Resident Inspector  
P.O. Box 52  
Shickshinny, Pennsylvania 18655

Mr. E. B. Poser  
Project Engineer  
Bechtel Power Corporation  
P. O. Box 3965  
San Francisco, California 94119

Mr. Thomas M. Gerusky, Director  
Bureau of Radiation Protection Resources  
Commonwealth of Pennsylvania  
P. O. Box 2063  
Harrisburg, Pennsylvania 17120

Mr. N. D. Weiss  
Project Manager  
Mail Code 391  
General Electric Company  
175 Curtner Avenue  
San Jose, California 95125

Robert W. Alder, Esquire  
Office of Attorney General  
P. O. Box 2357  
Harrisburg, Pennsylvania 17120

Mr. William Matson  
Allegheny Elec. Cooperative, Inc.  
212 Locust Street  
P. O. Box 1266  
Harrisburg, PA 17108-1266

Susquehanna

cc: Governor's Office of State Planning & Development  
Attn: Coordinator, State Clearinghouse  
P O. Box 1323  
Harrisburg, Pennsylvania 17120

Mr. Bruce Thomas, President  
Board of Supervisors  
R. D. #1  
Berwick, Pennsylvania 18603

U. S. Environmental Protection Agency  
Attn: EIS Coordinator  
Region III Office  
Curtis Building  
6th and Walnut Streets  
Philadelphia, Pennsylvania 19106



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

PENNSYLVANIA POWER & LIGHT COMPANY  
ALLEGHENY ELECTRIC COOPERATIVE, INC.  
DOCKET NO. 50-387  
SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1  
AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 35  
License No. NPF-14

1. The Nuclear Regulatory Commission (the Commission or the NRC) having found that:
  - A. The application for the amendment filed by the Pennsylvania Power & Light Company, dated September 28, 1984, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the regulations of the Commission;
  - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of the Facility Operating License No. NPF-14 is hereby amended to read as follows:

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 35, and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. The licensee shall operate the facilities in accordance with the Technical Specifications and the Environmental Protection Plan.

8502250881 850215  
PDR ADOCK 05000387  
P PDR

3. This amendment is effective as of the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



A. Schwencer, Chief  
Licensing Branch No. 2  
Division of Licensing

Enclosure:  
Changes to the Technical  
Specifications

Date of Issuance: FEB 15 1985

3. This amendment is effective as of the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

Original signed by:

A. Schwencer, Chief  
Licensing Branch No. 2  
Division of Licensing

Enclosure:  
Changes to the Technical  
Specifications

Date of Issuance:

DL:LB#2  
EHW/ton  
1/15/85

DL:LB#2  
M. C. [unclear] one: pob  
1/15/85

DL:LB#2  
ASchwencer  
2/13/85

with noted  
change to  
notice  
OED  
I. Gork [unclear]  
2/11/85  
DL:AD/L  
TNovak  
2/13/85

ENCLOSURE TO LICENSE AMENDMENT NO. 35  
FACILITY OPERATING LICENSE NO. NPF-14  
DOCKET NO. 50-387

Replace the following pages of the Appendix "A" Technical Specifications with the enclosed pages. The revised pages are identified by Amendment number and contain a vertical line indicating the area of change.

REMOVE

3/4 6-35  
3/4 6-36

3/4 7-5  
3/4 7-6

INSERT

3/4 6-35  
3/4 6-36

3/4 7-5  
3/4 7-6



## CONTAINMENT SYSTEMS

### SURVEILLANCE REQUIREMENTS (Continued)

---

- b. At least once per 18 months or (1) after any structural maintenance on the HEPA filter or charcoal adsorber housings, or (2) following painting, fire or chemical release in any ventilation zone communicating with the subsystem by:
  - 1. Verifying that the subsystem satisfies the in-place penetration and bypass leakage testing acceptance criteria of less than 0.05% and uses the test procedures of Regulatory Positions C.5.a, C.5.c and C.5.d of Regulatory Guide 1.52, Revision 2, March 1978, and the system flow rate is 10,100 cfm  $\pm$  10%.
  - 2. Verifying within 31 days after removal that a laboratory analysis of a representative carbon sample obtained in accordance with Regulatory Position C.6.b of Regulatory Guide 1.52, Revision 2, March 1978, meets the laboratory testing criteria of Regulatory Position C.6.a of Regulatory Guide 1.52, Revision 2, March 1978, for a methyl iodide penetration of less than 0.175%; and
  - 3. Verifying a subsystem flow rate of 10,100 cfm  $\pm$  10% during system operation when tested in accordance with ANSI N510-1975.
- c. After every 720 hours of charcoal adsorber operation by verifying within 31 days after removal that a laboratory analysis of a representative carbon sample obtained in accordance with Regulatory Position C.6.b of Regulatory Guide 1.52, Revision 2, March 1978, meets the laboratory testing criteria of Regulatory Position C.6.a of Regulatory Guide 1.52, Revision 2, March 1978, for a methyl iodide penetration of less than 0.175%.
- d. At least once per 18 months by:
  - 1. Verifying that the pressure drop across the combined HEPA filters and charcoal adsorber banks is less than 13 inches Water Gauge while operating the filter train at a flow rate of 10,100 cfm  $\pm$  10%.
  - 2. Verifying that the filter train starts and associated dampers open on each of the following test signals:
    - a. Manual initiation from the control room, and
    - b. Simulated automatic initiation signal.
  - 3. Verifying that the filter cooling bypass and outside air dampers open and the fan start on filter cooling initiation.
  - 4. Verifying that the temperature differential across each heating coil is  $> 17^{\circ}\text{F}$  when tested in accordance with ANSI N510-1975.

CONTAINMENT SYSTEMS

SURVEILLANCE REQUIREMENTS (Continued)

---

- e. After each complete or partial replacement of a HEPA filter bank, by verifying that the HEPA filter bank satisfies the in-place penetration and bypass leakage testing acceptance criteria of less than 0.05% in accordance with ANSI N510-1975 for a DOP test aerosol while operating the system at a flow rate of 10,100 cfm  $\pm$  10%.
- f. After each complete or partial replacement of a charcoal adsorber bank by verifying that the charcoal adsorber bank satisfies the in-place penetration and bypass leakage testing acceptance criteria of less than 0.05% in accordance with ANSI N510-1975 for a hydrogenated hydrocarbon refrigerant test gas while operating the system at a flow rate of 10,100 cfm  $\pm$  10%.

## PLANT SYSTEMS

### SURVEILLANCE REQUIREMENTS (Continued)

1. Verifying that the subsystem satisfies the in-place penetration and bypass leakage testing acceptance criteria of less than 0.05% and uses the test procedures of Regulatory Positions C.5.a, C.5.c and C.5.d of Regulatory Guide 1.52, Revision 2, March 1978, and the system flow rate is 5810 cfm  $\pm$  10%. |16 |
  2. Verifying within 31 days after removal that a laboratory analysis of a representative carbon sample obtained in accordance with Regulatory Position C.6.b of Regulatory Guide 1.52, Revision 2, March 1978, meets the laboratory testing criteria of Regulatory Position C.6.a of Regulatory Guide 1.52, Revision 2, March 1978, for a methyl iodide penetration of less than 0.175%; and |16 |
  3. Verifying a subsystem flow rate of 5810 cfm  $\pm$  10% during subsystem operation when tested in accordance with ANSI N510-1975. |16 |
- c. After every 720 hours of charcoal adsorber operation by verifying within 31 days after removal that a laboratory analysis of a representative carbon sample obtained in accordance with Regulatory Position C.6.b of Regulatory Guide 1.52, Revision 2, March 1978, meets the laboratory testing criteria of Regulatory Position C.6.a of Regulatory Guide 1.52, Revision 2, March 1978, for a methyl iodide penetration of less than 0.175%.
- d. At least once per 18 months by:
1. Verifying that the pressure drop across the combined prefilter, upstream and downstream HEPA filters and charcoal adsorber banks is less than 9.1 inches Water Gauge while operating the subsystem at a flow rate of 5810 cfm  $\pm$  10%.
  2. Verifying that on each of the below isolation mode actuation test signals, the subsystem automatically switches to the isolation mode of operation and the isolation dampers close within 8 seconds:
    - a) Outside air intake chlorine - high,
    - b) Outside air intake radiation - high, and
    - c) Reactor Building isolation.
  3. Verifying that on each of the below pressurization mode actuation test signals, the subsystem automatically switches to the pressurization mode of operation and the control structure is maintained at a positive pressure of 1/8 inch W.G. relative to the outside atmosphere during subsystem operation at a flow rate less than or equal to 5810 cfm:
    - a) Reactor Building isolation, and
    - b) Outside air intake radiation - high.
  4. Verifying that the heaters dissipate  $30 \pm 3.0$  Kw when tested in accordance with ANSI N510-1975.

PLANT SYSTEMS

SURVEILLANCE REQUIREMENTS (Continued)

---

- e. After each complete or partial replacement of a HEPA filter bank, by verifying that the HEPA filter bank satisfies the in-place penetration and bypass leakage testing acceptance criteria of less than 0.05% in accordance with ANSI N510-1975 for a DOP test aerosol while operating the system at a flow rate of 5810 cfm  $\pm$  10%.
  
- f. After each complete or partial replacement of a charcoal adsorber bank by verifying that the charcoal adsorber bank satisfies the in-place penetration and bypass leakage testing acceptance criteria of less than 0.05% in accordance with ANSI N510-1975 for a halogenated hydrocarbon refrigerant test gas while operating the system at a flow rate of 5810 cfm  $\pm$  10%.



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

PENNSYLVANIA POWER & LIGHT COMPANY  
ALLEGHENY ELECTRIC COOPERATIVE, INC.  
DOCKET NO. 50-388  
SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 2  
AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 8  
License No. NPF-22

1. The Nuclear Regulatory Commission (the Commission or the NRC) having found that:
  - A. The application for the amendment filed by the Pennsylvania Power and Light Company, dated September 28, 1984, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the regulations of the Commission;
  - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of the Facility Operating License No. NPF-22 hereby amended to read as follows:

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 8, and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This amendment is effective as of the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



A. Schwencer, Chief  
Licensing Branch No. 2  
Division of Licensing

Enclosure:  
Changes to the Technical  
Specifications

Date of Issuance: FEB 15 1965

3. This amendment is effective as of the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

Approved by:

A. Schwencer, Chief  
Licensing Branch No. 2  
Division of Licensing

Enclosure:  
Changes to the Technical  
Specifications

Date of Issuance: FEB 15 1985

DL:LB#2  
EMW/ton  
1/15/85

DL:LB#2  
MJC/none:pob  
1/15/85

DL:LB#2  
ASchwencer  
1/31/85

with noted  
change to  
notice  
J. Goldberger  
2/1/85

DL:ADL  
TNovak  
2/13/85

ENCLOSURE TO LICENSE AMENDMENT NO. 8  
FACILITY OPERATING LICENSE NO. NPF-22  
DOCKET NO. 50-388

Replace the following pages of the Appendix "A" Technical Specifications with the enclosed pages. The revised pages are identified by Amendment number and contain a vertical line indicating the area of change.

REMOVE

3/4 6-37  
3/4 6-38

3/4 7-5  
3/4 7-6

3/4 7-7  
3/4 7-8

INSERT

3/4 6-37  
3/4 6-38

3/4 7-5  
3/4 7-6

3/4 7-7  
3/4 7-8



## CONTAINMENT SYSTEMS

### SURVEILLANCE REQUIREMENTS (Continued)

- b. At least once per 18 months or (1) after any structural maintenance on the HEPA filter or charcoal adsorber housings, or (2) following painting, fire or chemical release in any ventilation zone communicating with the subsystem by:
1. Verifying that the subsystem satisfies the in-place penetration and bypass leakage testing acceptance criteria of less than 0.05% and uses the test procedures of Regulatory Positions C.5.a, C.5.c and C.5.d of Regulatory Guide 1.52, Revision 2, March 1978, and the system flow rate is 10,100 cfm  $\pm$  10%.
  2. Verifying within 31 days after removal that a laboratory analysis of a representative carbon sample obtained in accordance with Regulatory Position C.6.b of Regulatory Guide 1.52, Revision 2, March 1978, meets the laboratory testing criteria of Regulatory Position C.6.a of Regulatory Guide 1.52, Revision 2, March 1978, for a methyl iodide penetration of less than 0.175%; and
  3. Verifying a subsystem flow rate of 10,100 cfm  $\pm$  10% during system operation when tested in accordance with ANSI N510-1975.
- c. After every 720 hours of charcoal adsorber operation by verifying within 31 days after removal that a laboratory analysis of a representative carbon sample obtained in accordance with Regulatory Position C.6.b of Regulatory Guide 1.52, Revision 2, March 1978, meets the laboratory testing criteria of Regulatory Position C.6.a of Regulatory Guide 1.52, Revision 2, March 1978, for a methyl iodide penetration of less than 0.175%.
- d. At least once per 18 months by:
1. Verifying that the pressure drop across the combined HEPA filters and charcoal adsorber banks is less than 13 inches Water Gauge while operating the filter train at a flow rate of 10,100 cfm  $\pm$  10%.
  2. Verifying that the filter train starts and associated dampers open on each of the following test signals:
    - a. Manual initiation from the control room, and
    - b. Simulated automatic initiation signal.
  3. Verifying that the filter cooling bypass and outside air dampers open and the fan start on filter cooling initiation.
  4. Verifying that the temperature differential across each heating coil is  $\geq$  17°F when tested in accordance with ANSI N510-1975.

## CONTAINMENT SYSTEMS

### SURVEILLANCE REQUIREMENTS (Continued)

---

- e. After each complete or partial replacement of a HEPA filter bank by verifying that the HEPA filter bank satisfies the in-place penetration and bypass leakage testing acceptance criteria of less than 0.05% in accordance with ANSI N510-1975 for a DOP test aerosol while operating the system at a flow rate of 10,100 cfm  $\pm$  10%.
- f. After each complete or partial replacement of a charcoal adsorber bank by verifying that the charcoal adsorber bank satisfies the in-place penetration and bypass leakage testing acceptance criteria of less than 0.05% in accordance with ANSI N510-1975 for a hydro-generated hydrocarbon refrigerant test gas while operating the system at a flow rate of 10,100 cfm  $\pm$  10%.

## PLANT SYSTEMS

### 3/4.7.2 CONTROL ROOM EMERGENCY OUTSIDE AIR SUPPLY SYSTEM

#### LIMITING CONDITION FOR OPERATION

---

3.7.2 Two independent control room emergency outside air supply system subsystems shall be OPERABLE with each subsystem consisting of:

- a. One makeup fan, and
- b. One filter train.

APPLICABILITY: ALL OPERATIONAL CONDITIONS and \*.

#### ACTION:

- a. In OPERATIONAL CONDITION 1, 2, or 3 with one control room emergency outside air supply subsystem inoperable, restore the inoperable subsystem to OPERABLE status within 7 days or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.
- b. In OPERATIONAL CONDITION 4, 5, or \*:
  1. With one control room emergency outside air supply subsystem inoperable, restore the inoperable subsystem to OPERABLE status within 7 days or initiate and maintain operation of the OPERABLE subsystem in the pressurization mode of operation.
  2. With both control room emergency outside air supply subsystems inoperable, suspend CORE ALTERATIONS, handling of irradiated fuel in the secondary containment and operations with a potential for draining the reactor vessel.
- c. The provisions of Specification 3.0.3 are not applicable in Operational Condition \*.

#### SURVEILLANCE REQUIREMENTS

---

4.7.2 Each control room emergency outside air supply subsystem shall be demonstrated OPERABLE:

- a. At least once per 31 days on a STAGGERED TEST BASIS by initiating, from the control room, flow through the HEPA filters and charcoal adsorbers and verifying that the subsystem operates for at least 10 hours with the heaters OPERABLE.
- b. At least once per 18 months or (1) after any structural maintenance on the HEPA filter or charcoal adsorber housings, or (2) following painting, fire, or chemical release in any ventilation zone communicating with the subsystem by:

---

\*When irradiated fuel is being handled in the secondary containment.

## PLANT SYSTEMS

### SURVEILLANCE REQUIREMENTS (Continued)

---

1. Verifying that the subsystem satisfies the in-place penetration and bypass leakage testing acceptance criteria of less than 0.05% and uses the test procedures of Regulatory Positions C.5.a, C.5.c, and C.5.d of Regulatory Guide 1.52, Revision 2, March 1978, and the system flow rate is 5810 cfm  $\pm$  10%.
  2. Verifying within 31 days after removal that a laboratory analysis of a representative carbon sample obtained in accordance with Regulatory Position C.6.b of Regulatory Guide 1.52, Revision 2, March 1978, meets the laboratory testing criteria of Regulatory Position C.6.a of Regulatory Guide 1.52, Revision 2, March 1978, for a methyl iodide penetration of less than 0.175%; and
  3. Verifying a subsystem flow rate of 5810 cfm  $\pm$  10% during subsystem operation when tested in accordance with ANSI N510-1975.
- c. After every 720 hours of charcoal adsorber operation by verifying within 31 days after removal that a laboratory analysis of a representative carbon sample obtained in accordance with Regulatory Position C.6.b of Regulatory Guide 1.52, Revision 2, March 1978, meets the laboratory testing criteria of Regulatory Position C.6.a of Regulatory Guide 1.52, Revision 2, March 1978, for a methyl iodide penetration of less than 0.75%.
- d. At least once per 18 months by:
1. Verifying that the pressure drop across the combined prefilter, upstream and downstream HEPA filters and charcoal adsorber banks is less than 9.1 inches Water Gauge while operating the subsystem at a flow rate of 5810 cfm  $\pm$  10%.
  2. Verifying that on each of the below isolation mode actuation test signals, the subsystem automatically switches to the isolation mode of operation and the isolation dampers close within 8 seconds:
    - a) Outside air intake chlorine - high,
    - b) Outside air intake radiation - high, and
    - c) Reactor Building isolation.
  3. Verifying that on each of the below pressurization mode actuation test signals, the subsystem automatically switches to the pressurization mode of operation and the control structure is maintained at a positive pressure of 1/8 inch W.G. relative to the outside atmosphere during subsystem operation at a flow rate less than or equal to 5810 cfm:
    - a) Reactor Building isolation, and
    - b) Outside air intake radiation - high.
  4. Verifying that the heaters dissipate 30  $\pm$  3.0 Kw when tested in accordance with ANSI N510-1975.

## PLANT SYSTEMS

### SURVEILLANCE REQUIREMENTS (Continued)

---

- e. After each complete or partial replacement of a HEPA filter bank by verifying that the HEPA filter bank satisfies the in-place penetration and bypass leakage testing acceptance criteria of less than 0.05% in accordance with ANSI N510-1975 for a DOP test aerosol while operating the system at a flow rate of 5810 cfm  $\pm$  10%.
- f. After each complete or partial replacement of a charcoal adsorber bank by verifying that the charcoal adsorber bank satisfies the in-place penetration and bypass leakage testing acceptance criteria of less than 0.05% in accordance with ANSI N510-1975 for a halogenated hydrocarbon refrigerant test gas while operating the system at a flow rate of 5810 cfm  $\pm$  10%.

## PLANT SYSTEMS

### 3/4.7.3 REACTOR CORE ISOLATION COOLING SYSTEM

#### LIMITING CONDITION FOR OPERATION

---

3.7.3 The reactor core isolation cooling (RCIC) system shall be OPERABLE with an OPERABLE flow path capable of taking suction from the suppression pool and transferring the water to the reactor pressure vessel.

APPLICABILITY: OPERATIONAL CONDITIONS 1, 2, and 3 with reactor steam dome pressure greater than 150 psig.

#### ACTION:

- a. With the condensate transfer pump discharge low pressure alarm instrumentation inoperable, monitor the CSS, LPCI, HPCI, and RCIC pressure locally at least once per 24 hours.
- b. With the RCIC system otherwise inoperable, operation may continue provided the HPCI system is OPERABLE; restore the RCIC system to OPERABLE status within 14 days or be in at least HOT SHUTDOWN within the next 12 hours and reduce reactor steam dome pressure to less than or equal to 150 psig within the following 24 hours.

#### SURVEILLANCE REQUIREMENTS

---

4.7.3 The RCIC system shall be demonstrated OPERABLE:

- a. At least once per 31 days by:
  1. Verifying that the system piping from the pump discharge valve to the system isolation valve is filled with water by:
    - a. Venting at the high point vents.
    - b. Performance a CHANNEL FUNCTIONAL TEST of the condensate transfer pump discharge low pressure alarm instrumentation.
  2. Verifying that each valve, manual, power operated or automatic in the flow path that is not locked, sealed or otherwise secured in position, is in its correct position.
  3. Verifying that the pump flow controller is in the correct position.
- b. At least once per 92 days by verifying that the RCIC pump develops a flow of greater than or equal to 600 gpm in the test flow path with a system head corresponding to reactor vessel operating pressure when steam is being supplied to the turbine at 920 + 140, - 0 psig.\*

---

\*The provisions of Specification 4.0.4 are not applicable provided the surveillance is performed within 12 hours after reactor steam pressure is adequate to perform the test.



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

SAFETY EVALUATION

AMENDMENT NO. 35 TO NPF-14 AND

AMENDMENT NO. 8 TO NPF-22

SUSQUEHANNA STEAM ELECTRIC STATION, UNITS 1 AND 2

DOCKET NOS. 50-387 AND 50-388

Introduction

The licensee proposed changes to Technical Specifications 4.6.5.3 and 4.7.2 of the operating license for the Susquehanna Steam Electric Station, Units 1 and 2. These changes regard HEPA filters and charcoal adsorber units to incorporate clarifications discussed in NRC Generic Letter No. 83-13.

Evaluation

In the licensee's September 28, 1984 submittal, proposed technical specification changes were aimed at clarifying surveillance testing requirements for engineered safety feature (ESF) charcoal and HEPA filters. In addition to referencing, the changes inserted the testing acceptance criteria specified in Regulatory Guide 1.52, Revision 2, into the technical specification surveillance testing equipment.

The staff finds that the proposed technical specification changes are acceptable and consistent with the testing requirements for ESF filter systems listed in Regulatory Guide 1.52.

Environmental Consideration

These amendments involve changes in the installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20. The staff has determined that these amendments involve no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that these amendments involve no significant hazards consideration and there has been no public comment on such finding. Accordingly, these amendments meet the eligibility criteria for categorical exclusion set forth in CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of these amendments.

8502250890 850215  
PDR ADOCK 05000387  
P PDR

Conclusion

We have concluded, based on the considerations discussed above, that:  
(1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (2) such activities will be conducted in compliance with the Commission's regulations and the issuance of these amendments will not be inimical to the common defense and security or to the health and safety of the public.

Dated: FEB 15 1985



AMENDMENT NO. 35 TO FACILITY OPERATING LICENSE NO. NPF-14 AND AMENDMENT NO. 8  
TO FACILITY OPERATING LICENSE NO. NPF-22 - SUSQUEHANNA STEAM ELECTRIC STATION,  
UNITS 1 AND 2 RESPECTIVELY

DISTRIBUTION:

Docket File 50-387  
NRC PDR  
Local PDR  
PRC System  
NSIC  
LB#2 Reading  
EHylton  
MJCampagnone  
TNovak  
JSaltzman, SAB  
OELD, Attorney  
CMiles  
HDenton  
JRutberg  
AToalston  
WMiller, LFMB  
NGrace  
EJordan  
LHarmon  
DBrinkman, SSPB  
TBarnhart(8)