

50-387

May 16, 1988

Posted  
Correction to  
Amdt 80  
to NPF-46

NOTE TO: DISTRIBUTION

FROM: PDI-2

The overleaf page 3/4 3-81 was incorrectly copied in Amendment No. 80.

Please replace the attached back-to-back pages 3/4 3-81 and 3/4 3-82, distributed in Amendment No. 80, with the attached pages.

DISTRIBUTION

Docket File  
NRC PDR  
LPDR  
PDI-2 Rdg.  
SVarga  
BBoger  
WButler  
MThadani(2)  
DFischer  
**MO'Brien(4)**  
RDiggs, ARM/LFMB  
OGC  
DHagan  
EJordan  
JPartlow  
TBarnhart(8)  
Wanda Jones  
EButcher  
RBlough  
ACRS (10)  
CMiles, GPA/PA  
BClayton

Correct  
B-to-B P.  
for am. 80.

May 3, 1988

Docket Nos. 50-387/388

Mr. Harold W. Keiser  
Senior Vice President-Nuclear  
Pennsylvania Power and Light Company  
2 North Ninth Street  
Allentown, Pennsylvania 18101

Dear Mr. Keiser:

DISTRIBUTION

Docket File	OGC	BClayton
NRC PDR	DHagan	
LPDR	EJordan	
PDI-2 Rdg.	JPartlow	
SVaroa	TRarnhart (8)	
RRoger	Wanda Jones	
WButler	EButcher	
MThadani(2)	RBlough	
DFischer	ACRS (10)	
MO'Brien(2)	CMiles, GPA/PA	
RDiggs, ARM/LFMB		

SUBJECT: TECHNICAL SPECIFICATION CHANGES RELATED TO RADIOLOGICAL EFFLUENT  
MONITORING AND COOLING TOWER BLOWDOWN INSTRUMENTATION  
(TAC NOS. 66925 and 66926)

RE: SUSQUEHANNA STEAM ELECTRIC STATION, UNITS 1 AND 2

The Commission has issued the enclosed Amendment No. 80 to Facility Operating License No. NPF-14 and Amendment No. 46 to Facility Operating License No. NPF-22 for the Susquehanna Steam Electric Station, Units 1 and 2. These amendments are in response to your letter dated December 15, 1987.

These amendments revise the Technical Specification related to operation of effluent monitor and sampling pump, and cooling tower blowdown instrumentation.

A copy of our Safety Evaluation is also enclosed. Notice of Issuance, will be included in the Commission's Biweekly Federal Register Notice.

Sincerely,

/S/

Walter R. Butler, Director  
Project Directorate I-2  
Division of Reactor Projects I/II  
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 80 to License No. NPF-14
2. Amendment No. 46 to License No. NPF-22
3. Safety Evaluation

cc w/enclosures:  
See next page

PDI-2/VA  
MO'Brien  
4/15/88

PDI-2/PM  
MThadani:mr  
4/15/88

PDI-2/D  
WButler  
5/3/88

OGC  
4/28/88

WMM  
4/15/88  
PDR  
OLynch  
4/15/88

## INSTRUMENTATION

### RADIOACTIVE LIQUID EFFLUENT MONITORING INSTRUMENTATION

#### LIMITING CONDITION FOR OPERATION

3.3.7.10 The radioactive liquid effluent monitoring instrumentation channels shown in Table 3.3.7.10-1 shall be OPERABLE with their alarm/trip setpoints set to ensure that the limits of Specification 3.11.1.1 are not exceeded. The alarm/trip setpoints of these channels shall be determined in accordance with the methodology and parameters described in the Offsite Dose Calculation Manual (ODCM).

APPLICABILITY: At all times.

#### ACTION:

- a. With a radioactive liquid effluent monitoring instrumentation channel alarm/trip setpoint less conservative than required by the above specification, immediately suspend the release of radioactive liquid effluents monitored by the affected channel or declare the channel inoperable.
- b. With less than the minimum number of radioactive liquid effluent monitoring instrumentation channels OPERABLE, take the ACTION shown in Table 3.3.7.10-1. Restore the inoperable instrumentation to OPERABLE status within the time specified in the ACTION or explain why this inoperability was not corrected in a timely manner in the next Semiannual Radioactive Effluent Release Report.
- c. The provisions of Specifications 3.0.3 and 3.0.4 are not applicable.

#### SURVEILLANCE REQUIREMENTS

4.3.7.10 Each radioactive liquid effluent monitoring instrumentation channel shall be demonstrated OPERABLE by performance of the CHANNEL CHECK, SOURCE CHECK, CHANNEL CALIBRATION and CHANNEL FUNCTIONAL TEST operations at the frequencies shown in Table 4.3.7.10-1.

TABLE 3.3.7.10-1

RADIOACTIVE LIQUID EFFLUENT MONITORING INSTRUMENTATION

<u>INSTRUMENT</u>		<u>MINIMUM CHANNELS OPERABLE</u>	<u>ACTION</u>
1.	GROSS RADIOACTIVITY MONITORS PROVIDING AUTOMATIC TERMINATION OF RELEASE		
a.	Liquid Radwaste Effluent Line*	1	100
2.	GROSS RADIOACTIVITY MONITORS NOT PROVIDING AUTOMATIC TERMINATION OF RELEASE		
a.	Service Water System Effluent Line	1	101
b.	RHR Service Water System Effluent Line	1/loop	101
3.	FLOW RATE MEASUREMENT DEVICES		
a.	Liquid Radwaste Effluent Line	1	102
b.	Cooling Tower Blowdown**	1	102

\*OPERABILITY of this monitor includes the proper functioning of the discharge valve interlocks (sample pump low flow, high radiation alarm, and radiation monitor failure).

\*\*OPERABILITY of this device includes the proper functioning of the Liquid Radwaste Effluent Line discharge valve interlock (i.e. cooling tower blowdown low flow).