

March 27, 1995

Mr. Robert G. Byram
Senior Vice President-Nuclear
Pennsylvania Power and Light
Company
2 North Ninth Street
Allentown, PA 18101

SUBJECT: POWER UPRATE WITH INCREASED CORE FLOW, SUSQUEHANNA STEAM ELECTRIC
STATION, UNIT 1 -CORRECTED TECHNICAL SPECIFICATION PAGES
(TAC NO. 90075)

Dear Mr. Byram:

On February 22, 1995, the Commission issued Amendment No. 143 to Facility
Operating License No. NPF-14 for the Susquehanna Steam Electric Station,
Unit 1. Due to an administrative error, Technical Specifications
Page 3/4 3-18 was not included in the amendment package and Page B 3/4 4-9 was
incomplete. Accordingly, I am providing the missing and updated pages for
your authority file.

If you have any questions concerning these changes, please contact me on
(301) 415-1402.

Sincerely,
original signed by
Chester Poslusny, Project Manager
Project Directorate I-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket Nos. 50-387

Enclosure: Corrected Pages

cc w/encl: See next page

DISTRIBUTION

Docket File	RZimmerman	WLeFave	JWhite, RGN-I
PUBLIC	GHill(2), P1-22	MRazzaque	WRussell
PDI-2 Reading	CGrimes, 11E-21	HGarg	FMiraglia
SVarga	CMcCracken	RGoel	ATHadani
JZwolinski	JWermiel	WLong	OPA
JStolz	RJones	CWu	OC/LFDCB
RClark(2)	RWessman	RStransky	
MO'Brien(2)	RBarrett	ACRS(4)	
OGC	CMiller		

OFFICE	PDI-2/LA	PDI-2/PM	PDI-2/D		
NAME	MO'Brien	CPoslusny:rb	JStolz		
DATE	3/27/95	3/27/95	3/27/95		

OFFICIAL RECORD COPY DOCUMENT NAME: SU90075.COR

300073
9503300199 950327
PDR ADOCK 05000387
P PDR

FILE CENTER COPY



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001
March 27, 1995

Mr. Robert G. Byram
Senior Vice President-Nuclear
Pennsylvania Power and Light
Company
2 North Ninth Street
Allentown, PA 18101

SUBJECT: POWER UPRATE WITH INCREASED CORE FLOW, SUSQUEHANNA STEAM ELECTRIC
STATION, UNIT 1 -CORRECTED TECHNICAL SPECIFICATION PAGES
(TAC NO. 90075)

Dear Mr. Byram:

On February 22, 1995, the Commission issued Amendment No. 143 to Facility Operating License No. NPF-14 for the Susquehanna Steam Electric Station, Unit 1. Due to an administrative error, Technical Specifications Page 3/4 3-18 was not included in the amendment package and Page B 3/4 4-9 was incomplete. Accordingly, I am providing the missing and updated pages for your authority file.

If you have any questions concerning these changes, please contact me on (301) 415-1402.

Sincerely,

Chester Poslusny
Chester Poslusny, Project Manager
Project Directorate I-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket Nos. 50-387

Enclosure: Corrected Pages

cc w/encl: See next page

Mr. Robert G. Byram
Pennsylvania Power & Light Company

Susquehanna Steam Electric Station,
Units 1 & 2

cc:

Jay Silberg, Esq.
Shaw, Pittman, Potts & Trowbridge
2300 N Street N.W.
Washington, D.C. 20037

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406

Bryan A. Snapp, Esq.
Assistant Corporate Counsel
Pennsylvania Power & Light Company
2 North Ninth Street
Allentown, Pennsylvania 18101

Mr. Harold G. Stanley
Vice President-Nuclear Operations
Susquehanna Steam Electric Station
Pennsylvania Power and Light Company
Box 467
Berwick, Pennsylvania 18603

Mr. J. M. Kenny
Licensing Group Supervisor
Pennsylvania Power & Light Company
2 North Ninth Street
Allentown, Pennsylvania 18101

Mr. Herbert D. Woodeshick
Special Office of the President
Pennsylvania Power and Light Company
Rural Route 1, Box 1797
Berwick, Pennsylvania 18603

Mrs. Maitri Banerjee
Senior Resident Inspector
U. S. Nuclear Regulatory Commission
P.O. Box 35
Berwick, Pennsylvania 18603-0035

George T. Jones
Vice President-Nuclear Engineering
Pennsylvania Power and Light Company
2 North Ninth Street
Allentown, Pennsylvania 18101

Mr. William P. Dornsife, Director
Bureau of Radiation Protection
Pennsylvania Department of
Environmental Resources
P. O. Box 8469
Harrisburg, Pennsylvania 17105-8469


Dr. Judith Johnsrud
National Energy Committee
Sierra Club
433 Orlando Avenue
State College, PA 16803

Mr. Jesse C. Tilton, III
Allegheny Elec. Cooperative, Inc.
212 Locust Street
P.O. Box 1266
Harrisburg, Pennsylvania 17108-1266

Chairman
Board of Supervisors
738 East Third Street
Berwick, PA 18603

TABLE 3.3.2-2 (Continued)
ISOLATION ACTUATION INSTRUMENTATION SETPOINTS

TRIP FUNCTION	TRIP SETPOINT	ALLOWABLE VALUE
MAIN STEAM LINE ISOLATION (Continued)		
e. Condenser Vacuum - Low	≥ 9.0 inches Hg vacuum	≥ 8.8 inches Hg vacuum
f. Reactor Building Main Steam Line Tunnel Temperature - High	≤ 177°F**	≤ 184°F**
g. Reactor Building Main Steam Line Tunnel Δ Temperature - High	≤ 99°F**	** ≤ 108°F
h. Manual Initiation	NA	NA
i. Turbine Building Main Steam Line Tunnel Temperature - High	≤ 197°F**	≤ 200°F**
4. REACTOR WATER CLEANUP SYSTEM ISOLATION		
a. RWCU Δ Flow - High	≤ 60 gpm	≤ 80 gpm
b. RWCU Area Temperature - High	≤ 147° F or 131°F [#]	≤ 154°F or 137°F [#]
c. RWCU/Area Ventilation Δ Temperature - High	≤ 69°F or 40.5°F [#]	≤ 72° F or 43.5°F [#]
d. SLCS Initiation	NA	NA
e. Reactor Vessel Water Level - Low Low, Level 2	≥ -38 inches [*]	≥ -45 inches
f. RWCU Flow - High	≤ 462 gpm	≤ 472 gpm
g. Manual Initiation	NA	NA
5. REACTOR CORE ISOLATION COOLING SYSTEM ISOLATION		
a. RCIC Steam Line Δ Pressure - High	≤ 188" H ₂ O	≤ 193" H ₂ O
b. RCIC Steam Supply Pressure - Low	≥ 60 psig	≥ 53 psig
c. RCIC Turbine Exhaust Diaphragm Pressure - High	≤ 10.0 psig	≤ 20.0 psig



7.6×10^{17}
@ 32 EFPY
40 Yrs. Operating

Service Life (Years*)
Fast Neutron Fluence (E > 1 MeV) at I.D. Surface as a Function of Service Life*
Bases Figure B 3/4.4.6-1

* Based on Power Uprate conditions as described in PLA-4127, dated May 19, 1994.