www.exeloncorp.com



Commonwealth Edison Company Quad Cities Generating Station 22710 206th Avenue North Cordova, IL 61242-9740

December 23, 2000

SVP-00-191

U. S. Nuclear Regulatory Commission ATTN: Document Control Desk Washington, D.C. 20555

> Quad Cities Generating Station, Unit 1 Facility Operating License No. DPR-29 NRC Docket No. 50-254

Subject: Licensee Event Report Concerning Automatic Reactor Scram from Low Reactor Vessel Level

Enclosed is Licensee Event Report (LER) 254/00-010, "Licensee Event Report Concerning Automatic Reactor Scram from Low Reactor Vessel Level" Revision 00, for Quad Cities Nuclear Power Station.

This report is submitted in accordance with the requirements of the Code of Federal Regulations, Title 10, Part 50.73(a)(2)(iv), which requires reporting of any operation or condition prohibited by the Plant's Technical Specifications

We are committing to the following actions:

The root cause determination for this event is in progress but has not been finalized. Upon completion of the root cause investigation, a supplemental report will be issued

Any other actions described in the submittal represent intended or planned actions by Commonwealth Edison (ComEd) Company. They are described for the NRC's information and are not regulatory commitments.

IE22

December 23, 2000 U.S. Nuclear Regulatory Commission Page 2

Should you have any questions concerning this letter, please contact Mr. C.C. Peterson at (309) 654-2241, extension 3609.

Respectfully,

Sunar P. Barnes, for

Joel P. Dimmette, Jr. Site Vice President Quad Cities Generating Station

cc: Regional Administrator – NRC Region III NRC Senior Resident Inspector – Quad Cities Generating Station December 23, 2000 U.S. Nuclear Regulatory Commission Page 3

bcc: Project Manager – NRR Office of Nuclear Facility Safety, - IDNS Senior Reactor Analyst - IDNS **Resident Inspector - IDNS** Manager of Energy Practice - Winston and Strawn Director, Licensing and Compliance - ComEd Vice President, Regulatory Services- ComEd ComEd Document Control Desk Licensing (Hard Copy) ComEd Document Control Desk Licensing (Electronic Copy) W. Leech – MidAmerican Energy Company D. Tubbs – MidAmerican Energy Company Regulatory Assurance Manager - Dresden Generating Station Regulatory Assurance Manager – Quad Cities Generating Station NRC Coordinator - Quad Cities Generating Station NSRB Site Coordinator – Quad Cities Generating Station Site Vice President - Quad Cities Generating Station Station Manager - Quad Cities Generating Station SVP Letter File

NRC FORM 366 U.S. NUCLEAR REGULATORY COMMISSION							APPROVED BY OMB NO. 3150-0104 EXPIRES 06/30/2001									
LICENSEE EVENT REPORT (LER)								Estimated burden per response to comply with this mandatory information collection request: 50 hrs Reported lessons learned are incorporated into the licensing process and fed back to industry. Forward comments regarding burden estimate to the information and Records Management Branch (t-6 f33), U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, and to the Paperwork Reduction Project (3150-0104), Office Of Management And Budget, Washington, DC 20503. If an information collection does not display a currently valid OMB control number, the NRC may not conduct or sponsor, and a person is not required to respond to, the information collection.								
FACILI	FACILITY NAME (1)									DOCKET NUMBER (2) PAGE (3)					(3)	F Q
Quad Cities Nuclear Power Station, Unit 1 05000254 1 of 3											<u> </u>					
Auto	matic	React	tor S	Scram fro	om Low Read	ctor Ves	sel Level				<u></u>					
E١	/ENT D/	ATE (5)		L	ER NUMBER (6	i)	REPO	ORT DA	ATE (7)) OTHER FACILITIES INVOLVED (8)						+
MON TH	DAY	YEAF	Ŕ	YEAR	SEQUENTIAL NUMBER	NUMBER	MONTH	DAY	YEA	R	FACILITY NAME			05000		мвен 0
12	06	200)0	2000	010	00	12	22	200	00	FACILITY NAME			05000		
OPEF	ATING			THIS REP	PORT IS SUBMI	TTED PU	IRSUANT T	O THE	REQU	REN	MENTS O	F 10 CFR § (Che	ck one	or more	e) (11)	
MOL)E (9)	1		20.2201(b)			20.2203(a	a)(2)(v)		50.73(a)(2)(i)			50.73(a)(2)(viii)		
PO	WER			20.2203(a)(i)			20.2203(a	a)(3)(i)			50.73(a)(2)(ii)			50.73(a)(2)(x)		
LEVF	EL (10)	100	2	20	2203(a)(2)(i))		20.2203(a	a)(3)(ii)		50.73(a)(2)(iii)			73.71		
				20	2203(a)(2)(ii)		20.2203(a)(4)		X		50.73(a)(2)(iv)			OTHER		
				20.2203(a)(2)(iii)			50.36(c)(1)				50.73(a)(2)(v)		Spe	pecity in Abstract below or in NRC Form 366A		
				20	2203(a)(2)(iv)		50.36(c)(2	2)		50.73(a)(2)(vii)						
						LICE	NSEE CON	TACT F	OR TH	IIS L	ER (12)					
NAME TELEPHONE NUMBER (Include Area Code) Charles Peterson, Regulatory Assurance Manager (309) 654-2241 ext 3609																
_				COMP	LETE ONE LINE	FOR EA	CH COMPC	NENT	FAILU	RED	DESCRIBE	D IN THIS REPO	ORT (1	3)		
CAUS	jE SY	SYSTEM CC		PONENT MANUFACTURER		ER	REPORTABLE TO EPIX		CAUSE		SYSTEM COMPONENT		M	MANUFACTURER		REPORTABLE TO EPIX
<u> </u>		\rightarrow								+						
<u> </u>			SU	PPLEMEN	TAL REPORT E	XPECTE	D (14)	100 B M		T	EX	PECTED	Т мо	NTH	DAY	YEAR
X YES (It use complete EXPECTED SLIBMISSION DATE)					C	SUBMISSION DATE (15)			C	2	07	2001				
ABSTI	RACT (Lim	it to 1400	space	es, i.e., approx	imately 15 single-spa	aced typewrit	ten lines) (16)			<u>ماير</u>		<u></u> }(1			
At 0940 hours on December 6, 2000, with reactor power at 100%, Unit One reactor water level started to decrease and the low level alarm was received. The operators took the Feedwater Level Control System (FWLC) out of three-element control and placed it in single-element control. They then took manual control of the 'B' Feedwater Regulating Valve (FWRV) and opened the valve, causing reactor level to increase. At about 0941 hours reactor level started to decrease rapidly and the 'A' FWRV locked up. A scram signal was received at 0942 hours, with indicated reactor water level at 20 inches. All automatic actions occurred consistent with a																

The root cause determination for this event is in progress but has not been finalized. Upon completion of the root cause investigation, a supplemental report will be issued.

The safety significance of this event was minimal. Although the event resulted in a reactor trip, all safety systems responded as designed.

NRC FORM 366A COMMISSION

U.S. NUCLEAR REGULATORY

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1)	DOCKET (2)		PAGE (3)		
		YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	
Quad Cities Nuclear Power Station, Unit 1	05000254	2000	010	00	2 of 3

TEXT (If more space is required, use additional copies of NRC Form 366A) (17)

PLANT AND SYSTEM IDENTIFICATION:

General Electric - Boiling Water Reactor - 2511 MWt rated core thermal power Energy Industry Identification System (EIIS) Codes are identified in the text as [XX] and are obtained from IEEE Standard 805-1984, IEEE Recommended Practice for System Identification in Nuclear Power Plants and Related Facilities.

EVENT IDENTIFICATION:

Automatic Reactor Scram from Low Reactor Vessel Level

A. PLANT CONDITIONS PRIOR TO EVENT:

Unit: 1	Event Date: December 6, 2000	Event Time: 0942 hours
Reactor Mode: 1	Mode Name: Power Operation	Power Level: 100%

Power Operation (1) - Mode switch in the RUN position with average reactor coolant temperature at any temperature.

B. DESCRIPTION OF EVENT:

At 0940 hours on December 6, 2000, with reactor power at 100%, Unit One reactor water level started to decrease and the low level alarm was received. The operators took the Feedwater Level Control System (FWLC) [JB] out of three-element control and placed it in single-element control. They then took manual control of the 'B' Feedwater Regulating Valve (FWRV) [LCV] and opened the valve, causing reactor level to increase. At about 0941 hours reactor level started to decrease rapidly and the 'A' FWRV locked up. A scram signal [JC] was received at 0942 hours, with indicated reactor water level at 20 inches. All automatic actions occurred consistent with a low-level trip.

C. CAUSE OF EVENT:

The root cause determination for this event is in progress but has not been finalized. Upon completion of the root cause investigation, a supplemental report will be issued.

D. SAFETY ANALYSIS

The safety significance of this event was minimal. Although the event resulted in a reactor trip, all safety systems responded as designed.

E. CORRECTIVE ACTIONS:

The root cause determination for this event is in progress but has not been finalized. Upon completion of the root cause investigation, a supplemental report will be issued.

NRC FORM 366A COMMISSION

(6-1998)

U.S. NUCLEAR REGULATORY

LICENSEE EVENT REPORT (LER)

	FACILITY NAME (1)	DOCKET (2)	ľ	PAGE (3)					
			YEAR	SEQUENTIAL NUMBER	REVISION NUMBER				
Quad	Cities Nuclear Power Station, Unit 1	05000254	2000	010	00	3 of 3			
TEXT (If m	ore space is required, use additional copies of NRC Form 366A) (17)								
i									
F	PREVIOUS OCCURRENCES:								
	Previous occurrences will be provided in the supplemental report.								
G.	COMPONENT FAILURE DATA:								
	Component failure data will be provided in the supplemental report.								
		•••							
	Component failure data will be provided in the s	supplemental repo	π.						