

February 28, 7

Mr. Robert G. Byram
Senior Vice President-Nuclear
Pennsylvania Power and Light
Company
2 North Ninth Street
Allentown, PA 18101

SUBJECT: NOTICE OF CONSIDERATION OF ISSUANCE OF AMENDMENTS TO FACILITY
OPERATING LICENSES AND OPPORTUNITY FOR A HEARING - SUSQUEHANNA
STEAM ELECTRIC STATION, UNITS 1 AND 2 (TAC NOS. M98005 AND M98006)

Dear Mr. Byram:

Enclosed is a copy of the subject notice for your information. This notice relates to your application dated February 11, 1997, for Susquehanna Steam Electric Station, Units 1 and 2. Your application proposes changes to the Technical Specifications for the two units to include sections that would define and permit the withdrawal of control rods in OPERATIONAL CONDITIONS 3 and 4, hot shutdown and cold shutdown, respectively, with reactor mode switch in the REFUEL position.

This notice will be forwarded to the Office of the Federal Register for publication.

Sincerely,

/S/ J. Stolz for

NRC FILE CENTER COPY

Chester Poslusny, Senior Project Manager
Project Directorate I-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket Nos. 50-387 and 50-388

Enclosure: Notice

cc w/encl: See next page

DISTRIBUTION

Socket File	MO'Brien	TLiu
PUBLIC	CPoslusny	
PDI-2 Reading	OGC	
SVarga/JZwolinski	ACRS	
JStolz	WPasciak, RGN-I	

OFFICE	PDI-2/PM	PDI-2/PM	PDI-2/LA	PDI-2/D	
NAME	TLiu <i>LL</i>	CPoslusny:cw	MO'Brien	JStolz	
DATE	2/27/97	2/27/97	2/27/97	2/28/97	

OFFICIAL RECORD COPY

DOCUMENT NAME: SUS98005.IND

9703060365 970228
PDR ADOCK 05000387
P PDR

CP-1



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

February 28, 1997

Mr. Robert G. Byram
Senior Vice President-Nuclear
Pennsylvania Power and Light
Company
2 North Ninth Street
Allentown, PA 18101

SUBJECT: NOTICE OF CONSIDERATION OF ISSUANCE OF AMENDMENTS TO FACILITY
OPERATING LICENSES AND OPPORTUNITY FOR A HEARING - SUSQUEHANNA
STEAM ELECTRIC STATION, UNITS 1 AND 2 (TAC NOS. M98005 AND M98006)

Dear Mr. Byram:

Enclosed is a copy of the subject notice for your information. This notice relates to your application dated February 11, 1997, for Susquehanna Steam Electric Station, Units 1 and 2. Your application proposes changes to the Technical Specifications for the two units to include sections that would define and permit the withdrawal of control rods in OPERATIONAL CONDITIONS 3 and 4, hot shutdown and cold shutdown, respectively, with reactor mode switch in the REFUEL position.

This notice will be forwarded to the Office of the Federal Register for publication.

Sincerely,

A handwritten signature in dark ink, appearing to read "Chester Poslusny", is written over a horizontal line.

Chester Poslusny, Senior Project Manager
Project Directorate I-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket Nos. 50-387 and 50-388

Enclosure: Notice

cc w/encl: See next page

Pennsylvania Power & Light Company

Units 1 & 2

cc:

Jay Silberg, Esq.
Shaw, Pittman, Potts & Trowbridge
2300 N Street N.W.
Washington, D.C. 20037

Bryan A. Snapp, Esq.
Assistant Corporate Counsel
Pennsylvania Power & Light Company
2 North Ninth Street
Allentown, Pennsylvania 18101

Mr. J. M. Kenny
Licensing Group Supervisor
Pennsylvania Power & Light Company
2 North Ninth Street
Allentown, Pennsylvania 18101

Mr. K. Jenison
Senior Resident Inspector
U. S. Nuclear Regulatory Commission
P.O. Box 35
Berwick, Pennsylvania 18603-0035

Mr. William P. Dornsife, Director
Bureau of Radiation Protection
Pennsylvania Department of
Environmental Resources
P. O. Box 8469
Harrisburg, Pennsylvania 17105-8469

Mr. Jesse C. Tilton, III
Allegheny Elec. Cooperative, Inc.
212 Locust Street
P.O. Box 1266
Harrisburg, Pennsylvania 17108-1266

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406

Mr. George Kuczynski
Plant Manager
Susquehanna Steam Electric Station
Pennsylvania Power and Light Company
Box 467
Berwick, Pennsylvania 18603

Mr. Herbert D. Woodeshick
Special Office of the President
Pennsylvania Power and Light Company
Rural Route 1, Box 1797
Berwick, Pennsylvania 18603

George T. Jones
Vice President-Nuclear Operations
Pennsylvania Power and Light Company
2 North Ninth Street
Allentown, Pennsylvania 18101

Dr. Judith Johnsrud
National Energy Committee
Sierra Club
433 Orlando Avenue
State College, PA 16803

Chairman
Board of Supervisors
738 East Third Street
Berwick, PA 18603

UNITED STATES NUCLEAR REGULATORY COMMISSIONPENNSYLVANIA POWER AND LIGHT COMPANYDOCKET NOS. 50-387 AND 50-388NOTICE OF CONSIDERATION OF ISSUANCE OF AMENDMENTS TO
FACILITY OPERATING LICENSES AND OPPORTUNITY FOR A HEARING

The U.S. Nuclear Regulatory Commission (the Commission) is considering issuance of amendments to Facility Operating License Nos. NPF-14 and NPF-22 issued to Pennsylvania Power & Light Company (PP&L, the licensee) for operation of the Susquehanna Steam Electric Station, Units 1 and 2, located in Luzerne County, Pennsylvania.

The proposed amendment would change the Technical Specifications (TSs) for the two units to include sections that would define and permit the withdrawal of control rods in OPERATIONAL CONDITIONS 3 and 4, hot shutdown and cold shutdown, respectively, with the reactor mode switch in the REFUEL position. These specific changes had been included in a submittal dated August 1, 1996, which was the conversion to the Improved Technical Specifications (ITS); but in this current application, the specific ITS Sections 3.10.3 and 3.10.4 have been reformatted for incorporation into the current TSs for each unit.

Before issuance of the proposed license amendment, the Commission will have made findings required by the Atomic Energy Act of 1954, as amended (the Act) and the Commission's regulations.

By April 4, 1997, the licensee may file a request for a hearing with respect to issuance of the amendment to the subject facility operating license and any person whose interest may be affected by this

proceeding and who wishes to participate as a party in the proceeding must file a written request for a hearing and a petition for leave to intervene. Requests for a hearing and a petition for leave to intervene shall be filed in accordance with the Commission's "Rules of Practice for Domestic Licensing Proceedings" in 10 CFR Part 2. Interested persons should consult a current copy of 10 CFR 2.714 which is available at the Commission's Public Document Room, the Gelman Building, 2120 L Street, NW., Washington, DC, and at the local public document room located at the Osterhout Free Library, Reference Department, 71 South Franklin Street, Wilkes-Barre, Pennsylvania. If a request for a hearing or petition for leave to intervene is filed by the above date, the Commission or an Atomic Safety and Licensing Board, designated by the Commission or by the Chairman of the Atomic Safety and Licensing Board Panel, will rule on the request and/or petition; and the Secretary or the designated Atomic Safety and Licensing Board will issue a notice of hearing or an appropriate order.

As required by 10 CFR 2.714, a petition for leave to intervene shall set forth with particularity the interest of the petitioner in the proceeding, and how that interest may be affected by the results of the proceeding. The petition should specifically explain the reasons why intervention should be permitted with particular reference to the following factors: (1) the nature of the petitioner's right under the Act to be made a party to the proceeding; (2) the nature and extent of the petitioner's property, financial, or other interest in the proceeding; and (3) the possible effect of any order which may be entered in the proceeding on the petitioner's interest. The petition should also identify the specific aspect(s) of the subject matter of the

proceeding as to which petitioner wishes to intervene. Any person who has filed a petition for leave to intervene or who has been admitted as a party may amend the petition without requesting leave of the Board up to 15 days prior to the first prehearing conference scheduled in the proceeding, but such an amended petition must satisfy the specificity requirements described above.

Not later than 15 days prior to the first prehearing conference scheduled in the proceeding, a petitioner shall file a supplement to the petition to intervene which must include a list of the contentions which are sought to be litigated in the matter. Each contention must consist of a specific statement of the issue of law or fact to be raised or controverted. In addition, the petitioner shall provide a brief explanation of the bases of the contention and a concise statement of the alleged facts or expert opinion which support the contention and on which the petitioner intends to rely in proving the contention at the hearing. The petitioner must also provide references to those specific sources and documents of which the petitioner is aware and on which the petitioner intends to rely to establish those facts or expert opinion. Petitioner must provide sufficient information to show that a genuine dispute exists with the applicant on a material issue of law or fact. Contentions shall be limited to matters within the scope of the amendment under consideration. The contention must be one which, if proven, would entitle the petitioner to relief. A petitioner who fails to file such a supplement which satisfies these requirements with respect to at least one contention will not be permitted to participate as a party.

Those permitted to intervene become parties to the proceeding, subject to any limitations in the order granting leave to intervene, and have the

opportunity to participate fully in the conduct of the hearing, including the opportunity to present evidence and cross-examine witnesses.

A request for a hearing or a petition for leave to intervene must be filed with the Secretary of the Commission, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, Attention: Docketing and Services Branch, or may be delivered to the Commission's Public Document Room, the Gelman Building, 2120 L Street, NW., Washington, DC, by the above date. Where petitions are filed during the last 10 days of the notice period, it is requested that the petitioner promptly so inform the Commission by a toll-free telephone call to Western Union at 1-(800) 248-5100 (in Missouri 1-(800) 342-6700). The Western Union operator should be given Datagram Identification Number N1023 and the following message addressed to John F. Stolz: petitioner's name and telephone number; date petition was mailed; plant name; and publication date and page number of this FEDERAL REGISTER notice. A copy of the petition should also be sent to the Office of the General Counsel, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, and to Jay Silberg, Esquire, Shaw, Pittman, Potts and Trowbridge, 2300 N Street NW, Washington, DC 20037, attorney for the licensee.

Nontimely filings of petitions for leave to intervene, amended petitions, supplemental petitions and/or requests for hearing will not be entertained absent a determination by the Commission, the presiding officer or


the presiding Atomic Safety and Licensing Board that the petition and/or request should be granted based upon a balancing of the factors specified in 10 CFR 2.714(a)(1)(i)-(v) and 2.714(d).

If a request for a hearing is received, the Commission's staff may issue the amendments after it completes its technical review and prior to the completion of any required hearing if it publishes a further notice for public comment of its proposed finding of no significant hazards consideration in accordance with 10 CFR 50.91 and 50.92.

For further details with respect to this action, see the application for amendments dated February 11, 1997, which is available for public inspection at the Commission's Public Document Room, the Gelman Building, 2120 L Street, NW., Washington, DC, and at the local public document room located at the Osterhout Free Library, Reference Department, 71 South Franklin Street, Wilkes-Barre, Pennsylvania.

Dated at Rockville, Maryland, this 28th day of February 1997.

FOR THE NUCLEAR REGULATORY COMMISSION

A handwritten signature in cursive script, appearing to read "John F. Stolz".

John F. Stolz, Director
Project Directorate I-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation