

December 20, 1994

Mr. Robert G. Byram
Senior Vice President-Nuclear
Pennsylvania Power and Light Company
2 North Ninth Street
Allentown, PA 18101

SUBJECT: SUSQUEHANNA STEAM ELECTRIC STATION, UNITS 1 AND 2
(TAC NOS. M89666 & M89667)

Dear Mr. Byram:

The Commission has issued the enclosed Amendment No. 136 to Facility Operating License No. NPF-14 and Amendment No. 106 to Facility Operating License No. NPF-22 for the Susquehanna Steam Electric Station, Units 1 and 2. These amendments are in response to your letter dated July 19, 1994.

These amendments change Technical Specification 3.1.5 for each unit for the standby liquid control system (SLCS) to remove the operability requirement for the SLCS while the plant is in Operational Condition 5 (refueling) with any control rod withdrawn, and to delete the 18-month system surveillance requirement, 4.1.5.d.3.

A copy of our Safety Evaluation is also enclosed. Notice of Issuance will be included in the Commission's Biweekly Federal Register Notice.

Sincerely,
/s/

Chester Poslusny, Senior Project Manager
Project Directorate I-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket Nos. 50-387/50-388

Enclosures:

1. Amendment No. 136 to License No. NPF-14
2. Amendment No. 106 to License No. NPF-22
3. Safety Evaluation

cc w/encls:
See next page

DISTRIBUTION:

| | | |
|---------------|-------------|---------------|
| Docket File | MO'Brien(2) | CGrimes |
| PUBLIC | CPoslusny | ACubbage |
| PDI-2 Reading | OGC | ACRS(4) |
| SVarga | OPA | OC/LFDCB |
| JZwolinski | GHill(4) | JWhite, RGN-I |
| JStolz | RJones | |

THIS FILE CONTAINS COPY

| | | | | | | |
|------|------------|-------------|------------|------------|------------|---|
| OFC | : PDI-2/LA | : PDI-2/PM | : SRXB | : OGC | : PDI-2/D | : |
| NAME | : MO'Brien | : CPoslusny | : RJones | : M20864 | : JStolz | : |
| DATE | : 12/16/94 | : 12/17/94 | : 12/17/94 | : 12/17/94 | : 12/19/94 | : |

OFFICIAL RECORD COPY
FILENAME: SU89666.AMD

9501050325 941220
PDR ADOCK 05000387
P PDR

↓ sub feed
rod ed
collations

JFOI



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

December 20, 1994

Mr. Robert G. Byram
Senior Vice President-Nuclear
Pennsylvania Power and Light Company
2 North Ninth Street
Allentown, PA 18101

SUBJECT: SUSQUEHANNA STEAM ELECTRIC STATION, UNITS 1 AND 2
(TAC NOS. M89666 & M89667)

Dear Mr. Byram:

The Commission has issued the enclosed Amendment No. 136 to Facility Operating License No. NPF-14 and Amendment No. 106 to Facility Operating License No. NPF-22 for the Susquehanna Steam Electric Station, Units 1 and 2. These amendments are in response to your letter dated July 19, 1994.

These amendments change Technical Specification 3.1.5 for each unit for the standby liquid control system (SLCS) to remove the operability requirement for the SLCS while the plant is in Operational Condition 5 (refueling) with any control rod withdrawn, and to delete the 18-month system surveillance requirement, 4.1.5.d.3.

A copy of our Safety Evaluation is also enclosed. Notice of Issuance will be included in the Commission's Biweekly Federal Register Notice.

Sincerely,

A handwritten signature in cursive script that reads "Chester Poslusny".

Chester Poslusny, Senior Project Manager
Project Directorate I-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket Nos. 50-387/50-388

Enclosures:

1. Amendment No. 136 to License No. NPF-14
2. Amendment No. 106 to License No. NPF-22
3. Safety Evaluation

cc w/encls:
See next page

Mr. Robert G. Byram
Pennsylvania Power & Light Company

Susquehanna Steam Electric Station,
Units 1 & 2

cc:

Jay Silberg, Esq.
Shaw, Pittman, Potts & Trowbridge
2300 N Street N.W.
Washington, D.C. 20037

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406

Bryan A. Snapp, Esq.
Assistant Corporate Counsel
Pennsylvania Power & Light Company
2 North Ninth Street
Allentown, Pennsylvania 18101

Mr. Harold G. Stanley
Vice President-Nuclear Operations
Susquehanna Steam Electric Station
Pennsylvania Power and Light Company
Box 467
Berwick, Pennsylvania 18603

Mr. J. M. Kenny
Licensing Group Supervisor
Pennsylvania Power & Light Company
2 North Ninth Street
Allentown, Pennsylvania 18101

Mr. Herbert D. Woodeshick
Special Office of the President
Pennsylvania Power and Light Company
Rural Route 1, Box 1797
Berwick, Pennsylvania 18603

Mr. Scott Barber
Senior Resident Inspector
U. S. Nuclear Regulatory Commission
P.O. Box 35
Berwick, Pennsylvania 18603-0035

George T. Jones
Vice President-Nuclear Engineering
Pennsylvania Power and Light Company
2 North Ninth Street
Allentown, Pennsylvania 18101

Mr. William P. Dornsife, Director
Bureau of Radiation Protection
Pennsylvania Department of
Environmental Resources
P. O. Box 8469
Harrisburg, Pennsylvania 17105-8469

Dr. Judith Johnsrud
National Energy Committee
Sierra Club
433 Orlando Avenue
State College, PA 16803

Mr. Jesse C. Tilton, III
Allegheny Elec. Cooperative, Inc.
212 Locust Street
P.O. Box 1266
Harrisburg, Pennsylvania 17108-1266



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

PENNSYLVANIA POWER & LIGHT COMPANY

ALLEGHENY ELECTRIC COOPERATIVE, INC.

DOCKET NO. 50-387

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 136
License No. NPF-14

1. The Nuclear Regulatory Commission (the Commission or the NRC) having found that:
 - A. The application for the amendment filed by the Pennsylvania Power & Light Company, dated July 19, 1994, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

9501050331 941220
PDR ADOCK 05000387
P PDR

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of the Facility Operating License No. NPF-14 is hereby amended to read as follows:

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 136 and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. PP&L shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance and is to be implemented within 30 days after its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



John F. Stolz, Director
Project Directorate 1-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: December 20, 1994

ATTACHMENT TO LICENSE AMENDMENT NO. 136

FACILITY OPERATING LICENSE NO. NPF-14

DOCKET NO. 50-387

Replace the following pages of the Appendix A Technical Specifications with enclosed pages. The revised pages are identified by Amendment number and contain vertical lines indicating the area of change.

REMOVE

3/4 1-19

3/4 1-20

INSERT

3/4 1-19

3/4 1-20

REACTIVITY CONTROL SYSTEMS

3/4.1.5 STANDBY LIQUID CONTROL SYSTEM

LIMITING CONDITION FOR OPERATION

3.1.5 The standby liquid control system shall be OPERABLE.

APPLICABILITY: OPERATIONAL CONDITIONS 1, 2.

ACTION:

- a. In OPERATIONAL CONDITION 1 or 2:
 1. With one pump and/or one explosive valve inoperable, restore the inoperable pump and/or explosive valve to OPERABLE status within 7 days or be in at least HOT SHUTDOWN within the next 12 hours.
 2. With the standby liquid control system otherwise inoperable, restore the system to OPERABLE status within 8 hours or be in at least HOT SHUTDOWN within the next 12 hours.

SURVEILLANCE REQUIREMENTS

4.1.5 The standby liquid control system shall be demonstrated OPERABLE:

- a. At least once per 24 hours by verifying that:
 1. The temperature of the sodium pentaborate solution is within the limits of Figure 3.1.5-1.
 2. The available volume of sodium pentaborate solution is within the limits of Figure 3.1.5-2.
 3. The heat tracing circuit is OPERABLE by actuating the test feature and determining that the power available light on the local heat tracing panel energizes.

REACTIVITY CONTROL SYSTEMS

SURVEILLANCE REQUIREMENTS (Continued)

- b. At least once per 31 days by;
 - 1. Verifying the continuity of the explosive charge.
 - 2. Determining that the available weight of sodium pentaborate is greater than or equal to 5500 lbs and the concentration of boron in solution is within the limits of Figure 3.1.5-2 by chemical analysis.
 - 3. Verifying that each valve, manual, power operated or automatic, in the flow path that is not locked, sealed, or otherwise secured in position, is in its correct position.

- c. Demonstrating that, when tested pursuant to Specification 4.0.5, the minimum flow requirement of 41.2 gpm at a pressure of greater than or equal to 1190 psig is met.

- d. At least once per 18 months during shutdown by;
 - 1. Initiating one of the standby liquid control system loops, including an explosive valve, and verifying that a flow path from the pumps to the reactor pressure vessel is available by pumping demineralized water into the reactor vessel. The replacement charge for the explosive valve shall be from the same manufactured batch as the one fired or from another batch which has been certified by having one of that batch successfully fired. Both injection loops shall be tested in 36 months.
 - 2. ** Demonstrating that all heat traced piping is unblocked by pumping from the storage tank to the test tank and then draining and flushing the discharge piping and test tank with demineralized water.

* This test shall also be performed anytime water or boron is added to the solution or when the solution temperature drops below the limit of Figure 3.1.5-1.

** This test shall also be performed whenever both heat tracing circuits have been found to be inoperable and may be performed by any series of sequential, overlapping or total flow steps such that the entire flow path is included.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

PENNSYLVANIA POWER & LIGHT COMPANY

ALLEGHENY ELECTRIC COOPERATIVE, INC.

DOCKET NO. 50-388

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 106
License No. NPF-22

1. The Nuclear Regulatory Commission (the Commission or the NRC) having found that:
 - A. The application for the amendment filed by the Pennsylvania Power & Light Company, dated July 19, 1994, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of the Facility Operating License No. NPF-22 is hereby amended to read as follows:

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 106 and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. PP&L shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance and is to be implemented within 30 days after its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



John F. Stolz, Director
Project Directorate I-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: December 20, 1994

ATTACHMENT TO LICENSE AMENDMENT NO. 106

FACILITY OPERATING LICENSE NO. NPF-22

DOCKET NO. 50-388

Replace the following pages of the Appendix A Technical Specifications with enclosed pages. The revised pages are identified by Amendment number and contain vertical lines indicating the area of change.

REMOVE

3/4 1-19

3/4 1-20

INSERT

3/4 1-19

3/4 1-20

REACTIVITY CONTROL SYSTEMS

3/4.1.5 STANDBY LIQUID CONTROL SYSTEM

LIMITING CONDITION FOR OPERATION

3.1.5 The standby liquid control system shall be OPERABLE.

APPLICABILITY: OPERATIONAL CONDITIONS 1, 2.

ACTION:

- a. In OPERATIONAL CONDITION 1 or 2:
 1. With one pump and/or one explosive valve inoperable, restore the inoperable pump and/or explosive valve to OPERABLE status within 7 days or be in at least HOT SHUTDOWN within the next 12 hours.
 2. With the standby liquid control system otherwise inoperable, restore the system to OPERABLE status within 8 hours or be in at least HOT SHUTDOWN within the next 12 hours.

SURVEILLANCE REQUIREMENTS

4.1.5 The standby liquid control system shall be demonstrated OPERABLE:

- a. At least once per 24 hours by verifying that;
 1. The temperature of the sodium pentaborate solution is within the limits of Figure 3.1.5-1.
 2. The available volume of sodium pentaborate solution is within the limits of Figure 3.1.5-2.
 3. The heat tracing circuit is OPERABLE by actuating the test feature and determining that the power available light on the local heat tracing panel energizes.

REACTIVITY CONTROL SYSTEMS

SURVEILLANCE REQUIREMENTS (Continued)

- b. At least once per 31 days by;
 - 1. Verifying the continuity of the explosive charge.
 - 2. Determining that the available weight of sodium pentaborate is greater than or equal to 5500 lbs and the concentration of boron in solution is within the limits of Figure 3.1.5-2 by chemical analysis.
 - 3. Verifying that each valve, manual, power operated or automatic, in the flow path that is not locked, sealed, or otherwise secured in position, is in its correct position.

- c. Demonstrating that, when tested pursuant to Specification 4.0.5, the minimum flow requirement of 41.2 gpm at a pressure of greater than or equal to 1124 psig is met.

- d. At least once per 18 months during shutdown by;
 - 1. Initiating one of the standby liquid control system loops, including an explosive valve, and verifying that a flow path from the pumps to the reactor pressure vessel is available by pumping demineralized water into the reactor vessel. The replacement charge for the explosive valve shall be from the same manufactured batch as the one fired or from another batch which has been certified by having one of that batch successfully fired. Both injection loops shall be tested in 36 months.
 - 2. ** Demonstrating that all heat traced piping is unblocked by pumping from the storage tank to the test tank and then draining and flushing the discharge piping and test tank with demineralized water.

* This test shall also be performed anytime water or boron is added to the solution or when the solution temperature drops below the limit of Figure 3.1.5-1.

** This test shall also be performed whenever both heat tracing circuits have been found to be inoperable and may be performed by any series of sequential, overlapping or total flow steps such that the entire flow path is included.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION
RELATED TO AMENDMENT NO.136 TO FACILITY OPERATING LICENSE NO. NPF-14
AMENDMENT NO.106 TO FACILITY OPERATING LICENSE NO. NPF-22
PENNSYLVANIA POWER & LIGHT COMPANY
ALLEGHENY ELECTRIC COOPERATIVE, INC.
SUSQUEHANNA STEAM ELECTRIC STATION, UNITS 1 AND 2
DOCKET NOS. 50-387 AND 388

1.0 INTRODUCTION

By letter dated July 19, 1994, Pennsylvania Power & Light Company (PP&L or the licensee) submitted a request to amend the Technical Specifications for Susquehanna Units 1 and 2. The proposed Technical Specification change involves the requirement for operability of the Standby Liquid Control (SLC) system in operational condition 5 with any control rod withdrawn and the surveillance requirements for the SLC system tank heaters.

The current Technical Specification (TS) 3.1.5 for Susquehanna Units 1 and 2 requires that the SLC systems be operable during operational condition 5 with any control rod withdrawn (OPCON 5). The current TS also requires an operability check on the SLC system tank heaters every 18 months per Surveillance Requirement 4.1.5.d.3. The licensee has proposed to delete both the requirement for SLC system operability during OPCON 5 and the 18-month surveillance requirement for the SLC system tank heaters. The staff has reviewed this proposed TS change and our evaluation follows.

2.0 EVALUATION

2.1 SLC System Operability in OPCON 5*

The purpose of the SLC system is to provide a backup means to shutdown the reactor from full power to a cold, xenon-free shutdown condition, assuming that none of the withdrawn control rods can be inserted. General Design Criteria (GDC) 26 and 27 contain guidance for the purpose and capability of the SLC system.

GDC 26 discusses reactivity control system redundancy and capability. It states that two independent systems shall be provided, and that one of the systems shall be capable of holding the reactor core subcritical under cold conditions. Compliance with this design criteria is accomplished for Susquehanna with the control rod system and the reactor recirculation system. The control rod system has the capability to maintain the reactor subcritical under cold conditions regardless of the reactor water level assuming that the

highest worth control rod is withdrawn from the core. In the event that additional control rods were withdrawn, the reactor protection system (RPS) would respond and insert all control rods prior to reaching criticality. During OPGON 5*, the RPS monitors recriticality with source range monitors (SRMs), intermediate range monitors (IRMs) and average power range monitors (APRMs). GDC 27 discusses combined reactivity control system capability. The criteria states that the reactivity control systems shall be designed to have a combined capability, in conjunction with poison addition by the emergency core cooling system, of reliably controlling reactivity changes to assure that under postulated accident conditions and with the appropriate margin for stuck rods, the capability to cool the core is maintained. However, the Susquehanna Final Safety Analysis Report Section 3.1.2.3.8, which discusses design conformance to GDC 27, states that there is no credible event applicable to the BWR which requires combined capability of the control rod system and poison additions by the emergency core cooling network. The primary reactivity control system for the BWR during postulated accident conditions is the control rod system. In the event that more than one control rods fails to insert, and the core cannot be maintained in a subcritical condition by control rods alone as the reactor is cooled subsequent to initial shutdown, the SLC system will be actuated to insert soluble boron into the reactor core to achieve and maintain a subcritical condition. This scenario is anticipated transient without scram (ATWS). The function described above for the SLC system, ATWS mitigation, is the design purpose for SLC in OPGONS 1 and 2.

Pursuant to 10 CFR 50.62, requirements are provided for reduction of risk from ATWS events for light-water-cooled nuclear power plants. It is required by 50.62(c)(4) that each boiling water reactor must have an SLC system, and provide requirements for the design of the SLC system. The SLC system at Susquehanna meets this regulatory requirement. Operability of the SLC system in OPGON 5* is not required for Susquehanna to meet their licensing basis.

In OPGON 5*, adequate shutdown margin (SDM) and redundancy are maintained by systems and control independent of the SLC system. Adequate SDM is maintained during OPGON 5* through design and administrative control. In addition, the RPS monitors for recriticality and scrams the reactor before a return to criticality. There are four conditions during OPGON 5* which involve SDM: (1) the shutdown phase prior to core offload; (2) core off-loading; (3) core reloading; and (4) full core reloaded. During the first condition, adequate SDM is assured via the SDM demonstration which was performed when the core was loaded. During core off-loading, adequate SDM is maintained or increased as required by TS 3.1.1 and implemented through procedural controls. Fuel movement and other core alterations with control rods removed from the core are controlled by TS Section 3/4.9, Refueling Operations. Prior to core reload, SDM is determined analytically, and the calculated SDM is the acceptance criteria used in TS Surveillance requirement 4.1.1. The TS surveillance requirement, refueling interlocks, and procedural controls assure that inadvertent criticality will not occur during core reload. TS 3.10.3, SDM demonstration, establishes additional controls after core reload so that

no more than one control rod can be withdrawn. In the event that inadvertent criticality occurs at this time, this additional control ensures that the RPS system would scram the reactor. Therefore, SLC operability in OPCON 5* does not impact the ability to maintain SDM.

The SLC system is not designed to terminate an inadvertent criticality event during core alterations (OPCON 5)* with the vessel water level at least 22 feet above the top of the vessel flange. The amount of sodium pentaborate solution in the SLC system is based on normal power operating vessel level, and with the reactor cavity flooded, the amount of sodium pentaborate solution may not be adequate to prevent recriticality.

Therefore, based on the above evaluation, the staff has determined that the SLC system is not required to be operable in OPCON 5* and that the associated action statement can be removed from the TS. This proposed TS change is consistent with the Improved Standard Technical Specifications, NUREG-1434, issued September 28, 1992.

2.2 SLC System Tank Heaters Surveillance

The purpose of the SLC system tank heaters is to maintain the temperature of the tank high enough to prevent the boric acid from precipitating out of solution, and to maintain the tank temperature while chemicals are being mixed. During steady state operation, heater 'A' is used to maintain tank temperature between 85°F and 95°F. Typically both heaters are used during chemical mixing which is an endothermic reaction.

Currently the TS require that an 18-month operability test be performed on the heaters. The test is performed by recording the initial tank temperature, energizing both heaters for 2 hours, and recording the temperature rise. A 2 °F rise in tank temperature is required to demonstrate operability of the heaters.

The operability of heater 'A' is also verified by other means, TS Surveillance Requirement 4.1.5.a.1 and a control room alarm. Surveillance Requirement 4.1.5.a.1 is performed daily, and requires that the temperature of the sodium pentaborate solution be within the acceptance range for the solution concentration. Failure of tank heater 'A' would be detected by gradually decreasing tank temperature recorded during the surveillance. In addition, the tank temperature is monitored by a control room alarm. In the event of heater failure, it is not likely that a drastic reduction of tank temperature below the acceptance value of 70 °F would result, due to the average ambient temperature in the area of the tanks which is approximately 80 °F.

The operability of heater 'B', which is used during chemical addition and mixing, is verified by the procedure used when adding chemicals to the tank. Prior to adding chemicals to the tank, the procedure instructs the operator to turn on heater 'B' and verify that the tank temperature increases to above

100 °F from its normal temperature of 85 °F to 95 °F, thereby verifying the operability of the 'B' heater. The procedure also instructs the operator to ensure that the solution temperature does not decrease below 100 °F during the chemical addition. The control room alarm provides further verification of heater operability, since heater operation is required to maintain tank temperature during chemical addition.

The 18-month surveillance requirement for SLC system tank heater operability is redundant to other surveillance requirements, procedures and controls which verify the operability of both the 'A' and 'B' heaters. Further the 18-month heater surveillance requirement does not ensure that the SLC tank solution temperature is maintained in the TS acceptance range. This is verified by SLC solution temperature measurements. Lastly, ambient temperatures in the SLC area are likely to maintain the SLC solution temperature in the acceptance range or prevent a rapid decrease in solution temperature.

The staff has reviewed the licensee submittal requesting a TS change involving the requirement for operability of the Standby Liquid Control (SLC) system in operational condition 5 with any control rod withdrawn and the surveillance requirements for the SLC system tank heaters.

Based on the reasons discussed above, the staff finds this proposed TS change to be acceptable. This proposed TS change is consistent with the Improved Standard Technical Specifications, NUREG-1434, issued September 28, 1992.

3.0 STATE CONSULTATION

In accordance with the Commission's regulations, the Pennsylvania State official was notified of the proposed issuance of the amendments. The State official had no comments.

4.0 ENVIRONMENTAL CONSIDERATION

The amendments change a requirement with respect to installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20. The NRC staff has determined that the amendments involve no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that the amendments involve no significant hazards consideration, and there has been no public comment on such finding (59 FR 42344). Accordingly, the amendments meet eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendments.

The Commission has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendments will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: A. Cabbage

Date: December 20, 1994