

August 22, 1995

Mr. Robert G. Byram
Senior Vice President-Nuclear
Pennsylvania Power and Light
Company
2 North Ninth Street
Allentown, PA 18101

SUBJECT: CORRECTION OF A BIWEEKLY NOTICE, SUSQUEHANNA STEAM ELECTRIC STATION,
UNITS 1 AND 2 (TAC NOS. M91664 AND M91665)

Dear Mr. Byram:

Enclosed is a Correction which will be published in the Federal Register. The March 29, 1995, Federal Register contained a "Notice of Consideration of Issuance of Amendment to Facility Operating License, Proposed No Significant Hazards Consideration Determination, and Opportunity for a Hearing," for the Susquehanna Steam Electric Station, Units 1 and 2. This notice corrects the notice published in the Federal Register on March 29, 1995, (60 FR 16192). The second sentence of the description section should read as follows: Specifically, for the refueling floor exhaust duct and wall exhaust duct radiation monitors, the proposed change would modify the applicable operational condition during specific control rod testing evolutions which are core alterations and would indicate that the operability requirement change does not apply during shutdown margin demonstrations.

Sincerely,

Original signed by:

Chester Poslusny, Senior Project Manager
Project Directorate I-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket No. 50-387/388

Enclosure: Notice

cc w/encl: See next page

DISTRIBUTION:

~~Public File~~ JStolz
PUBLIC CPoslusny
PDI-2 r/f OGC
SVarga MO'Brien (2) *CP*

OFFICE	PDI-2/LA <i>MB</i>	PDI-2/PM	PDI-2/D <i>CP</i>		
NAME	MO'Brien	CPoslusny:mw	JStolz		
DATE	8/16/95	8/18/95	8/27/95		

OFFICIAL RECORD COPY
DOCUMENT NAME: SUM91664.LTR

150021
9508250290 950822
PDR ADOCK 05000387
P PDR

DFE1

August 22, 1995

Mr. Robert G. Byram
Senior Vice President-Nuclear
Pennsylvania Power and Light
Company
2 North Ninth Street
Allentown, PA 18101

SUBJECT: CORRECTION OF A BIWEEKLY NOTICE, SUSQUEHANNA STEAM ELECTRIC STATION,
UNITS 1 AND 2 (TAC NOS. M91664 AND M91665)

Dear Mr. Byram:

Enclosed is a Correction which will be published in the Federal Register. The March 29, 1995, Federal Register contained a "Notice of Consideration of Issuance of Amendment to Facility Operating License, Proposed No Significant Hazards Consideration Determination, and Opportunity for a Hearing," for the Susquehanna Steam Electric Station, Units 1 and 2. This notice corrects the notice published in the Federal Register on March 29, 1995, (60 FR 16192). The second sentence of the description section should read as follows: Specifically, for the refueling floor exhaust duct and wall exhaust duct radiation monitors, the proposed change would modify the applicable operational condition during specific control rod testing evolutions which are core alterations and would indicate that the operability requirement change does not apply during shutdown margin demonstrations.

Sincerely,

Original signed by:

Chester Poslusny, Senior Project Manager
Project Directorate I-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket No. 50-387/388

Enclosure: Notice

cc w/encl: See next page

DISTRIBUTION:

Docket File JStolz
PUBLIC CPoslusny
PDI-2 r/f OGC
SVarga MO'Brien (2) *CP*

OFFICE	PDI-2/LA <i>MB</i>	PDI-2/PM	PDI-2/D <i>CP</i>		
NAME	MO'Brien	CPoslusny:mw	JStolz		
DATE	8/16/95	8/18/95	8/27/95		

OFFICIAL RECORD COPY
DOCUMENT NAME: SUM91664.LTR



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

August 22, 1995

Mr. Robert G. Byram
Senior Vice President-Nuclear
Pennsylvania Power and Light
Company
2 North Ninth Street
Allentown, PA 18101

SUBJECT: CORRECTION OF A BIWEEKLY NOTICE, SUSQUEHANNA STEAM ELECTRIC STATION,
UNITS 1 AND 2 (TAC NOS. M91664 AND M91665)

Dear Mr. Byram:

Enclosed is a Correction which will be published in the Federal Register. The March 29, 1995, Federal Register contained a "Notice of Consideration of Issuance of Amendment to Facility Operating License, Proposed No Significant Hazards Consideration Determination, and Opportunity for a Hearing," for the Susquehanna Steam Electric Station, Units 1 and 2. This notice corrects the notice published in the Federal Register on March 29, 1995, (60 FR 16192). The second sentence of the description section should read as follows: Specifically, for the refueling floor exhaust duct and wall exhaust duct radiation monitors, the proposed change would modify the applicable operational condition during specific control rod testing evolutions which are core alterations and would indicate that the operability requirement change does not apply during shutdown margin demonstrations.

Sincerely,

A handwritten signature in cursive script, reading "Chester Poslusny", is written above the typed name.

Chester Poslusny, Senior Project Manager
Project Directorate I-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket No. 50-387/388

Enclosure: Notice

cc w/encl: See next page

Mr. Robert G. Byram
Pennsylvania Power & Light Company

Susquehanna Steam Electric Station,
Units 1 & 2

cc:

Jay Silberg, Esq.
Shaw, Pittman, Potts & Trowbridge
2300 N Street N.W.
Washington, D.C. 20037

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406

Bryan A. Snapp, Esq.
Assistant Corporate Counsel
Pennsylvania Power & Light Company
2 North Ninth Street
Allentown, Pennsylvania 18101

Mr. Harold G. Stanley
Vice President-Nuclear Operations
Susquehanna Steam Electric Station
Pennsylvania Power and Light Company
Box 467
Berwick, Pennsylvania 18603

Mr. J. M. Kenny
Licensing Group Supervisor
Pennsylvania Power & Light Company
2 North Ninth Street
Allentown, Pennsylvania 18101

Mr. Herbert D. Woodeshick
Special Office of the President
Pennsylvania Power and Light Company
Rural Route 1, Box 1797
Berwick, Pennsylvania 18603

Mrs. Maitri Banerjee
Senior Resident Inspector
U. S. Nuclear Regulatory Commission
P.O. Box 35
Berwick, Pennsylvania 18603-0035

George T. Jones
Vice President-Nuclear Engineering
Pennsylvania Power and Light Company
2 North Ninth Street
Allentown, Pennsylvania 18101

Mr. William P. Dornsife, Director
Bureau of Radiation Protection
Pennsylvania Department of
Environmental Resources
P. O. Box 8469
Harrisburg, Pennsylvania 17105-8469

Dr. Judith Johnsrud
National Energy Committee
Sierra Club
433 Orlando Avenue
State College, PA 16803

Mr. Jesse C. Tilton, III
Allegheny Elec. Cooperative, Inc.
212 Locust Street
P.O. Box 1266
Harrisburg, Pennsylvania 17108-1266

Chairman
Board of Supervisors
738 East Third Street
Berwick, PA 18603

UNITED STATES NUCLEAR REGULATORY COMMISSIONPENNSYLVANIA POWER AND LIGHT COMPANYDOCKET NOS. 50-387 AND 50-388CORRECTION

The March 29, 1995, Federal Register contained a "Notice of Consideration of Issuance of Amendment to Facility Operating License, Proposed No Significant Hazards Consideration Determination, and Opportunity for a Hearing," for the Susquehanna Steam Electric Station. This notice corrects the notice published in the Federal Register on March 29, 1995, (60 FR 16192). The second sentence of the description section should read as follows: Specifically, for the refueling floor exhaust duct and wall exhaust duct radiation monitors, the proposed change would modify the applicable operational condition during specific control rod testing evolutions which are core alterations and would indicate that the operability requirement change does not apply during shutdown margin demonstrations.

Dated at Rockville, Maryland, this 22nd day of August 1995.

FOR THE NUCLEAR REGULATORY COMMISSION



Leonard N. Olshan, Acting Director
Project Directorate I-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation