Docket No. 50-388

Mr. Harold W. Keiser Senior Vice President-Nuclear Pennsylvania Power and Light Company 2 North Ninth Street Allentown, Pennsylvania 18101

Dear Mr. Keiser:

DISTRIBUTION:Docket FileEJCNRC PDRJPaLocal PDRTBaPDI-2 Rdg.WanSVargaEBuBBogerTecWButlerACRMThadani/DFischerCMiMO'BrienRDiOGCDHaBClaytonRBI

EJordan JPartlow TBarnhart (4) Wanda Jones EButcher Tech Branch ACRS (10) CMiles, GPA/PA RDiggs, ARM/LFMB DHagan RBlough

SUBJECT: TECHNICAL SPECIFICATION CHANGES REFLECTING CANCELLATION OF DRYWELL FAN MODIFICATIONS (TAC NO. 67901)

RE: SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 2

The Commission has issued the enclosed Amendment No. 48 to Facility Operating License No. NPF-22 for the Susquehanna Steam Electric Station (SSES), Unit 2. This amendment is in response to your letter dated April 8, 1988.

This amendment revises the SSES Unit 2 Technical Specifications to cancel the changes previously approved in Amendment No. 36. That amendment was approved on June 5, 1987 and was intended to provide operational control on equipment which must be operable to ensure proper functioning of the new drywell cooling fans intended to be installed during the current refueling outage. Your letter dated April 8, 1988 states that you have now decided not to install the new drywell cooling fans and would, therefore, not need the Technical Specification changes approved in Amendment No. 36. We have completed our review of your request to change the drywell cooling fans Technical Specifications to those which existed prior to issuance of Amendment No. 36 and find the request to be acceptable.

A copy of our Safety Evaluation is also enclosed. Notice of Issuance will be included in the Commission's Biweekly Federal Register Notice.

Sincerely,

/s/

Walter R. Butler, Director Project Directorate I-2 Division of Reactor Projects I/II Office of Nuclear Reactor Regulation

Enclosures: Amendment No. 48 to 1. License No. NPF-22 )52503 ADOCK 2. Safety Evaluation cc w/enclosures: See next page PDI-2/PM PDI-2/D OGC MThadani:tr WButler BMBorderick 5/17/88 4 129/88 05 /03 /88

FOR THE NUCLEAR REGULATORY COMMISSION

/s/

Walter R. Butler, Director Project Directorate J-2 Division of Reactor Projects I/II

Attachment: Changes to the Technical Specifications

Date of Issuance: May 17, 1988





OGC BMBorderick 05/03/88



Mr. Harold W. Keiser Pennsylvania Power & Light Company

cc: Jay Silberg, Esq. Shaw, Pittman, Potts & Trowbridge 2300 N Street N.W. Washington, D.C. 20037

Bryan A. Snapp, Esq. Assistant Corporate Counsel Pennsylvania Power & Light Company 2 North Ninth Street Allentown, Pennsylvania 18101

Mr. E. A. Heckman Licensing Group Supervisor Pennsylvania Power & Light Company 2 North Ninth Street Allentown, Pennsylvania 18101

Mr. F. I. Young Resident Inspector P.O. Box 52 Shickshinny, Pennsylvania 18655

Mr. R. J. Benich Services Project Manager General Electric Company 1000 First Avenue King of Prussia, Pennsylvania 19406

Mr. Thomas M. Gerusky, Director
Bureau of Radiation Protection Resources
Commonwealth of Pennsylvania
P. O. Box 2063
Harrisburg, Pennsylvania 17120

Mr. Jesse C. Tilton, III Allegheny Elec. Coorperative, Inc. 212 Locust Street P.O. Box 1266 Harrisburg, Pennsylvania 17108-1266 Susquehanna Steam Electric Station Units 1 & 2

Mr. W. H. Hirst, Manager Joint Generation Projects Department Atlantic Electric P.O. Box 1500 1199 Black Horse Pike Pleasantville, New Jersey 08232

Regional Administrator, Region I U.S. Nuclear Regulatory Commission 475 Allendale Road King of Prussia, Pennsylvania 19406



UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

# PENNSYLVANIA POWER & LIGHT COMPANY

# ALLEGHENY ELECTRIC COOPERATIVE, INC.

## DOCKET NO. 50-388

# SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 2

## AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 48 License No. NPF-22

- 1. The Nuclear Regulatory Commission (the Commission or the NRC) having found that:
  - A. The application for the amendment filed by the Pennsylvania Power & Light Company, dated April 8, 1988 complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the regulations of the Commission;
  - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
- Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of the Facility Operating License No. NPF-22 is hereby amended to read as follows:
  - (2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 48 and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. PP&L shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

8805250332 880517 PDR ADOCK 05000388 PDR PDR FOR THE NUCLEAR REGULATORY COMMISSION

/s/

Walter R. Butler, Director Project Directorate J-2 Division of Reactor Projects I/II

Attachment: Changes to the Technical Specifications

Date of Issuance: May 17, 1988







FOR THE NUCLEAR REGULATORY COMMISSION

alter R. Butle

Walter R. Butler, Director Project Directorate I-2 Division of Reactor Projects I/II

Attachment: Changes to the Technical Specifications

\_\_\_\_\_

Date of Issuance: May 17, 1988

# ATTACHMENT TO LICENSE AMENDMENT NO. 48

## FACILITY OPERATING LICENSE NO. NPF-22

### DOCKET NO. 50-388

Replace the following pages of the Appendix A Technical Specifications with enclosed pages. The revised pages are identified by Amendment number and contain vertical lines indicating the area of change. The overleaf pages are provided to maintain document completeness.\*

INSERT
3/4 6-39* 3/4 6-40
3/4 8-25* 3/4 8-26
3/4 8-27 3/4 8-28*

~

#### CONTAINMENT SYSTEMS

### 3/4.6.6 PRIMARY CONTAINMENT ATMOSPHERE CONTROL

## DRYWELL AND SUPPRESSION CHAMBER HYDROGEN RECOMBINER SYSTEMS

## LIMITING CONDITION FOR OPERATION

3.6.6.1 Two drywell and two suppression chamber hydrogen recombiner systems shall be OPERABLE.

APPLICABILITY: OPERATIONAL CONDITIONS 1 and 2.

#### ACTION:

With one drywell and/or one suppression chamber hydrogen recombiner system inoperable, restore the inoperable system to OPERABLE status within 30 days or be in at least HOT SHUTDOWN within the next 12 hours.

#### SURVEILLANCE REQUIREMENTS

4.6.6.1 Each drywell and suppression chamber hydrogen recombiner system shall be demonstrated OPERABLE:

- a. At least once per 6 months by energizing the recombiner system to at least 10 kw for  $\geq$  5 minutes.
- b. At least once per 18 months by:
  - 1. Performing a CHANNEL CALIBRATION of all recombiner operating instrumentation and control circuits.
  - 2. Verifying the integrity of all heater electrical circuits by performing a resistance to ground test following the above required energization. The resistance to ground for any heater phase shall be greater than or equal to 10,000 ohms.
  - 3. Verifying through a visual examination that there is no evidence of abnormal conditions within the recombiner enclosure; i.e, loose wiring or structural connections, deposits of foreign materials, etc.

## CONTAINMENT SYSTEMS

#### DRYWELL AIR FLOW SYSTEM

#### LIMITING CONDITION FOR OPERATION

3.6.6.2 Drywell unit cooler fans 2V414A&B, 2V415A&B, and 2V416A&B shall be OPERABLE at low speed.

APPLICABILITY: OPERATIONAL CONDITIONS 1 and 2.

ACTION:

- a. With one fan in one or more of the above pairs of fans inoperable at low speed, restore the inoperable fan(s) to OPERABLE status within 30 days or be in at least HOT SHUTDOWN within the next 12 hours.
- b. With both fans in any pair inoperable at low speed, follow the requirements of Specification 3.0.3.

## SURVEILLANCE REQUIREMENTS

4.6.6.2 Each of the fans required above shall be demonstrated OPERABLE at least once per 92 days by:

- a. Starting each fan at low speed from the control room, and
- b. Verifying that each fan operates for at least 15 minutes.

ł

## ELECTRICAL POWER SYSTEMS

#### SURVEILLANCE REQUIREMENTS (Continued)

that current specified by the manufacturer for the test current. The magnetic (instantaneous) element shall be tested by injecting a current in excess of 120% of the pickup value of the magnetic (instantaneous) element and verifying that the circuit breaker trips instantaneously with no intentional time delay. Type HFB-M (magnetic only) circuit breaker testing shall also follow this procedure except that no thermal trip elements will be involved. Circuit breakers found inoperable during functional testing shall be restored to OPERABLE status prior to resuming operation. For each circuit breaker found inoperable during these functional tests, an additional representative sample of at least 10% of all the circuit breakers of the inoperable type shall also be functionally tested until no more failures are found or all circuit breakers of that type have been functionally tested.

- 2. a.By selecting and functionally testing a representative sample of each type of fuse on a rotating basis. Each representative sample of fuses shall include at least 10% of all fuses of that type. The functional test shall consist of a non-destructive resistance measurement test which demonstrates that the fuse meets its manufacturer's design criteria. Fuses found inoperable during these functional testing shall be replaced with OPERABLE fuses prior to resuming operation. For each fuse found inoperable during these functional tests, an additional representative sample of at least 10% of all fuses of that type shall be functionally tested until no more failures are found or all fuses of that type have been functionally tested, or
  - b. By replacing 100% of all required fuses.
- 3. Functionally testing each overcurrent relay listed in Table 3.8.4.1-1. Testing of these relays shall consist of injecting a current in excess of 120% of the nominal relay initiation current and measuring the response time. The measured response time shall be within ±10% of the specified value.
- b. At least once per 60 months by subjecting each circuit breaker to an inspection and preventive maintenance in accordance with procedures prepared in conjunction with its manufacturer's recommendations.

SUSQUEHANNA - UNIT 2

5 Amendment No. 24 effective upon startup following the linit & first requering outage

# TABLE 3.8.4.1-1

# PRIMARY CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICES

CIRCUIT BREAKER DESIGNATION		
Α.	Туре	HFB-TM*
	1.	2B237043
	2.	2B219022
	3.	2B219023
	4.	2B246011
	5.	2B229022
	6.	2B229023
	7.	2B236042
	8.	2B236032
	9.	2B236011
	10.	2B236033
	11.	2B236082
	12.	2B236043
	13.	2B236021
	14.	2B246091
	15.	2B246103
	16.	2B246102
	17.	2B246061
	18.	2B246072
	19.	2B246081
	20.	2B246051

# TABLE 3.8.4.1-1 (Continued)

----

# PRIMARY CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICES

	CUIT I	BREAKER	
	01		STSTEM/ EQUIPMENT POWERED
	21.	28236052	RHR/HV-E11-2F009
	22.	2B237073	RHR/HV-E11-2F022
	23.	2B237082	HPCI/HV-E41-2F002
	24.	2B253021	NSSS/HV-B21-2F011A
	25.	2B263023	NSSS/HV-B21-2F011B
	26.	2B253041	MSIV Hoist/TB0815
	27.	2B263021	MSIV Hoist/TB0816
Β.	Туре	HFB-M*	
	1.	2B236023	Cont. Inst. Gas/HV-22603
	2.	2B246022	RCIC/HV-E51-2F007
	3.	2B237072	NSSS/HV-B21-2F016
	4.	2B236102	NSSS/HV-B21-2F001
	5.	2B246112	NSSS/HV-B21-2F002
	6.	2B246113	NSSS/HV-B21-2F005
	7.	2B236053	RWCU/HV-G33-2F001
	8.	2B253053	RWCU/HV-G33-2F102
	9.	2B263043	RWCU/HV-G33-2F100
	10.	2B263053	RWCU/HV-G33-2F106
	11.	28263081	RWCU/HV-G33-2F101
	12.	2B246062	RBCCW/HV-21346
	13.	2B246012	RBCCW/HV-21345
	14.	2B253063	Drywell Sump/2P402A
	15.	2B263071	Drywell Sump/2P402B

\_\_\_\_\_

-

3/4 8-27

# TABLE 3.8.4.1-1 (Continued)

# PRIMARY CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICES

CIR 	CUIT ESIGN	BREAKER ATION	SYSTEM/EQUIPMENT_POWERED
	16.	2B253043	Drywell Sump/2P403A
	17.	2B263072	Drywell Sump/2P403B
C.	Type	KB-TM	
	1.	2B216083 2B216092	Cont. H2 Recombiner/2E440A
	2.	2B226102 2B226103	Cont. H2 Recombiner/2E440B
	3.	2B236103 2B236121	Cont. H2 Recombiner/2E440C
	4.	2B246032 2B246033	Cont. H2 Recombiner/2E440D
D.	Circo By Ov	uit Breakers Tripped vercurrent Relays	
	1.	2A20501 2A20502	Rx Recirc/2P401A
	2.	2A20601 2A20602	Rx Recirc/2P401B

\*Each circuit breaker designation represents two redundant circuit breakers.

3/4 8-28

-28 Amendment No. 24 exercitive with starting followers the white of furt realling



#### UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

## SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

## SUPPORTING AMENDMENT NO. 48 TO FACILITY OPERATING LICENSE NO. NPF-22

## PENNSYLVANIA POWER & LIGHT COMPANY

ALLEGHENY ELECTRIC COOPERATIVE, INC.

## DOCKET NO. 50-388

### SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 2

#### 1.0 INTRODUCTION

By letter dated April 8, 1988, Pennsylvania Power & Light Company (the licensee) requested an amendment to Facility Operating License No. NPF-22 for the Susquehanna Steam Electric Station (SSES), Unit 2. The proposed amendment would cancel the Technical Specification changes approved in Amendment No. 36. That Amendment provided approval of Technical Specification changes to support operational control for the proposed new drywell cooling fans which the licensee had planned to install during the second refueling outage. The April 8, 1988 letter indicated that the licensee no longer plans to install the new drywell cooling fans and would like the affected Technical Specification changes to be cancelled, and the requirements restored to as they existed prior to issuance of Amendment No. 36.

#### 2.0 EVALUATION

The Technical Specification section 3.6.6.2 and Table 3.8.4.1-1 are being revised to reflect the licensee's decision not to install new drywell cooling fans. Since the Technical Specifications are being changed to reflect all the requirements which existed prior to June 5, 1987 approval of Amendment No. 36, they will continue to meet all the staff requirements which formed the prior basis of the Technical Specifications. Therefore, the proposed changes are acceptable.

#### 3.0 ENVIRONMENTAL CONSIDERATION

This amendment involves a change to a requirement with respect to the installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20. The staff has determined that the amendment involves no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that this amendment involves no significant hazards consideration and there has been no public comment on such finding. Accordingly, this amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement nor environmental assessment need be prepared in connection with the issuance of this amendment.

880 <b>5250334</b> PDR ADOCK	880517 05000388 PDR
---------------------------------	---------------------------

#### 4.0 CONCLUSION

The Commission made a proposed determination that the amendment involves no significant hazards consideration which was published in the <u>Federal</u> <u>Register</u> (53 FR 12625) on April 15, 1988 and consulted with the State of Pennsylvania. No public comments were received, and the State of Pennsylvania did not have any comments.

The staff has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (2) such activities will be conducted in compliance with the Commission's regulations and the issuance of this amendment will not be inimical to the common defense and security nor to the health and safety of the public.

Principal Contributor: Mohan C. Thadani

Dated: May 17, 1988