



Entergy Nuclear Northeast
Entergy Nuclear Operations, Inc.
James A. FitzPatrick NPP
P.O. Box 110
Lycoming, NY 13093
Tel 315 342 3840

January 12, 2001
JAFP-01-0005

U. S. Nuclear Regulatory Commission
Mail Station P1-137
Washington, D. C. 20555

ATTENTION: Document Control Desk

SUBJECT: **OPERATING STATUS REPORT**

Reference: Docket No. 50-333

Dear Sir:

Enclosed is the Operating Status Report for the James A. FitzPatrick Nuclear Power Plant for the month of December 2000.

If there are any questions concerning this report, please contact Jeff Boyer, Lead Systems Engineer, (315) 349-6147.

A handwritten signature in black ink, appearing to read "Michael J. Colomb".

MICHAEL J. COLOMB

MJC:GC:JB:tb
Enclosure

cc: JAF Department Heads
White Plains Office
Todd Tierney IP3
Barb Taggart IP3
Paul Lemberg WPO
Robert Penny WPO
JTS JAFP File
RMS (JAF)
RMS (WPO)

IE24

**ENTERGY NUCLEAR NORTHEAST
JAMES A. FITZPATRICK NUCLEAR POWER PLANT
OPERATING DATA REPORT**

REPORT MONTH: DECEMBER 2000

Docket No.:	50-333
Unit Name:	FitzPatrick
Date:	January 11, 2001
Completed By:	J. Boyer
Telephone:	(315)349-6147

DAY	NET AVERAGE DAILY POWER LEVEL	DAY	NET AVERAGE DAILY POWER LEVEL
1	839	17	840
2	838	18	728
3	839	19	841
4	840	20	840
5	841	21	841
6	841	22	842
7	841	23	842
8	829	24	841
9	840	25	842
10	840	26	843
11	448	27	842
12	437	28	725
13	435	29	841
14	435	30	841
15	669	31	842
16	838		

REPORT MONTH: DECEMBER 2000

Docket No.:	50-333
Unit Name:	FitzPatrick
Date:	January 11, 2001
Completed By:	J. Boyer
Telephone:	(315)349-6147

NO.	DATE	TYPE	DURATION HOURS	REASON	METHOD OF SHUTTING DOWN THE REACTOR	LICENSEE EVENT REPORT NO.	SYSTEM CODE	COMPONENT CODE	CAUSE and CORRECTIVE ACTION TO PREVENT RECURRENCE
N/A									

F: FORCED
S: SCHEDULED

REASON:
 A. Equipment failure (explain)
 B. Maintenance or Test
 C. Refueling
 D. Regulatory Restriction
 E. Operator training and license examination
 F. Administrative
 G. Operational error (explain)
 H. Other (explain)

METHOD:
 1. Manual
 2. Manual Scram
 3. Automatic Scram
 4. Continued
 5. Reduced load
 9. Other

EXHIBIT G: Instructions for preparation of data entry sheets for Licensee Event Report (LER) file (NUREG-0161)

REPORT MONTH: DECEMBER 2000

Docket No.:	50-333
Unit Name:	FitzPatrick
Date:	January 11, 2001
Completed By:	J. Boyer
Telephone:	(315)349-6147

The FitzPatrick plant with the exception of minor derates for rod adjustments operated at or near rated power with the following exceptions:

- 12/10/00 – 12/16/00 Derate to 50% for Reactor Feed Pump Turbine maintenance and overspeed testing
- 12/18/00 Derate to 50% for Defish of Main Condenser
- 12/28/00 Derate to 50% for Defish of Main Condenser