



TXU Electric
Comanche Peak
Steam Electric Station
P.O. Box 1002
Glen Rose, TX 76043
Tel: 254 897 8920
Fax: 254 897 6652
lterry1@txu.com

C. Lance Terry
Senior Vice President & Principal Nuclear Officer

Ref: 10CFR50.46

CPSES-200100075
Log # TXX-01004
File # 10010

January 8, 2001

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555

**SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION (CPSES)
DOCKET NOS. 50-445 AND 50-446
ANNUAL REPORT OF CHANGES IN
PEAK CLADDING TEMPERATURE**

Gentlemen:

In accordance with the requirements of 10CFR50.46(a)(3)(ii), TXU Electric submits the attached changes or errors discovered in the Emergency Core Cooling System (ECCS) evaluation model used to calculate peak cladding temperature (PCT) and the estimated effect of these changes or errors on the limiting ECCS analysis. The analyses for Unit 1 were performed with a Steam Generator Tube Plugging (SGTP) allowance of 10% and those for Unit 2 with an SGTP allowance of 5%.

A revised Large-Break Loss-of-Coolant-Accident (LBLOCA) Methodology, approved in Amendment 80 to the CPSES Technical Specifications, was used to perform the CPSES Unit 1, Cycle 8 and Unit 2, Cycle 6 LBLOCA analyses.


A001

TXX-01004
Page 2 of 2

This communication contains no new licensing basis commitments regarding CPSES Units 1 and 2.

Sincerely,

C. L. Terry

By: 
Roger D. Walker
Regulatory Affairs Manager

JDS/js

Attachment

c - E. W. Merschoff, Region IV
J. I. Tapia, Region IV
D. H. Jaffe, NRR
Resident Inspectors, CPSES

CPSES Units 1 and 2
Peak Clad Temperatures

Analysis/Evaluation	CPSES Unit 1*	CPSES Unit 2*
	PCT (°F)	PCT (°F)
Limiting LOCA PCT (°F) [Large Break]	1964	1912
Small Break LOCA PCT (°F)	1834	1824

* There are no ECCS evaluation model assessments or input errors.