



**North
Atlantic**

North Atlantic Energy Service Corporation
P.O. Box 300
Seabrook, NH 03874
(603) 474-9521

The Northeast Utilities System

January 12, 2001

Docket No. 50-443

NYN-01004

CR 99-02616-03

United States Nuclear Regulatory Commission
Attn.: Document Control Desk
Washington, DC 20555-0001

Seabrook Station
2000 Annual Report of Removable
Contamination from Sealed Source or Fission Detector

Seabrook Station Technical Specification 4.7.8.3 requires a report be prepared and submitted if sealed source or fission detector leakage tests reveal the presence of greater than or equal to 0.005 microCurie of removable contamination. In accordance with this requirement, North Atlantic Energy Service Corporation hereby reports that during 2000, there were no leaking sources.

Should you have any questions, please contact Mr. James M. Peschel, Manager – Regulatory Programs, at (603) 773-7194.

Very truly yours,

NORTH ATLANTIC ENERGY SERVICE CORP.

G. F. St. Pierre
Station Director

cc: H. J. Miller, NRC Regional Administrator
V. Nerses, NRC Project Manager, Project Directorate 1-2
R. K. Lorson, NRC Senior Resident Inspector

ADD 1