



Duke Power Company
A Duke Energy Company
Energy Center
P.O. Box 1006
Charlotte, NC 28201-1006

January 10, 2001

U.S Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

Subject: Duke Energy Corporation
Oconee Nuclear Station, Units 1, 2, and 3
Docket Numbers 50-269, 50-270 and 50-287
Monthly Performance and Operation Status-December, 2000

Please find attached information concerning the performance and operation status of the Oconee Nuclear Station for the month of December, 2000.

Any questions or comments December be directed to Roger A. Williams at (704) 382-5346.

Sincerely,

Terry Dimmery, Manager
Nuclear Business Support

Attachment
XC:

L. A. Reyes, Regional Administrator
USNRC, Region II

Dave LaBarge, Project Manager
USNRC, ONRR

INPO Records Center

Ms. Margaret Aucoin
Nuclear Assurance Corporation

Dottie Sherman, ANI Library
American Nuclear Insurers

Oconee NRC Inspector

IE24

Document Control Desk
U.S. NRC - Oconee

bxc:

L. E. Nicholson (ON03RC)
RGC Site Licensing File
ELL (EC050)

Operating Data Report

Docket No.	<u>50-269</u>
Date	<u>January 10, 2001</u>
Completed By	<u>Roger Williams</u>
Telephone	<u>704-382-5346</u>

Operating Status

1. Unit Name: Oconee 1
2. Reporting Period: December 1, 2000 - December 31, 2000
3. Licensed Thermal Power (MWt): 2568
4. Nameplate Rating (Gross MWe): 934
5. Design Electrical Rating (Net MWe): 886
6. Maximum Dependable Capacity (Gross MWe): 886
7. Maximum Dependable Capacity (Net MWe): 846
8. If Changes Occured in Capacity Ratings (Items Number 3-7) Since Last Report, Give Reasons:

Notes: Year-to-date and cumulative capacity factors are calculated using a weighted average for maximum dependable capacity.

9. Power Level To Which Restricted, If Any (Net MWe): _____

10. Reason for Restrictions, If any: _____

	This Month	YTD	Cumulative
11. Hours in Reporting Period	744.0	8784.0	240745.0
12. Number of Hours Reactor was Critical	0.0	7468.8	187297.1
13. Reactor Reserve Shutdown Hours	0.0	0.0	0.0
14. Hours Generator On-Line	0.0	7446.0	184059.5
15. Unit Reserve Shutdown Hours	0.0	0.0	0.0
16. Gross Thermal Energy Generated (MWH)	0	19009158	454332012
17. Gross Electrical Energy Generated (MWH)	0	6609474	157045564
18. Net Electrical Energy Generated (MWH)	0	6309935	149303971
19. Unit Service Factor	0.0	84.8	76.5
20. Unit Availability Factor	0.0	84.8	76.5
21. Unit Capacity Factor (Using MDC Net)	0.0	84.9	72.6
22. Unit Capacity Factor (Using DER Net)	0.0	81.1	70.0
23. Unit Forced Outage Rate	0.0	5.1	9.7
24. Shutdown Scheduled Over Next 6 Months (Type, Date and Duration of Each)			

25. If ShutDown At End Of Report Period, Estimated Date of Startup

26. Units in Test Status (Prior to Commercial Operation)

	Forecast	Achieved
Initial Criticality	_____	_____
Initial Electricity	_____	_____
Commercial Operation	_____	_____

NRC Calculated from Generator Nameplate Data:
 1 037 937 KVA x 0.90 Pf=934 MW

UNIT SHUTDOWNS

DOCKET NO. 50-269
UNIT NAME: Oconee 1
DATE: January 10, 2001
COMPLETED BY: Roger Williams
TELEPHONE: 704-382-5346

REPORT MONTH: December, 2000

No.	Date:	Type F - Forced S - Scheduled	Duration Hours	(1) Reason	(2) Method of Shutdown R/X	Licensed Event Report No.	Cause and Corrective Action to Prevent Recurrence
3	12/01/00	S	744.00	C	4		END-OF-CYCLE 19 REFUELING OUTAGE

Summary:

The unit began the month of December, 2000 in end-of-cycle 19 refueling outage. The unit remained in the end-of-cycle 19 refueling outage during the month of December, 2000.

(1) Reason

- A - Equipment failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operator Error (Explain)
- H - Other (Explain)

(2) Method

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)

MONTHLY REFUELING INFORMATION REQUEST

1. Facility name: Oconee Unit 1
2. Scheduled next refueling shutdown: Currently Refueling
3. Scheduled restart following refueling: December, 2000

THE PROJECT MANAGER HAS BEEN ADVISED BY SEPARATE COMMUNICATION OF ANY T.S. CHANGE OR LICENSE AMENDMENT. THEREFORE, QUESTIONS 4 THROUGH 6 WILL NO LONGER BE MAINTAINED IN THIS REPORT.

4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?

If yes, what will these be?

If no, has reload design and core configuration been reviewed by Safety Review Committee regarding unreviewed safety questions?

5. Scheduled date(s) for submitting proposed licensing action and supporting information.
6. Important licensing considerations (new or different design or supplier, unreviewed design or performance analysis methods, significant changes in design or new operating procedures).
7. Number of Fuel assemblies
(a) in the core: 177
(b) in the spent fuel pool: 986*
(c) in the ISFSI: 1368****
8. Present licensed fuel pool capacity: 1312
Size of requested or planned increase: **
9. Projected date of last refueling which can be accommodated by present capacity: January 2005***

DUKE POWER COMPANY

DATE: January 10, 2001

Name of Contact: R. A. Williams

Phone: (704) - 382-5346

* Represents the combined total for Units 1 and 2

** On March 29, 1990, received a license for ISFSI which will store 2112 assemblies

*** We currently have 60 modules of which 49 modules are loaded.
Additional modules will be built on an as-needed basis.

**** Represents the combined total for Units 1, 2, and 3

Operating Data Report

Docket No.	<u>50-270</u>
Date	<u>January 10, 2001</u>
Completed By	<u>Roger Williams</u>
Telephone	<u>704-382-5346</u>

Operating Status

1. Unit Name: Oconee 2
2. Reporting Period: December 1, 2000 - December 31, 2000
3. Licensed Thermal Power (MWt): 2568
4. Nameplate Rating (Gross MWe): 934
5. Design Electrical Rating (Net MWe): 886
6. Maximum Dependable Capacity (Gross MWe): 886
7. Maximum Dependable Capacity (Net MWe): 846
8. If Changes Occured in Capacity Ratings (Items Number 3-7) Since Last Report, Give Reasons:

Notes: Year-to-date and cumulative capacity factors are calculated using a weighted average for maximum dependable capacity.

9. Power Level To Which Restricted, If Any (Net MWe): _____

10. Reason for Restrictions, If any: _____

	This Month	YTD	Cumulative
11. Hours in Reporting Period	744.0	8784.0	230665.0
12. Number of Hours Reactor was Critical	744.0	8784.0	185341.3
13. Reactor Reserve Shutdown Hours	0.0	0.0	0.0
14. Hours Generator On-Line	744.0	8784.0	182915.5
15. Unit Reserve Shutdown Hours	0.0	0.0	0.0
16. Gross Thermal Energy Generated (MWH)	1908743	41476488	469701294
17. Gross Electrical Energy Generated (MWH)	670318	7830521	154756864
18. Net Electrical Energy Generated (MWH)	642394	7499515	147431415
19. Unit Service Factor	100.0	100.0	79.3
20. Unit Availability Factor	100.0	100.0	79.3
21. Unit Capacity Factor (Using MDC Net)	102.1	100.9	74.8
22. Unit Capacity Factor (Using DER Net)	97.5	96.4	72.1
23. Unit Forced Outage Rate	0.0	0.0	9.3
24. Shutdown Scheduled Over Next 6 Months (Type, Date and Duration of Each)			

25. If ShutDown At End Of Report Period, Estimated Date of Startup

26. Units in Test Status (Prior to Commercial Operation)

	Forecast	Achieved
Initial Criticality	_____	_____
Initial Electricity	_____	_____
Commercial Operation	_____	_____

NRC Calculated from Generator Nameplate Data:
 1 037 937 KVA x 0.90 Pf=934 MW

UNIT SHUTDOWNS

DOCKET NO. 50-270

UNIT NAME: Oconee 2

DATE: January 10, 2001

COMPLETED BY: Roger Williams

TELEPHONE: 704-382-5346

REPORT MONTH: December, 2000

No.	Date:	Type F - Forced S - Scheduled	Duration Hours	(1) Reason	(2) Method of Shutdown R/X	Licensed Event Report No.	Cause and Corrective Action to Prevent Recurrence
			No	Outages	for the Month		

Summary:

(1) Reason

- A - Equipment failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operator Error (Explain)
- H - Other (Explain)

(2) Method

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)

MONTHLY REFUELING INFORMATION REQUEST

1. Facility name: Oconee Unit 2
2. Scheduled next refueling shutdown: April, 2001
3. Scheduled restart following refueling: May, 2001

THE PROJECT MANAGER HAS BEEN ADVISED BY SEPARATE COMMUNICATION OF ANY T.S. CHANGE OR LICENSE AMENDMENT. THEREFORE, QUESTIONS 4 THROUGH 6 WILL NO LONGER BE MAINTAINED IN THIS REPORT.

4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?

If yes, what will these be?

If no, has reload design and core configuration been reviewed by Safety Review Committee regarding unreviewed safety questions?

5. Scheduled date(s) for submitting proposed licensing action and supporting information.
6. Important licensing considerations (new or different design or supplier, unreviewed design or performance analysis methods, significant changes in design or new operating procedures).
7. Number of Fuel assemblies
(a) in the core: 177
(b) in the spent fuel pool: 926*
(c) in the ISFSI: See unit 1 ****
8. Present licensed fuel pool capacity: 1312
Size of requested or planned increase: **
9. Projected date of last refueling which can be accommodated by present capacity: January 2005***

DUKE POWER COMPANY

DATE: January 10, 2001

Name of Contact: R. A. Williams

Phone: (704) - 382-5346

* Represents the combined total for Units 1 and 2

** See footnote on Unit 1

*** We currently have 60 modules of which 49 modules are loaded.
Additional modules will be built on an as needed basis.

**** See footnote on Unit 1

Operating Data Report

Docket No.	<u>50-287</u>
Date	<u>January 10, 2001</u>
Completed By	<u>Roger Williams</u>
Telephone	<u>704-382-5346</u>

Operating Status

1. Unit Name: Oconee 3
2. Reporting Period: December 1, 2000 - December 31, 2000
3. Licensed Thermal Power (MWt): 2568
4. Nameplate Rating (Gross MWe): 934
5. Design Electrical Rating (Net Mwe): 886
6. Maximum Dependable Capacity (Gross MWe): 886
7. Maximum Dependable Capacity (Net MWe): 846
8. If Changes Occured in Capacity Ratings (Items Number 3-7) Since Last Report, Give Reasons:

Notes: Year-to-date and cumulative capacity factors are calculated using a weighted average for maximum dependable capacity.

9. Power Level To Which Restricted, If Any (Net MWe): _____

10. Reason for Restrictions, If any: _____

	This Month	YTD	Cumulative
11. Hours in Reporting Period	744.0	8784.0	228312.0
12. Number of Hours Reactor was Critical	744.0	7894.7	179946.8
13. Reactor Reserve Shutdown Hours	0.0	0.0	0.0
14. Hours Generator On-Line	744.0	7730.7	177361.9
15. Unit Reserve Shutdown Hours	0.0	0.0	0.0
16. Gross Thermal Energy Generated (MWH)	1908743	61205509	484268411
17. Gross Electrical Energy Generated (MWH)	671180	6883760	153100887
18. Net Electrical Energy Generated (MWH)	643523	6577844	146040035
19. Unit Service Factor	100.0	88.0	77.7
20. Unit Availability Factor	100.0	88.0	77.7
21. Unit Capacity Factor (Using MDC Net)	102.2	88.5	74.9
22. Unit Capacity Factor (Using DER Net)	97.6	84.5	72.2
23. Unit Forced Outage Rate	0.0	1.5	9.6
24. Shutdown Scheduled Over Next 6 Months (Type, Date and Duration of Each)			

25. If ShutDown At End Of Report Period, Estimated Date of Startup

26. Units in Test Status (Prior to Commercial Operation)

	Forecast	Achieved
Initial Criticality	_____	_____
Initial Electricity	_____	_____
Commercial Operation	_____	_____

NRC Calculated from Generator Nameplate Data:
 1 037 937 KVA x 0.90 Pf=934 MW

UNIT SHUTDOWNS

DOCKET NO. 50-287

UNIT NAME: Oconee 3

DATE: January 10, 2001

COMPLETED BY: Roger Williams

TELEPHONE: 704-382-5346

REPORT MONTH: December, 2000

No.	Date:	Type F - Forced S - Scheduled	Duration Hours	(1) Reason	(2) Method of Shutdown R/X	Licensed Event Report No.	Cause and Corrective Action to Prevent Recurrence
			No	Outages	for the Month		

Summary:

(1) Reason

- A - Equipment failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operator Error (Explain)
- H - Other (Explain)

(2) Method

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)

MONTHLY REFUELING INFORMATION REQUEST

1. Facility name: Oconee Unit 3
2. Scheduled next refueling shutdown: October 2001
3. Scheduled restart following refueling: November 2001

THE PROJECT MANAGER HAS BEEN ADVISED BY SEPARATE COMMUNICATION OF ANY T.S. CHANGE OR LICENSE AMENDMENT. THEREFORE, QUESTIONS 4 THROUGH 6 WILL NO LONGER BE MAINTAINED IN THIS REPORT.

4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?

If yes, what will these be?

If no, has reload design and core configuration been reviewed by Safety Review Committee regarding unreviewed safety questions?

5. Scheduled date(s) for submitting proposed licensing action and supporting information.
6. Important licensing considerations (new or different design or supplier, unreviewed design or performance analysis methods, significant changes in design or new operating procedures).
7. Number of Fuel assemblies (a) in the core: 177
 (b) in the spent fuel pool: 552
 (c) in the ISFSI: See Unit 1 ****
8. Present licensed fuel pool capacity: 825
Size of requested or planned increase: **
9. Projected date of last refueling which can be accommodated by present capacity: January 2005***

DUKE POWER COMPANY

DATE: January 10, 2001

Name of Contact: R. A. Williams

Phone: (704) - 382-5346

** See footnote of Unit 1

*** We currently have 60 modules of which 49 modules are loaded.
Additional modules will be built on an as needed basis.

**** See footnote on Unit 1

OCONEE NUCLEAR STATION

MONTHLY OPERATING STATUS REPORT

NOVEMBER 2000

1. Personnel Exposure -

The total station liquid release for NOVEMBER has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

The total station gaseous release for NOVEMBER has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.