SIEMENS

January 12, 2001 NRC:01:004

Document Control Desk ATTN: Chief, Planning, Program and Management Support Branch U.S. Nuclear Regulatory Commission Washington, D.C. 20555-0001

Viewgraphs for January 16, 2001 Meeting Between SPC and the NRC – EXEM BWR-2000 LOCA Methodology

Two proprietary copies and two nonproprietary copies of the viewgraphs to be presented at the January 16, 2001 meeting between SPC and the NRC are provided with this letter. The subject of the meeting is the recently submitted topical report on BWR LOCA methodology. (NOTE: One proprietary copy and one nonproprietary copy have been sent directly to Mr. N. Kalyanam.)

Siemens Power Corporation considers some of the information contained in the enclosure to this letter to be proprietary. As required by 10 CFR 2.790(b), an affidavit is enclosed to support the withholding of this information from public disclosure.

Very truly yours,

Smit Anall

James. F. Mallay, Director Regulatory Affairs

/arn

Enclosures

cc: N. Kalyanam (w/Enclosures) Project No. 702

Siemens Power Corporation

2101 Horn Rapids Road Richland, WA 99352

Tel: Fax:

(509) 375-8100 (509) 375-8402

AFFIDAVIT

STATE OF WASHINGTON)) ss. COUNTY OF BENTON)

1. My name is Jerry S. Holm. I am Manager, Product Licensing, for Siemens Power Corporation ("SPC"), and as such I am authorized to execute this Affidavit.

2. I am familiar with the criteria applied by SPC to determine whether certain SPC information is proprietary. I am familiar with the policies established by SPC to ensure the proper application of these criteria.

3. I am familiar with the SPC information included in the presentation material transmitted with the letter NRC:01:004, dated January 12, 2001, from James F. Mallay to the Document Control Desk. These viewgraphs are referred to herein as "Documents." Information contained in these Documents has been classified by SPC as proprietary in accordance with the policies established by SPC for the control and protection of proprietary and confidential information.

4. These Documents contain information of a proprietary and confidential nature and is of the type customarily held in confidence by SPC and not made available to the public. Based on my experience, I am aware that other companies regard information of the kind contained in these Documents as proprietary and confidential.

5. These Documents have been made available to the U.S. Nuclear Regulatory Commission in confidence with the request that the information contained in the Documents be withheld from public disclosure. 6. The following criteria are customarily applied by SPC to determine whether information should be classified as proprietary:

- (a) The information reveals details of SPC's research and development plans and programs or their results.
- (b) Use of the information by a competitor would permit the competitor to significantly reduce its expenditures, in time or resources, to design, produce, or market a similar product or service.
- (c) The information includes test data or analytical techniques concerning a process, methodology, or component, the application of which results in a competitive advantage for SPC.
- (d) The information reveals certain distinguishing aspects of a process,
 methodology, or component, the exclusive use of which provides a
 competitive advantage for SPC in product optimization or marketability.
- (e) The information is vital to a competitive advantage held by SPC, would be helpful to competitors to SPC, and would likely cause substantial harm to the competitive position of SPC.

7. In accordance with SPC's policies governing the protection and control of information, proprietary information contained in these Documents has been made available, on a limited basis, to others outside SPC only as required and under suitable agreement providing for nondisclosure and limited use of the information.

8. SPC policy requires that proprietary information be kept in a secured file or area and distributed on a need-to-know basis.

9. The foregoing statements are true and correct to the best of my knowledge, information, and belief.

Jerold Stolm

SUBSCRIBED before me this <u>// th</u>

day of January, 2001.

Umy R. Nixon

Amy R. Nixon NOTARY PUBLIC, STATE OF WASHINGTON MY COMMISSION EXPIRES: 12/06/03



SIEMENS
EXEM BWR-2000 ECCS Evaluation Model Agenda
 Introduction (Jerry Holm) Current Approved Methodology (Gene Jensen) Code Changes (Scott Franz) Application Changes (Chuck Hendrix) Sample Problems / Sensitivity Studies (Chuck Hendrix) Verification (Scott Franz and Chuck Hendrix) Conclusion
Stemene Power Corporation : January 16, 2001



SIEMENS
Current Approved Methodology
Evolution of BWR Evaluation Models
 4 Principal Models and Additional Minor Upgrades
 BWR Fuel Heatup Model, {XN-235(A)} HUXY Code
 NJP BWR Evaluation Model, {XN-75-55(A) Rev. 2 and Supplements 1 & 2} (RELAP-EM, HUXY)
 Jet Pump EXEM/BWR Evaluation Model, {XN-NF-80- 19(P)(A) Volumes 2, 2A, 2B, & 2C} (RELAX, FLEX, HUXY)
 Revised EXEM/BWR Evaluation Model, {ANF-91-048(P)(A)} (Same Codes)
 Evolution described and detailed roadmap with references for each evaluation model feature is presented in Section 2 of EMF-2361(P)
Siemens Power Corporation



SIEMENS		
Current Approved Metho	dology (Cont.)	
RODEX2 Code		
 Calculates burnup depende LOCA analysis 	ent fuel rod initial condition	s for
 Provides conservative initia 	I stored energy	
 Provides burnup dependent 	t fuel and cladding dimens	ions
 Calculates fission gas releated 	se for LOCA initial conditi	ons
Stemens Power Corporation	3	January 16, 2001



SIEMENS
Current Approved Methodology (Cont.)
FLEX Code
 System transient code developed to calculate jet pump BWR refill behavior and time of core reflood
 Obtains initial conditions from RELAX at end of blowdown (time of rated LPCS)
 Calculates the transient flow and accumulation of ECCS in the RCS lower plenum
 Principal output is the time of core reflood when fluid mixture has filled the lower plenum and entrained liquid has reached the plane of interest (POI)
 Secondary output is time when mixture level in bypass region reaches the POI
Siemens Power Corporeton 6 January 16, 2001







SIEMENS	····	
Code Changes (C	Cont.)	
Replacement of Fl	_EX with RELAX	
 FLEX was origina reflood. This was concerning hardw 	Illy developed to determ done to resolve compu- vare and software using	nine the time of utational limitations I RELAX
 Improved numering of RELAX couple reduced the need 	cal techniques installed d with faster computers l for FLEX	in the 1991 version has significantly
The removal of F	LEX provides:	
Reduced opport possible discont	unity for errors in input de inuities which may occur	cks. Removes
Is more efficient	for calculations	
Reduces the nu benchmarking	mber of codes for mainter	nance and
The time of refloc	ed is now determined us	sing RELAX
Stamene Power Corporation	12	January 16, 2001



.

SIEMENS	
Code Changes (Cont.) Reflood Criteria	
 The FLEX mechanism for the determination of reflood has been implemented into RELAX as follows. 	
 The following parameters are used to determine if a reflood has occurred 	
 When these criteria have been met, the condition for the start of reflood will be accepted. 	
Siemene Hower Corboration 4 January 16, 2001	

Code Changes	(Cont.)	
Ishii / Ohkawa-Lah	hey	
 1991 version of RI Lahey drift flux cor 	ELAX contains both the Ish	nii and Ohkawa-
 It is desireable to r singularity which e 	remove the Ishii correlation exists in the formulation	i due to a
 Removal of the Isl discontinuity in the two correlations 	hii drift flux correlation remo e RELAX code when switch	oved a hing between the
The Ohkawa-Lahe the entire computa	ey drift flux correlation is no ational space of a boiler ca	w used throughout lculation
 The Ohkawa-Lahe Kutateladze CCFL CCFL calculation 	ey drift flux correlation redu L condition; therefore, it is a	ces to the also used for the
Stemens Power Corporation	15	January 16, 2001

SIEMENS	
Code Changes (Cont.)	
Isbii / Obkawa-Labey	
	•
	:
Siemene Power Corporation	January 15, 2001



SIEMENS		
Code Changes (Cor ANFB CHF Correlation	nt.)	
Skemens Power Corporation	16	January 16, 2001







SIEMENS		
Code Changes (Co Over Condensation M	ont.) odel	
• Aspects of the Entha	alpy Injection Mod	el (cont.)
Semens Power Corporation	22	January 18, 2001



SIEMENS
Modeling Application Changes
 Four Modeling Modifications are Required for EXEM BWR-2000
 Increased jet pump noding and modified jet pump exit description
 Phase separation model in the bypass
Core nodalization
 Upper plenum nodalization
vemens rower Exportation 24 January 16, 2001











SIEMENS		*** **********************************
Modeling Applica Core Bypass Regior	tion Changes (Co Modeling	ont.)
1		
		•
Stemene Power Corporation	x	January 18, 2001



SIEMENS		
Modeling Applicatio Core Nodalization for L	n Changes (Con OCA Analysis	t.)
		<u> </u>
Stemens Power Corporation	ц	January 16, 2001











SIEMENS	· · · · · · · · · · · · · · · · · · ·	
Model Application	on and Sensitivities	······
- BWR LOCA/ECO - EXEM BWR-200	CS Analysis Example Pro 00 Methodology Sensitivi	oblems ity Studies
Siemens Power Corboration	38	Januery 18, 2001



SIEMENS	
Model Applications and Sensitivities (Cont.) Example Problem Summary	
 Break Spectrum Parameters Break size/location Recirculation pump suction line Recirculation pump discharge line Break type Double-ended guillotine Split 	
 ECCS Single Failure (BWR/3) SF-LPCI (2 LPCS) SF-DG (2 LPCI and 1 LPCS) SF-HPCI (4 LPCI and 2 LPCS) 	
 Axial Power Profile Top peaked Center peaked 	
Siemens Power Carbonson 21	angany 15, 2001



SIEMENS					
Model Applications Example Problem Sun	Model Applications and Sensitivities (Cont.) Example Problem Summary				
Semens Power Corporation	42	January 16, 2001			

SIEMENS		
Example Problem Upper Plenum Pressure	!	
		I
Siemens Power Corporation	43	January 18, 2001
Siemens Power Corporation	43	January 16, 2001

















SIEMENS
Verification
 Verification of the new models has been done using two facilities:
. TLTA
 The Two Loop Testing Facility benchmark has been rerun through blowdown
- FIST
 Three cases have been explored. Two large break cases and one small break
Lemens //wer , stocrador



SIEMENS		
Verification (cont.)	·	
	Lower Plenum Mass	
		;
		_
Siemens Power Corporation	54	January (d. 2001







SIEMENS	
Verification (cont.) FIST	
· Large Break 6DB1-B	
 Test 6DB1-B is a BWR/6 DBA simulation, with and LPCI available. 	n HPCS, LPCS
 Scaled 1.878 ft² suction line and 0.348 ft² driv 	e line breaks.
 An average central orifice region bundle is mo power of 5.045 MW. 	odeled with a
 The transient begins with a coincident double recirculation line break and power trip. 	-ended
vernens Power Corborston 58	January 16, 2001



SIEMENS			
		· · · · · · · · · · · · · · · · · · ·	
Verification (cont.)			
FIST (Large Break DB1-B))		
			•
Siemens Power Corporation	50		January 16, 2001







SIEMENS	
Verification (cont.) FIST (Large Break DB1-B)	
Semens Power Corporation 4	anuary 16, 2001



SIEMENS	
Verification (con	it.)
· Large Break 4DB	BA1
 4DBA1 is a BWR/4 of from 4.14 ft²) suction breaks 	design basis accident simulation with a 1.065 in ² (scaled n line and 0.1645 in ² (scaled from 0.064 ft ²) drive line
 The test simulates a one LPCI pump. On The HPCI is connect the intact drive line. feedwater line. Beca RELAX, SPC metho downcomer and the 	failure of a single diesel generator, resulting in the loss he HPCI, one LPCS, and two LPCI are assumed available ted to the upper plenum and the LPCIs are connected to In an actual BWR/4 plant, the HPCI injects through the ause the upper plenum is a homogeneous volume in indology connects the feedwater line to the middle HPCI to the upper downcomer.
 The FIST ECCS pur BWR/6 DBA tests w tripped off at a press driven pumps). 	mps all are tripped on at 30 seconds, as opposed to the there Level 2 trips with a delay are used. Also, the HPCI sure of 115 psia, consistent with an actual BWR/4 (turbin
Semene Power Corporation	es January 10







Verification (cont.) FIST (Large Break 4DI	3A1)	
Stemens Power Corporation		January 18, 2001



SIEMENS	
FIST (Large Break 4DBA1)	
	1
Siemens Power Corporation	January 15, 2001
1	



-

SIEMENS	
Verification (cont.) FIST	
 Small Break 6SB2C 	
 This test simulated a BWR/6 recirculation su of 0.05 ft² (0.01227 in² actual). 	iction line break
 The system is configured as in the large-bre HPCS being injected into the upper plenum the bypass. 	ak test with and LPCI into
 The event is initiated by the "break" on the s recirculation pump number 2 and coincident trip of the recirculation pumps, and feedwate 	uction side of power scram, er flow.
 The pressure controller maintained the syste essentially constant until the MSIV was close Level 1 trip. 	em pressure ed following the
 This test simulated three LPCI systems avail 	iabie.
Stemans Power Corporation	January 16, 2001



SIEMENS		
Verification (cont.) FIST (Small Break 6SI	B2C)	
]
Jemens Power Corporation		January 16, 2001



SIEMENS	<u> </u>	··
Verification (cont.) FIST (Small Break 6SB2C)		
	-	
Siemens Power Corporation	۳۶	anuary 16 2001



SIEMENS		
Verification (cont.) FIST (Small Break 6SB2	2C)	
Siemena Power Corboration	*0	.anuary 16 _301



SIEMENS		
Verification (cont.) FIST (Small Break 6SB2	2C)	
		1
Stemens Power Corporation	52	January 16, 2001

 SIEMENS	
Verification (cont.) FIST	
Conclusion	
 The hydraulics and mass inventories were co predicted. 	enservatively
 Large-break (DBA) PCTs are conservatively estimate methods. 	calculated using best-
 SBLOCA PCTs are bound when the conservation EM methodology is applied. This result is ac small break events are not limiting in BWRs a simulated an extremely small break in which resulting heat-up is minor such that the conservation of the second s	atism included in the ceptable because and the test evaluated core uncovery and the ervatism (Appendix K perature to values of
 It is concluded that the SPC methodology usi simulate the blowdown and refill/reflood period HUXY code for the heat-up period will produce 	ng the RELAX code to ods of a LOCA and the ce conservative PCTs.
 Siemens Power Corporation 83	January 16, 2001

.

SIEMENS	
EXEM BWR-2000	
Conclusion / Summary	
 The EXEM BWR-2000 methodol current methodology by the remo replacing it with RELAX 	ogy is simplified from the oval of FLEX and
 Changes made to the methodolo results for small breaks while larg impacted 	gy significantly improve ge breaks are less
 The overall EXEM BWR-2000 m 	ethodology is more robust
Stemens Power Corporation 34	January 18, 2001