

MEETING MINUTES

(redacted) Bechtel Badge (redacted) came to my office on 10/26/93, with some concerns that he felt were the reasons for his layoff. After a short discussion, I asked him if he would be willing to come back tomorrow to discuss these concerns with appropriate ANO management present. He agreed and we met on 10/27/93 at 8:00 am in the TSB-2 Conference Room. Present at that meeting were also (redacted) from ANO and (redacted) from Bechtel. (redacted) repeated his concerns as follows:

(redacted) He said that they even went into his locker one evening to retrieve a package needing closeout instead of waiting until the next morning.

Room 129

In Panel C 13 in the Unit 1 Control Room while doing penetration foam sealing, he found one penetration with four wires coming out but Bechtel had paperwork showing four separate penetrations which is not correct (redacted) told him that this was only one penetration). He believes that Bechtel is cheating ANO out of money.

Also, he found that penetration 129-0129 that had no firewatch documentation and he wrote a CR on it (per (redacted) direction) and it got closed out.

He has had some run-ins and a heated discussion with ANO's (redacted) who is acting as a Modifications Engineer. The flare-up came about over the fact that he was no longer being given the foam sample density numbers he's supposed to enter on the paperwork for foam seals per Procedure 6030.101. He's being told only that it's "good" and that is not acceptable to him since the form requires an actual density number.

On one occasion, (redacted) told him in front of witnesses that the cell structure from Pony Packs (cartridges) was not acceptable on some penetrations that were shot but nobody did anything about this. He said that (redacted) told him to shoot the seal and that he would take the heat. This particular seal was in the control room and while (redacted) wanted him to use the foam machine, he needed to use the cartridges since the shift supervisor didn't want the machine's hoses being dragged near the Decay Heat Panel area.

He said that he has brought up his concerns through his supervision up to (redacted) and that they've been swept under the rug by Bechtel.

He believes that he's being laid off because of his confrontation with (redacted) who is (redacted) and nobody would touch him (redacted) and also because he's brought up problems.

Information in this record was deleted
in accordance with the Freedom of Information
Act, exemptions 7C
FOIA- 99-76

MM/3