

|   |   |                      |
|---|---|----------------------|
| Facility: <u>SONGS</u>  | Scenario No.: <u>1</u>  | Op-Test No: <u>1</u> |
| Examiners: <u>T. Stetka</u><br><u>H. Bundy</u>  | Operators: <u>SRO-1</u><br><u>RO-CO</u><br><u>SURROGATE-ACO</u> |                      |
| <p>Initial Conditions: 70% reactor power Middle of Core Life, 2HPSI 18 OOS, 2PI0351-1<br/>         Containment NR pressure Failed Channel A , Channel A high Containment pressure trip bypassed</p> <p>Turnover: 70% power 285 EFPD CCW Train B in service.</p> |   |                      |

| Event No. | Malf. No.              | Event Type*   | Event Description   |
|-----------|------------------------|---------------|---|
| 1         |                        | N-ACO<br>R-CO | <b>T+5</b><br>Raise power   |
| 2         | SG03A<br>RLP2          | I-ACO         | <b>T+15</b><br>2PT1023-1 Fails low (SG E088 pressure Protection Channel A)<br>Reactor Protection System Failure/Loss of Vital Inverter AOI<br><b>SO23-13-18</b> |
| 3         | ED11<br>RLP3           | I-ALL         | <b>T+25</b><br>Loss of all Control Room Annunciators <b>SO23-13-22</b>  |
| 3         | RC10B<br>RLP3          | I-CO          | <b>T+27</b><br>TE0111Y RCS cold leg Temperature input to RRS Fails high,<br>Pressurizer level set point 1 input failure.  |
| 4         | RLP4                   |               | <b>T+35</b><br>Small Earthquake, Earthquake AOI <b>SO23-13-3</b>  |
| 5         | CC03B<br>RLP4          | C-ACO         | <b>T+35</b><br>CCW train B pipe rupture<br>Loss of CCW/SWC AOI <b>SO23-13-7</b>   |
| 6         | RC07<br>RLP5           |               | <b>T+50</b><br>RCP 2P003 seized shaft Reactor Trip  |
| 6         | RC03<br>RLP5           | M-ALL         | Reactor Trip<br>Small Break LOCA  |
| 7         | RP01A<br>EC08E<br>RLP1 | C-CO          | SIAS<br>HPSI 17 Fail to Start of only available HPSI pump.<br>HPSI 19 OC Trip   |
| 8         |                        |               | EOI Actions starting with LOCA procedure SO23-12-3..  |
|           |                        |               |   |
|           |                        |               |   |

\* (N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor

Objectives:

- Evaluate the crew's ability to raise reactor power and control RCS temperature.
- The crew should recognize and respond to a failure of Steam Generator Pressure instrument.
- Respond to a Loss of Annunciators
- Evaluate the crew's response to a failure of an input to the Pressurizer Level Controller set point and control Pressurizer level.
- Evaluate the crew's response to a seismic event.
- Evaluate the crew's response to a loss of Component Cooling Water caused by a rupture of a Critical loop.
- Evaluate the crew's response to a Loss of Coolant Accident complicated by failure of the HPSI pump to start.
- Evaluate the crew's restoration of RCS subcooling.

#### Critical Tasks

##### CO

Manually control Pressurizer level.

Manually start HPSI pump after SIAS to provide adequate HPSI flow.

##### ACO

Transfer NCL to train A to prevent damage to RCP and Reactor Trip.

Cooldown to restore Core Exit Sat. margin to greater than 20°F

#### Core Damage Risk related events:

Event 5 Operator Action 19

6 Important Risk Accident

7 Operator Action 47

DYNAMIC NRC # 1  
MACHINE OPERATOR'S INSTRUCTIONS

| USER: NRCDYN           |      | IC: 61-70% POWER |  | M OF CYCLE |  | DYNAMIC NRC # 1 |           | SETUP RLP: 1         |  |
|------------------------|------|------------------|--|------------|--|-----------------|-----------|----------------------|--|
| CCW ALIGNED TO TRAIN B |      |                  |  |            |  |                 |           |                      |  |
| RLPs/STEPS             | TYPE | MALF #           | DESCRIPTION  |            |  |                 | DEM VALUE | INITIATING PARAMETER |  |
| 1(1)                   | OVER | MP-018           | HPSI PUMP MP-018 OOS FOR BOW                             |            |  |                 | MAG TAGS  | STARTUP OF SETUP RLP |  |
| 1(2)                   | OVER | PI-0351-1        | PI-0351-1 CHANNEL A CONTAINMENT NR PRESSURE IND. FAILURE |            |  |                 | BYPASSES  | STARTUP OF SETUP RLP |  |
| 1(3)                   | MF   | RP01A            | HPSI PUMP MP-017 AUTO START FAILURE                      |            |  |                 | TRUE      | STARTUP OF SETUP RLP |  |
| 1(4)                   | MF   | EC08E            | LOSS OF HPSI 19  |            |  |                 | TRUE      | SIAS                 |  |

| RLPs/STEPS | TYPE | MALF #       | DESCRIPTION  | DEM VALUE | RAMP   | DELAY                                   |
|------------|------|--------------|--|-----------|--------|---|
| 2(1)       | MF   | SG03A        | SG E-088 PRESSURE TRANSMITTER PT-1023-1 FAILS LOW  | 0%        | 2 MINS | 2 SECS                                  |
| 2(2)       | OVER | PPS BYPASSES | PPS DOOR OPEN ALARM<br>LO SG-2 PRESS<br>HI SG-1 DP EFAS 1<br>HI SG-2 DP EFAS 2<br>PPS DOOR OPEN ALARM CLEARS | TRUE      |        | 5 SECS<br>10 SECS<br>15 SECS<br>20 SECS |
| 3(1)       | MF   | ED11         | LOSS OF ANNUNCIATORS   | TRUE      |        |   |
| 3(2)       | MF   | RC10B        | RCS COLD LEG TEMP TE-0111Y FAILS HIGH  | 100%      | 2 MINS | 3 MINS                                  |
| 4(1 - 5)   | MF   | SIESMIC      | SMALL SIESMIC EVENTS   |           |        |   |
| 4(5)       | MF   | CC03B        | CCW TRAIN B PIPE RUPTURE   | 100       |        |   |
| 4(6)       | OVER | SIESMIC      | CLEAR SIESMIC ALARM  | DELETE    |        | 40 SECS                                 |
| 5(1)       | MF   | RC07         | RCP MP-003 SHAFT SEIZURE   | TRUE      |        |   |
| 5(2)       | MF   | RC03         | RCS LEAK INSIDE CONTAINMENT  | 10%       | 5 MINS | RX TRIP                                 |

(0) INDICATES THE SUB STEP OF THE INDICATED RLP.

Op-Test No.: 1      Scenario No.: 1      Event No.: 1

Page 4 of 15

Event Description: Raise reactor power

**CO Reactivity Manipulation****ACO Normal Evolution**

| Time | Position | Applicant's Actions or Behavior  |
|------|----------|--|
|      |          | <b>T+ 5</b>  |
|      | SRO      | Direct raising power.  |
|      |          |  |
|      | CO       | RAISE RCS temperature by dilution per SO23-3-2.2 Makeup Operations, Section for Dilution Makeup Mode.  |
|      |          |  |
|      | CO       | <ul style="list-style-type: none"> <li>● Selects HS 0210 Make Up Mode Selector to Dilution Mode.</li> <li>● Opens FV9253 Blended Makeup valve to VCT.</li> <li>● Verifies PMW Controller controls flowrate.</li> </ul> |
|      |          |  |
|      | ACO      | RAISE Turbine load, as necessary, to maintain Tc within the normal operating band of the chart in Attachment 3 of SO23-5-1.7, Power Operations.  |
|      |          |  |
|      |          | <b>End of event.</b>   |

Comments:

Op-Test No.: 1 Scenario No.: 1 Event No.: 2

Page 5 of 15

Event Description: Steam Generator # 2 EO88 2PT1023-1 Fails low pressure Protection Channel A.  
**ACO Instrument Failure**

| Time | Position | Applicant's Actions or Behavior  |
|------|----------|--|
|      |          | <b>CUE: Machine Operator contact evaluators at T+14 to verify execution of RLP#2 at T+ 15</b>  |
|      |          | <b>CUE: Machine Operator execute RLP #2 (1) (SG03A) per Lead Examiner</b>  |
|      |          | Alarms 56A51 SG2 E088 PRESS LO PRETRIP<br>56A54 SG1 E089 PRESS > SG2 E088 PRETRIP<br>56A41 SG2 E088 PRESS LO CHANNEL TRIP<br>56A44 SG1 E089 PRESS > SG2 E088 ESFAS CH TRIP<br>Indications 2PI1023A1 lowering (Channel A SGE088 Press.)<br>Pretrip and Trip lights on channel A PPS ROM |
|      | CO       | Refers to ARP for 56A41 SG2 E088 PRESS LO CHANNEL TRIP   |
|      |          |  |
|      | SRO      | Enter SO23-13-18 Reactor Protection System Failure/Loss of Vital Inverter AOI  |
|      |          |  |
|      | ACO      | Determine 2PI1023A1 is the only failed instrument  |
|      |          |  |
|      | SRO      | Determine A Single Functional Unit has FAILED.   |
|      |          |  |
|      |          | <b>Note</b> Tech Specs impacted<br>1 hr to place in bypass 3.3.1, 3.3.3  |
|      |          |  |
|      | SRO      | Request placing in bypass on Channel A:<br>S/G 2 Pressure - Low(RPS)<br>S/G 1 ΔP (EFAS 1)<br>S/G 2 ΔP (EFAS 2)   |
|      |          |  |
|      |          | <b>Cue: Machine Operator execute RLP #2 (2) to bypass the above trips.</b>   |
|      | CO       | Verify correct bypasses installed on correct channel   |

|  |  |                      |
|--|--|----------------------|
|  |  | <b>End of event.</b> |
|--|--|----------------------|

|            |                  |             |
|------------|------------------|-------------|
| Appendix D | Operator Actions | Form ES-D-2 |
|------------|------------------|-------------|

| Op-Test No.: 1    Scenario No.: 1    Event No.: 3  |          |  | Page <u>6</u> of <u>15</u> |
|--|----------|--|----------------------------|
| Event Description: Loss of All Control Room Annunciators with TE0111Y RCS Cold Leg Temperature Fails high, RRS input to Pressurizer level control level set point 1.<br><b>CO &amp; ACO Component Failure</b><br><b>CO Instrument Failure</b><br><b>CO Critical Task</b> |          |  |                            |
| Time   | Position | Applicant's Actions or Behavior (Event 3)  |                            |
|  |          | <b>CUE: Machine Operator</b> contact evaluators at <b>T+24</b> to verify execution of <b>RLP#3 at T+ 25</b>  |                            |
|  |          | <b>CUE: Machine Operator</b> execute RLP #3 (1) per Lead Examiner  |                            |
|  | CO       | Respond to Alarm 50C01 Loss of Annunciator   |                            |
|  |          |  |                            |
|  |          | <b>CUE: if requested to investigate 2L040 Annunciator Panel for Fire report no Fire.</b>   |                            |
|  |          |  |                            |
|  | CO/ACO   | Test All Annunciators  |                            |
|  |          |  |                            |
|  | CO/ACO   | Report all Annunciators have failed  |                            |
|  |          |  |                            |
|  | CO       | Secure Dilution<br>● Selects HS 0210 Make Up Mode Selector to Auto or Manual Mode.<br>● Closes FV9253 Blended Makeup valve to VCT.<br>● Verifies PMW flow stops. |                            |
|  |          |  |                            |
|  | SRO      | Direct Monitoring Plant Parameters per Loss of all Control Room Annunciators SO23-13-22 Att. 3   |                            |
|  |          |  |                            |
|  | SRO      | Contact Electrical Maint. to assist with troubleshooting.  |                            |
|  |          |  |                            |
|  | SRO      | Request CO to Report D5 bus Voltage  |                            |
|  |          |  |                            |

| Time | Position | Applicant's Actions or Behavior (Event 3)  |
|------|----------|--|
|      | CO       | Reports Bus Voltage normal   |
|      |          |  |
|      | SRO      | Request outside operator to verify normal D5 alignment and check status of D5P4 Breaker 74   |
|      |          |  |
|      |          | <b>CUE: if requested to get the status of the 2L040 DC Power and Power Normal lights are all extinguished.</b>                                       |
|      |          |  |
|      |          | Indications 2TI011AY rising<br>Min. letdown Max charging   |
|      |          |  |
|      | CO       | (Actions Directed by ARP 50A05 Tave HI)<br>Depress the "A/M" Button on 2LIC-0110, PZR Level Controller, to place PZR level control in MANUAL.        |
|      |          |  |
|      | CO       | Stop Charging Pumps to match Letdown flow as closely as possible.  |
|      |          |  |
|      | CO       | Adjust 2(3)LIC-0110, PZR Level Controller, to match Letdown and Charging flows.  |
|      |          |  |
|      | CO       | <i>Manually control pressurizer level</i>  |
|      |          |  |
|      |          | <b>CUE: Machine Operator report 2D5P4 Breaker 74 open not tripped, cleaning crew in the area and worker reports accidental contact with breaker.</b> |
|      |          |  |
|      | SRO      | Request the outside operator to reclose 2D5P4 Breaker 74   |
|      |          |  |
|      |          | <b>CUE: Machine Operator remove malfunction ED11 and report 2D5P4 Breaker 74 is closed</b>   |
|      |          |  |
|      | CO       | Determine T111AY has failed by comparing temperature instruments.  |
|      |          |  |
|      | CO       | Change LIC-0110 to level set point 2 and return to automatic   |

| Time | Position | Applicant's Actions or Behavior (Event 3)                            |
|------|----------|--|
|      |          |  |
|      | CO       | Checks Annunciators that are in alarm and verifies actions per ARPs. |
|      |          |  |
|      |          | <b>End of event.</b>   |

Comment:

---



---



Op-Test No.: 1 Scenario No.: 1 Event No.: 4

Page 9 of 15

Event Description: Seismic Event

**Abnormal Event - All**

| Time | Position | Applicant's Actions or Behavior  |
|------|----------|--|
|      |          | <b>CUE: Machine Operator</b> contact evaluators at <b>T+34</b> to verify execution of <b>RLP#4 at T+ 35</b>  |
|      |          | <b>CUE: Machine Operator</b> execute RLP #4 (1-5) per Lead Examiner  |
|      |          | Alarms 61C21 Seismic Recording System Activated  |
|      |          |  |
|      |          | <b>CUE: Floor Operator</b> report ground motion.   |
|      |          | <b>CUE: Machine Operator</b> Unit 1 SCFH Calls to report ground motion felt.   |
|      |          |  |
|      | ACO      | Reviews ARP 61C21 and informs the SRO that it directs entry into SO23-13-3, Earthquake.  |
|      |          |  |
|      | SRO      | Enter Earthquake AOI SO23-13-3 and determine the alarm is valid  |
|      |          |  |
|      | SRO      | Direct Attachment 4 to be performed  |
|      |          |  |
|      |          | <b>Cue : Machine Operator</b> when the Floor Operator is requested to perform Attachment 4 then remove seismic alarm 64A21 and have floor operator return a completed copy of attachment 4 of SO23-13-3. |
|      |          |  |
|      |          | <b>End of event.</b>   |

Comments:

Op-Test No.: 1 Scenario No.: 1 Event No.: 5

Page 10 of 15

Event Description: CCW Train B pipe rupture

**ACO component****ACO critical task**

| Time | Position | Applicant's Actions or Behavior (Event 5)  |
|------|----------|--|
|      |          | <b>CUE: Malfunction on timer from RLP#4 5 min ramp T+ 35</b>   |
|      |          | Alarms 64A08 CCW Pump Train B Disch Press lo<br>64A29 CCW Surge Tank Train B Level HI/LO<br>64A50 CCW Hx Train B Outlet Press LO<br>56C58 Safety Eqpt Bldg Sump Level HI-HI<br>57C56 Safety Eqpt Bldg Train B Flooding<br>Indications 2LI6499-2 T004 surge tank level lowering |
|      |          |  |
|      | SRO      | Enter SO23-13-7 Loss of CCW/SWC  |
|      |          |  |
|      | SRO      | Directs transfer of CCW Non Critical Loop to Train A CCW   |
|      |          |  |
|      | ACO      | <b>Transfer NCL to train A to prevent damage to RCP and Reactor Trip.</b><br>● Start 2P024.<br>● Open 2HV6212 and 2HV6218.<br>● Verify 2HV6213 and 2HV6219 close.  |
|      |          |  |
|      | SRO      | Directs transfer of Letdown Heat Exchanger to Train A CCW  |
|      |          |  |
|      | ACO      | Transfer of Letdown Heat Exchanger to Train A CCW<br>● Close 2HV6522B/A<br>● Open 2HV6593B/A   |
|      |          |  |
|      | SRO      | Direct stopping of CCW Pump P025   |
|      |          |  |
|      |          | <b>Note</b> Tech Specs impacted<br>72 hrs to restore to Operable CCW 3.7.7   |
|      |          |  |
|      |          | <b>End of event.</b>   |

| Time | Position | Applicant's Actions or Behavior (Event 5) |
|------|----------|---|
|------|----------|---|

Comments:

---

---

---

---

---

---

---

---

Op-Test No.: 1 Scenario No.: 1 Event No.: 6

Page 12 of 15

Event Description: RCP P003 seized shaft and Small break LOCA, Standard Post Trip Actions

| Time | Position | Applicant's Actions or Behavior (Event 7)   |
|------|----------|---|
|      |          | <b>CUE: Machine Operator</b> contact evaluators at <b>T+49</b> to verify execution of <b>RLP#5</b> at <b>T+ 50</b>  |
|      |          | <b>CUE: Machine Operator</b> execute RLP #5 (1)<br><b>Machine Operator</b> verify RC03 is active upon reactor trip and ramping to 10%   |
|      |          | Alarms 56C06 OC trip P003<br>56A35 Containment Press Hi Pretrip<br>56A55 Containment Sump Level Hi Hi<br>56A56 Containment Sump Level Hi<br>57C10 Containment Radiation hi<br>Indications 2LI5839 Containment Sump level rising<br>2RE7848 Rad Hi |
|      |          |   |
|      | SRO/CO   | <b>Reactivity Control</b> criteria satisfied.   |
|      |          |   |
|      | SRO/ACO  | <b>Vital Auxiliaries</b> criteria satisfied.  |
|      |          |   |
|      | SRO/CO   | <b>RCS Inventory Control</b> criteria not satisfied because Pressurizer level is not recovering.  |
|      |          |   |
|      | SRO/CO   | <b>RCS Pressure Control</b> criteria not satisfied because pressure is low and not recovering.  |
|      |          |   |
|      | SRO/CO   | <b>Core Heat Removal</b> criteria not satisfied because no RCPs operating.<br><b>Note</b> may be satisfied prior to CIAS.   |
|      |          |   |
|      | SRO/ACO  | <b>RCS Heat Removal</b> criteria satisfied.   |
|      |          |   |



Op-Test No.: 1 Scenario No.: 1 Event No.: 7

Page 14 of 15

Event Description: Failure of the only HPSI pump with CCW to start

**CO Component failure****CO Critical Task**

| Time | Position | Applicant's Actions or Behavior  |
|------|----------|--|
|      |          | <b>Note</b> Triggered by SIAS  |
|      |          | Alarms 57B21 Safety Inj Pump Train B OC<br><br>Indications FI-0311, FI-0321, FI-0331, and FI-0341 HPSI flow instruments indicate zero flow when RCS pressure is below shutoff head of the HPSI pumps |
|      |          |  |
|      | CO       | Recognize HPSI pump 17 Failed to start and HPSI 19 failed on a SIAS  |
|      |          |  |
|      | CO       | <b><i>Manually start HPSI pump 17 after SIAS to provide adequate HPSI flow.</i></b>  |
|      |          |  |
|      | SRO      | Direct Securing pumps cooled by CCW if Started by ESFAS signal if not needed to maintain a safety function.  |
|      |          |  |
|      |          | <b>End of event.</b>   |

Comments:

Op-Test No.: 1 Scenario No.: 1 Event No.: 8

Page 15 of 15

Event Description: Small break LOCA , LOCA procedure SO23-12-3

***ACO Critical task***

| Time | Position | Applicant's Actions or Behavior (Event 8)   |
|------|----------|---|
|      | SRO      | Direct the STA to initiate Attachment 1, Safety Function Status Check of SO23-12-3, LOCA.                                   |
|      |          |   |
|      | SRO      | VERIFY LOCA diagnosis, using Attachment 16, Break Identification Chart.   |
|      |          |   |
|      | CO       | Report Natural Circulation conditions not met and determine the need to increase feeding and steaming.                      |
|      |          |   |
|      | SRO      | Directs the ACO to STOP unloaded Diesel Generators.   |
|      |          |   |
|      | ACO      | STOP unloaded Diesel Generators.  |
|      |          |   |
|      | SRO      | Direct ARO to perform Attachment 12, Non-Qualified Loads Restoration  |
|      |          |   |
|      | SRO      | VERIFY SI pump flow - greater than minimum limits of Attachment 4, Minimum Expected SI Flowrates During Cold Leg Injection. |
|      |          |   |
|      | SRO      | Direct RCS Cooldown   |
|      |          |   |
|      | ACO      | INITIATE RCS Cooldown   |
|      |          |   |
|      | ACO      | <b><i>Cooldown to restore Core Exit Sat. margin to &gt;20 °F</i></b>  |
|      |          |   |
|      |          | Terminate when Core Exit Sat. margin restored to greater than 20°F  |

Comments

|   |                         |                       |
|---|-------------------------|-----------------------|
| Facility: <u>SONGS</u>  | Scenario No.: <u>2</u>  | Op-Test No.: <u>1</u> |
| Examiners: <u>T. Stetka</u>   | Operators: <u>SRO-2</u> |                       |
| <u>H. Bundy</u>   | <u>SURROGATE-CO</u>     |                       |
|   | <u>RO-ACO</u>           |                       |
| <p>Initial Conditions: 100% reactor power Middle of Core Life, 2HPSI 18 OOS, 2PI0351-1<br/>           Containment NR pressure Failed Channel A , Channel A high Containment pressure trip bypassed</p> <p>Turnover 100% power 285 EFPD CCW train B in service</p> |                         |                       |

| Event No. | Malf. No.          | Event Type*   | Event Description  |
|-----------|--------------------|---------------|--|
| 1         | CV22B<br>RLP9      | C-CO          | <b>T+5</b><br>2P191 Charging pump trips  |
| 2         | SG04A<br>RLP10     | I-ACO         | <b>T+10</b><br>2LT1106 SG 88 fails high.   |
| 3         | RC17B<br>RLP11     | I-CO          | <b>T+15</b><br>Pressurizer Press Trans Failure PT0102-2 low<br>Reactor Protection System Failure/Loss of Vital Inverter AOI<br><b>SO23-13-18</b> |
| 4         | SG01B<br>RLP12     | C-ALL         | <b>T+25</b><br>6gpm tube leak on SG E089   |
| 5         |                    | R-CO<br>N-ACO | <b>T+35</b><br>Plant shutdown per Reactor Coolant Leak AOI <b>SO23-13-14</b>   |
| 6         | CC06B<br>RLP13     | C-ACO         | <b>T+45</b><br>CCW Pump 25 trips on OC<br>Loss of Component Cooling Water/Saltwater Cooling AOI<br><b>SO23-13-7</b>                              |
| 7         | Overrides<br>RLP14 | M-ALL         | <b>T+50</b><br>Inadvertent MSIS  |
| 7         | MS01A<br>RLP14     |               | <b>Reactor Trip</b><br>Main Steam Safety Valve Failure PSV8401   |
| 8         |                    |               | Functional Recovery SO23-12-9  |

\* (N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor



## Objectives

- Evaluate the crew's response to the loss of a charging pump
- The crew should recognize and respond to a failure of Condenser Vacuum instrument
- The crew should recognize and respond to a failure of 1E Wide Range Pressurizer Pressure Instrument.
- Evaluate the crew's response to an RCS leak.
- Evaluate the crew's ability to lower reactor and turbine power.
- The crew should recognize and respond to a loss of a CCW Pump.
- Evaluate the crew's response to and recovery from an Excessive Steam Demand Event and a Steam Generator Tube Rupture.

## Critical Tasks

### CO

Perform HPSI throttle stop

### ACO

Prevent PTS

Restore CCW to the ECCS Equipment to prevent damage and loss.

## Core Damage Risk related events:

Event 4 Operator Action 26

6 Operator Action 19

DYNAMIC NRC # 2  
MACHINE OPERATOR'S INSTRUCTIONS

| USER: NRCDYN    IC:100% POWER    M OF CYCLE    DYNAMIC NRC #2    SETUP RLP: 8<br>CCW ALIGNED TO TRAIN B |      |           |  |           |                      |
|---|------|-----------|--|-----------|----------------------|
| RLPs/STEPS  | TYPE | MALF #    | DESCRIPTION  | DEM VALUE | INITIATING PARAMETER |
| 8(1)  | OVER | MP-018    | HPSI PUMP MP-018 OOS FOR BOW                             | MAG TAGS  | STARTUP OF SETUP RLP |
| 8(2)  | OVER | PI-0351-1 | PI-0351-1 CHANNEL A CONTAINMENT NR PRESSURE IND. FAILURE | BYPASSES  | STARTUP OF SETUP RLP |

| RLPs/STEPS | TYPE | MALF #       | DESCRIPTION  | DEM VALUE              | RAMP              | DELAY   |
|------------|------|--------------|--|------------------------|-------------------|---------|
| 9(1)       | MF   | CV22B        | CHARGING PUMP MP-191 OC/GRD  | TRUE                   |                   |         |
| 9(2)       | OVER | MP-191       | CHARGING PUMP MP-191 BREAKER RACKED-OUT ON TRAIN B                   | RACKED OUT (3)         |                   |         |
| 10(1)      | MF   | SG04A        | STEAM GENERATOR LEVEL LT 1106 FAILURE                                | 100                    |                   |         |
| 10(2)      | RF   | RX54         | SG E088 Control channel to LT1121                                    | 2                      |                   |         |
| 11(1)      | MF   | RC17B        | PZR PRESSURE INSTRUMENT PT-0102-2 FAILS LOW                          | 0%                     | 5 MINS            |         |
| 11(2)      | OVER | PPS BYPASSES | PPS DOOR OPEN ALARM<br>PZR PRESS LO BYPASS<br>PPS DOOR ALARM CLEARS  | TRUE<br>TRUE<br>DELETE | 5 SECS<br>10 SECS |         |
| 12(1)      | MF   | SG01B        | SG E-089 TUBE RUPTURE (6 GPM)  | 1%                     |                   |         |
| 13(1)      | MF   | CC06B & C    | CCW PUMP MP-025 TRIPS ON OC  | TRUE                   |                   |         |
| 13(2)      | OVER | MP-025       | CCW PUMP MP-025 BREAKER RACK-OUT AND KIRK KEY TRANSFERRED TO TRAIN A | 3                      |                   |         |
| 14(1)      | OVER | MSIS         | INADVERTENT MSIS   | TRUE                   |                   |         |
| 14(2)      | MF   | MS01A        | MAIN STEAM SAFETY PSV-8401 FAILS OPEN (E-088)                        | 35%                    |                   | RX TRIP |

(0) INDICATES THE SUB STEP OF THE INDICATED RLP.

Event Description: 2P191 Charging pump trips.

**CO Component**

| Time     | Position | Applicant's Actions or Behavior   |
|----------|----------|---|
|          |          | <b>CUE: Machine Operator</b> contact evaluators at T+4 to verify execution of RLP#9 at T+5                                |
|          |          | <b>CUE: Machine Operator</b> execute RLP#9 (1)  |
|          |          | Alarms 58A12 Charging Header Flow lo<br>58A43 Charging Pump P191 Train B OC<br><br>Indications Charging Flow goes to Zero |
|          |          |   |
|          | CO       | Determine the running charging pump tripped   |
|          |          |   |
|          | CO       | Start one of the remaining charging pumps   |
|          |          |   |
|          | CO       | Review ARP SO23-15-58A for 58A43 alarm Charging Pump P191 Train B OC  |
|          |          |   |
|          | SRO      | Request outside operator to investigate 2P191 Trip  |
|          |          |   |
|          |          | <b>CUE: Machine Operator</b> report the solid state device tripped 2P191 (little white button is extended)                |
|          |          | <b>CUE: Machine Operator</b> if requested to rack out 2P191 breaker execute RLP#9 (2)                                     |
|          |          | <b>End of event.</b>  |
| Comments |          |   |
|          |          |   |
|          |          |   |
|          |          |   |
|          |          |   |

Event Description: SG 88 Level LT 1106 fails high  
**ACO Instrument**

| Time | Position | Applicant's Actions or Behavior   |
|------|----------|---|
|      |          | <b>CUE: Machine Operator</b> contact evaluators at <b>T+9</b> to verify execution of <b>RLP#10 at T+10</b>          |
|      |          | <b>CUE: Machine Operator</b> execute RLP#10 (1)   |
|      |          | Alarms 52A01 SG 88 level HI/LO<br>52A02 SG 88 Level deviation<br><br>Indications SG E088 level rising               |
|      |          |   |
|      | ACO      | Take manual control of SG E088 level  |
|      |          |   |
|      | CO       | Review ARP for alarm 52A02 SG 88 Level deviation.   |
|      |          |   |
|      | ACO      | Determine LT1106 has failed.  |
|      |          |   |
|      | SRO      | Request ARO change FWCS #2 to selected level #2 (LT1121)  |
|      |          |   |
|      |          | <b>CUE Machine Operator Remote Function RX54 to 2</b><br><b>Report to SRO FWCS #2 to selected level #2</b>          |
|      | SRO      | Direct return to automatic FW control when level and setpoint are matched.  |
|      |          |   |
|      | ACO      | Restore FWCS to auto by verifying orange pointer, actual level, and black and white pointer, setpoint, are matched. |
|      |          |   |
|      |          | <b>End of event.</b>  |

Event Description: Pressurizer Press Trans Failure PT0102-2 low  
**CO Instrument**

| Time | Position | Applicant's Actions or Behavior (Event 3)   |
|------|----------|---|
|      |          | <b>CUE: Machine Operator contact evaluators at T+14 to verify execution of RLP#11 at T+ 15</b>  |
|      |          | <b>CUE: Machine Operator execute RLP#11 (1)</b>   |
|      |          | Alarms 56A06 PZR Press Lo Channel Trip<br>56A16 PZR Press Lo Pretrip<br>56B45 RCS Subcooled Margin Lo<br><br>Indications 2PI 0102A2 pressure lowering<br>2PI0102B pressure lowering<br>PPS ROM Trip and Pre Trip lights Channel 2<br>QSPDS Channel B low subcooling |
|      |          |   |
|      | CO       | Review ARP for 56A06 PZR Press Lo Channel Trip.   |
|      |          |   |
|      |          | Review ARP for 56B45 RCS Subcooled Margin Lo.   |
|      |          |   |
|      | SRO      | Enters SO23-13-18, Reactor Protection System Failure/Loss of Vital Inverter AOI .   |
|      |          |   |
|      | CO       | Determine 2PI 0102A2 is the only failed RPS instrument<br>Note input to LIC103 has also failed.   |
|      |          |   |
|      | SRO      | Determine A Single Functional Unit has failed.  |
|      |          |   |
|      |          | <b>Note</b> Tech Specs impacted<br>1 hr to place in bypass 3.3.1, 3.3.5   |
|      | SRO      | Request placing in bypass on Channel B:<br>Pressurizer Pressure - Low - (RPS)<br>Pressurizer Pressure - Low - (SIAS/CCAS)   |



Event Description: Steam Generator tube leak on SG E089

| Time | Position | Applicant's Actions or Behavior (Event 4)  |
|------|----------|--|
|      |          | <b>CUE: Machine Operator</b> contact evaluators at <b>T+24</b> to verify execution of <b>RLP#12 at T+ 25</b>   |
|      |          | <b>CUE: Machine Operator</b> execute RLP#12 (1)  |
|      |          | Alarm 60A46 Secondary Radiation Hi<br><br>Indications 2RE7818 (condenser) radiation levels rising.<br>2RE7870 (condenser) radiation levels rising.<br>2RE7874B1 (MSL) radiation levels rising.<br>2RE6753 (SG Blowdown) radiation levels rising.<br>Letdown flow lowers about 7gpm |
|      |          |  |
|      | CO       | Reviews ARP for alarm 60A46 Secondary Radiation Hi   |
|      |          |  |
|      | SRO      | Enters SO23-13-14, Reactor Coolant Leak AOI  |
|      |          |  |
|      | SRO      | Determine the leakage is within the Charging Pump capacity and CVCS makeup   |
|      |          |  |
|      | SRO      | Initiate SO23-3-3.37 RCS Water Inventory Balance.  |
|      |          |  |
|      | SRO      | REQUEST Chemistry to confirm and quantify Steam Generator Tube leak.   |
|      |          |  |
|      | SRO      | Initiates Att. 1 of SO23-13-14 to evaluate SG leakage by directing the ARO or STA to perform Att. 1  |
|      |          |  |
|      |          | <b>CUE: Floor Operator</b> If requested to evaluate leak rate report 6gpm or 8640gpd   |





Op-Test No.: 1    Scenario No.: 2    Event No.: 2

Page 10 of 14

Event Description:      Plant shutdown

**CO Reactivity**

**ACO Normal**

| Time | Position | Applicant's Actions or Behavior  |
|------|----------|--|
|      |          | <b>T+35</b>  |
|      | SRO      | Direct performance of SO23-13-14 Att. 3 to min. contamination during a SG Tube Leak. |
|      |          |  |
|      | ACO      | Perform of SO23-13-14 Att. 3 to min. contamination during a SG Tube Leak             |
|      |          |  |
|      | CO       | Begin boration   |
|      |          |  |
|      | ACO      | Reduce Turbine load and maintain Tc within the Tech Spec Band                        |
|      |          | <b>End of event.</b>   |

Comments:

Event Description: CCW Pump 25 trips on OC  
**ACO Component**

| Time | Position | Applicant's Actions or Behavior  |
|------|----------|--|
|      |          | <b>CUE: Machine Operator</b> contact evaluators at <b>T+44</b> to verify execution of <b>RLP#13 at T+ 45</b>   |
|      |          | <b>CUE: Machine Operator</b> execute RLP#13 (1)  |
|      |          | Alarms 64A22 CCW Pump Train B OC<br>56C34 RCP P001 CCW Flow lo<br>56C36 RCP P003 CCW Flow lo<br>56C38 RCP P004 CCW Flow lo<br>56C40 RCP P002 CCW Flow lo<br><br>Indications 2P025 hand switch bright green light |
|      |          |  |
|      | ACO      | Report 2P025 has tripped and refer to ARP for 64A22 CCW Pump Train B OC.   |
|      |          |  |
|      | SRO      | Direct Starting 2P026 (per ARP 64A22)<br><b>OR</b><br>Ensure that 2P024 is running and direct transfer of NCL and LDHX to train A (Per AOI)  |
|      |          |  |
|      | ACO      | Start 2P026 if Directed<br><b>OR</b><br>Transfer NCL and LDHX if directed train A  |
|      |          |  |
|      | SRO      | Direct outside operator to determine the breaker status  |
|      |          |  |
|      |          | <b>CUE: Machine Operator</b> 186 relay and 151N relay actuated on 2AO608 for 2P025 train B no other signs of distress.   |
|      |          | <b>CUE: If requested to rack out 2AO608 delay until 2P026 is started by crew.</b>  |
|      |          | <b>End of event.</b>   |

Op-Test No.: 1 Scenario No.: 2 Event No.: 7Page 12 of 14

Event Description: Inadvertent MSIS with a stuck open SG E088 safety.

**ACO Component**  
**ACO Critical Task**

| Time | Position | Applicant's Actions or Behavior (Event 7)   |
|------|----------|---|
|      |          | <b>CUE: Machine Operator contact evaluators at T+49 to verify execution of RLP#14 at T+ 50</b>  |
|      |          | <b>CUE: Machine Operator execute RLP#14 (1)</b>   |
|      |          | Alarms 52A20 MSIV HV-8205 Trouble<br>52A30 MSIV HV-8204 Trouble<br>50A05 T AVG HI<br>50A07 SBCS Demand Present<br>56A15 PZR Press Hi Pretrip<br>Indications Hand Switches for MSIVs closed lights lit |
|      |          |   |
|      | ALL      | Trip the Reactor and enter SO23-12-1 SPTA   |
|      |          |   |
|      | SRO/CO   | <b>Reactivity Control</b> criteria satisfied.   |
|      |          |   |
|      | SRO/ACO  | <b>Vital Auxiliaries</b> criteria satisfied.  |
|      |          |   |
|      | SRO/CO   | <b>RCS Inventory Control</b> criteria - not satisfied because level is not trending up.   |
|      |          |   |
|      | SRO/CO   | <b>RCS Pressure Control</b> criteria not satisfied because pressure is not controlled.  |
|      | ACO      | If Alarms 64A8, 18, and 28 are in then Start 2P026<br><b>Restore CCW to the ECCS Equipment to prevent damage and loss.</b><br>(May have been performed earlier)                                       |
|      |          |   |
|      | SRO/CO   | <b>Core Heat Removal</b> criteria satisfied.  |
|      |          |   |
|      |          |   |



Event Description:      SO23-12-9 Functional Recovery actions.

***CO Critical Task******ACO Critical task***

| Time | Position | Applicant's Actions or Behavior   |
|------|----------|---|
|      | SRO      | Direct the STA to Initiate Attachment 1, Safety Function Status Check per SO23-12-9, Functional Recovery.   |
|      |          |   |
|      | SRO      | Direct HPSI Throttle Stop FS 7  |
|      |          |   |
|      | CO       | <b><i>Perform HPSI throttle stop</i></b>  |
|      |          |   |
|      | SRO      | Direct the ACO to stop unloaded Diesel Generators.  |
|      |          |   |
|      | ACO      | Stop unloaded Diesel Generators   |
|      |          |   |
|      | SRO      | Direct ACO to initiate attachment 2, FS-27 establish stable RCS temperature during ESDE   |
|      |          |   |
|      | ACO      | <b><i>Prevent PTS</i></b> by initiating attachment 2, FS-27, establish stable RCS temperature during ESDE<br><br>@ 10% Level Position ADV 10% open in manual for least affected S/G<br>@ 5% Level Set least affected S/G ADV at $P_{sat}$ for lowest $T_C$ and place in auto.<br>@ Initial Dry Out Adjust least affected S/G ADV at $P_{sat}$ for lowest $T_C$ attained as S/G boils dry. |
|      |          |   |
|      |          |   |
|      |          |   |
|      |          | <b>Terminate scenario when the RCS is stable and HPSI throttle stop has been performed.</b>   |

|   |                         |                       |
|---|-------------------------|-----------------------|
| Facility: <u>SONGS</u>  | Scenario No.: <u>3</u>  | Op-Test No.: <u>1</u> |
| Examiners: <u>H. Bundy</u>  | Operators: <u>SRO-3</u> |                       |
| <u>T. Stetka</u>  | <u>SRO-1-CO</u>         |                       |
| <u>T. Stetka</u>  | <u>SRO-2-ACO</u>        |                       |
| <p>Initial Conditions: 100% reactor power Middle of Core Life,, 2HPSI 18 OOS, 2PI0351-1<br/>           Containment NR pressure Failed Channel A , Channel A high Containment pressure trip bypassed</p> <p>Turnover: 100% power 285 EFPD CCW train B in service</p> |                         |                       |

| Event No. | Malf. No.      | Event Type*   | Event Description  |
|-----------|----------------|---------------|--|
| 1         | NI08E<br>RLP18 | I-CO          | <b>T+ 5</b><br>Linear Amplifier Failure Ch 1 Middle detector amplifier failed low.<br>Reactor Protection System Failure/Loss of Vital Inverter <b>SO23-13-18</b> |
| 2         | ED03A<br>RLP19 | C-ALL         | <b>T+ 15</b><br>Loss of 2A04 Bus   |
| 3         | RX11A<br>RLP20 | I-ACO         | <b>T+25</b><br>2MP062 Main Feedwater Pump Speed failure  |
| 4         |                | R-CO<br>N-ACO | <b>T+ 35</b><br>Down power due to Tech Spec LCO 3.0.3  |
| 4         | FW17A<br>RLP21 | C-ACO         | Initiate when down power started<br>Input to 2FV1121 Main Feedwater Regulating Valve fails   |
| 5         | MS03A<br>RPL22 | M-ALL         | <b>T+ 45</b><br>Steam line break inside containment SG E089  |
| 5         | CS03B<br>RLP17 | C-CO          | <b>SIAS</b><br>Loss of Containment Spray Pump P013   |
| 6         |                |               | Excessive Steam Demand Event SO23-12-5 and Functional Recovery SO23-12-9   |
|           |                |               |  |
|           |                |               |  |
|           |                |               |  |
|           |                |               |  |
|           |                |               |  |

\* (N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor

---

Objectives:

- The crew should recognize and respond to a failure of Excore NI.
- Evaluate the crew's response to the loss of a 1E 4kv bus.
- Evaluate the crew's ability to lower reactor and turbine power.
- The crew should recognize and respond to an input failure to Main Feedwater Reg. Valve.
- Evaluate the crew's response to an ESDE inside containment without Containment Spray.
- The crew should recognize and respond to a loss of Containment Spray Pump.

Critical Tasks:

CO

Perform HPSI throttle stop.

ACO

Control SG level on line to prevent Reactor trip.

Prevent PTS

Core Damage Risk related events:

Event 2 Operator Action 9

DYNAMIC NRC # 3  
MACHINE OPERATOR'S INSTRUCTIONS

| USER: NRC DYN    IC:100% POWER    M OF CYCLE    DYNAMIC NRC #3    SETUP RLP: 18<br>CCW ALIGNED TO TRAIN B |      |           |  |           |                      |
|---|------|-----------|--|-----------|----------------------|
| RLPs/STEPS  | TYPE | MALF #    | DESCRIPTION  | DEM VALUE | INITIATING PARAMETER |
| 17(1)   | OVER | MP-018    | HPSI PUMP MP-018 OOS FOR BOW                             | MAG TAGS  | STARTUP OF SETUP RLP |
| 17(2)   | OVER | PI-0351-1 | PI-0351-1 CHANNEL A CONTAINMENT NR PRESSURE IND. FAILURE | BYPASSES  | STARTUP OF SETUP RLP |
| 17(3)   | MF   | CS03B     | LOSS OF CONTAINMENT SPRAY PUMP MP-013                    | TRUE      | SIAS A & B           |

| RLPs/STEPS | TYPE | MALF #       | DESCRIPTION   | DEM VALUE                                      | RAMP    | DELAY  |
|------------|------|--------------|---|--|---------|--|
| 18(1)      | MF   | NI08E        | CHANNEL 1 LINEAR AMPLIFIER MIDDLE DETECTOR FAILURE  | 0%   |         |  |
| 18(2)      | OVER | PPS BYPASSES | PPS DOOR OPEN ALARM<br>HI LIN POWER<br>HI LOCAL POWER<br>LOW DNBR<br>LOSS OF LOAD<br>PPS DOOR OPEN ALARM CLEARS | TRUE<br>TRUE<br>TRUE<br>TRUE<br>TRUE<br>DELETE |         | 5 SECS<br>10 SECS<br>15 SECS<br>20 SECS<br>25 SECS |
| 19(1)      | MF   | ED03A        | LOSS OF 4KV EMERGENCY BUS 2A04  | TRUE   |         |  |
| 20(1)      | MF   | RX11A        | MFWP P062 (K006) SPEED FAILURE  | 0  |         |  |
| 21(1)      | MF   | RX09A        | INPUT TO 2FV1121 MAIN FEEDWATER REGULATING VALVE FAILS  | 83   |         |  |
| 22(1)      | MF   | MS03B        | MAIN STEAM LINE BREAK INSIDE CONTAINMENT E-089  | 1 to 3%  | 15 MINS |  |

(0) INDICATES THE SUB STEP OF THE INDICATED RLP.



Op-Test No.: 1 Scenario No.: 3 Event No.: 1Page 4 of 11Event Description: Linear Amplifier Failure Ch 1 Middle detector fail low SO23-13-18**CO Instrument Failure**

| Time | Position | Applicant's Actions or Behavior  |
|------|----------|--|
|      |          | <b>CUE: Machine Operator contact evaluators at T+4 to verify execution of RLP#18 at T+ 5</b>   |
|      |          | <b>Cue: Machine Operator execute RLP#18 (1)</b>  |
|      |          | Alarms 56B06 PPS Channel 1 Trouble<br>56A03 Local Power Level Hi Channel Trip<br>56A04 DNBR Lo Channel Trip<br>56A13 LOCAL Power Density Hi Pretrip<br>56A14 DNBR Lo RPS Pretrip<br><br>Indications Channel A 2JR0002A1 Cal. Lin Pwr. Mid scale.<br>2JR0002B1 Lin Pwr Mid scale. |
|      | CO       | Respond to alarms and identify 2JR0002A1 and 2JR0002B1 failed on channel A   |
|      |          |  |
|      | SRO      | Enter SO23-13-18 Reactor Protection System Failure/Loss of Vital Inverter  |
|      |          |  |
|      | SRO      | Determine A Single Functional Unit has failed.   |
|      |          |  |
|      |          | <b>Note</b> Tech Spec impacted<br>1 hr to place in bypass LCO 3.3.1  |
|      | SRO      | Request the following bypasses installed on channel A<br>Linear Power Level - High<br>Local Power Density - High<br>DNBR - Low<br>Loss of Load   |
|      |          |  |
|      |          | <b>Cue: Machine Operator execute RLP#18 (2) to bypass the above.</b>   |

|  |  |                      |
|--|--|----------------------|
|  |  | <b>End of Event.</b> |
|--|--|----------------------|

Appendix D

Operator Actions

Form ES-D-2

Op-Test No.: 1 Scenario No.: 3 Event No.: 2Page 5 of 11Event Description: Loss of Vital 4kv bus 2A04**Component All**

| Time | Position | Applicant's Actions or Behavior   |
|------|----------|---|
|      |          | <b>CUE: Machine Operator contact evaluators at T+14 to verify execution of RLP#19 at T+ 15</b>  |
|      |          | <b>CUE: Machine Operator execute RLP#19 (1)</b>   |
|      |          | Alarms 63B14 Unit 2 Non 1E UPS Trouble<br>63B25 2A04 Supply Bkr 2A0418 OC<br>63B05 2A04 Voltage Lo<br>63B06 2B04 Voltage Lo<br>Numerous other alarms due to loss of power to equipment.<br>Indications No voltage on the 4kv bus 2A04 |
|      | ACO      | Place 2G002 Train A Emergency Diesel Generator in Maint. Lockout.<br>Note: EDG will trip when placed in Maint. Lockout.   |
|      |          |   |
|      | ACO      | ARP indicates Unit is in 3.0.3 Tech Spec due to 2 1E Battery chargers OOS.  |
|      |          |   |
|      | CO       | Place CVCS blended makeup selector switch in manual to prevent dilution.  |
|      |          |   |
|      |          | <b>Cue: Machine Operator</b> When asked to investigate as the outside operator report the smell of smoke and the 150 and 151 and 186 protection relays actuated and strong smell of smoke.  |
|      |          | <b>Cue: Machine Operator</b> When asked to investigate as maintenance report bus damage that will require a clearance to investigate and repair, no possibility of returning to service without repairs.                              |
|      |          | <b>Cue: Machine Operator</b> If requested to place temporary Battery Chargers in service report cleared for Maintenance.  |
|      |          | <b>End of Event.</b>  |

---

Comments:

---

Appendix D

Operator Actions

Form ES-D-2

Op-Test No.:   1   Scenario No.:   3   Event No.:   3  

Page  6  of 11

Event Description: Main Feedwater Pump P062 (K006) Speed input fails low  
**ACO instrument**

| Time | Position | Applicant's Actions or Behavior   |
|------|----------|---|
|      |          | <b>CUE: Machine Operator contact evaluators at T+24 to verify execution of RLP#20 at T+ 25</b>  |
|      |          | <b>CUE: Machine Operator execute RLP#20 (1)</b>   |
|      |          | Alarms 52A01 SG88 level HI/LO<br>52A06 SG89 level HI/LO<br>53A20 MFWP MINI FLOW VALVE OPEN<br>53A28 MFWP P062 FLOW LO<br>Indications MP62 K006 speed lowering<br>MP63 K005 speed increasing |
|      | SRO      | Determine K006 speed is failing by the output of both FWCS outputs increasing.  |
|      |          |   |
|      | SRO      | Direct the ACO to take manual control of K006 speed   |
|      |          |   |
|      | ACO      | Take manual control of K006 speed with EAP and raise speed  |
|      |          |   |
|      | SRO      | Discuss actions if the plant trips to prevent trip of both FW pumps on high discharge pressure  |
|      |          |   |
|      |          | <b>End of Event.</b>  |

Comments:

---

Op-Test No.: 1 Scenario No.: 3 Event No.: 4Page 7 of 11

Event Description: Tech Spec LCO 3.0.3 plant shutdown and 2FV1121 Feedwater Regulating Valve input failure.

**CO Reactivity****ACO Normal****ACO Component*****ACO Critical Task***

| Time | Position | Applicant's Actions or Behavior   |
|------|----------|---|
|      |          | <b>CUE: Floor Operator as the Shift Manager direct down power at T+35</b>   |
|      | SRO      | Reviews the guidelines of SO23-5-1.7 Power Operations to do the down power. |
|      |          |   |
|      | SRO      | Directs plant shutdown to comply with Tech Specs                            |
|      |          |   |
|      |          | <b>CUE: Machine Operator execute RLP#21</b>                                 |
|      | CO       | Starts boration with BAMU gravity feed valves or the RWST suction valve     |
|      |          |   |
|      | ACO      | Reduces Turbine load to maintain RCS temp.                                  |
|      |          |   |

|  |     |  |
|--|-----|--|
|  |     | Alarms 52A01 SG2 E088 Level HI/LO<br><br>Indications FIC1121 valve demand lowering<br>2FV1106 closing<br>2FV1106 Closed light on<br>2FIC1121 FWCS Master Controller 2FIC 1121 compensated level red pen rising |
|  | ACO | Take manual control of 2FV1121 Feedwater Reg. Valve.   |
|  |     |  |
|  | ACO | <b><i>Control SG. level on line to prevent Reactor trip.</i></b>   |
|  |     |  |
|  |     | <b>End of Event.</b>   |

Comments:

Appendix D

Operator Actions

Form ES-D-2

| Op-Test No.: <u>  1  </u> Scenario No.: <u>  3  </u> Event No.: <u>  5  </u> |          |  | Page <u>  8  </u> of <u>  11  </u> |
|--|----------|--|------------------------------------|
| Event Description: Main Steam Line Break in Containment.                     |          |  |                                    |
| Time   | Position | Applicant's Actions or Behavior (Event 5)  |                                    |
|  |          | <b>CUE: Machine Operator contact evaluators at T+44 to verify execution of RLP#22 at T+45</b>  |                                    |
|  |          | <b>CUE: Machine Operator execute RLP#22 (1)</b>  |                                    |
|  |          | Alarms 60A03 Containment/FHB Temperature High<br>56A17 Containment Pressure Hi ESFAS Pretrip<br>56A35 Containment Pressure Hi Pretrip<br><br>Indications 2TJR9899 points 2&3 in alarm<br>Containment pressure instruments rising |                                    |
|  | CO       | Report containment parameter trends  |                                    |
|  |          |  |                                    |
|  | SRO      | Direct Reactor Trip  |                                    |
|  |          |  |                                    |
|  | CO/ACO   | Manually trip the reactor  |                                    |
|  |          |  |                                    |

| Time | Position | Applicant's Actions or Behavior (Event 5)  |
|------|----------|--|
|      | SRO/CO   | <b>Reactivity Control</b> criteria satisfied   |
|      |          |  |
|      |          | <b>Note</b> When SIAS is actuated Containment Spray Pump trips.  |
|      |          | Alarms 57B23 Containment Spray Pump P013 OC<br><br>Indications Bright Stop light on hand switch for P013<br>No Spray flow after CSAS |
|      | CO       | Report the failure of P013   |
|      |          |  |
|      | CO       | Report no Spray Flow after CSAS  |
|      |          |  |

| Time | Position       | Applicant's Actions or Behavior (Event 5)   |
|------|----------------|---|
|      | SRO/ACO        | <b>Vital Auxiliaries</b> criteria satisfied:  |
|      |                |   |
|      | SRO/CO         | <b>RCS Inventory Control</b> criteria - not satisfied because Pressurizer level is not rising.  |
|      |                |   |
|      | SRO/CO         | <b>RCS Pressure Control</b> criteria not satisfied because Pressurizer Pressure is low.   |
|      |                |   |
|      | SRO/CO         | <b>Core Heat Removal</b> criteria not satisfied because all RCPs are secured. <b>Note</b> may be satisfied prior to CIAS.                               |
|      |                |   |
|      | SRO/ACO<br>ACO | <b>RCS Heat Removal</b> criteria not satisfied because SG pressure is low:<br><i>Close Feedwater block valve to prevent overfilling Steam Generator</i> |
|      |                |   |
|      | SRO/CO         | <b>VERIFY Containment Isolation</b> criteria not satisfied because Containment pressure is high.  |
|      |                |   |
|      | SRO/CO         | <b>Containment Temperature, Pressure and Combustible Gas Control</b> criteria not satisfied because Containment pressure and temperature are high.      |
|      |                |   |
|      | SRO            | <b>DIAGNOSE Event in Progress</b> , using the Diagnostic chart from SO23-12-1as an ESDE go to SO23-12-5   |

Comments:

---



---



---



---



---



---



---



---

Op-Test No.: 1 Scenario No.: 3 Event No.: 6Page 10 of 11

Event Description: Excessive Steam Demand Event SO23-12-5 and Functional Recovery SO23-12-9

**CO Critical Task****ACO Critical Task**

| Time | Position | Applicant's Actions or Behavior (Event 6)  |
|------|----------|--|
|      | SRO      | Direct performance of Att. 2 FS7 HPSI Throttle stop  |
|      |          |  |
|      | SRO      | Direct performance of the Safety Function Status Check Att. 1  |
|      |          |  |
|      | SRO      | Confirm ESDE diagnosis   |
|      |          |  |
|      | SRO      | Request Chemistry to Sample both Steam Generators  |
|      |          |  |
|      |          | <b>CUE: Machine Operator If the sample valves are not overridden and opened then report to SRO no sample flow.</b>         |
|      | STA      | Report Failure of Containment Pressure and Temperature Control due to no Containment Spray flow and only 2 ECUs operating. |
|      |          |  |
|      | SRO      | Rediagnose ESDE<br>Announce going to SO23-12-9 Functional Recovery Procedure   |
|      |          |  |
|      | SRO      | Direct CO to perform SO23-12-9 Attachment 10   |
|      |          |  |
|      | SRO      | Direct the STA to Initiate Attachment 1, Safety Function Status Check  |
|      |          |  |
|      | SRO      | Direct the ACO to stop unloaded Diesel Generators  |
|      |          |  |



| Time | Position | Applicant's Actions or Behavior (Event 6)   |
|------|----------|---|
|      | SRO      | Direct ACO to initiate attachment 29, Isolation of S/G with ESDE and<br>Direct attachment 2, FS-27 establish stable RCS temperature during ESDE   |
|      |          |   |
|      | ACO      | <b><i>Prevent PTS</i></b> by initiate attachment 2, FS-27, establish stable RCS temperature during ESDE.<br><br>@ 10% Level Position ADV 10% open for least affected S/G<br>@ 5% Level Set least affected S/G ADV at $P_{sat}$ for lowest $T_C$ .<br>@ Initial Dry Out Adjust least affected S/G ADV at $P_{sat}$ for lowest $T_C$ attained as S/G boils dry. |
|      |          |   |
|      | CO       | <b><i>Perform HPSI Throttle Stop</i></b> by initiate attachment 2, FS-7 HPSI Throttle Stop.   |
|      |          |   |
|      |          | Terminate the Scenario after RCS temperature is controlled and HPSI throttle stop met.  |

## Comments

|   |   |  |
|---|---|--|
| Facility: San Onofre 2 & 3                      |   | Date of Examination: <b>09/25/00</b>   |
| Examination Level (circle one): <b>RO</b> / SRO |   | Operating Test Number: 1   |
| Administrative Topic/Subject Description        |   | Describe method of evaluation:<br>1. ONE Administrative JPM, OR<br>2. TWO Administrative Questions |
| A.1   | Shift Staffing<br>J173A<br>[K/A 2.1.3 (3.0)]            | Determine Proper Crew Complement   |
|   |   |  |
|   | Plant Data<br>Evaluation<br>J053S<br>[K/A 2.1.23 (3.9)] | Calculate the Time Until Shutdown Cooling is Required  |
|   |   |  |
| A.2   | Equipment<br>Control<br>N167A<br>[K/A 2.2.13 (3.6)]     | Disable a Nuisance Annunciator   |
|   |   |  |
| A.3   | Radiation<br>Controls<br>N166A<br>[K/A 2.3.10 (2.9)]    | Determine Dose Rates and Contaminated Areas on HP Survey Map                                       |
|   |   |  |
| A.4   | Emergency<br>Plan<br>J157A<br>[K/A 2.4.39 (3.3)]        | Perform Siren and PA Coordination During Emergency Plan Implementation                             |
|   |   |  |

|  |   |                                      |                         |
|--|---|--------------------------------------|-------------------------|
| Facility: San Onofre 2 & 3   |   | Date of Examination: <b>09/25/00</b> |                         |
| Exam Level (circle one): <b>RO</b> / SRO(I) / SRO(U)   |   | Operating Test Number: 1             |                         |
| <b>B.1 Control Room Systems</b>  |   |                                      |                         |
| System / JPM Title   |   | Type Code*                           | Safety Function         |
| a. AC  | Transfer 2A04 from the Bus Tie to the Reserve Auxiliary Transformer       | D, S                                 | <b>6</b><br>J054S       |
| b. ESFAS   | Perform RAS Actuation Verification  | D, S, A                              | <b>2</b><br>J113FS      |
| c. <b>MSS/AFW</b>  | Perform Affected SG Isolation During SGTR                                 | M, S, A                              | <b>4</b><br>J094FS      |
| d. RHR   | Perform Actions for a Loss of Shutdown Cooling                            | N, S, L                              | <b>4</b><br>N152S       |
| e. CVCS  | Perform an Emergency Boration   | D, S, A                              | <b>1</b><br>J025FS      |
| f. RPS   | Restore a Bypassed RPS Channel to Service                                 | D, S                                 | <b>7</b><br>J143S       |
| g. CSS   | Terminate Containment Spray   | N, S, A                              | <b>5</b><br>J049FS      |
| <b>B.2 Facility Walk-Through</b>   |   |                                      |                         |
| a. FPS   | Perform the Duties of the Unit 2 CO Following Control Room Evacuation     | D, R                                 | <b>8</b><br>J004        |
| b. <b>PZR PCS</b>  | <b>Perform Manual Auxiliary Spray Actions in the Penetration Building</b> | N                                    | <b>3</b><br><b>N148</b> |
| c. CRDS  | Locally Perform ATWS Actions  | D, R                                 | <b>1</b><br>J021        |
| * Type Codes: (D)irect from bank, (M)odified from bank, (N)ew, (A)lternate path, (C)ontrol room, (S)imulator, (L)ow-Power, (R)CA |   |                                      |                         |

|  |  |  |
|--|--|--|
| Facility: San Onofre 2 & 3                         |  | Date of Examination: <b>09/25/00</b>   |
| Examination Level (circle one): RO / <b>SRO(U)</b> |  | Operating Test Number: <b>1</b>  |
| Administrative Topic/Subject Description           |  | Describe method of evaluation:<br>1. ONE Administrative JPM, OR<br>2. TWO Administrative Questions |
| A.1  | Parameter Verification<br>N169A<br>[K/A 2.1.20 (4.2)]    | Determine Required Boron Concentration for Cooldown to Mode 5                                      |
|  |  |  |
|  | Surveillance Verification<br>N170A<br>[K/A 2.1.12 (4.0)] | Verify Equipment Operability   |
|  |  |  |
| A.2  | Equipment Control<br>N167A<br>[K/A 2.2.13 (3.8)]         | Disable a Nuisance Annunciator   |
|  |  |  |
| A.3  | Radiation Controls<br>N166A<br>[K/A 2.3.10 (3.3)]        | Determine Dose Rates and Contaminated Areas on HP Survey Map                                       |
|  |  |  |
| A.4  | Emergency Plan<br>J126S<br>[K/A 2.4.44 (4.0)]            | Determine Protective Action Recommendations  |
|  |  |  |

Facility: San Onofre 2 &amp; 3

Date of Examination: 09/25/00

Exam Level (circle one): RO / SRO(I) / SRO(U)

Operating Test Number: 1

## B.1 Control Room Systems

| System / JPM Title                                    | Type Code* | Safety Function    |
|---|------------|--------------------|
| a.  |            |                    |
| b. ESFAS Perform RAS Actuation Verification           | D, S, A    | <b>2</b><br>J113FS |
| c.  |            |                    |
| d. RHR Perform Actions for a Loss of Shutdown Cooling | N, S, L    | <b>4</b><br>N152S  |
| e.  |            |                    |
| f.  |            |                    |
| g. CSS Terminate Containment Spray                    | N, S, A    | <b>5</b><br>J049FS |

## B.2 Facility Walk-Through

|  |      |                  |
|--|------|------------------|
| a. FPS Perform the Duties of the CRS Following Control Room Evacuation | D    | <b>8</b><br>J019 |
| b. CRDS Locally Perform ATWS Actions                                   | D, R | <b>1</b><br>J021 |
| c.   |      |                  |

\* Type Codes: (D)irect from bank, (M)odified from bank, (N)ew, (A)lternate path, (C)ontrol room, (S)imulator, (L)ow-Power, (R)CA

---

## JPM INFORMATION SHEET

### JPM NUMBER

J173A

### INITIAL PLANT CONDITIONS

Unit 2 is in Mode 5 and Unit 3 is in Mode 1 at 100% power.

The following people are inside the Protected Area as members of the oncoming shift operating crew:

|        |               |        |      |
|--------|---------------|--------|------|
| Joe:   | Shift Manager | Sam:   | PPEO |
| Bill:  | CRS           | Sally: | PPEO |
| Tom:   | CRS           | Ron:   | PPEO |
| Andy:  | CO            | Al:    | PEO  |
| Arnie: | CO            | Mary:  | PEO  |
| Dave:  | ACO           | Bob:   | STA  |

### TASK TO BE PERFORMED

Determine if each individual crew position meets the minimum "administrative" manning requirements for shift relief.

**J173A**

OPERATOR'S NAME: \_\_\_\_\_  
(Print)

**SATISFACTORY:** \_\_\_\_\_

UNSATISFACTORY: \_\_\_\_\_

---

## DOCUMENTATION

J173A

JPM LEVEL: RO/SRO

ESTIMATED TIME TO COMPLETE: 10 minutes

TIME CRITICAL JPM: NO CRITICAL TIME: N/A

POSITION: CO/ACO

TASK SYS ID: 3212

**TASK DESCRIPTION:**

Describe the guidelines and administrative requirements for operations shift relief.

KA NUMBER: 2.1.3

KA VALUES: RO 3.0 SRO 3.4

10CFR55.45 APPLICABILITY: 12

**REFERENCES:**

S023-0-46, Conduct of Operations, Rev. 1, TCN 1-4.

AUTHOR: K. Rauch DATE: 08/30/00

OPERATIONS REVIEW: R. Clement DATE: 09/04/00

APPROVED BY: W. Lyke DATE: 09/05/00



---

**MODIFICATION HISTORY**

| REV | DESCRIPTION OF CHANGE | MODIFIED<br>BY | DATE<br>MODIFIED | SOL<br>APPROVAL |
|-----|-----------------------|----------------|------------------|-----------------|
| 0   | New                   |                |                  |                 |
|     |                       |                |                  |                 |

---

**SET-UP**

Provide the examinee with a copy of Section 6.25, Shift Manning of SO23-0-46, Conduct of Operations, when requested.

**JPM: J173A TITLE:** Determine Administrative Shift Manning Requirements

\* Denotes a CRITICAL STEP

| NO  | PERFORMANCE STEP   | STANDARD   | S/U | Comments<br>(Required for Unsat) |
|---|--|--|-----|----------------------------------|
| <b>NOTE: Provide the examinee with a copy of Section 6.25, Shift Manning of S023-0-46, Conduct of Operations, when requested.</b> |  |  |     |                                  |
| 1   | Obtain a copy S023-0-46, Conduct of Operations                         | Obtains a copy of S023-0-46, Conduct of Operations, Section 6.25.  |     | Start Time: _____                |
| 2*  | Review administrative requirement for Shift Manager manning.           | Determines that the minimum administrative manning for Shift Manager <b>is</b> satisfied.  |     |                                  |
| 3*  | Review administrative requirement for Control Room Supervisor manning. | Determines that the minimum administrative manning for Control Room Supervisor <b>is</b> satisfied.                                      |     |                                  |
| 4*  | Review administrative requirement for CO/ACO manning.                  | Determines that the minimum administrative manning for CO/ACO <b>is NOT</b> satisfied.   |     |                                  |
| 5*  | Review administrative requirement for Primary Qualified NPEO manning.  | Determines that the minimum administrative manning for Primary Qualified NPEO <b>is NOT</b> satisfied.                                   |     |                                  |
| 6*  | Review administrative requirement for STA manning.                     | Determines that the minimum administrative manning for STA <b>is</b> satisfied.<br><br><b>TERMINATING CUE:<br/>This JPM is complete.</b> |     | Stop Time: _____                 |



COMPLETED BY: X hX q.X fX eX. Z1ldi c.Xb.Xa.X2 DATE: ch08/09/08 FILE: These JPM i

REV 0, 08/29/00

Operations Management

JPM CHI

53

1 t C h e s u n g i t A t o h U n k e w T h e S t a n d a r d M a g a z i n e M a n a g e m e n t S t a f f P o s t e d F o r M a n a g e m e n t P a n e l F e b 23

JPM INFO

| INITIAL | PLANT | CONDITION |
|---------|-------|-----------|
| 1       | 1     | 1         |
| 2       | 2     | 2         |
| 3       | 3     | 3         |
| 4       | 4     | 4         |
| 5       | 5     | 5         |
| 6       | 6     | 6         |
| 7       | 7     | 7         |
| 8       | 8     | 8         |
| 9       | 9     | 9         |
| 10      | 10    | 10        |
| 11      | 11    | 11        |
| 12      | 12    | 12        |
| 13      | 13    | 13        |
| 14      | 14    | 14        |
| 15      | 15    | 15        |
| 16      | 16    | 16        |
| 17      | 17    | 17        |
| 18      | 18    | 18        |
| 19      | 19    | 19        |
| 20      | 20    | 20        |
| 21      | 21    | 21        |
| 22      | 22    | 22        |
| 23      | 23    | 23        |
| 24      | 24    | 24        |
| 25      | 25    | 25        |
| 26      | 26    | 26        |
| 27      | 27    | 27        |
| 28      | 28    | 28        |
| 29      | 29    | 29        |
| 30      | 30    | 30        |
| 31      | 31    | 31        |
| 32      | 32    | 32        |
| 33      | 33    | 33        |
| 34      | 34    | 34        |
| 35      | 35    | 35        |
| 36      | 36    | 36        |
| 37      | 37    | 37        |
| 38      | 38    | 38        |
| 39      | 39    | 39        |
| 40      | 40    | 40        |
| 41      | 41    | 41        |
| 42      | 42    | 42        |
| 43      | 43    | 43        |
| 44      | 44    | 44        |
| 45      | 45    | 45        |
| 46      | 46    | 46        |
| 47      | 47    | 47        |
| 48      | 48    | 48        |
| 49      | 49    | 49        |
| 50      | 50    | 50        |
| 51      | 51    | 51        |
| 52      | 52    | 52        |
| 53      | 53    | 53        |
| 54      | 54    | 54        |
| 55      | 55    | 55        |
| 56      | 56    | 56        |
| 57      | 57    | 57        |
| 58      | 58    | 58        |
| 59      | 59    | 59        |
| 60      | 60    | 60        |
| 61      | 61    | 61        |
| 62      | 62    | 62        |
| 63      | 63    | 63        |
| 64      | 64    | 64        |
| 65      | 65    | 65        |
| 66      | 66    | 66        |
| 67      | 67    | 67        |
| 68      | 68    | 68        |
| 69      | 69    | 69        |
| 70      | 70    | 70        |
| 71      | 71    | 71        |
| 72      | 72    | 72        |
| 73      | 73    | 73        |
| 74      | 74    | 74        |
| 75      | 75    | 75        |
| 76      | 76    | 76        |
| 77      | 77    | 77        |
| 78      | 78    | 78        |
| 79      | 79    | 79        |
| 80      | 80    | 80        |
| 81      | 81    | 81        |
| 82      | 82    | 82        |
| 83      | 83    | 83        |
| 84      | 84    | 84        |
| 85      | 85    | 85        |
| 86      | 86    | 86        |
| 87      | 87    | 87        |
| 88      | 88    | 88        |
| 89      | 89    | 89        |
| 90      | 90    | 90        |
| 91      | 91    | 91        |
| 92      | 92    | 92        |
| 93      | 93    | 93        |
| 94      | 94    | 94        |
| 95      | 95    | 95        |
| 96      | 96    | 96        |
| 97      | 97    | 97        |
| 98      | 98    | 98        |
| 99      | 99    | 99        |
| 100     | 100   | 100       |

**TASK TO BE PERFORMED**

**JPM    NUMBER**

J053S

REV 3, 06/14/00

55

Page 55 of 9

## JOB PER

```
(Print)
```

PERFORMED

PLANTANT

X

**J053S**

SIMSINSTRATOR

X

REV 3, 06/14/00

56

[illegible]



| REV | DESCRIPTION OF MODIFICATION | MODIFIED BY | MODIFIED DATE | APPROVAL |
|-----|-----------------------------|-------------|---------------|----------|
| 1-1 | 1-1                         | HJW         | 04/01/94      | N/A      |
| 1-2 | 1-2                         | HJW         | 09/30/94      | N/A      |
| 1-3 | 1-3                         | HJW         | 10/27/95      | N/A      |
| 2   | 2                           | SGA         | 6/18/97       | KHR      |
| 2-1 | 2-1                         | JJM         | 10/01/99      | WLL      |

|  |     |
|--|-----|
|  | 3   |
|  |     |
|  | LRZ |
|  |     |
|  | WLL |

REV 3, 06/14/00

SET-UP

**JPM: J053S TITLE:** Determine the time until Shutdown Cooling is required.

\* Denotes a CRITICAL STEP

| NO  | PERFORMANCE STEP   | STANDARD   | S/U | Comments<br>(Required for Unsat) |
|---|--|--|-----|----------------------------------|
| <p><b>NOTE:</b> Provide the examinee with a copy of SO23-12-7, Loss of Forced Circulation/Loss of Offsite Power, Attachment 9.</p> <p><b>CUE:</b> Once you have identified the appropriate instrumentation the examiner will supply you with the value the instrument is reading.</p> |  |  |     |                                  |
| 1   | Verify T-120/T-121 the only current feedwater source to S/G's.             | Verifies T-120/T-121 the only current feedwater source to S/G's.   |     | Start Time: _____                |
| <b>CUE: T-120/T-121 are the only current Feedwater Sources to the S/G's.</b>  |  |  |     |                                  |
| 2   | Verify T-120 level indication - available.                                 | Observes 2LI-4357B, CONDENSATE STORAGE TANK LEVEL 2T120(W) on CR52/53.   |     |                                  |
| <b>CUE: LI-4357B indicates 13.4%.</b>   |  |  |     |                                  |
| 3*  | Determine T-120 inventory from Table 1, Condensate Storage Tank Inventory. | Determines T-120 inventory to be <b>60,270 gallons</b> .   |     |                                  |
| 4   | Verify T-121 level indication - available.                                 | Observes 2LI-4356B, CONDENSATE STORAGE TANK LEVEL 2T121 <b>or</b> 2LI-3204-1, CONDENSATE STORAGE TK 2T-121 LEVEL, <b>and/or</b> 2LI-3204-2, CONDENSATE STORAGE TK 2T-121 LEVEL on CR52/53. |     |                                  |
| <b>CUE: LI-3204-1 and LI-3204-2 indicate 94%.</b>   |  |  |     |                                  |
| 5*  | Determine T-121 inventory from Table 1, Condensate Storage Tank Inventory. | Determines T-121 inventory to be <b>139,748 gallons</b> .  |     |                                  |

**JPM: J053S TITLE:** Determine the time until Shutdown Cooling is required.

\* Denotes a CRITICAL STEP

| NO | PERFORMANCE STEP  | STANDARD  | S/U | Comments<br>(Required for Unsat) |
|----|---|---|-----|----------------------------------|
| 6* | Determine total Feedwater Source inventory.   | Determines total condensate inventory to be <b>200,018 gallons.</b>   |     |                                  |
| 7* | Determine Net Available Feedwater for decay heat removal.   | Determines condensate inventory available for decay heat removal to be <b>145,018 gallons.</b>  |     |                                  |
| 8  | Determine the number of hours the reactor has been shutdown.  | The reactor was shutdown four (4) hours ago.  |     |                                  |
| 9* | Using Figure 1: Remaining Time S/G's Available for Heat Sink determine time remaining until Shutdown Cooling required for decay heat removal. | Determines time Steam Generators remain available for a heat sink and Shutdown Cooling will be required to be <b>11 to 13 hours.</b><br><br><b>TERMINATING CUE:<br/>This JPM is complete.</b> |     | Stop Time: _____                 |



COMPLETED BY ~~X~~ ~~h~~ ~~g~~ ~~X~~ ~~h~~ ~~L~~ ~~W~~ ~~ill~~ ~~d~~ ~~c~~ ~~X~~ ~~b~~ ~~X~~ ~~a~~ ~~X~~ ~~2~~ ~~DATE~~ ~~ca~~ ~~n~~ ~~6~~ ~~h~~ ~~2~~ ~~Ma~~ ~~0~~ ~~8~~ ~~cl~~ ~~X~~ ~~nd~~ Else JPM is

REV 3, 06/14/00

Operations Division of the United States Coast Guard, 1111 North 11th Street, Suite 1111, Norfolk, Virginia 23502-4101

JPM CHI

Page 64 of 8

**JPM    NUMBER**

J167A



REV 0, 06/20/00

65

Page 65 of 8

## JOB PER

```
(Print)
```

PERFORMED

PLANTANT

X

**J167A**

SIMSINSTAULTOR

X

REV 0, 06/20/00

66

DATE:

06/26/26/19/00

|  |   |                 |
|--|---|-----------------|
|  | 0 | REV             |
|  |   | New             |
|  |   | DESCRIPTION C   |
|  |   | <u>MODIFIED</u> |
|  |   | MODIFIED        |
|  |   | BY              |
|  |   | MODIFIED        |
|  |   | DATE            |
|  |   | APPROVAL        |
|  |   | SOL             |

REV 0, 06/20/00

68

SET-UP

**JPM: J167A TITLE:** Disable a Nuisance Annunciator.

\* Denotes a CRITICAL STEP

| NO   | PERFORMANCE STEP  | STANDARD  | S/U | Comments<br>(Required for Unsat) |
|--|---|---|-----|----------------------------------|
| <p><b>NOTE:</b> Provide the examinee with a copy of SO23-6-29, Operation of Annunciators and Indicators and SO23-15-53.A, 53A46 2<sup>nd</sup> Point Heater Level HI/LO, when located.</p> <p><b>CUE:</b> The alarm is not a result of any maintenance or planned testing.</p> |   |   |     |                                  |
| 1  | Locate the Step in SO23-6-29 that applies to this alarm.                                  | Locates Step 6.3.4 in SO23-6-29.  |     | Start Time: _____                |
| 2  | Tailboard the Compensatory Actions from the associated ARP with the responsible operator. | Identifies the requirement to monitor 2ME-039 Second Point Heater Level every four (4) hours with the responsible operator. |     |                                  |
| <p><b>CUE:</b> The tailboard for Compensatory Actions from the associated ARP is complete.</p>   |   |   |     |                                  |
| 3*   | Disable the alarm inputs.   | Determines disabling of the alarm inputs is required.   |     |                                  |
| <p><b>CUE:</b> The annunciator inputs have been disabled. The Electrician informs you that full reflash capability is no longer available.</p>   |   |   |     |                                  |
| 4  | Evaluate for compensatory actions per Step 6.3.8.   | Evaluates for compensatory actions per Step 6.3.8.  |     |                                  |
| <p><b>NOTE:</b> JPM terminates at Step 5 for the ROs and Step 6 for the SROs.</p>  |   |   |     |                                  |

**JPM: J167A TITLE:** Disable a Nuisance Annunciator.

\* Denotes a CRITICAL STEP

| NO | PERFORMANCE STEP   | STANDARD  | S/U | Comments<br>(Required for Unsat) |
|----|--|---|-----|----------------------------------|
| 5* | Determine that equipment serviced by the alarm is still in service.  | <p>Determines that another 2<sup>nd</sup> Point Heater Level Switch is serviced by this annunciator and full reflash capability is no longer available, therefore, an ACA sticker is required.</p> <p><b>TERMINATING CUE:</b><br/>This JPM is complete for the RO examinee.</p> |     | Stop Time: _____                 |
| 6* | Request the SRO Operations Supervisor review the associated ARP to determine if any compensatory actions are required. | <p>Requests the SRO Operations Supervisor review the associated ARP and determines that 2<sup>nd</sup> Point heater levels will have to be monitored every four (4) hours.</p> <p><b>TERMINATING CUE:</b><br/>This JPM is complete for the SRO examinee.</p>                    |     | Stop Time: _____                 |



COMPLETED BY: X hX g.X fX Ziel X d. c.X b.X a.X 2DATE: ch8709a(0)clXdThe JPM

REV 0, 06/20/00

# Operations Management

JPM CH



REV 1, 6/13/00

[illegible]

| TASK TO BE PERFORMED | INITIAL | PLANT | JPM INFO  |  |
|----------------------|---------|-------|-----------|--|
|                      |         |       | CONDITION |  |
|                      |         |       |           |  |

JPM   NUMBER

J157A

REV 1, 6/13/00

74

Page 74 of 10

## JOB PER

```
(Print)
```

PERFORMED

PLAINTANT

X

**J157A**

SIMSINSTRATOR



REV 1, 6/13/00

|  |     |                        |
|--|-----|------------------------|
|  | 1   | REV                    |
|  |     | required and 5000-Mile |
|  |     | DESCRIPTION C          |
|  |     | MODIFI                 |
|  |     | MODIFIED               |
|  | LRZ | BY                     |
|  | 06/ | MODIFIED               |
|  |     | DATE                   |
|  |     | APPROVAL               |
|  | WLL | SOL                    |

REV 1, 6/13/00

**JPM: J157A TITLE:** Perform Siren and PA Coordination Duties as Operations Leader

\* Denotes a CRITICAL STEP

| NO  | PERFORMANCE STEP  | STANDARD   | S/U | Comments<br>(Required for Unsat) |
|---|---|--|-----|----------------------------------|
| <p><b>NOTE:</b> Provide the examinee with a copy of SO23-VIII-30, Units 2/3 Operations Leader Duties.</p> <p><b>CUE:</b> The Siren/PA process is <u>not</u> being coordinated from outside the Control Room.</p>                        |   |  |     |                                  |
| 1*  | Prepare the Site PA message using Attachment 1.   | Prepares the Site PA message using Attachment 1 and the information provided by the Shift Manager (EC).  |     | Start Time: _____                |
| 2*  | Announce the message <u>once</u> over the Site PA system.   | Makes the announcement by reading the message <u>once</u> over the Site PA system by depressing the SITE PA button(s) on 2CR65 <b>and</b> depressing the button on the handset <b>or</b> dial 429 on any Control Room phone. |     |                                  |
| 3*  | Hold down the PA Tone Generator "Siren All" button on the phone turret until the "Kill" button illuminates. | Holds down the PA Tone Generator "Siren All" button on the phone turret until the "Kill" button/light illuminates (approximately 1-4 seconds).   |     |                                  |
| <p><b>NOTE:</b> The PA Tone Generator will time out and stop after 60 seconds and the "Kill" button/light will extinguish.</p> <p><b>CUE:</b> The "Kill" button is illuminated. After 60 seconds the "Kill" light has extinguished.</p> |   |  |     |                                  |
| 4*  | Press the Emergency Evacuation Siren START pushbutton (HS-7890-1) on CR 57.                                 | Presses the Emergency Evacuation Siren START pushbutton (HS-7890-1) on CR 57.  |     |                                  |

**JPM: J157A TITLE:** Perform Siren and PA Coordination Duties as Operations Leader

\* Denotes a CRITICAL STEP

| NO  | PERFORMANCE STEP   | STANDARD  | S/U | Comments<br>(Required for Unsat) |
|---|--|---|-----|----------------------------------|
| 5*  | After a 60 second run, press the Emergency Evacuation Siren Stop pushbutton. | After a 60 second run, presses the Emergency Evacuation Siren Stop pushbutton on CR 57.   |     |                                  |
| 6   | Ensure all sirens are secured.   | Ensures all sirens are secured by checking with plant personnel.  |     |                                  |
| <b>CUE: All sirens are secured.</b>   |  |   |     |                                  |
| 7*  | Repeat the PA announcement from Attachment 1 <u>two</u> times.               | Repeats the PA announcement from Attachment 1 by reading the message two (2) times over the Site PA system by depressing the SITE PA button(s) on 2CR65 <b>and</b> depressing the button on the handset <b>or</b> dial 429 on any Control Room phone. |     |                                  |
| <b>CUE: The Emergency Coordinator directs you to make a perimeter PA announcement for beach evacuation.</b> |  |   |     |                                  |
| 8*  | Make a Perimeter PA announcement for beach evacuation.                       | Makes the Perimeter PA announcement for beach evacuation by reading the announcement from Step 3.0 of Attachment 1 twice over the Perimeter PA handset in the Shift Manager's office.   |     |                                  |

**JPM: J157A TITLE:** Perform Siren and PA Coordination Duties as Operations Leader

\* Denotes a CRITICAL STEP

| NO | PERFORMANCE STEP                             | STANDARD   | S/U | Comments<br>(Required for Unsat) |
|----|--|--|-----|----------------------------------|
| 9  | Inform the Shift Manager (EC) when complete. | Informs the Shift Manager (EC) that the sirens have been sounded, and the Site and Beach Evacuation PA announcements have been completed.<br><br><b>TERMINATING CUE:</b><br><b>This JPM is complete.</b> |     | Stop Time: _____                 |



REV 1, 6/13/00

81

Page 81 of 10

COMPLETED BY ~~hX~~ ~~g.X~~ ~~fx~~ L.eXill ~~d. c.Xb.Xa.X2~~ DATE ~~ach672Ma/08clX~~ Else JPM

REV 1, 6/13/00

Operations ~~From 11/11/00 to 11/11/00~~

JPM CHI

Remove the 1E 4 kV Bus Tie from Service on 2A04.3614111200

| <u>TASK TO BE PERFORMED</u> | <u>INITIAL</u> | <u>PLANT</u> | <u>CONDITION</u> | <u>JPM</u> | <u>INF</u> |
|-----------------------------|----------------|--------------|------------------|------------|------------|
|-----------------------------|----------------|--------------|------------------|------------|------------|

| <u>JPM</u> | <u>NUMBER</u> |
|------------|---------------|
|------------|---------------|

J054S

REV 1, 06/15/00

84

Page 84 of 10

## JOB PER

```
(Print)
```

PERFORMED

PLANTANT

J054S

SIMSINSTRATOR

X



|  |          |          |          |          |          |               |
|--|----------|----------|----------|----------|----------|---------------|
|  | 1        | 0-4      | 0-3      | 0-2      | 0-1      | REV           |
|  |          |          |          |          |          |               |
|  |          |          |          |          |          | DESCRIPTION C |
|  |          |          |          |          |          | MODIFI        |
|  |          |          |          |          |          | MODIFIED      |
|  | LRZ      | JJM      | RCW      | HJW      | HJW      | BY            |
|  | 06/15/00 | 10/26/99 | 09/02/98 | 08/02/97 | 07/02/96 | MODIFIED      |
|  |          |          |          |          |          | DATE          |
|  |          |          |          |          |          | APPROVAL      |
|  | WLL      | WLL      | N/A      | N/A      | N/A      | SOL           |

REV 1, 06/15/00

87

## SET-UP

\* Denotes a CRITICAL STEP

| NO  | PERFORMANCE STEP  | STANDARD  | S/U | Comments<br>(Required for Unsat) |
|---|---|---|-----|----------------------------------|
| <p><b>NOTE:</b> Provide the examinee with a copy of SO23-6-2, Transferring of 4 kV Buses, when located.</p> <p><b>CUE:</b> The CRS has reviewed Technical Specification 3.8.1 and actions are being met.</p> <p><b>CUE:</b> The Tailboard session between all participants is complete.</p> |   |   |     |                                  |
| 1   | Verify the incoming 4160V source has normal voltage and is available for load.                        | Checks RSV AUX XFR 2XR1 MEGAWATTS meter 2JI-1606 <b>and/or</b> places sync circuit in service to verify incoming volts/Hz OK.                         |     | Start Time: _____                |
| <b>CUE:</b> The incoming 4 kV source has normal voltage and is available for load.  |   |   |     |                                  |
| 2*  | Place the synchroscope in service by placing the respective key operated Master Control switch to ON. | Places the synchroscope, 2/3SI-1627A, in service by placing key operated TRAIN A SYNC CKT CONTROL, 2HS-1627-1 ESF A SYNC MASTER Control switch to ON. |     |                                  |
| 3*  | Place synchronizing circuit in service by depressing SYNC pushbutton for the Incoming Breaker.        | Presses SYNC pushbutton for Incoming Breaker (identified from Attachment 1) RES AUX XFMR 2XR1 FDR BREAKER 2A0418, 2HS-1659-1.                         |     |                                  |
| 4   | Verify breaker SYNC light illuminated.  | Verifies breaker SYNC light illuminated on RES AUX XFMR 2XR1 FDR BREAKER 2A0418, 2HS-1659-1.  |     |                                  |
| 5   | Verify SYNC IN MODE light illuminated.  | Verifies SYNC IN MODE light illuminated on TRAIN A SYNC CKT CONTROL, 2HS-1627-1 ESF A SYNC MASTER Control switch.                                     |     |                                  |



**JPM: J054S TITLE:** Remove the 1E 4 kV Bus Tie from Service on 2A04

\* Denotes a CRITICAL STEP

| NO  | PERFORMANCE STEP  | STANDARD  | S/U | Comments<br>(Required for Unsat) |
|---|---|---|-----|----------------------------------|
| 6   | Verify SYNC RELAY TROUBLE light off.                            | Verifies SYNC RELAY TROUBLE light off on TRAIN A SYNC CKT CONTROL, 2HS-1627-1 ESF A SYNC MASTER Control switch.                   |     |                                  |
| 7   | Verify Incoming and Running voltages and frequencies matched.   | Verifies Incoming and Running voltages matched on 2/3EI-1627A & 2/3EI-1627B and frequencies matched on 2/3SI-1627C & 2/3SI-1627D. |     |                                  |
| 8   | Verify synchroscope moves to straight up (12 o'clock) position. | Verifies synchroscope 2/3SI-1627A moves to straight up (12 o'clock) position.   |     |                                  |
| 9   | Select the Bus Transfer Controls AUTO/MANUAL switch to MANUAL.  | Ensures BUS TIE 2A04 TO 3A04 FDR BKR 2A0417 SELECTOR 2HS-1660B1 in MANUAL.  |     |                                  |
| 10*   | Close the Incoming breaker.                                     | Depresses the CLOSE pushbutton on RES AUX XFMR 2XR1 FDR BREAKER 2A0418 2HS-1659-1.  |     |                                  |
| 11  | Verify the BUSES PARALLELED alarm.                              | Observes 63B55 2A04/3A04 BUSES PARALLELED alarm.  |     |                                  |
| 12*   | Open the running bus tie breaker manually.                      | Depresses the TRIP pushbutton on BUS TIE 2A04 TO 3A04 FDR BKR 2A0417 2HS-1660A-1.   |     |                                  |
| 13  | Open the opposite unit supply bus tie breaker.                  | Opens the Unit 3 supply bus tie breaker.  |     |                                  |
| <b>CUE: The Unit 3 bus tie breaker is open.</b> |   |   |     |                                  |

**JPM: J054S TITLE: Remove the 1E 4 kV Bus Tie from Service on 2A04**

\* Denotes a CRITICAL STEP

| NO  | PERFORMANCE STEP   | STANDARD   | S/U | Comments<br>(Required for Unsat) |
|---|--|--|-----|----------------------------------|
| 14*   | Select the Bus Transfer Controls AUTO/MANUAL switch to AUTO for both units.                                | Selects BUS TIE 2A04 TO 3A04 FDR BKR 2A0417 SELECTOR 2HS-1660B1 to AUTO and requests the Unit 3 CO/ACO place the bus tie breaker Auto/Manual switch in AUTO.   |     |                                  |
| <b>CUE: The Unit 3 bus tie breaker Auto/Manual switch is in AUTO.</b> |  |  |     |                                  |
| 15  | Remove the synchronizing circuit from service by depressing SYNC pushbutton for the Incoming breaker.      | Presses SYNC pushbutton for Incoming Breaker RES AUX XFMR 2XR1 FDR BREAKER 2A0418, 2HS-1659-1.   |     |                                  |
| 16  | Remove the synchroscope from service by placing the respective key-operated Master Controls switch to OFF. | Removes the synchroscope, 2/3SI-1627A, from service by placing key operated TRAIN A SYNC CKT CONTROL, 2HS-1627-1 ESF A SYNC MASTER Control switch to OFF.<br><br><b>TERMINATING CUE:<br/>This JPM is complete.</b> |     | Stop Time: _____                 |

REV 1, 06/15/00

91

Page 91 of 10

COMPLETED BY: X bX g.X fX L.eZillX d. c.Xb.Xa.X2DATE: ch9b09B/01cXndThe JPM

REV 1, 06/15/00

Operations Division

JPM CH

92

[illegible]

JPM INFO

| INITIAL | PLANT | CONDITION |
|---------|-------|-----------|
| 1       | 2     | 3         |
| 4       | 5     | 6         |
| 7       | 8     | 9         |
| 10      | 11    | 12        |
| 13      | 14    | 15        |
| 16      | 17    | 18        |
| 19      | 20    | 21        |
| 22      | 23    | 24        |
| 25      | 26    | 27        |
| 28      | 29    | 30        |
| 31      | 32    | 33        |
| 34      | 35    | 36        |
| 37      | 38    | 39        |
| 40      | 41    | 42        |
| 43      | 44    | 45        |
| 46      | 47    | 48        |
| 49      | 50    | 51        |
| 52      | 53    | 54        |
| 55      | 56    | 57        |
| 58      | 59    | 60        |
| 61      | 62    | 63        |
| 64      | 65    | 66        |
| 67      | 68    | 69        |
| 70      | 71    | 72        |
| 73      | 74    | 75        |
| 76      | 77    | 78        |
| 79      | 80    | 81        |
| 82      | 83    | 84        |
| 85      | 86    | 87        |
| 88      | 89    | 90        |
| 91      | 92    | 93        |
| 94      | 95    | 96        |
| 97      | 98    | 99        |
| 100     | 101   | 102       |
| 103     | 104   | 105       |
| 106     | 107   | 108       |
| 109     | 110   | 111       |
| 112     | 113   | 114       |
| 115     | 116   | 117       |
| 118     | 119   | 120       |
| 121     | 122   | 123       |
| 124     | 125   | 126       |
| 127     | 128   | 129       |
| 130     | 131   | 132       |
| 133     | 134   | 135       |
| 136     | 137   | 138       |
| 139     | 140   | 141       |
| 142     | 143   | 144       |
| 145     | 146   | 147       |
| 148     | 149   | 150       |
| 151     | 152   | 153       |
| 154     | 155   | 156       |
| 157     | 158   | 159       |
| 160     | 161   | 162       |
| 163     | 164   | 165       |
| 166     | 167   | 168       |
| 169     | 170   | 171       |
| 172     | 173   | 174       |
| 175     | 176   | 177       |
| 178     | 179   | 180       |
| 181     | 182   | 183       |
| 184     | 185   | 186       |
| 187     | 188   | 189       |
| 190     | 191   | 192       |
| 193     | 194   | 195       |
| 196     | 197   | 198       |
| 199     | 200   | 201       |
| 202     | 203   | 204       |
| 205     | 206   | 207       |
| 208     | 209   | 210       |
| 211     | 212   | 213       |
| 214     | 215   | 216       |
| 217     | 218   | 219       |
| 220     | 221   | 222       |
| 223     | 224   | 225       |
| 226     | 227   | 228       |
| 229     | 230   | 231       |
| 232     | 233   | 234       |
| 235     | 236   | 237       |
| 238     | 239   | 240       |
| 241     | 242   | 243       |
| 244     | 245   | 246       |
| 247     | 248   | 249       |
| 250     | 251   | 252       |
| 253     | 254   | 255       |
| 256     | 257   | 258       |
| 259     | 260   | 261       |
| 262     | 263   | 264       |
| 265     | 266   | 267       |
| 268     | 269   | 270       |
| 271     | 272   | 273       |
| 274     | 275   | 276       |
| 277     | 278   | 279       |
| 280     | 281   | 282       |
| 283     | 284   | 285       |
| 286     | 287   | 288       |
| 289     | 290   | 291       |
| 292     | 293   | 294       |
| 295     | 296   | 297       |
| 298     | 299   | 300       |
| 301     | 302   | 303       |
| 304     | 305   | 306       |
| 307     | 308   | 309       |
| 310     | 311   | 312       |
| 313     | 314   | 315       |
| 316     | 317   | 318       |
| 319     | 320   | 321       |
| 322     | 323   | 324       |
| 325     | 326   | 327       |
| 328     | 329   | 330       |
| 331     | 332   | 333       |
| 334     | 335   | 336       |
| 337     | 338   | 339       |
| 340     | 341   | 342       |
| 343     | 344   | 345       |
| 346     | 347   | 348       |
| 349     | 350   | 351       |
| 352     | 353   | 354       |
| 355     | 356   | 357       |
| 358     | 359   | 360       |
| 361     | 362   | 363       |
| 364     | 365   | 366       |
| 367     |       |           |

### TASK TO BE PERFORMED

JPM NUMBER

J113FS



REV 1, 06/14/00

95

|          |          |          |           |            |                |         |                 |
|----------|----------|----------|-----------|------------|----------------|---------|-----------------|
|          |          | L. Zilli | RO<br>4.2 | 011-EA1.11 | UACO<br>2007   | RO/SRO  |                 |
|          |          |          | SRO       |            | NO             |         | <u>DOCUMENT</u> |
| W.       | Lyke     | M. Jones |           |            |                | J113FS  |                 |
|          |          |          | 4,        | 4.2 7      | CRITICAL TIME: | minutes |                 |
|          |          |          |           |            | N/A            |         |                 |
| DATE:    | TIME:    |          |           |            |                |         |                 |
| 06/09/06 | 08/14/00 |          |           |            |                |         |                 |

|  |          |          |          |          |                |
|--|----------|----------|----------|----------|----------------|
|  | 1        | 0-3      | 0-2      | 0-1      | REV            |
|  |          |          |          |          | DESCRIPTION OF |
|  |          |          |          |          | MODIFIED       |
|  | LRZ      | JJM      | HJW      | SGA      | MODIFIED BY    |
|  | 06/14/00 | 10/21/99 | 09/09/97 | 06/14/00 | MODIFIED DATE  |
|  |          |          |          |          | APPROVAL       |
|  | WLL      | WLL      | N/A      | N/A      | SOL            |



REV 1, 06/14/00

SET-UP

97

\* Denotes a CRITICAL STEP

| NO  | PERFORMANCE STEP   | STANDARD   | S/U | Comments<br>(Required for Unsat) |
|---|--|--|-----|----------------------------------|
| <b>NOTE: Provide the examinee with a copy of SO23-12-3, Loss of Coolant Accident, Attachment 6.</b> |  |  |     |                                  |
| 1   | Verify RAS conditions established by checking RWST level <19%. | Observes at least two (2) of the following; RWT 2T006 LEVEL LI-0305-1, 2, 3, <b>and/or</b> 4 RWST levels <19%. |     | Time Start: _____                |
| 2   | Verify Containment Emergency Sump level >18' 4".               | Observes CNTMT EMER SUMP LEVEL 2LI-9386-1 <b>or</b> 2LI-9389-2 >18' 4".  |     |                                  |
| <b>NOTE: The following four (4) valves can be opened in any order.</b>                              |  |  |     |                                  |
| 3*  | Ensure Containment Emergency Sump Outlet Valve, HV-9303, open. | Depresses OPEN pushbutton for CNTMT EMER SUMP OUTLET ISO VALVE, 2HV-9303.                                      |     |                                  |
| 4*  | Ensure Containment Emergency Sump Outlet Valve, HV-9305, open. | Depresses OPEN pushbutton for CNTMT EMER SUMP OUTLET ISO VALVE, 2HV-9305.                                      |     |                                  |
| 5*  | Ensure Containment Emergency Sump Outlet Valve, HV-9302, open. | Depresses OPEN pushbutton for CNTMT EMER SUMP OUTLET ISO VALVE, 2HV-9302.                                      |     |                                  |
| 6*  | Ensure Containment Emergency Sump Outlet Valve, HV-9304, open. | Depresses OPEN pushbutton for CNTMT EMER SUMP OUTLET ISO VALVE, 2HV-9304.                                      |     |                                  |
| 7*  | Ensure LPSI Pump P015 stopped.                                 | Depresses SIAS OVERRIDE pushbutton and then STOP pushbutton for LPSI PUMP P015, 2HS-9390-1.                    |     |                                  |

\* Denotes a CRITICAL STEP

| NO   | PERFORMANCE STEP  | STANDARD  | S/U | Comments<br>(Required for Unsat) |
|--|---|---|-----|----------------------------------|
| 8*   | Ensure LPSI Pump P016 stopped.  | Depresses SIAS OVERRIDE pushbutton and then STOP pushbutton for LPSI PUMP P016, 2HS-9391-2.       |     |                                  |
| <b>NOTE: The following four (4) valves can be closed in any order.</b> |   |   |     |                                  |
| 9*   | Ensure SI Pump & CNTMT Spray Pump mini-flow HV-9306 closed.                                     | Closes SI Pump & CNTMT Spray Pump mini-flow Iso valve, 2HV-9306. (Key #9)                         |     |                                  |
| 10*  | Ensure SI Pump & CNTMT Spray Pump mini-flow HV-9307 closed.                                     | Closes SI Pump & CNTMT Spray Pump mini-flow Iso valve, 2HV-9307. (Key #10)                        |     |                                  |
| 11*  | Ensure SI Pump & CNTMT Spray Pump mini-flow HV-9347 closed.                                     | Closes SI Pump & CNTMT Spray Pump mini-flow Iso valve, 2HV-9347. (Key #24)                        |     |                                  |
| 12*  | Ensure SI Pump & CNTMT Spray Pump mini-flow HV-9348 closed.                                     | Closes SI Pump & CNTMT Spray Pump mini-flow Iso valve, 2HV-9348. (Key #25)                        |     |                                  |
| 13   | Verify Containment Spray flow on each operating train >1625 gpm.                                | Observes Containment Spray Hdr No. 1 & No. 2 flow indicators 2FI-0338-1 and 2FI-0348-2 >1625 gpm. |     |                                  |
| 14   | Verify Containment Emergency Sump level >18' 4" and RWST not required for borated water source. | Observes CNTMT EMER SUMP LEVEL 2LI-9386-1 OR 2LI-9389-2 >18' 4".                                  |     |                                  |
| <b>CUE: The RWST is not required for a borated water source.</b>       |   |   |     |                                  |
| <b>NOTE: The RWST valves may be aligned in any order.</b>              |   |   |     |                                  |

\* Denotes a CRITICAL STEP

| NO  | PERFORMANCE STEP  | STANDARD   | S/U | Comments<br>(Required for Unsat) |
|-----|---|--|-----|----------------------------------|
| 15* | Close RWST outlet Isolation valve HV-9300.  | Inserts key and closes RWT 2T005 Outlet Iso Valve, 2HV-9300. (Key #8)  |     |                                  |
| 16* | Close RWST outlet Isolation valve HV-9301.  | Inserts key and closes RWT 2T005 Outlet Iso Valve, 2HV-9301. (Key #23)   |     |                                  |
| 17  | Verify HPSI Flow criteria: With Cold Leg Injection only: Total HPSI flow >160 gpm in any one loop per operating pump. | Observes HPSI FLOW TO COLD LEGS (any one (1) instrument) 2FI-0321-1, 2FI-0331-1, 2FI-0311-2, & 2FI-0341-2 to verify total HPSI flow >160 gpm in any one loop per operating pump.           |     |                                  |
| 18  | Close CCW to Letdown Heat Exchanger valve Train A 2HV-6293B/A and 2HV-6522B/A.  | Depresses the CLOSE pushbutton for the in-service CCW CLA/B LTDN HX 2E062 Supply/Return valves, 2HV-6293B/A or 2HV-6522B/A.<br><br><b>TERMINATING CUE:</b><br><b>This JPM is complete.</b> |     | Time Stop: _____                 |



COMPLETED BY: X hX g.X fX L.eXzillX d. c.Xb.Xa.X2DATE: 2019-09-01 cXclX dXse JPM

REV 1, 06/14/00

Operations Management

JPM CH

102



REV 3, 09/01/00

104

Page 104 of 12

## JOB PER

```
(Print)
```

PERFORMED

PLANTANT

**J094FS**

SIMSINSTRATOR

X



09/05/05//05/00

|  |          |          |          |          |          |          |          |                 |
|--|----------|----------|----------|----------|----------|----------|----------|-----------------|
|  | 3        | 2-2      | 2-1      | 2        | 1-2      | 1-1      | 1        | REV             |
|  |          |          |          |          |          |          |          | DESCRIPTION OF  |
|  |          |          |          |          |          |          |          | <u>MODIFIED</u> |
|  |          |          |          |          |          |          |          | MODIFIED        |
|  | CFB      | JJM      | HJW      | HJW      | HJW      | SW       | RJR      | BY              |
|  | 09/05/00 | 10/04/99 | 08/16/96 | 02/09/94 | 04/10/92 | 12/13/93 | 10/10/91 | MODIFIED        |
|  |          |          |          |          |          |          |          | DATE            |
|  |          |          |          |          |          |          |          | APPROVAL        |
|  | WLL      | WLL      | N/A      | MJK      | N/A      | N/A      | MJK      | SOT             |

REV 3, 09/01/00

107

SET-UP

**JPM: J094FS TITLE:** Verify Isolation of Most Affected Steam Generator per SO23-12-4

\* Denotes a CRITICAL STEP

| NO  | PERFORMANCE STEP                               | STANDARD   | S/U | Comments<br>(Required for Unsat) |
|---|--|--|-----|----------------------------------|
| <b>NOTE: Provide the examinee with a copy of SO23-12-4, Steam Generator Tube Rupture, when located.</b> |  |  |     |                                  |
| 1   | Identify appropriate procedure and step.       | Identifies SO23-12-4, Steam Generator Tube Rupture, Step 14 to be performed.                       |     | Start Time: _____                |
| 2   | VERIFY one S/G isolated.                       | Observes Control Board indications and determines that S/G E088 is isolated.                       |     |                                  |
| <b>NOTE: The examinee may exit to the RNO column for any of the next four (4) steps.</b>                |  |  |     |                                  |
| 3   | VERIFY Steam Line radiation level not rising.  | Observes Main Steam Line Radiation Monitor 2RI-7874B1 and verifies it is not rising.               |     |                                  |
| <b>CUE: 2RI-7874B1, Main Steam Line Radiation Monitor, indicates a rising trend.</b>                    |  |  |     |                                  |
| 4   | VERIFY Blowdown radiation level not rising.    | Observes Blowdown Radiation Monitor 2RR-6759 and verifies it is not rising.                        |     |                                  |
| <b>CUE: 2RR-6759, Blowdown Radiation Monitor, indicates a rising trend.</b>                             |  |  |     |                                  |
| 5   | VERIFY Air Ejector radiation level not rising. | Observes Air Ejector Radiation Monitors 2RE-7818A and 2RE-7870-1 and verifies they are not rising. |     |                                  |
| <b>CUE: 2RE-7818A and 2RE-7870-1, Air Ejector Radiation Monitor, indicate a rising trend.</b>           |  |  |     |                                  |

\* Denotes a CRITICAL STEP

| NO   | PERFORMANCE STEP   | STANDARD   | S/U | Comments<br>(Required for Unsat) |
|--|--|--|-----|----------------------------------|
| 6  | Evaluate S/G samples and VERIFY isolated S/G has highest activity levels.              | Identifies Chemistry results that show E089 most affected S/G vs E088. Enters RNO to restore isolated S/G to service and isolate opposite S/G.   |     |                                  |
| <b>CUE: Chemistry reports E089 activity is 1.9E-2 <math>\mu</math>ci/ml and E088 activity is 7.7E-3 <math>\mu</math>ci/ml.</b> |  |  |     |                                  |
| <b>NOTE: The SBCS Interlock Setpoint is 6.5 inches of mercury absolute.</b>  |  |  |     |                                  |
| 7  | VERIFY SBCS available - Condenser back pressure less than the SBCS interlock setpoint. | Observes Condenser back pressure on Condenser absolute pressure recorder <b>or</b> Condenser pressure instruments 2PI-3202A, 2PI-3383A, <b>or</b> 2PI-3395A.   |     |                                  |
| 8  | OPEN S/G E-088 MSIV Bypass, HV-8203.   | Depresses OPEN/MODULATE pushbutton for SG 2E088 Main Steam Iso Valve Bypass and operates SG 2E088 2E089 Main Steam Iso Valve Bypass Control 2HV-8203/2HV-8202 to open 2HV-8203.  |     |                                  |
| 9  | Attempt to lower MSIV D/P to 85 psid for HV-8205.                                      | Compares 2PI-1023A1 through A4, SG E088 Pressure, <b>with</b> 2PI-8207, Steam Pressure to MFWPT K006, <b>or</b> 2PI-8214, Steam Pressure to MFWPT K005, <b>or</b> 2PI-2050A/B/C/D Main Steam Before Stop Valves Selected Pressure <b>and</b> verifies differential pressure is $\leq$ 85 psid. |     |                                  |

\* Denotes a CRITICAL STEP

| NO  | PERFORMANCE STEP  | STANDARD   | S/U | Comments<br>(Required for Unsat) |
|-----|---|--|-----|----------------------------------|
| 10* | OPEN S/G E-088 MSIV,<br>HV-8205.  | Depresses both OPEN<br>pushbuttons on Train A<br>2HS-8205 <b>and</b> Train B<br>2HS-8205 for SG E088 Main<br>Steam Iso Valve.              |     |                                  |
| 11  | Establish RCS temperature<br>control with SBCS on<br>isolated S/G.                                | Establishes RCS temperature<br>control with SBCS by<br>adjusting the controller(s)<br>to throttle 2HV-8423 and/or<br>2HV-8425 as required. |     |                                  |
| 12* | START Aux Feed Pump P-504.  | Depresses START pushbutton on<br>2HS-4733-2, AFWP 2P504.   |     |                                  |
| 13  | Check E-088 level.  | Observes E-088 level<br>indicators on CR-52 >40% by<br>observing 2LI-1123A1 through<br>A4, SG E088 Downcomer Level.                        |     |                                  |
| 14* | OPEN Aux Feed to S/G E-088,<br>2HV-4714 or 2HV-4730.  | Depresses OPEN pushbutton on<br><b>either</b> 2HV-4714, AFW to SG<br>E088 Iso Valve <b>or</b> 2HV-4730,<br>AFW to SG E088 Iso Valve.       |     |                                  |
| 15* | THROTTLE Aux Feed Pump<br>P-504 Discharge Valve<br>2HV-4712 to maintain AFW<br>flow as necessary. | Depresses JOG OPEN or JOG<br>CLOSE pushbutton on 2HV-4712,<br>AFWP 2P504 to SG E088 Disch<br>Valve to maintain AFW flow as<br>necessary.   |     |                                  |
| 16  | Maintain E-088 level<br>between 40% and 80% NR.   | Maintains E-088 level between<br>40% and 80% NR by observing<br>2LI-1123A1 through A4, SG<br>E088 Downcomer Level.                         |     |                                  |

\* Denotes a CRITICAL STEP

| NO  | PERFORMANCE STEP  | STANDARD  | S/U | Comments<br>(Required for Unsat) |
|-----|---|---|-----|----------------------------------|
| 17  | Verify least affected Steam Generator available for continued heat removal. | Verifies least affected Steam Generator available for continued heat removal.   |     |                                  |
| 18  | Ensure RCS Th less than 530°F.  | Ensures RCS Th less than 530°F by observing:<br>• 2TI-0911X1, Loop 1 WR Th<br>• 2TI-0921X2, Loop 2 WR Th  |     |                                  |
| 19* | CLOSE S/G E-089 MSIV, 2HV-8204.   | Depresses both CLOSE pushbuttons on Train A 2HV-8204 <b>or</b> Train B 2HV-8204, SG 2E089 Main Steam Iso Valve, and verifies 2HV-8204 closed at CR52 or CR57. |     |                                  |
| 20  | VERIFY S/G E-089 MSIV Bypass, 2HV-8202 is closed.                           | Verifies green closed indicating light on 2HV-8202, SG 2E089 Main Steam Iso Valve Bypass.   |     |                                  |
| 21  | VERIFY S/G E-089 ADV, 2HV-8421 is closed.                                   | Verifies green closed indicating light on 2HV-8421, SG 2E089 Atmospheric Dump Valve.  |     |                                  |
| 22* | CLOSE S/G E-089 Main Feed Isolation, 2HV-4052.                              | Depresses both CLOSE pushbuttons on Train A 2HV-4052 <b>or</b> Train B 2HS-4052, FW to SG 2E089 Iso Valve, and verifies 2HV-4052 closed at CR52 or CR57.      |     |                                  |
| 23  | CLOSE Aux Feed to S/G E-089, 2HV-4731.                                      | Ensures 2HV-4731, AFW to SG 2E089 Iso Valve, is CLOSED.   |     |                                  |

**JPM: J094FS TITLE:** Verify Isolation of Most Affected Steam Generator per SO23-12-4

\* Denotes a CRITICAL STEP

| NO  | PERFORMANCE STEP  | STANDARD   | S/U | Comments<br>(Required for Unsat) |
|-----|---|--|-----|----------------------------------|
| 24  | CLOSE Aux Feed to S/G E-089, 2HV-4715.                            | Ensures 2HV-4715, AFW to SG 2E089 Iso Valve, is CLOSED.  |     |                                  |
| 25* | CLOSE Main Steam to Aux Feed Pump Turbine, 2HV-8200.              | Depresses OVERRIDE and CLOSE pushbuttons for 2HV-8200, Main Steam to AFWPT 2K007 SG 2E089 Iso Valve.                         |     |                                  |
| 26  | CLOSE S/G E-089 Blowdown Isolation.                               | Ensures 2HV-4053-2, SG 2E089 Blowdown Iso Valve, is closed.  |     |                                  |
| 27* | CLOSE S/G E-089 Steam Generator Water Sample Isolation, 2HV-4057. | Depresses CLOSE for 2HV-4057, SG 2E089 Water Sample Iso Valve.   |     |                                  |
| 28* | STOP Aux Feed Pump P-141.   | Depresses OVERRIDE and STOP pushbuttons for 2HS-4707-1, AFWP 2P141.<br><br><b>TERMINATION CUE:<br/>This JPM is Complete.</b> |     | Stop Time: _____                 |





COMPLETED BY X h x q X FL. A l l i x d. c X b X a. DATE 09 / 11 / 2018 Incluse JPM i

REV 3, 09/01/00

the Comprehensive National Health and Medical Research Institute (CNHRI) and the National Health and Medical Research Council (NH&MRC) in Australia.

JPM CHI

114

Perform actions as defined by the following table (which all agents should follow):

**JPM INFO**

| INITIAL | PLANT | CONDITION |
|---------|-------|-----------|
| 1       | 1     | 1         |
| 2       | 2     | 2         |
| 3       | 3     | 3         |
| 4       | 4     | 4         |
| 5       | 5     | 5         |
| 6       | 6     | 6         |
| 7       | 7     | 7         |
| 8       | 8     | 8         |
| 9       | 9     | 9         |
| 10      | 10    | 10        |
| 11      | 11    | 11        |
| 12      | 12    | 12        |
| 13      | 13    | 13        |
| 14      | 14    | 14        |
| 15      | 15    | 15        |
| 16      | 16    | 16        |
| 17      | 17    | 17        |
| 18      | 18    | 18        |
| 19      | 19    | 19        |
| 20      | 20    | 20        |
| 21      | 21    | 21        |
| 22      | 22    | 22        |
| 23      | 23    | 23        |
| 24      | 24    | 24        |
| 25      | 25    | 25        |
| 26      | 26    | 26        |
| 27      | 27    | 27        |
| 28      | 28    | 28        |
| 29      | 29    | 29        |
| 30      | 30    | 30        |
| 31      | 31    | 31        |
| 32      | 32    | 32        |
| 33      | 33    | 33        |
| 34      | 34    | 34        |
| 35      | 35    | 35        |
| 36      | 36    | 36        |
| 37      | 37    | 37        |
| 38      | 38    | 38        |
| 39      | 39    | 39        |
| 40      | 40    | 40        |
| 41      | 41    | 41        |
| 42      | 42    | 42        |
| 43      | 43    | 43        |
| 44      | 44    | 44        |
| 45      | 45    | 45        |
| 46      | 46    | 46        |
| 47      | 47    | 47        |
| 48      | 48    | 48        |
| 49      | 49    | 49        |
| 50      | 50    | 50        |
| 51      | 51    | 51        |
| 52      | 52    | 52        |
| 53      | 53    | 53        |
| 54      | 54    | 54        |
| 55      | 55    | 55        |
| 56      | 56    | 56        |
| 57      | 57    | 57        |
| 58      | 58    | 58        |
| 59      | 59    | 59        |
| 60      | 60    | 60        |
| 61      | 61    | 61        |
| 62      | 62    | 62        |
| 63      | 63    | 63        |
| 64      | 64    | 64        |
| 65      | 65    | 65        |
| 66      | 66    | 66        |
| 67      | 67    | 67        |
| 68      | 68    | 68        |
| 69      | 69    | 69        |
| 70      | 70    | 70        |
| 71      | 71    | 71        |
| 72      | 72    | 72        |
| 73      | 73    | 73        |
| 74      | 74    | 74        |
| 75      | 75    | 75        |
| 76      | 76    | 76        |
| 77      | 77    | 77        |
| 78      | 78    | 78        |
| 79      | 79    | 79        |
| 80      | 80    | 80        |
| 81      | 81    | 81        |
| 82      | 82    | 82        |
| 83      | 83    | 83        |
| 84      | 84    | 84        |
| 85      | 85    | 85        |
| 86      | 86    | 86        |
| 87      | 87    | 87        |
| 88      | 88    | 88        |
| 89      | 89    | 89        |
| 90      | 90    | 90        |
| 91      | 91    | 91        |
| 92      | 92    | 92        |
| 93      | 93    | 93        |
| 94      | 94    | 94        |
| 95      | 95    | 95        |
| 96      | 96    | 96        |
| 97      | 97    | 97        |
| 98      | 98    | 98        |
| 99      | 99    | 99        |
| 100     | 100   | 100       |

### TASK TO BE PERFORMED

JPM    NUMBER

J152S

REV 0, 06/20/00

116

Page 116 of 10

## JOB PER

```
(Print)
```

PERFORMED

PLANTANT

**J152S**

SIMS INSTRUCTOR

X

REV 0, 06/20/00

117

DATE:

06/26/20/00

|  |     |                 |
|--|-----|-----------------|
|  | 0   | REV             |
|  | New |                 |
|  |     | DESCRIPTION C   |
|  |     | <u>MODIFIED</u> |
|  |     | MODIFIED        |
|  |     | BY              |
|  |     | MODIFIED        |
|  |     | DATE            |
|  |     | APPROVAL        |
|  |     | SOL             |

REV 0, 06/20/00

119

SET-UP

**JPM: J152S TITLE:** Perform Actions for a Loss of Shutdown Cooling

\* Denotes a CRITICAL STEP

| NO   | PERFORMANCE STEP   | STANDARD  | S/U | Comments<br>(Required for Unsat) |
|--|--|---|-----|----------------------------------|
| <b>NOTE: Provide the examinee with a copy of SO23-13-15 , Loss of Shutdown Cooling, when identified.</b>                             |  |   |     |                                  |
| 1  | Identify correct procedure to use.                             | Identifies SO23-13-15, Loss of Shutdown Cooling as the correct procedure to use.  |     | Start Time: _____                |
| <b>CUE: There are no personnel in Containment, the Containment Equipment Hatch is closed, and the RCS is closed and pressurized.</b> |  |   |     |                                  |
| 2  | Initiate Attachment 4, Containment Closure/RCS Vent Checklist. | Initiates Containment closure and RCS monitoring.   |     |                                  |
| <b>CUE: Attachment 4, Containment Closure/RCS Vent Checklist is being performed by the ARO.</b>                                      |  |   |     |                                  |
| 3  | Implement Attachment 1, RCS/SDCS Parameter Monitoring.         | Implements Attachment 1, RCS/SDCS Parameter Monitoring.   |     |                                  |
| <b>CUE: Attachment 1, RCS/SDCS Parameter Monitoring is also being performed by the ARO.</b>  |  |   |     |                                  |
| 4  | Ensure RCS dilutions stopped.                                  | Ensures all RCS dilutions in progress are stopped.  |     |                                  |
| 5  | Verify RCS/SDCS parameters.                                    | Verifies RCS/SDCS parameters by: <ul style="list-style-type: none"> <li>• Verifying all SDCS/LTOP Isolation valves OPEN: HV-9339, HV-9336, HV-9377, HV-9378</li> <li>• Verifying RCS level greater than or equal to 21 inches in the Hot Leg and NOT lowering on page 622 of QSPDS or CFMS</li> </ul> |     |                                  |



**JPM: J152S TITLE: Perform Actions for a Loss of Shutdown Cooling**

\* Denotes a CRITICAL STEP

| NO  | PERFORMANCE STEP  | STANDARD   | S/U | Comments<br>(Required for Unsat) |
|-----|---|--|-----|----------------------------------|
| 6*  | Recognize that SDC flow is < 2300 gpm and the SDC pump START light is off and/or motor amperage is zero and go to the RNO column. | Recognizes that SDC flow is < 2300 gpm and the SDC pump START light is off and/or motor amperage is zero and goes to Step 5.   |     |                                  |
| 7*  | Recover SDC flow - Verify at least one SDC pump running.  | Cannot verify that a SDC pump is running and refers to the RNO for 4 kV Buses A04 or A06 energized by the Diesel Generator. Exits main body of procedure to Attachment 8, Restoration of 1E Bus Voltage, Step 6. |     |                                  |
| 8a* | Load 4 kV Bus A06.  | Ensures a CCW Pump started by checking CCW PUMP 2HS-6320-2 start light on and amps normal.   |     |                                  |
| 8b* | Load 4 kV Bus A06.  | Ensures a Salt Water Pump started on loop with running CCW Pump by checking SALTWATER PUMP 2P114 UNIT 3 INTAKE 2HS-6383-2 start light on and amps normal.  |     |                                  |
| 8c  | Load 4 kV Bus A06.  | Ensures Intake Cooling Unit associated with operating SWC Pump started by checking SWTR PUMP 2P-114 ROOM VENT UNIT 2A372 UNIT 3 INTAKE 2ZL-9606-2 start light on.  |     |                                  |

**JPM: J152S TITLE: Perform Actions for a Loss of Shutdown Cooling**

\* Denotes a CRITICAL STEP

| NO  | PERFORMANCE STEP                                    | STANDARD   | S/U | Comments<br>(Required for Unsat) |
|-----|---|--|-----|----------------------------------|
| 8d* | Load 4 kV Bus A06.                                  | Starts the SDC Pump associated with the running CCW pump by DEPRESSING LPSI PUMP 2P-016 2HS-9391-2 START pushbutton.   |     |                                  |
| 8e  | Exit Attachment 8 and go to Step 5.b of SO23-13-15. | Exits Attachment 8 and goes to Step 5.b of SO23-13-15.   |     |                                  |
| 9   | Verify running SDC Pump amperage normal.            | Verifies running SDC Pump amperage normal on LPSI PUMP 2P-016 2HS-9391-2 escutcheon.   |     |                                  |
| 10  | Recover SDC flow. Verify SDCS flow > 2300 gpm.      | Verifies SDC flow by observing LPSI/SDC FLOW 2FI-0306 (or PMS display F306) is greater than 2300 gpm.<br><br><b>TERMINATING CUE:<br/>This JPM is complete.</b> |     | Stop Time: _____                 |

REV 0, 06/20/00

123

Page 123 of 10

~~COMPLETED BY:~~ ~~X~~ ~~h~~ ~~g.~~ ~~X~~ ~~f~~ ~~L.eZill~~ ~~d.~~ ~~c.~~ ~~Xb.~~ ~~Xa.~~ ~~X2DATE~~ ~~ch9b09B~~ ~~(M)~~ ~~C~~ ~~Id~~ ~~The JPM~~

REV 0, 06/20/00

# Operations Management

JPM CH

124

THIS IS A TIME CRITICAL JPM

fr Take the require The on the 15th of 23rd of 1980 11:12 AM 11th of 1980

TASK TO BE PERFORMED INITIAL PLANT CONDITION JPM INFO

JPM NUMBER

J025FS

REV 2, 06/06/00

126

Page 126 of 8

## JOB PER

```
(Print)
```

PERFORMED

PLANTANT

**J025FS**

SIMSINSTAULTOR

X



128

|  | 2        | 1-6      | 1-5      | 1-4      | 1-3      | 1-2      | 1-1      | REV                          |
|--|----------|----------|----------|----------|----------|----------|----------|------------------------------|
|  | ma       | Ch       | and      | H        | T        | i        | f        | e                            |
|  |          |          |          |          |          |          |          | DESCRIPTION OF MODIFICATIONS |
|  |          |          |          |          |          |          |          | MODIFIED BY                  |
|  | LRZ      | JJM      | RCW      | HJW      | HJW      | HJW      | HJW      | DATE                         |
|  | 06/06/00 | 10/21/99 | 09/15/98 | 08/19/98 | 08/19/98 | 05/09/95 | 03/22/95 | APPROVAL                     |
|  | WLL      | WLL      | N/A      | N/A      | N/A      | N/A      | N/A      | SOL                          |



REV 2, 06/06/00

• • • • • Time Action  
Enset Overhaul 5/15/00 15:41:44  
Enset Overhaul 5/15/00 15:41:44

129

**SET-UP**

\* Denotes a CRITICAL STEP

| NO   | PERFORMANCE STEP  | STANDARD  | S/U | Comments<br>(Required for Unsat) |
|--|---|---|-----|----------------------------------|
| <b>CUE: Steps do <u>not</u> need to be performed in order.</b>   |   |   |     |                                  |
| 1  | Verify at least one Charging Pump is available.                             | Observes at least one charging pump 2-190, 2P-191, or 2P-192 operating on CR-58.  |     | Start Time: _____                |
| 2  | Place Makeup Mode Selector Switch in the MANUAL position.                   | Places Makeup Mode Selector Switch, 2HS-0210, in the MANUAL position.   |     |                                  |
| 3  | Start BAMU Pump P-175.  | Depresses START pushbutton for P-175, BAMU Pump.  |     |                                  |
| <b>NOTE: P-175 and P-174 do not start.</b>   |   |   |     |                                  |
| <b>NOTE: Opening either valve 2HV-9240 or 2HV-9235 admits boric acid to the RCS. Opening either valve satisfies the critical nature of the step.</b> |   |   |     |                                  |
| 4*   | Open 2HV-9240 and 2HV-9235, BAMU Tank to Charging Pump Gravity Feed Valves. | Depresses OPEN on 2HV-9240, BAMU Tk 2T071 Gravity Feed Valve and 2HV-9235, BAMU Tk 2T072 Gravity Feed Valve.  |     |                                  |
| 5*   | Close 2LV-0227B, Volume Control Tank T-077 Outlet Valve.                    | Depresses MANUAL and CLOSE on 2LV-0227B, Volume Control Tank Outlet Block Valve.  |     | Critical Time: _____             |
| 6  | Ensure charging flow >40 gpm.   | Observes Charging Flow Digital Display on 2UJI-0051G <b>or</b> Charging Flow indication 2FI-0212 on CR-58.<br><br><b>TERMINATION CUE:<br/>This JPM is complete.</b> |     | Stop Time: _____                 |

REV 2, 06/06/00

131

Page 131 of 8

COMPLETED BY: ~~X~~ ~~h~~ ~~g~~ ~~X~~ ~~fx~~ ~~L.e~~ ~~Zill~~ ~~X~~ ~~d.~~ ~~c~~ ~~Xb~~ ~~Xa~~ ~~X2~~ ~~DATE~~ ~~ach~~ ~~9~~ ~~10~~ ~~09~~ ~~01~~ ~~11~~ ~~cd~~ ~~the~~ JPM

REV 2, 06/06/00

Operations Division

JPM CH

132

Systematic Open Access J. Biol. Res., 6(2023)1-19 | DOI:10.21875/S2502-4742.2023.00001-1

JPM INFO

| INITIAL | PLANT | CONDITION |
|---------|-------|-----------|
| 1       | 2     | 3         |

| <u>TASK</u> | <u>TO</u> | <u>BE</u> | <u>PERFORMED</u> |
|-------------|-----------|-----------|------------------|
| 1           | 2         | 3         | 4                |
| 5           | 6         | 7         | 8                |
| 9           | 10        | 11        | 12               |
| 13          | 14        | 15        | 16               |
| 17          | 18        | 19        | 20               |
| 21          | 22        | 23        | 24               |
| 25          | 26        | 27        | 28               |
| 29          | 30        | 31        | 32               |
| 33          | 34        | 35        | 36               |
| 37          | 38        | 39        | 40               |
| 41          | 42        | 43        | 44               |
| 45          | 46        | 47        | 48               |
| 49          | 50        | 51        | 52               |
| 53          | 54        | 55        | 56               |
| 57          | 58        | 59        | 60               |
| 61          | 62        | 63        | 64               |
| 65          | 66        | 67        | 68               |
| 69          | 70        | 71        | 72               |
| 73          | 74        | 75        | 76               |
| 77          | 78        | 79        | 80               |
| 81          | 82        | 83        | 84               |
| 85          | 86        | 87        | 88               |
| 89          | 90        | 91        | 92               |
| 93          | 94        | 95        | 96               |
| 97          | 98        | 99        | 100              |

JPM NUMBER

J143S

REV 1, 06/14/00

134

Page 134 of 10

## JOB PER

```
(Print)
```

PERFORMED

PLANTANT

J143S

SIMULASTHAUGATOR

X



REV 1, 06/14/00

|  |   |                             |
|--|---|-----------------------------|
|  | 1 | REV                         |
|  |   | REQUESTED BY: WLL SOL       |
|  |   | DESCRIPTION OF MODIFICATION |
|  |   | MODIFIED BY: LRZ            |
|  |   | MODIFIED DATE: 06/14/00     |
|  |   | APPROVAL                    |
|  |   | WLL SOL                     |



REV 1, 06/14/00

restate the State's position on the issue of the

- DNR's Highrizer Pre

137

SET-UP

**JPM: J143S TITLE:** Return a Reactor Protective System Trip Channel to service.

\* Denotes a CRITICAL STEP

| NO  | PERFORMANCE STEP   | STANDARD   | S/U | Comments<br>(Required for Unsat) |
|---|--|--|-----|----------------------------------|
| <p><b>NOTE:</b> Provide the examinee with a copy of SO23-3-2.12, Reactor Protective System Operation, Section 6.2.</p> <p><b>NOTE:</b> The Trip Bypasses may be removed in any order.</p> |  |  |     |                                  |
| 1   | Verify no trip signals are present.                                  | <p>Verifies the following annunciators, and their associated PPS Operator Module lights on 2UI-9149-1, are extinguished:</p> <ul style="list-style-type: none"> <li>• 56A03, LOCAL POWER LEVEL HI CHANNEL TRIP</li> <li>• 56A04, DNBR LO CHANNEL TRIP</li> <li>• 56A05, PZR PRESS HI CHANNEL TRIP</li> </ul> |     | Start Time: _____                |
| 2*  | Remove the Trip Bypass for LPD High by depressing the Bypass switch. | At 2UIK078, A Cabinet, depresses pushbutton #3, making sure the white light extinguishes.  |     |                                  |
| <p><b>NOTE:</b> Show the cabinet mimic to the examinee.</p> <p><b>CUE:</b> The white light is off.</p>  |  |  |     |                                  |
| 3*  | Remove the Trip Bypass for DNBR Low by depressing the Bypass switch. | At 2UIK078, A Cabinet, depresses pushbutton #4, making sure the white light extinguishes.  |     |                                  |
| <p><b>NOTE:</b> Provide the cabinet mimic to the examinee.</p> <p><b>CUE:</b> The white light is off.</p>   |  |  |     |                                  |

**JPM: J143S TITLE:** Return a Reactor Protective System Trip Channel to service.

\* Denotes a CRITICAL STEP

| NO  | PERFORMANCE STEP  | STANDARD   | S/U | Comments<br>(Required for Unsat) |
|---|---|--|-----|----------------------------------|
| 4*  | Remove the Trip Bypass for Pressurizer Pressure High by depressing the Bypass switch. | At 2UIK078, A Cabinet, depresses pushbutton #5, making sure the white light extinguishes.                          |     |                                  |
| <p><b>NOTE: Provide the cabinet mimic to the examinee.</b></p> <p><b>CUE: The white light is off.</b></p> |   |  |     |                                  |
| 5   | Verify the Trip Channel Bypassed Annunciator 56A29 (Channel 1) is reset.              | <p>Verifies annunciator 56A29 is extinguished.</p> <p><b>TERMINATING CUE:</b><br/><b>This JPM is complete.</b></p> |     | Stop Time: _____                 |

REV 1, 06/14/00

140

Page 140 of 10

COMPLETED BY: ~~X~~ ~~h~~ ~~g~~ ~~X~~ ~~fx~~ ~~L.e~~ ~~Zill~~ ~~X~~ ~~d.~~ ~~c~~ ~~Xb~~ ~~Xa~~ ~~X2~~ ~~DATE~~ ~~ch6~~ ~~02~~ ~~Ma~~ ~~01~~ ~~Xc~~ ~~Xd~~ ~~Else~~ ~~JPM~~

REV 1, 06/14/00

# Operations Management

JPM CH

141

Sperry, C. M. 2012. *At the edge of the world: a journey to the edge of the world*. New York: HarperCollins.

**JPM INFO**

| INITIAL | PLANT | CONDITION |
|---------|-------|-----------|
| 1       | 2     | 3         |
| 4       | 5     | 6         |
| 7       | 8     | 9         |
| 10      | 11    | 12        |
| 13      | 14    | 15        |
| 16      | 17    | 18        |
| 19      | 20    | 21        |
| 22      | 23    | 24        |
| 25      | 26    | 27        |
| 28      | 29    | 30        |
| 31      | 32    | 33        |
| 34      | 35    | 36        |
| 37      | 38    | 39        |
| 40      | 41    | 42        |
| 43      | 44    | 45        |
| 46      | 47    | 48        |
| 49      | 50    | 51        |
| 52      | 53    | 54        |
| 55      | 56    | 57        |
| 58      | 59    | 60        |
| 61      | 62    | 63        |
| 64      | 65    | 66        |
| 67      | 68    | 69        |
| 70      | 71    | 72        |
| 73      | 74    | 75        |
| 76      | 77    | 78        |
| 79      | 80    | 81        |
| 82      | 83    | 84        |
| 85      | 86    | 87        |
| 88      | 89    | 90        |
| 91      | 92    | 93        |
| 94      | 95    | 96        |
| 97      | 98    | 99        |
| 100     | 101   | 102       |
| 103     | 104   | 105       |
| 106     | 107   | 108       |
| 109     | 110   | 111       |
| 112     | 113   | 114       |
| 115     | 116   | 117       |
| 118     | 119   | 120       |
| 121     | 122   | 123       |
| 124     | 125   | 126       |
| 127     | 128   | 129       |
| 130     | 131   | 132       |
| 133     | 134   | 135       |
| 136     | 137   | 138       |
| 139     | 140   | 141       |
| 142     | 143   | 144       |
| 145     | 146   | 147       |
| 148     | 149   | 150       |
| 151     | 152   | 153       |
| 154     | 155   | 156       |
| 157     | 158   | 159       |
| 160     | 161   | 162       |
| 163     | 164   | 165       |
| 166     | 167   | 168       |
| 169     | 170   | 171       |
| 172     | 173   | 174       |
| 175     | 176   | 177       |
| 178     | 179   | 180       |
| 181     | 182   | 183       |
| 184     | 185   | 186       |
| 187     | 188   | 189       |
| 190     | 191   | 192       |
| 193     | 194   | 195       |
| 196     | 197   | 198       |
| 199     | 200   | 201       |
| 202     | 203   | 204       |
| 205     | 206   | 207       |
| 208     | 209   | 210       |
| 211     | 212   | 213       |
| 214     | 215   | 216       |
| 217     | 218   | 219       |
| 220     | 221   | 222       |
| 223     | 224   | 225       |
| 226     | 227   | 228       |
| 229     | 230   | 231       |
| 232     | 233   | 234       |
| 235     | 236   | 237       |
| 238     | 239   | 240       |
| 241     | 242   | 243       |
| 244     | 245   | 246       |
| 247     | 248   | 249       |
| 250     | 251   | 252       |
| 253     | 254   | 255       |
| 256     | 257   | 258       |
| 259     | 260   | 261       |
| 262     | 263   | 264       |
| 265     | 266   | 267       |
| 268     | 269   | 270       |
| 271     | 272   | 273       |
| 274     | 275   | 276       |
| 277     | 278   | 279       |
| 280     | 281   | 282       |
| 283     | 284   | 285       |
| 286     | 287   | 288       |
| 289     | 290   | 291       |
| 292     | 293   | 294       |
| 295     | 296   | 297       |
| 298     | 299   | 300       |
| 301     | 302   | 303       |
| 304     | 305   | 306       |
| 307     | 308   | 309       |
| 310     | 311   | 312       |
| 313     | 314   | 315       |
| 316     | 317   | 318       |
| 319     | 320   | 321       |
| 322     | 323   | 324       |
| 325     | 326   | 327       |
| 328     | 329   | 330       |
| 331     | 332   | 333       |
| 334     | 335   | 336       |
| 337     | 338   | 339       |
| 340     | 341   | 342       |
| 343     | 344   | 345       |
| 346     | 347   | 348       |
| 349     | 350   | 351       |
| 352     | 353   | 354       |
| 355     | 356   | 357       |
| 358     | 359   | 360       |
| 361     | 362   | 363       |
| 364     | 365   | 366       |
| 367     |       |           |

**TASK TO BE PERFORMED**

JPM    NUMBER

J049FS

REV 0, 06/08/00

143

Page 143 of 11

```
(Print)
```

PERFORMED

PLANTANT

**J049FS**

SIMS LAST NAME FIRST INITIAL OR  

X

06/26/26/08/00



REV 0, 06/08/00

145

|       |   |                   |
|-------|---|-------------------|
|       | 0 | REV               |
| J0496 |   | Updated faulted J |
|       |   | DESCRIPTION C     |
|       |   | <u>MODIFIED</u>   |
|       |   | MODIFIED          |
|       |   | BY                |
|       |   | MODIFIED          |
|       |   | DATE              |
|       |   | APPROVAL          |
|       |   | SOL               |

REV 0, 06/08/00

146

SET-UP

\* Denotes a CRITICAL STEP

| NO  | PERFORMANCE STEP   | STANDARD   | S/U | Comments<br>(Required for Unsat) |
|---|--|--|-----|----------------------------------|
| <b>NOTE: Provide the examinee with a copy of SO23-12-3, Loss of Coolant Accident, Attachment 2.</b> |  |  |     |                                  |
| 1   | Verify Containment pressure less than 14 psig, stable, and lowering.                 | Observes Containment Pressure NR indications 2PI-0351-1, 2, 3, & 4 on CR-57 <b>or</b> Containment Pressure WR indications 2PI-0352-1, 2, 3, & 4 on CR-57.  |     | Start Time: _____                |
| <b>CUE: Containment pressure is lowering.</b>   |  |  |     |                                  |
| 2   | Verify at least 2 Containment Emergency Cooling Units operating.                     | Observes indicating lights for Containment Emergency Cooling Units (ECU):<br><ul style="list-style-type: none"> <li>• 2E399 2HS-9953-1 on</li> <li>• 2E401 2HS-9947-1 off</li> <li>• 2E402 2HS-9955-2 off</li> <li>• 2E400 2HS-9939-2 off</li> </ul> |     |                                  |
| 3*  | With only Containment Emergency Cooling Unit E399 operating the RNO must be entered. | Recognizes that the AER column is not met and enters the RNO column due to only one Containment Emergency Cooling Unit operating.  |     |                                  |
| 4   | Ensure that CSAS is actuated.  | Verifies that CSAS is actuated by observing annunciators 57A/B03 CSAS TRAIN A/B ACTUATION illuminated.<br>Verifies Containment Spray pumps (2P012/2P013) operating and Containment Spray Header Control valves (2HV-9367 & 2HV-9368) open.           |     |                                  |

\* Denotes a CRITICAL STEP

| NO  | PERFORMANCE STEP   | STANDARD   | S/U | Comments<br>(Required for Unsat) |
|-----|--|--|-----|----------------------------------|
| 5*  | Close CCW to/from Letdown Heat Exchanger Valves.                         | Depresses the CLOSE pushbutton for Train B L/D HX valve CCW CLB LTDN HX 2E062 SUPPLY/RETURN VALVE 2HV-6522B/A. |     |                                  |
| 6*  | Ensure that each Containment Spray Header flow is greater than 1625 gpm. | Observes Containment Spray Hdr No.1 & No.2 flow indicators 2FI-0338-1 and 2FI-0348-2.                          |     |                                  |
| 7*  | Exits FS-13 and goes to FS-14, Transfer Charging Pump Suction.           | Proceeds to Floating Step 14, Transfer Charging Pump Suction of S023-12-3, LOCA.                               |     |                                  |
| 8   | Verifies elapsed time from SIAS actuation greater than 1-1/2 hours.      | Calculates per initial conditions state that 1-3/4 hours have elapsed.   |     |                                  |
| 9   | Verifies elapsed time from SIAS actuation less than 2 hours.             | Calculates per initial conditions state that 1-3/4 hours have elapsed.   |     |                                  |
| 10  | Verify RWST level greater than 6%.                                       | Observes RWT 2T006 Level, 2LI-0305-1 through 4.  |     |                                  |
| 11  | Ensure LV-0227C, RWST to Charging Pumps gravity feed valve open.         | Verifies open 2LV-0227C, RWT 2T006 Gravity Feed Valve.   |     |                                  |
| 12* | Override BAMU Pump 2P174.  | Depresses the OVERRIDE pushbutton for BAMU Pump 2P174.   |     |                                  |
| 13* | Stop BAMU Pump 2P174.  | Depresses the STOP pushbutton for BAMU Pump 2P174.   |     |                                  |

\* Denotes a CRITICAL STEP

| NO  | PERFORMANCE STEP  | STANDARD  | S/U | Comments<br>(Required for Unsat) |
|-----|---|---|-----|----------------------------------|
| 14* | Override BAMU Pump 2P175.                                 | Depresses the OVERRIDE pushbutton for BAMU Pump 2P175.                              |     |                                  |
| 15* | Stop BAMU Pump 2P175.                                     | Depresses the STOP pushbutton for BAMU Pump 2P175.                                  |     |                                  |
| 16* | Override gravity feed valve 2HV-9235.                     | Depresses the OVERRIDE pushbutton for 2HV-9235, BAMU Tank 2T072 Gravity Feed Valve. |     |                                  |
| 17* | Close gravity feed valve 2HV-9235.                        | Depresses the CLOSE pushbutton for 2HV-9235, BAMU Tank 2T072 Gravity Feed Valve.    |     |                                  |
| 18* | Override gravity feed valve 2HV-9240.                     | Depresses the OVERRIDE pushbutton for 2HV-9240, BAMU Tank 2T071 Gravity Feed Valve. |     |                                  |
| 19* | Close gravity feed valve 2HV-9240.                        | Depresses the CLOSE pushbutton for 2HV-9240, BAMU Tank 2T071 Gravity Feed Valve.    |     |                                  |
| 20* | Override the emergency boration isolation valve 2HV-9247. | Depresses the OVERRIDE pushbutton for 2HV-9247, Emergency Boration Block Valve.     |     |                                  |
| 21* | Close emergency boration isolation valve 2HV-9247.        | Depresses the CLOSE pushbutton for 2HV-9247, Emergency Boration Block Valve.        |     |                                  |

**JPM:** J049FS

**TITLE:** Terminate Containment Spray

\* Denotes a CRITICAL STEP

| NO | PERFORMANCE STEP   | STANDARD   | S/U | Comments<br>(Required for Unsat) |
|----|--|--|-----|----------------------------------|
| 22 | Ensure the Volume Control Tank Outlet Valve 2LV-0227B is closed. | Verifies 2LV-0227B, Volume Control Tank Outlet Block Valve is closed.<br><br><b>TERMINATING CUE:</b><br><b>This JPM is complete.</b> |     | Stop time: _____                 |

REV 0, 06/08/00

151

Page 151 of 11

COMPLETED BY: ~~X~~ h X g X fx eL. Zildic.Xb.Xa.X2DATE: 09 May 2005 JPM

REV 0, 06/08/00

Operations Division

JPM CH

152



a Reinforced concrete slab was cast in the position of the slab shown in Figure 1. The slab was cast in the position of the slab shown in Figure 1. The slab was cast in the position of the slab shown in Figure 1.

THIS IS A TIME CRITICAL JPM

**JPM INFO**

| INITIAL | PLANT | CONDITION |
|---------|-------|-----------|
| 1       | 1     | 1         |
| 2       | 2     | 2         |
| 3       | 3     | 3         |
| 4       | 4     | 4         |
| 5       | 5     | 5         |
| 6       | 6     | 6         |
| 7       | 7     | 7         |
| 8       | 8     | 8         |
| 9       | 9     | 9         |
| 10      | 10    | 10        |
| 11      | 11    | 11        |
| 12      | 12    | 12        |
| 13      | 13    | 13        |
| 14      | 14    | 14        |
| 15      | 15    | 15        |
| 16      | 16    | 16        |
| 17      | 17    | 17        |
| 18      | 18    | 18        |
| 19      | 19    | 19        |
| 20      | 20    | 20        |
| 21      | 21    | 21        |
| 22      | 22    | 22        |
| 23      | 23    | 23        |
| 24      | 24    | 24        |
| 25      | 25    | 25        |
| 26      | 26    | 26        |
| 27      | 27    | 27        |
| 28      | 28    | 28        |
| 29      | 29    | 29        |
| 30      | 30    | 30        |
| 31      | 31    | 31        |
| 32      | 32    | 32        |
| 33      | 33    | 33        |
| 34      | 34    | 34        |
| 35      | 35    | 35        |
| 36      | 36    | 36        |
| 37      | 37    | 37        |
| 38      | 38    | 38        |
| 39      | 39    | 39        |
| 40      | 40    | 40        |
| 41      | 41    | 41        |
| 42      | 42    | 42        |
| 43      | 43    | 43        |
| 44      | 44    | 44        |
| 45      | 45    | 45        |
| 46      | 46    | 46        |
| 47      | 47    | 47        |
| 48      | 48    | 48        |
| 49      | 49    | 49        |
| 50      | 50    | 50        |
| 51      | 51    | 51        |
| 52      | 52    | 52        |
| 53      | 53    | 53        |
| 54      | 54    | 54        |
| 55      | 55    | 55        |
| 56      | 56    | 56        |
| 57      | 57    | 57        |
| 58      | 58    | 58        |
| 59      | 59    | 59        |
| 60      | 60    | 60        |
| 61      | 61    | 61        |
| 62      | 62    | 62        |
| 63      | 63    | 63        |
| 64      | 64    | 64        |
| 65      | 65    | 65        |
| 66      | 66    | 66        |
| 67      | 67    | 67        |
| 68      | 68    | 68        |
| 69      | 69    | 69        |
| 70      | 70    | 70        |
| 71      | 71    | 71        |
| 72      | 72    | 72        |
| 73      | 73    | 73        |
| 74      | 74    | 74        |
| 75      | 75    | 75        |
| 76      | 76    | 76        |
| 77      | 77    | 77        |
| 78      | 78    | 78        |
| 79      | 79    | 79        |
| 80      | 80    | 80        |
| 81      | 81    | 81        |
| 82      | 82    | 82        |
| 83      | 83    | 83        |
| 84      | 84    | 84        |
| 85      | 85    | 85        |
| 86      | 86    | 86        |
| 87      | 87    | 87        |
| 88      | 88    | 88        |
| 89      | 89    | 89        |
| 90      | 90    | 90        |
| 91      | 91    | 91        |
| 92      | 92    | 92        |
| 93      | 93    | 93        |
| 94      | 94    | 94        |
| 95      | 95    | 95        |
| 96      | 96    | 96        |
| 97      | 97    | 97        |
| 98      | 98    | 98        |
| 99      | 99    | 99        |
| 100     | 100   | 100       |

### TASK TO BE PERFORMED

JPM    NUMBER

J004

REV 3, 06/13/00

154

Page 154 of 15

## JOB PER

```
(Print)
```

PERFORMED

PLANTANT

X

J004

SIMSINSTAULTOR



REV 3, 06/13/00

| 2-5                         | 2-4      | 2-3      | 2-2      | 2-1      | 2        | 1-2      | 1-1      | 1       | REV           |
|-----------------------------|----------|----------|----------|----------|----------|----------|----------|---------|---------------|
| DESCRIPTION OF MODIFICATION |          |          |          |          |          |          |          |         |               |
| RCW                         | HJW      | HJW      | HJW      | HJW      | HJW      | HJW      | HJW      | SW      | MODIFIED BY   |
| 08/26/93                    | 08/13/93 | 05/07/94 | 05/26/95 | 05/08/94 | 03/01/94 | 04/30/93 | 03/28/93 | 8/25/93 | MODIFIED DATE |
| N/A                         | N/A      | N/A      | N/A      | N/A      | MJK      | N/A      | N/A      | MJK     | APPROVAL      |

|  |          |          |
|--|----------|----------|
|  | 3        | 2-6      |
|  |          |          |
|  | LRZ      | JJM      |
|  | 06/13/00 | 10/26/99 |
|  | WLL      | WLL      |

REV 3, 06/13/00

## SET-UP

158

**JPM: J004 TITLE:** Perform the duties of the Unit 2(3) CO following a Control Room evacuation

\* Denotes a CRITICAL STEP

| NO   | PERFORMANCE STEP  | STANDARD  | S/U | Comments<br>(Required for Unsat) |
|--|---|---|-----|----------------------------------|
| <p><b>NOTE:</b> Start this JPM from the Control Building lobby. Provide the examinee with a copy of SO23-13-2, Attachments 4(5) and 21.</p> <p><b>NOTE:</b> The initial start time is logged as the examinee leaves the Control Building lobby.</p> <p><b>CUE:</b> Simulate all actions throughout this procedure.</p> |   |   |     |                                  |
| 1*   | Proceed to SSD locker and obtain an emergency lantern, steam tables, alarming dosimeter, headsets, and 21(31) keyset. [SSD KIT: 21(31)] | Proceeds to SSD locker and obtains an emergency lantern, steam tables, alarming dosimeter, headsets, and 21(31) keyset. [SSD KIT: 21(31)] |     | Start Time: _____                |
| <p><b>CUE:</b> Identify CO duffel bag but do not remove from locker.</p> <p><b>CUE:</b> Locate from the Control Building side, the door leading to the Penetration Building, but do <u>not</u> open the door.</p>  |   |   |     |                                  |
| 2*   | Proceed to the door accessing the SSD route to Unit 2(3) Penetration Building.  | Locates the door to the Unit 2(3) Penetration Building. The door for Unit 2 is AC307 and Unit 3 is AC342.                                 |     | Stop Time: _____                 |
| <p><b>NOTE:</b> Stop the clock when the door to the Penetration Building is located. Restart the clock when the SSD route door in the Penetration Building side is located.</p> <p><b>CUE:</b> Proceed to the other side of the door via Radwaste.</p>   |   |   |     |                                  |
| <b>NOTE:</b> Restart time when examinee identifies the Penetration side of the door.   |   |   |     |                                  |
| 3*   | Proceed to penetration area 45'.  | Proceeds to penetration area and locates the SSD route door and then proceeds to Switchgear 2A01(3A01).                                   |     | Start Time: _____                |

**JPM: J004 TITLE:** Perform the duties of the Unit 2(3) CO following a Control Room evacuation

\* Denotes a CRITICAL STEP

| NO   | PERFORMANCE STEP  | STANDARD  | S/U | Comments<br>(Required for Unsat) |
|--|---|---|-----|----------------------------------|
| 4  | Check open RCP breaker 2A0101 for 2P-001 (3A0102 for 3P-001). | Observes the indicating lights for RCP P-001 supply breaker 2A0101 (3A0102).                  |     |                                  |
| <b>CUE: The green light is on. All actions to trip and lockout breakers should be simulated.</b> |   |   |     |                                  |
| 5*   | Remove plastic cover to AUX TRIP & LOCKOUT RELAY 286.         | Simulates removing plastic cover to AUX TRIP & LOCKOUT RELAY 286 on 2A0101(3A0102).           |     |                                  |
| 6*   | Trip the AUX TRIP & LOCKOUT RELAY 286 with the plastic cover. | Simulates using the plastic cover to trip the AUX TRIP & LOCKOUT RELAY 286 on 2A0101(3A0102). |     |                                  |
| 7  | Check open RCP breaker 2A0103 for 2P-004 (3A0104 for 3P-004). | Observes the indicating lights for RCP P-004 supply breaker 2A0103 (3A0104).                  |     |                                  |
| <b>CUE: The green light is on.</b>   |   |   |     |                                  |
| 8*   | Remove plastic cover to AUX TRIP & LOCKOUT RELAY 286.         | Simulates removing plastic cover to AUX TRIP & LOCKOUT RELAY 286 on 2A0103(3A0104).           |     |                                  |
| 9*   | Trip the AUX TRIP & LOCKOUT RELAY 286 with the plastic cover. | Simulates using the plastic cover to trip the AUX TRIP & LOCKOUT RELAY 286 on 2A0103(3A0104). |     |                                  |
| 10   | Proceed to the Penetration Area 63'.                          | Proceeds switchgear 2A02 (3A02) in the Penetration Area 63'.                                  |     |                                  |



**JPM: J004 TITLE:** Perform the duties of the Unit 2(3) CO following a Control Room evacuation

\* Denotes a CRITICAL STEP

| NO   | PERFORMANCE STEP  | STANDARD  | S/U | Comments<br>(Required for Unsat) |
|--|---|---|-----|----------------------------------|
| 11   | Check open RCP breaker 2A0201 for 2P-002(3A0202 for 3P-002).      | Observes the indicating lights for RCP P-002 supply breaker 2A0201(3A0202).                   |     |                                  |
| <b>CUE: The green light is on.</b>               |   |   |     |                                  |
| 12*  | Remove plastic cover to AUX TRIP & LOCKOUT RELAY 286.             | Simulates removing plastic cover to AUX TRIP & LOCKOUT RELAY 286 on 2A0201(3A0202).           |     |                                  |
| 13*  | Trip the AUX TRIP & LOCKOUT RELAY 286 with the plastic cover.     | Simulates using the plastic cover to trip the AUX TRIP & LOCKOUT RELAY 286 on 2A0201(3A0202). |     |                                  |
| 14   | Check open RCP breaker 2A0203 for 2P-003(3A0204 for 3P-003).      | Observes the indicating lights for RCP P-003 supply breaker 2A0203(3A0204).                   |     |                                  |
| <b>CUE: The green light is on.</b>               |   |   |     |                                  |
| 15*  | Remove plastic cover to AUX TRIP & LOCKOUT RELAY 286.             | Simulates removing plastic cover to AUX TRIP & LOCKOUT RELAY 286 on 2A0203(3A0204).           |     |                                  |
| 16*  | Trip the AUX TRIP & LOCKOUT RELAY 286 with the plastic cover.     | Simulates using the plastic cover to trip the AUX TRIP & LOCKOUT RELAY 286 on 2A0203(3A0204). |     |                                  |
| 17   | Check Non-1E PZR backup heater supply breaker 2(3)B0805 position. | Observes breaker 2(3)B0805 indication window.   |     |                                  |
| <b>CUE: The red closed indicator is visible.</b> |   |   |     |                                  |

**JPM: J004 TITLE:** Perform the duties of the Unit 2(3) CO following a Control Room evacuation

\* Denotes a CRITICAL STEP

| NO   | PERFORMANCE STEP  | STANDARD   | S/U | Comments<br>(Required for Unsat) |
|--|---|--|-----|----------------------------------|
| 18*  | Place the Charging Power Toggle Switch to OFF.                    | Simulates placing Charging Power Toggle Switch to OFF (down) on 2(3)B0805.               |     |                                  |
| 19*  | Trip breaker 2(3)B0805.   | Simulates moving the trip pushbutton guard aside then push the trip button on 2(3)B0805. |     |                                  |
| <b>CUE: The green open indicator is visible.</b> |   |  |     |                                  |
| 20   | Check Non-1E PZR backup heater supply breaker 2(3)B0806 position. | Observes breaker 2(3)B0806 indication window.  |     |                                  |
| <b>CUE: The red closed indicator is visible.</b> |   |  |     |                                  |
| 21*  | Place the Charging Power Toggle Switch to OFF.                    | Simulates placing Charging Power Toggle Switch to OFF (down) on 2(3)B0805.               |     |                                  |
| 22*  | Trip breaker 2(3)B0806.   | Simulates moving the trip pushbutton guard aside then push the trip button on 2(3)B0806. |     |                                  |
| <b>CUE: The green open indicator is visible.</b> |   |  |     |                                  |
| 23   | Check PZR proportional heater supply breaker 2(3)B0810 position.  | Observes breaker 2(3)B0810 indication window.  |     |                                  |
| <b>CUE: The red closed indicator is visible.</b> |   |  |     |                                  |

**JPM: J004 TITLE:** Perform the duties of the Unit 2(3) CO following a Control Room evacuation

\* Denotes a CRITICAL STEP

| NO  | PERFORMANCE STEP  | STANDARD   | S/U | Comments<br>(Required for Unsat) |
|---|---|--|-----|----------------------------------|
| 24*   | Place the Charging Power Toggle Switch to OFF.                                  | Simulates placing Charging Power Toggle Switch to OFF (down) on 2(3)B0810.   |     |                                  |
| 25*   | Trip breaker 2(3)B0810.   | Simulates moving the trip pushbutton guard aside then push the trip button on 2(3)B0810.   |     |                                  |
| <b>CUE: The green open indicator is visible.</b>    |   |  |     |                                  |
| 26  | Proceed to Penetration Area 45' by way of the Fuel Handling Building Stairwell. | Proceeds to Penetration Area 45' by way of the Fuel Handling Building Stairwell.   |     |                                  |
| 27  | Check Non-1E PZR back up heater supply breaker 2(3)B0205 position.              | Observes breaker 2(3)B0205 indication window.  |     |                                  |
| <b>CUE: The green open indicator is visible.</b>    |   |  |     |                                  |
| 28*   | Place the Charging Power Toggle Switch to OFF.                                  | Simulates placing charging power toggle switch to OFF (down) on 2(3)B0205.   |     |                                  |
| 29*   | Trip breaker 2(3)B0205.   | Simulates moving the trip pushbutton guard aside then push and hold the trip button while lifting the manual close lever to the right of the trip button on 2(3)B0205. |     |                                  |
| <b>CUE: You hear the closing springs discharge.</b> |   |  |     |                                  |

**JPM: J004 TITLE:** Perform the duties of the Unit 2(3) CO following a Control Room evacuation

\* Denotes a CRITICAL STEP

| NO  | PERFORMANCE STEP   | STANDARD   | S/U | Comments<br>(Required for Unsat) |
|---|--|--|-----|----------------------------------|
| 30  | Check Non-1E PZR back up heater supply breaker 2(3)B0206 position. | Observes breaker 2(3)B0206 indication window.  |     |                                  |
| <b>CUE: The green open indicator is visible.</b>    |  |  |     |                                  |
| 31*   | Place the Charging Power Toggle Switch to OFF.                     | Simulates placing charging power toggle switch to OFF (down) on 2(3)B0206.   |     |                                  |
| 32*   | Trip breaker 2(3)B0206.  | Simulates moving the trip pushbutton guard aside then push and hold the trip button while lifting the manual close lever to the right of the trip button on 2(3)B0206. |     |                                  |
| <b>CUE: You hear the closing springs discharge.</b> |  |  |     |                                  |
| 33  | Check PZR proportional heater supply breaker 2(3)B0210 position .  | Observes breaker 2(3)B0210 indication window.  |     |                                  |
| <b>CUE: The green open indicator is visible.</b>    |  |  |     |                                  |
| 34*   | Place the Charging Power Toggle Switch to OFF.                     | Simulates placing charging power toggle switch to OFF (down) on 2(3)B0210.   |     |                                  |

**JPM: J004    TITLE:**        Perform the duties of the Unit 2(3) CO following a Control Room evacuation

\* Denotes a CRITICAL STEP

| NO  | PERFORMANCE STEP        | STANDARD   | S/U | Comments<br>(Required for Unsat)  |
|-----|-------------------------|--|-----|---|
| 35* | Trip breaker 2(3)B0210. | Simulates moving the trip pushbutton guard aside then push and hold the trip button while lifting the manual close lever to the right of the trip button on 2(3)B0210.<br><br><b>TERMINATING CUE:</b><br>You hear the closing springs discharge. This JPM is complete. |     | Stop Time: _____<br><br>Examiner will combine both times to determine the total time to perform this JPM.<br><br>Total Time: _____<br><br><b>NOTE: Critical Time is 16 minutes.</b> |

REV 3, 06/13/00

166

Page 166 of 15

COMPLETED BY: ~~X~~ h X g X fx eL. Zildic.Xb.Xa.X2DATE: 09/09/2011 JPM

REV 3, 06/13/00

# Operations

JPM CH

167

Function: To provide a means for the operator to monitor the status of the plant and to initiate corrective action when necessary.

| <u>TASK TO BE PERFORMED</u> | <u>INITIAL</u> | <u>PLANT</u> | <u>JPM INFO</u><br><u>CONDITION</u> |
|-----------------------------|----------------|--------------|-------------------------------------|
|-----------------------------|----------------|--------------|-------------------------------------|

JPM NUMBER

J148



REV 0, 07/05/00

169

Page 169 of 7

## JOB PER

```
(Print)
```

PERFORMED

PLANTANT

X

J148

SIMSINSTRATOR

| N/A

REV 0, 07/05/00

171

|  |   |                 |
|--|---|-----------------|
|  | 0 | REV             |
|  |   | New             |
|  |   | DESCRIPTION C   |
|  |   | <u>MODIFIED</u> |
|  |   | MODIFIED        |
|  |   | BY              |
|  |   | MODIFIED        |
|  |   | DATE            |
|  |   | APPROVAL        |
|  |   | SOL             |

REV 0, 07/05/00

172

SET-UP

**JPM: J148 TITLE:** Perform Manual Auxiliary Spray Actions.

\* Denotes a CRITICAL STEP

| NO   | PERFORMANCE STEP   | STANDARD  | S/U | Comments<br>(Required for Unsat) |
|--|--|---|-----|----------------------------------|
| <b>NOTE: Provide the examinee with a copy of SO23-12-9, Functional Recovery, Attachment 7.</b> |  |   |     |                                  |
| 1  | Ensure 3HV-9201 is closed.   | Ensures 3HV-9201 is closed by contacting the Control Room and verifying 3HV-9201 position.  |     | Start Time: _____                |
| <b>CUE: The CRS reports that the PZR Auxiliary Spray Valve 3HV-9201 is closed.</b>             |  |   |     |                                  |
| 2*   | UNLOCK and OPEN 1208MU130, PZR Auxiliary Spray Bypass Line Isolation Valve (Penetration 68).                       | Simulates unlocking and opening 1208MU130, PZR Auxiliary Spray Bypass Line Isolation Valve at Penetration 68.                     |     |                                  |
| 3*   | UNLOCK and THROTTLE 1208MU084, Charging Line Block Valve to control spray flow to establish required PZR pressure. | Simulates unlocking and throttling 1208MU084, Charging Line Block Valve to control spray flow to establish required PZR pressure. |     |                                  |
| 4  | Contact the Control Room to verify correct valve position.   | Contacts the Control Room to verify correct valve position.<br><br><b>TERMINATING CUE:<br/>This JPM is complete.</b>              |     | Stop Time: _____                 |

REV 0, 07/05/00

174

COMPLETED BY: X L. X d. c. Xb. Xa. X2 DATE: 09/05/2011 JPM i

REV 0, 07/05/00

Operations Division

JPM CH

175

THIS IS A TIME CRITICAL JPM

Tr O P Task Description M JPM Number Initial Plant Condition JPM Number

TASK TO BE PERFORMED INITIAL PLANT CONDITION JPM INFO

JPM NUMBER

J021



REV 2, 06/13/00

177

Page 177 of 10

## JOB PER

```
(Print)
```

PERFORMED

PLANTANT


X

J021

SIMULASTHAUGATOR







**JPM: J021 TITLE: Locally Open Reactor Trip Breakers and MG Set Breakers**

\* Denotes a CRITICAL STEP

| NO  | PERFORMANCE STEP                          | STANDARD   | S/U | Comments<br>(Required for Unsat)                       |
|---|---|--|-----|--|
| <p><b>NOTE:</b> Proceed to the Rad Waste Control Room before providing the examinee with a copy of the task to be performed.</p> <p><b>NOTE:</b> The examinee is not allowed to refer to a procedure.</p> <p><b>NOTE:</b> Any combination of open breakers (either 1 or 2 and either 7 or 8 AND either 3 or 4 and either 5 or 6) that results in an open circuit to CEDM Buses 1 and 2 satisfies Critical Steps 1 through 8 inclusive for this JPM.</p> <p><b>NOTE:</b> The following steps may be performed in any sequence.</p> |   |  |     |  |
| 1*  | Open Reactor Trip Circuit Breakers TCB-1. | Presses the local trip push button on breaker cubicle (behind the stainless steel guard plate), <b>or</b> presses the Emergency Trip push button TCB-5 & TCB-1 on TCB-5 cubicle. |     | Start Time: _____<br>(From the Rad Waste Control Room) |
| <p><b>NOTE:</b> The Emergency Trip push button trips 2 associated breakers simultaneously.</p> <p><b>CUE:</b> The green light(s) is (are) on.</p>   |   |  |     |  |
| 2*  | Open Reactor Trip Circuit Breaker TCB-2.  | Presses the local trip push button on breaker cubicle (behind the stainless steel guard plate), <b>or</b> presses the Emergency Trip push button TCB-6 & TCB-2 on TCB-6 cubicle. |     |  |
| <p><b>CUE:</b> The green light(s) is (are) on.</p>  |   |  |     |  |

\* Denotes a CRITICAL STEP

| NO  | PERFORMANCE STEP                         | STANDARD   | S/U | Comments<br>(Required for Unsat) |
|---|--|--|-----|----------------------------------|
| 3*  | Open Reactor Trip Circuit Breaker TCB-3. | Presses the local trip push button on breaker cubicle (behind the stainless steel guard plate), <b>or</b> presses the Emergency Trip push button TCB-3 & TCB-7 on TCB-3 cubicle. |     |                                  |
| <b>CUE: The green light(s) is (are) on.</b> |  |  |     |                                  |
| 4*  | Open Reactor Trip Circuit Breaker TCB-4. | Presses the local trip push button on breaker cubicle (behind the stainless steel guard plate), <b>or</b> presses the Emergency Trip push button TCB-4 & TCB-8 on TCB-4 cubicle. |     |                                  |
| <b>CUE: The green light(s) is (are) on.</b> |  |  |     |                                  |
| 5*  | Open Reactor Trip Circuit Breaker TCB-5. | Presses the local trip push button on breaker cubicle (behind the stainless steel guard plate), <b>or</b> presses the Emergency Trip push button TCB-5 & TCB-1 on TCB-5 cubicle. |     |                                  |
| <b>CUE: The green light(s) is (are) on.</b> |  |  |     |                                  |
| 6*  | Open Reactor Trip Circuit Breaker TCB-6. | Presses the local trip push button on breaker cubicle (behind the stainless steel guard plate), <b>or</b> presses the Emergency Trip push button TCB-6 & TCB-2 on TCB-6 cubicle. |     |                                  |

\* Denotes a CRITICAL STEP

| NO  | PERFORMANCE STEP                         | STANDARD   | S/U | Comments<br>(Required for Unsat) |
|---|--|--|-----|----------------------------------|
| <b>CUE: The green light(s) is (are) on.</b> |  |  |     |                                  |
| 7*  | Open Reactor Trip Circuit Breaker TCB-7. | Presses the local trip push button on breaker cubicle (behind the stainless steel guard plate), <b>or</b> presses the Emergency Trip push button TCB-3 & TCB-7 on TCB-3 cubicle. |     |                                  |
| <b>CUE: The green light(s) is (are) on.</b> |  |  |     |                                  |
| 8*  | Open Reactor Trip Circuit Breaker TCB-8. | Presses the local trip push button on breaker cubicle (behind the stainless steel guard plate), <b>or</b> presses the Emergency Trip push button TCB-4 & TCB-8 on TCB-4 cubicle. |     |                                  |
| <b>CUE: The green light(s) is (are) on.</b> |  |  |     |                                  |
| 9*  | Open MG set 1 input breaker.             | On 3L-045 places the MOTOR INPUT breaker in Off.   |     |                                  |
| 10*   | Open MG set 1 output breaker.            | On 3L-045 places the GENERATOR OUTPUT breaker in Off.  |     |                                  |
| 11*   | Open MG set 2 input breaker.             | On 3L-046 places the MOTOR INPUT breaker in Off.   |     |                                  |

**JPM: J021    TITLE: Locally Open Reactor Trip Breakers and MG Set Breakers**

\* Denotes a CRITICAL STEP

| NO  | PERFORMANCE STEP              | STANDARD   | S/U | Comments<br>(Required for Unsat) |
|-----|-------------------------------|--|-----|----------------------------------|
| 12* | Open MG set 2 output breaker. | On 3L-046 places the GENERATOR OUTPUT breaker in Off.<br><br><b>TERMINATING CUE:<br/>This JPM is complete.</b> |     | Stop Time: _____                 |



REV 2, 06/13/00

185

Page 185 of 10

COMPLETED BY: X hX q.X fX eX. Zldi c.Xb.Xa.X2 DATE: 2019-09-01 BY: XdEse JPM

REV 2, 06/13/00

# Operations Management

JPM CH

186

Revised: 2019-01-23

| TASK TO BE PERFORMED | INITIAL | PLANT | JPM INFO  |  |
|----------------------|---------|-------|-----------|--|
|                      |         |       | CONDITION |  |
|                      |         |       |           |  |

JPM    NUMBER

J169A

REV 0, 06/20/00

188

Page 188 of 7

## JOB PER

```
(Print)
```

PERFORMED

PLANTANT

X

**J169A**

SIMS INVESTIGATOR

X

REV 0, 06/20/00

189

[illegible]

REV 0, 06/20/00

190

|  |     |                 |
|--|-----|-----------------|
|  | 0   | REV             |
|  | New |                 |
|  |     | DESCRIPTION OF  |
|  |     | <u>MODIFIED</u> |
|  |     | MODIFIED        |
|  |     | BY              |
|  |     | MODIFIED        |
|  |     | DATE            |
|  |     | APPROVAL        |
|  |     | SOL             |

REV 0, 06/20/00

191

SET-UP

**JPM: J169A TITLE:** Determine the Required Boron Concentration for Cooldown to Mode 5

\* Denotes a CRITICAL STEP

| NO   | PERFORMANCE STEP                      | STANDARD   | S/U | Comments<br>(Required for Unsat)                 |
|--|---------------------------------------|--|-----|--|
| <p><b>NOTE:</b> Provide the examinee with a copy of SO23-5-1.5, Plant Shutdown from Hot Standby to Cold Shutdown, when located. When located in the Simulator or plant, provide the examinee with a copy of Operations Figure 2.3-1, Songs Unit 2 Cycle 10 Minimum Boron Concentration for 5.15% Shutdown Margin.</p> <p><b>CUE:</b> The CO has commenced the boration. All control rods are inserted.</p> |                                       |  |     |  |
| 1*   | Determine target boron concentration. | <p>Determines target boron concentration using OPS Figure 2.3-1, SDM 5.15% <math>\Delta K/K</math> @ 200°F (Non-Refueling Outage Method).</p> <p>(Calculates a value between 1590 ppm &amp; 1610 ppm)</p> <p><b>TERMINATING CUE:</b><br/>This JPM is complete.</p> |     | <p>Start Time: _____</p> <p>Stop Time: _____</p> |



REV 0, 06/20/00

193

Page 193 of 7

COMPLETED BY: g.X fX L N/A illX d. c.Xb.Xa.X2DATE: 06/02/01 McLX dTse JPM

REV 0, 06/20/00

Operations Division

JPM CH

194

Operations in Support of the Initial and Final Stages of the Recovery and Maintenance of the System

| <u>TASK TO BE PERFORMED</u> | <u>INITIAL PLANT CONDITION</u> | <u>JPM INFO</u> |
|-----------------------------|--------------------------------|-----------------|
|-----------------------------|--------------------------------|-----------------|

JPM NUMBER

J170A

REV 0, 06/14/00

196

|  |         |           |   | JOB PER |
|--|---------|-----------|---|---------|
|  | (Print) | PERFORMED |   | J170A   |
|  |         | PLANTANT  |   |         |
|  |         | SIMS      |   |         |
|  |         | SIMS      |   |         |
|  |         |           | X |         |
|  |         |           | X |         |



REV 0, 06/14/00

198

|  |   |                 |
|--|---|-----------------|
|  | 0 | REV             |
|  |   | New             |
|  |   | DESCRIPTION C   |
|  |   | <u>MODIFIED</u> |
|  |   | MODIFIED        |
|  |   | BY              |
|  |   | MODIFIED        |
|  |   | DATE            |
|  |   | APPROVAL        |
|  |   | SOL             |

REV 0, 06/14/00

199

SET-UP

**JPM: J170A TITLE:** Authorize, Supervise, and Review all Surveillance Tests performed on shift.

\* Denotes a CRITICAL STEP

| NO   | PERFORMANCE STEP  | STANDARD  | S/U | Comments<br>(Required for Unsat) |
|--|---|---|-----|----------------------------------|
| <b>NOTE: Provide a marked-up copy of SO23-3-3.13, Containment Cooling/Spray Monthly Tests, Attachment 1.</b> |   |   |     |                                  |
| 1  | Perform final SRO review of the surveillance procedure. | Reviews the surveillance procedure provided.  |     | Start Time: _____                |
| 2*   | Discover error in Step 2.7.1.                           | Discovers that the difference between the Stop Time and Start Time for E-401 was less than 15 minutes, and that YES has been circled instead of NO.   |     |                                  |
| 3  | Perform the step required for unsatisfactory results.   | Performs the following:<br>- Refers to TS LCO's 3.6.6.1, 3.6.6.2, and 3.7.7.<br>- Initiates LCOAR/EDMR/AR<br>- Repeats the surveillance test<br><br><b>TERMINATING CUE:<br/>This JPM is complete.</b> |     | Stop Time: _____                 |



REV 0, 06/14/00

201

Page 201 of 7

COMPLETED BY ~~X~~ ~~h~~ ~~g~~ ~~X~~ ~~fx~~ L. ~~W~~ ~~ill~~ ~~X~~ d. c. ~~X~~ ~~b~~ ~~.~~ ~~X~~ ~~a~~ ~~.~~ ~~X~~ ~~2~~ ~~D~~ ~~A~~ ~~T~~ ~~E~~ ~~a~~ ~~c~~ ~~h~~ ~~6~~ ~~0~~ ~~0~~ ~~2~~ ~~M~~ ~~a~~ ~~0~~ ~~8~~ ~~c~~ ~~l~~ ~~X~~ ~~d~~ ~~e~~ JPM

REV 0, 06/14/00

Operations Division

JPM CH



REV 0, 06/14/00

204

Page 204 of 7

## JOB PER

```
(Print)
```

PERFORMED

PLANTANT

X

**J166A**

SIMS INVESTIGATOR

X

REV 0, 06/14/00

205

| RO       |          | CO/CRS | RO/SRO |
|----------|----------|--------|--------|
| 2.9      | 2.3.10   | 2923   |        |
| L. Zilli |          | NO     |        |
| SRO      |          |        |        |
| W. Lyke  |          |        |        |
| M. Jones |          |        |        |
| 10       | 3.3      |        |        |
| DATE:    |          |        |        |
| DATE:    |          | N/A    |        |
| 08/04/00 | 02/11/00 |        |        |

DOCUMENT

J166A

CRITICAL TIME:

5  
minutes

REV 0, 06/14/00

206

| MODIFIED |     |             |
|----------|-----|-------------|
|          | 0   | REV         |
|          | New |             |
|          |     | DESCRIPTION |
|          |     |             |
|          |     | MODIFIED    |
|          |     | BY          |
|          |     | MODIFIED    |
|          |     | DATE        |
|          |     | APPROVAL    |
|          |     | SOL         |

REV 0, 06/14/00

207

**JPM: J166A TITLE:** Determine does rates and contaminated areas from an HP survey map.

\* Denotes a CRITICAL STEP

| NO   | PERFORMANCE STEP  | STANDARD   | S/U | Comments<br>(Required for Unsat) |
|--|---|--|-----|----------------------------------|
| <p><b>NOTE: The following steps can be performed in any order.</b></p> <p><b>NOTE: Provide the examinee with a copy of SO123-VII-20.9, Radiological Surveys, if requested, and the applicable HP Survey Map.</b></p> |   |  |     |                                  |
| 1*   | Determine the highest "On Contact" dose rate in mrem/hr.              | Determines the highest "On Contact" dose rate to be 10 mrem/hr.  |     | Start Time: _____                |
| 2*   | Determine the highest "General Area" radiation level in mrem/hr.      | Determines the highest "General Area" radiation level to be 15 mrem/hr.  |     |                                  |
| 3*   | Determine the highest "Contaminated Area" in DPM/100cm <sup>2</sup> . | Determines the highest "Contaminated Area" to be <1K DPM/100cm <sup>2</sup> .  |     |                                  |
| 4  | Determine the highest "Dose Rate at 30 cm" in mrem/hr.                | <p>Determines the highest "Dose Rate at 30 cm" to be 6 mrem/hr.</p> <p><b>TERMINATING CUE:<br/>This JPM is complete.</b></p> |     | Stop Time: _____                 |



REV 0, 06/14/00

209

Page 209 of 7

COMPLETED BY: ~~X~~ ~~h~~ ~~g~~ ~~X~~ ~~h~~ ~~L~~ ~~z~~ ~~ill~~ ~~X~~ ~~d~~ ~~c~~ ~~X~~ ~~b~~ ~~X~~ ~~a~~ ~~X~~ ~~2~~ ~~D~~ ~~A~~ ~~T~~ ~~E~~ ~~:~~ ~~h~~ ~~0~~ ~~8~~ ~~2~~ ~~0~~ ~~1~~ ~~9~~ ~~1~~ ~~0~~ ~~1~~ ~~0~~ ~~X~~ ~~h~~ ~~i~~ ~~d~~ ~~e~~ ~~s~~ ~~The~~ ~~J~~ ~~P~~ ~~M~~ ~~i~~

REV 0, 06/14/00

Operations Division of the United States Coast Guard, 1111 North Washington Blvd., Suite 1100, Washington, DC 20004

JPM CHI

210

| TASK TO BE PERFORMED | INITIAL | PLANT | JPM INFO  |  |
|----------------------|---------|-------|-----------|--|
|                      |         |       | CONDITION |  |
|                      |         |       |           |  |

**JPM    NUMBER**

J126S

REV 1, 06/08/00

212

Page 212 of 7

## JOB PER

```
(Print)
```

PERFORMED

PLANTANT

X

**J126S**

SIMSINSTRATOR

X

REV 1, 06/08/00

213

DATE:

06/26/26/09/00

|  |   |                |
|--|---|----------------|
|  | 1 | REV            |
|  |   | DESCRIPTION OF |
|  |   | MODIFIED       |
|  |   | MODIFIED       |
|  |   | DATE           |
|  |   | APPROVAL       |
|  |   | SOL            |

REV 1, 06/08/00

215

SET-UP

**JPM: J126S TITLE: Determine Protective Action Recommendations**

\* Denotes a CRITICAL STEP

| NO   | PERFORMANCE STEP  | STANDARD   | S/U | Comments<br>(Required for Unsat) |
|--|---|--|-----|----------------------------------|
| <b>NOTE: Provide the examinee with a copy of SO123-VIII-10.3, Protective Action Recommendations.</b> |   |  |     |                                  |
| 1  | Determine that the PAR required is based on the Emergency Class.  | Uses criteria in Step 6.1.2.2 to determine that Emergency Class PARs apply.  |     | Start time: _____                |
| 2*   | Based on a Site Area Emergency with doses as stated in the Initial Conditions the PAR is to evacuate State Beach. | Using the Table in Step 6.1.2.2, based on a Site Area Emergency, recommends evacuating the State Beach.<br><br><b>TERMINATING CUE:<br/>This JPM is complete.</b> |     | Stop time: _____                 |



REV 1, 06/08/00

217

Page 217 of 7

~~COMPLETED BY X k q.X f L.eZillX d. c.Xb.Xa.X2DATEach6bQMa0RclXdEse JPM is~~

REV 1, 06/08/00

Operations Division of the United States Coast Guard

JPM CHI

218

Following the Control Room Shutdown, the JPM is to be placed in the Standby position.

| <u>TASK TO BE PERFORMED</u> | <u>INITIAL</u> | <u>PLANT</u> | <u>JPM INFO</u> | <u>CONDITION</u> |
|-----------------------------|----------------|--------------|-----------------|------------------|
|-----------------------------|----------------|--------------|-----------------|------------------|

JPM NUMBER

J019







REV 2, 06/15/00

223

SET-UP

**JPM: J019**     **TITLE:** Perform required duties of the Unit 2(3) CRS during a Shutdown from Outside the Control Room.

\* Denotes a CRITICAL STEP

| NO  | PERFORMANCE STEP   | STANDARD   | S/U | Comments<br>(Required for Unsat) |
|---|--|--|-----|----------------------------------|
| <p><b>NOTE:</b> Start this JPM from the Control Building Lobby. Provide the examinee with a copy of SO23-13-2, Shutdown from Outside the Control Room, Attachments 2(3) and 21.</p> <p><b>NOTE:</b> The start time is logged as the examinee leaves the Control Building lobby.</p> <p><b>NOTE:</b> When the examinee indicates how to gain access to the Safe Shutdown locker, unlock the Safe Shutdown Locker.</p> <p><b>CUE:</b> Simulate all actions throughout this procedure.</p> |  |  |     |                                  |
| 1*  | Proceed to Control Building 50' Safe Shutdown (SSD) locker and identify equipment to be taken. | Proceeds to SSD Locker and identifies SSD KIT: CRS 2(3) and simulates removal from locker. |     | Start time: _____                |
| <b>CUE: Identify CRS duffel bag but do not remove from locker.</b>  |  |  |     |                                  |
| 2   | Proceed to 2(3)D2 Vital Power Distribution Room.   | Locates Room 310-D.  |     |                                  |
| 3   | ENSURE closed ESF DC control power at 2(3)D2P1.  | Locates breaker 2(3)D2P101, Power to Sw Gr 2(3)A06, in Panel 2(3)D2P1.                     |     |                                  |
| <b>CUE: Breaker 2(3)D2P101 is closed.</b>   |  |  |     |                                  |
| 4   | ENSURE closed ESF DC control power at 2(3)D2P1.  | Locates breaker 2D2P102, Power to LC 2B06, in Panel 2D2P1.                                 |     |                                  |
| <b>CUE: Breaker 2(3)D2P102 is closed.</b>   |  |  |     |                                  |
| 5   | ENSURE closed ESF DC control power at 2(3)D2P1.  | Locates breaker 2(3)D2P111, Power to 2(3)G003 2(3)L-161, in Panel 2(3)D2P1.                |     |                                  |



**JPM: J019**     **TITLE:** Perform required duties of the Unit 2(3) CRS during a Shutdown from Outside the Control Room.

\* Denotes a CRITICAL STEP

| NO  | PERFORMANCE STEP        | STANDARD  | S/U | Comments<br>(Required for Unsat) |
|---|-------------------------|---|-----|----------------------------------|
| <b>CUE: Breaker 2(3)D2P111 is closed.</b> |                         |   |     |                                  |
| 6*  | ENSURE open 2(3)D2P103. | Simulates opening 2(3)D2P103, Power to 2(3)L-33, in Panel 2(3)D2P1.                               |     |                                  |
| <b>CUE: Breaker 2(3)D2P103 is open.</b>   |                         |   |     |                                  |
| 7*  | ENSURE open 2(3)D2P104. | Simulates opening 2(3)D2P104, Power to 2(3)L071-3R, in Panel 2(3)D2P1.                            |     |                                  |
| <b>CUE: Breaker 2(3)D2P104 is open.</b>   |                         |   |     |                                  |
| 8*  | ENSURE open 2(3)D2P105. | Simulates opening 2(3)D2P105, Power to 2(3)L421, in Panel 2D(3)2P1.                               |     |                                  |
| <b>CUE: Breaker 2(3)D2P105 is open.</b>   |                         |   |     |                                  |
| 9*  | ENSURE open 2(3)D2P108. | Simulates opening 2(3)D2P108, Power to 2(3)L-345, in Panel 2(3)D2P1.                              |     |                                  |
| <b>CUE: Breaker 2(3)D2P108 is open.</b>   |                         |   |     |                                  |
| 10*                                       | ENSURE open 2(3)D2P109. | Simulates opening 2(3)D2P109, Power to NSSS Cabinet 2(3)L-071-4R Flood Alarms, in Panel 2(3)D2P1. |     |                                  |
| <b>CUE: Breaker 2(3)D2P109 is open.</b>   |                         |   |     |                                  |

**JPM: J019**     **TITLE:** Perform required duties of the Unit 2(3) CRS during a Shutdown from Outside the Control Room.

\* Denotes a CRITICAL STEP

| NO  | PERFORMANCE STEP   | STANDARD   | S/U | Comments<br>(Required for Unsat) |
|---|--|--|-----|----------------------------------|
| 11*   | At the 2(3)D2 Switchboard open power supply breaker, 2(3)D205, providing power to HV-4706 and HV-4715. | Simulates opening breaker 2(3)D205, Power to 2(3)HV-4706 & 4715, in Panel 2(3)D2, 125 VDC Bus. |     |                                  |
| <b>CUE: Breaker 2(3)D205 is open.</b>   |  |  |     |                                  |
| 12  | Proceed to Unit 2(3) Train B Switchgear Room.  | Proceeds to Unit 2(3) Train B Switchgear Room 302A.  |     |                                  |
| <b>NOTE: The key for Fire Isolation Panel "B" 2(3)L-413 is not on the JPM key ring.</b>   |  |  |     |                                  |
| 13*   | Unlock and open Fire Isolation Panel 2(3)L-413.  | Simulates unlocking and opening Fire Isolation Panel "B" 2(3)L-413.                            |     |                                  |
| <b>NOTE: Ensure that examinee identifies all switches to be placed in "LOCAL" with the exception of the two (2) DG Cross Tie 50.54(X) switches. The spares may or may not be placed in "LOCAL".</b> |  |  |     |                                  |
| 14*   | Select all Fire Isolation Switches to LOCAL.   | Simulates or indicates the following:<br>• Placing all Fire Isolation Switches to LOCAL        |     |                                  |
| <b>CUE: All Fire Isolation Switches are in LOCAL.</b>   |  |  |     |                                  |
| 15*   | Open Second Point of Control cubicle 2(3)A0601.  | Opens Second Point of Control cubicle 2(3)A0601.   |     |                                  |
| 16*   | Select all control switches to stop.   | Simulates placing all Second Control Point switches to STOP.                                   |     |                                  |

**JPM: J019**    **TITLE:** Perform required duties of the Unit 2(3) CRS during a Shutdown from Outside the Control Room.

\* Denotes a CRITICAL STEP

| NO   | PERFORMANCE STEP  | STANDARD   | S/U | Comments<br>(Required for Unsat) |
|--|---|--|-----|----------------------------------|
| <b>CUE: All control switches are in STOP.</b><br><br><b>NOTE: Provide the following cue when breaker 2(3)A0613 is located.</b><br><br><b>CUE: 2(3)A0613, 2(3)G003 output breaker GREEN light is on.</b>  |   |  |     |                                  |
| 17*  | Lockout 2(3)A0613, 2(3)G003 output breaker.                       | Simulates removing cover to overcurrent lockout relay 186-2, DSL GEN 2(3)G003 LOCKOUT, (located on 2(3)A0614 cubicle) and uses insulated cover to actuate relay. |     |                                  |
| <b>CUE: 2(3)A0613 is open.</b>   |   |  |     |                                  |
| 18*  | Turn off DC control power to 2(3)A0613, 2(3)G003 output breaker.  | Simulates opening front panel of breaker and opening DC control power breaker.   |     |                                  |
| <b>CUE: DC control power switch is off.</b><br><br><b>NOTE: Provide the following cue when breaker 2A0619 (3A0603) is located.</b><br><br><b>CUE: 2A0619 (3A0603), 1E 4kV bus tie GREEN light is on.</b> |   |  |     |                                  |
| 19*  | Lockout 2A0619 (3A0603), 1E Bus Tie breaker.                      | Simulates removing cover to overcurrent lockout relay 186-1 and uses insulated cover to actuate relay.   |     |                                  |
| <b>CUE: 2A0619 (3A0603) is open.</b>   |   |  |     |                                  |
| 20*  | Turn off DC control power to 2A0619 (3A0603), 1E Bus Tie breaker. | Simulates opening front panel of breaker and opening DC control power breaker.   |     |                                  |

**JPM: J019**     **TITLE:** Perform required duties of the Unit 2(3) CRS during a Shutdown from Outside the Control Room.

\* Denotes a CRITICAL STEP

| NO   | PERFORMANCE STEP  | STANDARD  | S/U | Comments<br>(Required for Unsat) |
|--|---|---|-----|----------------------------------|
| <p><b>CUE: DC control power switch is off.</b></p> <p><b>NOTE: Provide the following cue when breaker 2(3)A0618 is located.</b></p> <p><b>CUE: 2(3)A0618, Reserve Aux Transformer breaker RED light is on.</b></p> |   |   |     |                                  |
| 21*  | Lockout 2(3)A0618, 1E Reserve Aux Transformer breaker.  | Removes cover to overcurrent lockout relay 186-1 and uses insulated cover to actuate relay.   |     |                                  |
| <p><b>CUE: 2(3)A0618 is open.</b></p>  |   |   |     |                                  |
| 22*  | Turn off DC control power to 2(3)A0618, 1E Reserve Aux Transformer breaker.                                       | Simulates opening front panel of breaker and opening DC control power breaker.  |     |                                  |
| <p><b>CUE: DC control power switch is off.</b></p>   |   |   |     |                                  |
| 23*  | Select Transfer Switch 2(3)XS539B for Train B Source Range Neutron Flux Monitor power supply to ALTERNATE SOURCE. | Simulates selecting Transfer Switch 2(3)XS539B for Train B Source Range Neutron Flux Monitor power supply to ALTERNATE SOURCE. (Transfer switch located in southeast corner of room). |     |                                  |
| <p><b>CUE: Transfer Switch is in ALTERNATE SOURCE.</b></p>   |   |   |     |                                  |
| 24*  | Remove key from Transfer Switch 2(3)XS539B.   | Simulates removing key from Transfer Switch 2(3)XS539B.   |     |                                  |

**JPM: J019**     **TITLE:** Perform required duties of the Unit 2(3) CRS during a Shutdown from Outside the Control Room.

\* Denotes a **CRITICAL STEP**

| NO  | PERFORMANCE STEP                           | STANDARD  | S/U | Comments<br>(Required for Unsat) |
|-----|--|---|-----|----------------------------------|
| 25* | Insert key in Isolation Switch 2(3)XS539A. | Simulates inserting key in Isolation Switch 2(3)XS539A. (Transfer switch located in southeast corner of Room 308A(B) Train A Switchgear Room).          |     |                                  |
| 26* | Select 2(3)XS539A to CLOSED.               | Simulates selecting 2(3)XS539A to CLOSED.   |     |                                  |
| 27  | Proceed to EVSD.                           | <p>Proceeds to Evacuation Shutdown Panel and simulates establishing communications.</p> <p><b>TERMINATING CUE:</b><br/><b>This JPM is complete.</b></p> |     | Stop Time: _____                 |

REV 2, 06/15/00

230

Page 230 of 13

COMPLETED BY: ~~X~~ h X g.X fx eL. Zildic.Xb.Xa.X2DATE: 09/09/2011 JPM

REV 2, 06/15/00

Operations Division

JPM CH

231