

**J. Bernie Beasley, Jr., P.E.**  
Vice President  
Vogtle Project

**Southern Nuclear  
Operating Company, Inc.**  
40 Inverness Center Parkway  
P.O. Box 1295  
Birmingham, Alabama 35201

Tel 205.992.7110  
Fax 205.992.0403



January 11, 2001

Docket Nos.: 50-424  
50-425

LCV-1483-A

U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, DC 20555-0001

**VOGTLE ELECTRIC GENERATING PLANT  
TECHNICAL SPECIFICATION CHANGE REQUEST  
INCORPORATING THE REVISION TO 10 CFR 50.59 - REVISION 1**

Ladies and Gentlemen:

In accordance with the provisions of 10 CFR 50.90, Southern Nuclear Operating Company (SNC) submitted a proposed amendment to Vogtle Electric Generating Plant (VEGP) Unit 1 and Unit 2 Technical Specifications (TS) in letter LCV-1483 dated November 16, 2000. The amendment revises TS 5.5.14, "Technical Specification Bases Control Program," to provide consistency with the changes to 10 CFR 50.59 as published in the Federal Register (64 FR 53582) dated October 4, 1999. SNC is submitting a revision to the November 16, 2000 amendment request to incorporate an editorial change (WOG-ED-24) to the Nuclear Energy Institute (NEI) Technical Specification Task Force (TSTF) Standard Technical Specification Change Traveler, TSTF-364 Revision 0, "Revision to TS Bases Control Program to Incorporate Changes to 10 CFR 50.59."

This minor editorial change replaces the phrase "changes do not involve" with "changes do not require" in TS 5.5.14.b. This change is made to be consistent with the new 10 CFR 50.59 rule.

The basis and the conclusions reached in the significant hazards evaluation provided in the November 16, 2000 submittal remain valid and therefore are not resubmitted.

The proposed Technical Specifications change is provided in the Attachment. In accordance with 10 CFR 50.91(b)(1), a copy of the proposed change has been sent to Mr. L. C. Barrett, Commissioner, Department of Natural Resources.


SNC requests that this amendment be approved by February 16, 2001, with an implementation date to correspond with the implementation of the new 10 CFR 50.59 rule.

A001

U. S. Nuclear Regulatory Commission  
LCV-1483-A  
Page 2


If you have any questions, please advise.

Respectfully submitted,

  
\_\_\_\_\_

J. B. Beasley, Jr.

Sworn to and subscribed before me this 11<sup>th</sup> day of January 2001

  
\_\_\_\_\_

Notary Public

My Commission Expires: 11/10/02

JBB/JMG

Attachment: Technical Specifications Changed Page List, Mark-up and Typed Pages

cc: Southern Nuclear Operating Company  
Mr. J. T. Gasser  
Mr. M. Sheibani  
SNC Document Management

U. S. Nuclear Regulatory Commission  
Mr. L. A. Reyes, Regional Administrator  
Mr. Ramin R. Assa, Vogtle Project Manager, NRR  
Mr. J. Zeiler, Senior Resident Inspector , Vogtle

Georgia Department of Natural Resources  
Mr. L. C. Barrett, Commissioner

Attachment

Vogle Electric Generating Plant  
Technical Specification Change Request  
Incorporating the Revision to 10 CFR 50.59 – Revision 1

VEGP Technical Specifications Changed Page List

VEGP Technical Specifications Mark-up Page

VEGP Technical Specifications Typed Page

Vogle Electric Generating Plant  
Technical Specification Change Request  
Incorporating the Revision to 10 CFR 50.59 – Revision 1

**Changed Pages List**

<u>Changed Page</u>	<u>Revision Instruction</u>
5.5-18	Replace

5.5 Programs and Manuals

5.5.14 Technical Specifications (TS) Bases Control Program

This program provides a means for processing changes to the Bases of these Technical Specifications.

- a. Changes to the Bases of the TS shall be made under appropriate administrative controls and reviews
- b. Licensees may make changes to Bases without prior NRC approval provided the changes do not involve either of the following:
  - 1. a change in the TS incorporated in the license; or
  - 2. a change to the updated FSAR or Bases that involves an unreviewed safety question as defined in 10 CFR 50.59.
- c. The Bases Control Program shall contain provisions to ensure that the Bases are maintained consistent with the FSAR.
- d. Proposed changes that meet the criteria of (b) above shall be reviewed and approved by the NRC prior to implementation. Changes to the Bases implemented without prior NRC approval shall be provided to the NRC on a frequency consistent with 10 CFR 50.71(e).

require

5.5.15 Safety Function Determination Program (SFDP)

This program ensures loss of safety function is detected and appropriate actions taken. Upon entry into LCO 3.0.6, an evaluation shall be made to determine if loss of safety function exists. Additionally, other appropriate actions may be taken as a result of the support system inoperability and corresponding exception to entering supported system Condition and Required Actions. This program implements the requirements of LCO 3.0.6. The SFDP shall contain the following:

- a. Provisions for cross train checks to ensure a loss of the capability to perform the safety function assumed in the accident analysis does not go undetected;
- b. (d.) Provisions for ensuring the plant is maintained in a safe condition if a loss of function condition exists;

that requires NRC approval pursuant to

(continued)

---

## 5.5 Programs and Manuals

---

### 5.5.14 Technical Specifications (TS) Bases Control Program

This program provides a means for processing changes to the Bases of these Technical Specifications.

- a. Changes to the Bases of the TS shall be made under appropriate administrative controls and reviews
- b. Licensees may make changes to Bases without prior NRC approval provided the changes do not require either of the following:
  1. a change in the TS incorporated in the license; or
  2. a change to the updated FSAR or Bases that requires NRC approval pursuant to 10 CFR 50.59.
- c. The Bases Control Program shall contain provisions to ensure that the Bases are maintained consistent with the FSAR.
- d. Proposed changes that meet the criteria of (b) above shall be reviewed and approved by the NRC prior to implementation. Changes to the Bases implemented without prior NRC approval shall be provided to the NRC on a frequency consistent with 10 CFR 50.71(e).

### 5.5.15 Safety Function Determination Program (SFDP)

This program ensures loss of safety function is detected and appropriate actions taken. Upon entry into LCO 3.0.6, an evaluation shall be made to determine if loss of safety function exists. Additionally, other appropriate actions may be taken as a result of the support system inoperability and corresponding exception to entering supported system Condition and Required Actions. This program implements the requirements of LCO 3.0.6. The SFDP shall contain the following:

- a. Provisions for cross train checks to ensure a loss of the capability to perform the safety function assumed in the accident analysis does not go undetected;
- b. Provisions for ensuring the plant is maintained in a safe condition if a loss of function condition exists;

(continued)

---