



John T. Conway
Vice President
Nuclear Generation

Phone: 315.349.4213
Fax: 315.349.2605

January 12, 2001
NMP93372

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555


RE: Nine Mile Point Unit 1
Docket No. 50-220
DPR-63

Subject: Monthly Operating Report for December 2000

Gentlemen:

Submitted herewith are the Operating Data Report, Unit Shutdowns, and a Narrative of Operating Experience for December 2000 for the Nine Mile Point Nuclear Station Unit #1. Submittal of this information complies with Section 6.9.1.c of the Unit #1 Technical Specifications.

Very truly yours,


John T. Conway
Vice President Nuclear Generation

/sls
Attachments

pc: H.J. Miller, Regional Administrator, Region I
G.K. Hunegs, Senior Resident Inspector
Records Management

JE24

ATTACHMENT A
OPERATING DATA REPORT

DOCKET NO: 50-220
DATE: 1/3/01
PREPARED BY: P. E. Netusil
TELEPHONE: (315) 349-7935

OPERATING STATUS

Unit Name: Nine Mile Point Unit #1
Reporting Period: December 2000

1	Design Electrical Rating: (Net MWe)	613
2	Maximum Dependable Capacity: (Net MWe)	565

	This Month	Yr-to-Date	Cumulative	
3	Critical Hours	744.0	8,134.5	189,560.0
4	Hours Generator On-Line	744.0	8,062.0	185,290.3
5	Unit Reserve Shutdown Hours	0.0	0.0	20.4
6	Net Electrical Energy Generated (MWH)	458,869.0	4,681,848.0	102,652,812.0

ATTACHMENT B

UNIT SHUTDOWNS
REPORTING PERIOD – DECEMBER 2000

DOCKET NO: 50-220
UNIT NAME: NMP1
DATE: 1/3/01
PREPARED BY: P. E. Netusil
TELEPHONE: (315) 349-7935

NO.*	DATE	TYPE F: FORCED S: SCHEDULED	DURATION (HOURS)	REASONS ¹	METHOD OF SHUTTING DOWN ²	CAUSE & CORRECTIVE ACTIONS COMMENTS
						NO SHUTDOWNS OCCURRED IN DECEMBER 2000.

- (1) Reason
- A. Equipment Failure (Explain)
 - B. Maintenance or Test
 - C. Refueling
 - D. Regulatory Restriction
 - E. Operator Training/License Examination
 - F. Administrative
 - G. Operational Error (Explain)
 - H. Other (Explain)

- (2) Method
- 1. Manual
 - 2. Manual Trip/Scram
 - 3. Automatic Trip/Scram
 - 4. Continuation
 - 5. Other (Explain)

*NOTE: Sequential numbering used.

ATTACHMENT C

NARRATIVE OF OPERATING EXPERIENCE

DOCKET NO: 50-220

UNIT NAME: NMP1

DATE: 1/3/01

PREPARED BY: P. E. Netusil

TELEPHONE: (315) 349-7935

The unit operated during the month of December with a net electrical design capacity factor of 100.6%. The unit was reduced to 92% core thermal power on December 3, 2000 to remove Reactor Recirculation Pump #14 from service for planned maintenance. The unit was reduced to 84% core thermal power on December 16, 2000 to start Reactor Recirculation Pump #14. There were no challenges to the electromatic relief valves or safety valves during the operating period.