



PECO NUCLEAR

A Unit of PECO Energy

John Doering, Jr.
Vice President
Peach Bottom Atomic Power Station

PECO Energy Company
1848 Lay Road
Delta, PA 17314-9032
717 456 4000
Fax 717 456 4243
E-mail: jdoering@peco-energy.com

January 4, 2001

**Docket Nos. 50-277
50-278**

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

SUBJECT: 2000 Annual Report on Safety Relief Challenges for the Peach Bottom Atomic Power Station

Gentlemen:

This represents the 2000 Annual Report on Safety Relief Challenges for the Peach Bottom Atomic Power Station (PBAPS) as required by the TMI Action Plan, Item II. K.3, and by PBAPS Technical Requirement Manual Appendix A Item 5.0 R17. During 2000 there were no automatic actuations of the Main Steam Relief Valves or the Main Steam Safety Valves in response to high reactor pressure.

If you have any questions regarding this matter, please call.

Sincerely,

John Doering, Jr.
Vice President,
Peach Bottom Atomic Power Station

JD CHM CLB JJK
JD/PJD/CHM/CLB/JJK/jjk

cc: E. Salowitz, Public Service Electric & Gas
R. R. Janati, Commonwealth of Pennsylvania
R. I. McLean, State of Maryland
H. J. Miller, Administrator, Region I, USNRC
A.C. McMurtry, USNRC, Senior Resident Inspector
A.F. Kirby, III, Delmarva Power & Light
INPO Records Center
A. Winter, PBAPS Experience Assessment
Correspondence Control Desk, KSA 1-N

CCN# 01-14001

A001