

From: Mahesh Chawla
To: Internet:kelly.root@exeloncorp.com
Date: Tue, Jan 23, 2001 5:40 PM
Subject: ComEd submittal dt: 11/7/2000 - Request for TS change to extend the STI for SSPS relays to 18 mos.

Following is the list of questions we would like to discuss with you on the subject amendment. Please let me know about your availability to have this telephone conference. If you have any further questions, please give me a call.

1. The licensee submittal does not define whether AR relay with DC coils are included in the request for surveillance test interval extension. It should be noted that Westinghouse Owners Group Topical report, WCAP-13877 does not cover AR relay with DC coil. Therefore, if AR relay with DC coil are included in the extension request then provide the basis for extending the applicability of the topical report to these relays based on the analysis similar to ac relays. Also attachment E of the submittal does not provide the similarity of the relays in the topical reports to the relays in the plant.

2. The licensee plan to extend the applicability of the topical reports to the future relays which will be used to replace existing relays. It is staff's understanding that these relays could be purchased from any vendor and could be of different model. The licensee should submit their request in the future when they replace the relay with a specific relay with the analysis similar to topical report for staff's approval at that time.

3. The licensee has requested to extend the topical report for Containment Ventilation Isolation System without providing enough justification. In order for the staff to determine the acceptability of the request, provide details to justify the applicability of the topical report to these relays.

4. Attachment B3 and B4, Table 3.3.2-1, page 1 of 6, function 1d and page 4 of 6, function 5b for Unit 2 has a change bar marked at the top line but Attachment B1 and B2 do not show any change. Please resubmit these pages correcting the discrepancies.

Mac Chawla
(301) 415-8371
MLC@NRC.GOV

CC: George Dick, Hukam Garg

Mail Envelope Properties

(3A6E085D.536 : 15 : 21352)

Subject: ComEd submittal dt: 11/7/2000 - Request for TS change to extend the STI for SSPS relays to 18 mos.

Creation Date: Tue, Jan 23, 2001 5:40 PM

From: Mahesh Chawla

Created By: OWFN_DO.OWF4_PO:MLC

Recipients	Action	Date & Time
Post Office Internet root (Internet:kelly.root@exeloncorp.com)	Transferred	01/23 5:40 PM
Post Office OWFN_DO.owf2_po HCG CC (Hukam Garg)	Delivered Opened	01/23 5:40 PM 01/24 7:55 AM
Post Office OWFN_DO.owf4_po GFD CC (George Dick)	Delivered Opened	01/23 5:40 PM 01/23 6:10 PM

Domain.Post Office	Delivered	Route
Internet Internet:exeloncorp.com:kelly OWFN_DO.owf2_po OWFN_DO.owf4_po	01/23 5:40 PM 01/23 5:40 PM	OWFN_DO.owf2_po OWFN_DO.owf4_po

Files	Size	Date & Time
MESSAGE	3701	Tuesday, January 23, 2001 5:40 PM

Options

Auto Delete:	No
Expiration Date:	None
Notify Recipients:	Yes
Priority:	Standard
Reply Requested:	No
Return Notification:	None

Concealed Subject:	No
Security:	Standard

To Be Delivered:	Immediate
Status Tracking:	Delivered & Opened