

From: George Dick
To: INTERNET:joseph.bauer@exeloncorp.com
Date: Fri, Jan 26, 2001 10:55 AM
Subject: Discussion on Meteorology re: Power Uprate for Byron and Braidwood

Joe,

Please see attached.

George

CC: Leta Brown, Mahesh Chawla, Mark Caruso

Mail Envelope Properties

(3A719E01.527 : 22 : 21110)

Subject: Discussion on Meteorology re: Power Uprate for Byron and Braidwood
Creation Date: Fri, Jan 26, 2001 10:55 AM
From: George Dick

Created By: OWFN_DO.OWF4_PO:GFD

Recipients	Action	Date & Time
Post Office INTERNET bauer (INTERNET:joseph.bauer@exeloncorp.c	Transferred	01/26 10:56 AM

Post Office OWFN_DO.owf2_po LAB2 CC (Leta Brown)	Delivered	01/26 10:56 AM
MAC CC (Mark Caruso)	Opened	01/26 11:48 AM
	Opened	01/29 9:08 AM

Post Office OWFN_DO.owf4_po MLC CC (Mahesh Chawla)	Delivered	01/26 10:55 AM
	Opened	01/29 9:12 AM

Domain.Post Office	Delivered	Route
INTERNET		
INTERNET:exeloncorp.com:joseph		
OWFN_DO.owf2_po	01/26 10:56 AM	OWFN_DO.owf2_po
OWFN_DO.owf4_po	01/26 10:55 AM	OWFN_DO.owf4_po

Files	Size	Date & Time
Uprate.Met.Questions.wpd	3759	Friday, January 26, 2001 10:51 AM
MESSAGE	653	Friday, January 26, 2001 10:55 AM

Options

Auto Delete: No
Expiration Date: None
Notify Recipients: Yes
Priority: Standard
Reply Requested: No
Return Notification: None

Concealed Subject: No
Security: Standard

To Be Delivered: Immediate
Status Tracking: Delivered & Opened

Byron/Braidwood

Questions and points for discussion on the July 5, 2000 power uprate amendment request

1. Are the atmospheric dispersion (X/Q) factors in Table 6.7.1-2 new or were they used previously in documents that have been submitted to the NRC for review, such as in the steam generator replacement amendment request several years ago?
2. Did the meteorological measurement program meet the guidelines of Regulatory Guide 1.23, "Onsite Meteorological Programs," from 1994 through 1998? Discuss checks made on the data to assure that the data input into the calculations were of good quality.
3. Discuss details of the methodologies, inputs and assumptions used to calculate new X/Q values.
4. Please provide, within several days if possible, an electronic copy of the hourly 1994 - 1998 meteorological data and a copy of the inputs used in making the new X/Q calculations?