



Entergy Nuclear Generation Company  
Pilgrim Nuclear Power Station  
600 Rocky Hill Road  
Plymouth, MA 02360

J. F. Alexander  
Director  
Nuclear Assessment

10 CFR 50.55a(a)(3)(i)

ENG. Ltr. 2.01.012  
January 19, 2001

U.S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, DC 20555

Docket No. 50-293  
License No. DPR-35

Supplementary Information in Support of Pilgrim Relief Request (PRR) No. 25:  
Relief from 10 CFR 50.55a(g)(6)(ii)(C), Implementation of Appendix VIII to Section XI,  
Division 1, 1995 Edition with the 1996 Addenda of ASME Code

This letter provides the following clarifications concerning PRR-25 that were discussed with the NRC staff Mr. Alan B. Wang and Mr. Don Naujock on December 19, 2000. ENG. Letter 2.00.079, dated November 15, 2000 submitted PRR-25 for NRC approval.

- Pilgrim seeks relief from CP-189 for Refueling Outage -13 and base the qualifications of NDT personnel in accordance SNT-TC-1A as required by 1989 ASME Code Section XI, Appendix VII.
- Pilgrim plans to implement CP-189 by August 2001, as required by 1995/96 ASME Code pursuant to 10 CFR 50.55a(g)(6)(ii)(C).

If you have any questions regarding the information contained in this letter, please contact Walter Lobo at (508) 830-7940.



J. Alexander  
WGL/rfo13isiRelief-25a.doc

CC: Mr. Alan B. Wang, Project Manager  
Project Directorate I-3  
Office of Nuclear Reactor Regulation  
Mail Stop: OWFN 8F2  
U. S. Nuclear Regulatory Commission  
1 White Flint North  
11555 Rockville Pike  
Rockville, MD 20852

U.S. NRC, Region 1  
475 Allendale Road  
King of Prussia, PA 19406

Senior Resident Inspector  
Pilgrim Nuclear Power Station

A047