

INDEX

LIMITING CONDITIONS FOR OPERATION AND SURVEILLANCE REQUIREMENTS

---

<u>SECTION</u>	<u>PAGE</u>
TABLE 3.3-5 DELETED	
TABLE 4.3-2 ENGINEERED SAFETY FEATURES ACTUATION SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS . . . . .	3/4 3-36
3/4.3.3 MONITORING INSTRUMENTATION	
Radiation Monitoring for Plant Operations . . . . .	3/4 3-42
TABLE 3.3-6 RADIATION MONITORING INSTRUMENTATION FOR PLANT OPERATIONS . . . . .	3/4 3-43
TABLE 4.3-3 RADIATION MONITORING INSTRUMENTATION FOR PLANT OPERATIONS SURVEILLANCE REQUIREMENTS . . . . .	3/4 3-45
TABLE 3.3-7 DELETED	
TABLE 4.3-4 DELETED	
TABLE 3.3-8 DELETED	
TABLE 4.3-5 DELETED	
Remote Shutdown Instrumentation . . . . .	3/4 3-53
TABLE 3.3-9 REMOTE SHUTDOWN INSTRUMENTATION . . . . .	3/4 3-54
TABLE 4.3-6 REMOTE SHUTDOWN MONITORING INSTRUMENTATION SURVEILLANCE REQUIREMENTS . . . . .	3/4 3-58
Accident Monitoring Instrumentation . . . . .	3/4 3-59
TABLE 3.3-10 ACCIDENT MONITORING INSTRUMENTATION . . . . .	3/4 3-60
TABLE 4.3-7 ACCIDENT MONITORING INSTRUMENTATION SURVEILLANCE REQUIREMENTS . . . . .	3/4 3-62
TABLE 3.3-11 DELETED	
TABLE 3.3-12 DELETED	
TABLE 4.3-8 DELETED	

**INDEX**

**LIMITING CONDITIONS FOR OPERATION AND SURVEILLANCE REQUIREMENTS**

---

---

<u>SECTION</u>	<u>PAGE</u>
TABLE 3.3-13 DELETED	
TABLE 4.3-9 DELETED	
3/4.3.4 DELETED	
3/4.3.5 SHUTDOWN MARGIN MONITOR . . . . .	3/4 3-82
 <b><u>3/4.4 REACTOR COOLANT SYSTEM</u></b>	
<b>3/4.4.1 REACTOR COOLANT LOOPS AND COOLANT CIRCULATION</b>	
Startup and Power Operation . . . . .	3/4 4-1
Hot Standby . . . . .	3/4 4-2
Hot Shutdown . . . . .	3/4 4-3
Cold Shutdown - Loops Filled . . . . .	3/4 4-5
Cold Shutdown - Loops Not Filled . . . . .	3/4 4-6
Isolated Loop . . . . .	3/4 4-7
Isolated Loop Startup . . . . .	3/4 4-8
 <b>3/4.4.2 SAFETY VALVES</b>	
Shutdown . . . . .	3/4 4-9
Operating . . . . .	3/4 4-10
 <b>3/4.4.3 PRESSURIZER</b>	
Startup and Power Operation . . . . .	3/4 4-11
FIGURE 3.4-5 PRESSURIZER LEVEL CONTROL . . . . .	3/4 4-11a
Hot Standby . . . . .	3/4 4-11b
3/4.4.4 RELIEF VALVES . . . . .	3/4 4-12
3/4.4.5 STEAM GENERATORS . . . . .	3/4 4-14
TABLE 4.4-1 MINIMUM NUMBER OF STEAM GENERATORS TO BE INSPECTED DURING INSERVICE INSPECTION . . . . .	3/4 4-19
TABLE 4.4-2 STEAM GENERATOR TUBE INSPECTION . . . . .	3/4 4-20
 <b>3/4.4.6 REACTOR COOLANT SYSTEM LEAKAGE</b>	
Leakage Detection Systems . . . . .	3/4 4-21
Operational Leakage . . . . .	3/4 4-22
TABLE 3.4-1 REACTOR COOLANT SYSTEM PRESSURE ISOLATION VALVES . . . . .	3/4 4-24
3/4.4.7 CHEMISTRY . . . . .	3/4 4-25
TABLE 3.4-2 REACTOR COOLANT SYSTEM CHEMISTRY LIMITS . . . . .	3/4 4-26
TABLE 4.4-3 REACTOR COOLANT SYSTEM CHEMISTRY LIMITS SURVEILLANCE REQUIREMENTS . . . . .	3/4 4-27
3/4.4.8 SPECIFIC ACTIVITY . . . . .	3/4 4-28

THIS PAGE LEFT BLANK INTENTIONALLY

THIS PAGE LEFT BLANK INTENTIONALLY

THIS PAGE LEFT BLANK INTENTIONALLY

THIS PAGE LEFT BLANK INTENTIONALLY

THIS PAGE LEFT BLANK INTENTIONALLY

THIS PAGE LEFT BLANK INTENTIONALLY



THIS PAGE LEFT BLANK INTENTIONALLY

THIS PAGE LEFT BLANK INTENTIONALLY

THIS PAGE LEFT BLANK INTENTIONALLY

## INSTRUMENTATION

### BASES

---

---

3/4.3.3.2 DELETED

3/4.3.3.3 DELETED

3/4.3.3.4 DELETED

#### 3/4.3.3.5 REMOTE SHUTDOWN INSTRUMENTATION

The OPERABILITY of the Remote Shutdown Instrumentation ensures that sufficient capability is available to permit safe shutdown of the facility from locations outside of the control room. This capability is required in the event control room habitability is lost and is consistent with General Design Criterion 19 of 10 CFR Part 50.

Calibration of the Intermediate Range Neutron Amps channel from Table 4.3-6 applies to the signal that originates from the output of the isolation amplifier within the intermediate range neutron flux processor drawers in the control room and terminates at the displays within the Auxiliary Shutdown Panel.

The OPERABILITY of the Remote Shutdown Instrumentation ensures that a fire will not preclude achieving safe shutdown. The remote shutdown monitoring

**INSTRUMENTATION**

**BASES**

---

**3/4.3.3.8 DELETED**

**3/4.3.3.9 DELETED**

**3/4.3.3.10 DELETED**

**3/4.3.4 DELETED**