



CALCULATION COVER SHEET

PROJECT Private Fuel Storage Facility (PFSP) JOB NO. 1083-000
 SUBJECT Storage Pad Analysis and Design FILE NO. 1083
 CALC NO. SC(P017)-1
 NO. OF SHEETS 184

RECORD OF ISSUES

NO.	DESCRIPTION	BY	DATE	CHKD	DATE	APPRD	DATE
0	Initial Issue	MTT DH	6/20/97	W	6/20/97	W	6/20/97

This set of calculations presents the analyses and detailed design calculations required for the structural design of the reinforced-concrete spent-fuel cask storage pads to be constructed at the PFSP project site.

This set of calculations has been prepared in accordance with CEC's quality assurance procedure for nuclear projects.

NAME	INITIAL	SIGNATURE
Ming T. Tsay (Preparer)	MTT	Ming T. Tsay
Donald Hamasaki (Preparer)	DH	Donald Hamasaki
Ming S. Yang (Preparer)	msy	Ming S. Yang
Kiat Lilhanand (Checker)	W	K. Lilhanand
Wen S. Tseng (Independent Reviewer)	WST	W. S. Tseng

International Civil Engineering Consultants, Inc.



CALCULATION SHEET

ORIGINATOR DATE 6/17/97 CALC. NO. SC(P017)- REV. NO. 0
PROJECT Private Fuel Storage Facility CHECKED MTT DATE 6/17/97
SUBJECT Storage Pad Analysis and Design JOB NO. 1083-000
SHEET NO. ii

TABLE OF CONTENTS

Section	Page
1. OBJECTIVE	1
2. ANALYSIS AND DESIGN SUMMARY	2
3. REFERENCES	5
4. DESIGN INPUT PARAMETERS AND CRITERIA	7
4.1 Codes & Standards	7
4.2 Site Condition	8
4.3 Geometry and Material Specifications	12
4.4 Design Loads	15
4.5 Load Combinations	18
4.6 Acceptance Criteria	19
5. DESIGN ANALYSIS	21
5.1 Static and Dynamic Analyses Using CECSAP	21
5.1.1 Mathematical Model	22
5.1.2 Static Analyses	33
5.1.3 Dynamic Loadings	36
5.1.4 Dynamic Analysis Output Selection	43
5.1.5 Static and Dynamic Analysis Inputs and Outputs	47
5.1.6 Static and Dynamic Analysis Results	48
5.2 Dynamic Analysis Using SASSI	78
5.2.1 SASSI Model	79



CALCULATION SHEET

CALC. NO. SC(P017)-1 REV. NO. 0ORIGINATOR ✓ DATE 6/17/97 CHECKED WJ DATE 6/8/97
PROJECT Private Fuel Storage Facility JOB NO. 1083-000
SUBJECT Storage Pad Analysis and Design SHEET NO. iii

TABLE OF CONTENTS (CONT'D)

<u>Section</u>	<u>Page</u>
5.2.2 Dynamic Loading	90
5.2.3 analysis Procedure	92
5.2.4 SASSI Analysis Results	97
5.2.5 Comparison of SASSI and CECSAP Results	136
5.3 Soil Pressures	144
5.3.1 Static Soil Pressure	144
5.3.2 Dynamic Lateral Soil Pressure	160
6. DESIGN CALCULATIONS	161
6.1 Design of Reinforced Concrete Pad	161
6.2 Site Bearing Stability Checks	174
6.2.1 Vertical Soil Bearing Pressure and Horizontal Soil Shear Stresses	174
6.2.2 Horizontal Sliding Stability Check	179
A. ATTACHMENT A - CECSAP ANALYSIS INPUT AND OUTPUT	A-1
B. ATTACHMENT B - SASSI ANALYSIS INPUT AND OUTPUT	B-1



CALCULATION SHEET

CALC. NO. SC(P017)-1 REV. NO. 0ORIGINATOR W DATE 6/17/07 CHECKED W DATE 6/21/07PROJECT Private Fuel Storage Facility JOB NO. 1083-000SUBJECT Storage Pad Analysis and Design SHEET NO. 1

1. OBJECTIVE

The objective of this set of calculations is to present the analyses and detailed calculations required for the design of the reinforced-concrete spent-fuel cask storage pads to be constructed at the PFSF project site.



CALCULATION SHEET

CALC. NO. SC(P017)-1 REV. NO. 0
DATE 6/17/97 CHECKED mm DATE 6/17/97
JOB NO. 1083-000
SHEET NO. 2

ORIGINATOR W
PROJECT Private Fuel Storage Facility
SUBJECT Storage Pad Analysis and Design

2. ANALYSIS AND DESIGN SUMMARY

A. Pad Geometry and Support Condition

- (a) Pad Dimensions: Length - 64'-0"
Width - 30'-0"
Thickness - 3'-0"
- (b) Support Condition: Pad directly support on in-situ soil with soil fills on its side walls
- (c) Pad Top Surface Elevation: 3.5" above finished grade elevation
- (d) Pad Bottom Surface Elevation: 2'-8½" below finished grade elevation

B. Pad Structural Design

- (a) Concrete: Normal weight concrete; $f'_c = 4,000$ psi at 28 days
- (b) Reinforcing: ASTM A615 Grade 60 deformed bar; $F_y = 60$ ksi
- (c) Horizontal (Flexural) Reinforcement:

Top Face - Two-way reinforcement with #10 @ 12" o.c.
each way; longitudinal bars at the top at 2.875"
below the top surface of the pad

Bottom Face - Two-way reinforcement with # 10 @ 6" o.c.
each way; longitudinal bars at the bottom at
3.875" above the bottom surface of the pad



CALCULATION SHEET

ORIGINATOR KL DATE 6/17/97 CALC. NO. SC(P017)-1 REV. NO. 0
PROJECT Private Fuel Storage Facility CHECKED mm DATE 5/2/00
SUBJECT Storage Pad Analysis and Design JOB NO. 1083-000
SHEET NO. 3

(d) Vertical (Shear) Reinforcement: One #7 @ 12" o.c. each way in two ways distributed uniformly over the entire pad; each vertical bar with a 135° hook anchored to the top longitudinal bars and a 90° bend anchored to the bottom longitudinal bars.

C. Structural Strengths

(a)	Ultimate static moment capacity (ϕM_u)	=	338 k-ft/ft
(b)	Ultimate dynamic moment capacity ($DIF \times \phi M_u$)	=	423 k-ft/ft
(c)	Ultimate static out-of-plane shear capacity (ϕV_u)	=	123 k/ft
(d)	Ultimate dynamic out-of-plane shear capacity ($DIF \times \phi V_u$)	=	135 k/ft

D. Structural Demand Loads

(a) Normal Loading condition (1.4D + 1.7L + 1.7H):

Maximum moment	=	145.4 k-ft/ft
Maximum (flexural) shear force	=	19.2 k/ft

(b) Accident-Level Loading Condition (D + L + H + E):

Maximum moment	=	383.3 k-ft/ft
Maximum (flexural) shear force	=	83.2 k/ft
Maximum punching shear force	=	111.1 k/ft



CALCULATION SHEET

ORIGINATOR KL DATE 6/17/97 CALC. NO. SC(P017)-1 REV. NO. 0
PROJECT Private Fuel Storage Facility CHECKED mm DATE 6/18/97
SUBJECT Storage Pad Analysis and Design JOB NO. 1083-000
SHEET NO. 4

E. Soil Bearing and Sliding Stabilities

- (a) Maximum soil bearing pressure under the static (dead plus live plus cask transporter) loading condition: 3.50 k/ft²
- (b) Maximum soil bearing pressure under dynamic (dead plus live plus the design earthquake) loading condition: 5.77 k/ft²
- (c) Minimum factor of safety against allowable soil bearing pressure under the long-term static (dead plus live) loading condition: 1.14
- (d) Minimum factor of safety against sliding failure under the dynamic (dead plus live plus design earthquake) loading condition: 2.03



CALCULATION SHEET

ORIGINATOR Private Fuel Storage Facility DATE 6/17/97 CHECKED mt DATE 6/2/97 REV. NO. 0
 PROJECT Storage Pad Analysis and Design JOB NO. 1083-000
 SUBJECT Storage Pad Analysis and Design SHEET NO. 5

3. REFERENCES

1. Stone & Webster Engineering Corporation (SWEC) Calculation No. 05996-01 G(P05)-1, "Development of Soil and Foundation Parameters in Support of Dynamic Soil-Structure Interaction Analysis", Rev. 1 by Geomatrix Consultants, Inc., June 9, 1997.
2. Fax Transmittal from Stan Macie of SWEC to Wen S. Tseng of International Civil Engineering Consultants, Inc. (CEC) on "Revised Table 1-Dynamic Soil Parameters for SASSI Model", dated June 4, 1997.
3. Holtec Report HI-971631, "Multi-Cask Seismic Response at PPS ISFSI", Transmitted through transmittal from Stephen Agace of Holtec to Wen S. Tseng of CEC, dated May 19, 1997.
4. Fax Transmittal from Stan Macie of SWEC to Wen S. Tseng of CEC on "Sketches of J & R Engineering Cask Transporter", dated May 22, 1997.
5. Holtec Document Transmittal from Maria C. Pepe of Holtec to Wen S. Tseng of CEC on "Storage Pad Seismic Response Acceleration Time History", dated May 20 and 22, 1997.
6. Fax Transmittal from Stan Macie of SWEC to Wen S. Tseng of CEC on "Storage Cask Base Details", dated May 29, 1997.
7. Fax Transmittal from Stan Macie of SWEC to Wen S. Tseng of CEC on "Private Fuel Storage Facility Safety Analysis Report" Chapter 3, Revision 0, dated May 9, 1997.



CALCULATION SHEET

ORIGINATOR WV DATE 6/17/97 CALC. NO. _____ REV. NO. 0
PROJECT Private Fuel Storage Facility CHECKED mm DATE 6/5/97
SUBJECT Storage Pad Analysis and Design JOB NO. 1083-000
SHEET NO. 6

3. REFERENCES (CONT'D)

8. Stone & Webster Engineering Corporation (SWEC) Document, "Geotechnical Design Criteria for the PFSF Storage Facility", Revision 1, June 9, 1997.
9. Transmittal from Stan Macie of SWEC to Wen S. Tseng of CEC on "Drawing 0599601-EC-1-B (Rev. B)", dated May 16, 1997.
10. Fax Transmittal from Stan Macie of SWEC to Wen S. Tseng of CEC on "Latest Drawing (0599601-EC-1-B)", dated June 4, 1997.
11. International Civil Engineering Consultants, Inc., "Computer Program SASSI for IMB/RS-6000 Workstation, Version 1.2 - User's Manual," March 1997.
12. International Civil Engineering Consultants, Inc., "Computer Program CECSAP, Version 1.0 - User's Manual," October 1996.
13. ACI 349-85 (1990), "Code Requirements for Nuclear Safety Related Concrete Structures," American Concrete Institute, March 1990.
14. ASCE Standard 4-86, "Seismic Analysis of Safety Related Nuclear Structures and Commentary," American Society of Civil Engineers, September 1986.



CALCULATION SHEET

CALC. NO. SC(P017)-1 REV. NO. 0
DATE 6/17/07 CHECKED LMR DATE 6/17/07
JOB NO. 1083-000
SHEET NO. 7

ORIGINATOR KV
PROJECT Private Fuel Storage Facility
SUBJECT Storage Pad Analysis and Design

4. DESIGN INPUT PARAMETERS AND CRITERIA

4.1 Codes and Standards

The codes and standards used in the analysis and design of the storage pad are as follows:

1. ACI 349-85 (1990), "Code Requirements for Nuclear Safety Related Concrete Structures," American Concrete Institute, March 1990.
2. ASCE Standard 4-86, "Seismic Analysis of Safety Related Nuclear Structures and Commentary," American Society of Civil Engineers, September 1986.



CALCULATION SHEET

ORIGINATOR W DATE 6/17/07 CALC. NO. SC(P017)-1 REV. NO. 0
PROJECT Private Fuel Storage Facility CHECKED MYT DATE 6/17/07
SUBJECT Storage Pad Analysis and Design JOB NO. 1083-000
SHEET NO. 8

4.2 Site Soil Condition

The local site soil profile at the cask storage area consists basically of three layers: an uppermost layer of silt, silty clay and clayey silt with layered thickness of 25 to 35 ft; followed by a layer of 25 to 30 ft thick of very dense fine sand overlying a silty layer, as shown in Fig. 1 (Ref. 8). Results of geophysical survey program indicate that the ground water table is at about 100 to 130 ft and the bedrock is between 520 ft and 880 ft below the ground surface.

The properties of the top soil layer based on the results of geotechnical investigations are as estimated in Ref. 8 as follows:

(a) Effective-stress strength parameters for drained analyses:

Angle of internal friction $\phi = 30^\circ$ and cohesion $c = 0$ ksf.

(b) Total-stress strength parameters for undrained analyses (e.g., dynamic loadings):

$\phi = 0^\circ$ and $c = 2.2$ ksf.

(c) Coefficients of earth pressure, K_0 :

• At-rest, $K_0 = 0.5$

• Active, $K_a = 0.33$

• Passive, $K_p = 3.0$

(d) Coefficient of vertical subgrade reaction of in-situ soil, k :

$k = 20$ kips/ft²

The strain-compatible dynamic soil properties given in Refs. 1 and 2 used in the pad dynamic response analyses using SASSI computer program (Ref. 11) are shown in Table 1.



CALCULATION SHEET

CALC. NO. SC(P017)-1 REV. NO. 0ORIGINATOR W DATE 6/17/07 CHECKED W DATE 6/21/07
PROJECT Private Fuel Storage Facility JOB NO. 1083-000
SUBJECT Storage Pad Analysis and Design SHEET NO. 9**Table 1****Dynamic Soil Parameters for SASSI Model**

(Source: Ref. 2)


Depth (ft)		Density (pcf)	Wave Velocity (fps)		Damping Ratio (%)	
Top	Bottom		Shear	Compressional	Shear	Compressional
0	5	81	637	1500	5	5
5	10	81	520	1500	10	10
10	15	81	469	1500	12	10
15	20	81	353	1500	15	10
20	25	81	327	1500	15	10
25	30	81	280	1500	15	10
30	60	115	1809	4000	4	4
60	120	120	1861	4000	8	8
120	300	130	2080	5600	8	8
300	600	130	2440	5600	8	8
600		150	5000	10000	2	1



CALCULATION SHEET

ORIGINATOR W DATE 6/17/97 CALC. NO. SC(PD17-1) REV. NO. 0
PROJECT Private Fuel Storage Facility CHECKED 11/2/97 DATE 6/17/97
SUBJECT Storage Pad Analysis and Design JOB NO. 1083-000
SHEET NO. 10

Figure 1



* SOURCE: REF. 8



CALCULATION SHEET

CALC. NO. SC(2017)-1 REV. NO. 0
DATE 6/17/97 CHECKED 1/1/25 DATE 5/17/97
JOB NO. 1083-000
SHEET NO. 11

ORIGINATOR ✓
PROJECT Private Fuel Storage Facility
SUBJECT Storage Pad Analysis and Design

The soil spring stiffnesses, damping coefficient, and mass value used to represent the soil foundation for dynamic analyses of the pad using CECSAP program (Ref. 12) are, as developed by Holtech (Ref. 3), shown in Table 2 below.

Table 2
Soil Masses, Spring Stiffnesses, and Damping Constants

Horizontal motion parallel to the long direction of pad

$$M_{HL} = 882.512 \quad \text{lb-sec}^2/\text{in}$$

$$K_{HL} = 6.641 \times 10^6 \quad \text{lb/in}$$

$$C_{HL} = 1.836 \times 10^5 \quad \text{lb-sec/in}$$

Horizontal motion parallel to the short direction of pad

$$M_{HS} = 882.512 \quad \text{lb-sec}^2/\text{in}$$

$$K_{HS} = 6.991 \times 10^6 \quad \text{lb/in}$$

$$C_{HS} = 1.933 \times 10^5 \quad \text{lb-sec/in}$$

Vertical motion

$$M_v = 4.766 \times 10^3 \quad \text{lb-sec}^2/\text{in}$$

$$K_v = 9.679 \times 10^6 \quad \text{lb/in}$$

$$C_v = 3.949 \times 10^5 \quad \text{lb-sec/in}$$



CALCULATION SHEET

CALC. NO. SC(P017-1) REV. NO. 0
DATE 6/17/97 CHECKED 12/1/1 DATE 6/1/97
JOB NO. 1083-000
SHEET NO. 12

ORIGINATOR W
PROJECT Private Fuel Storage Facility
SUBJECT Storage Pad Analysis and Design

4.3 Geometry and Material Specifications

4.3.1 Geometry

The configuration of the storage pad having dimensions of 64' × 30' × 3' supporting 8 dry storage casks considered in the analysis and design of the pad is as specified in Ref. 10 and shown on the following two pages.

4.3.2 Material Specifications

The properties of concrete and reinforcing bars used for the design of the pad are as specified in Ref. 2 as follows:

Concrete: Normal Weight Concrete

f'_c = Compressive strength = 4,000 psi

E_c = Modules of elasticity = $5,7000\sqrt{f'_c} = 3.60 \times 10^6$ psi

γ_c = Unit weight = 150 lb/ft³

ν_c = Poisson's ratio = 0.17

Reinforcing Bar: ATSM A615 Grade 60 Billet Steel

F_y = Specified minimum yield strength = 60 ksi



E_s = Modulus of elasticity = 29,000 ksi



CALCULATION SHEET

CALC. NO. SC(P017-1) REV. NO. 0
DATE 6/17/07 CHECKED 1312/ DATE 6/12/07
JOB NO. 1083-000
SHEET NO. 13

ORIGINATOR Private Fuel Storage Facility
PROJECT Storage Pad Analysis and Design
SUBJECT








SOURCE: LATEST DWG 0599601-EC-1-B (REF. 10)



CALCULATION SHEET

CALC. NO. SC(P017)-1 REV. NO. 0
DATE 6/17/07 CHECKED 11/21/07 DATE 5/1/08
JOB NO. 1083-000
SHEET NO. 14

ORIGINATOR W
PROJECT Private Fuel Storage Facility
SUBJECT Storage Pad Analysis and Design



DETAIL A SCALE: NTS
DETAIL B SCALE: NTS
SOURCE: LATEST DWG 0599601-EC-1-B (REF. 10)



CALCULATION SHEET

ORIGINATOR DATE 6/17/07CALC. NO. SC(D017)-1REV. NO. 0PROJECT Private Fuel Storage FacilityJOB NO. 1083-000SUBJECT Storage Pad Analysis and DesignSHEET NO. 15

4.4 Design Loads

Design loads considered in the analysis and design of the pad consists of the following:

4.4.1 Dead Load (D)

The dead load (D) considered is the gravitational dead weight of the reinforced concrete pad based on:

- Gross unit weight of the concrete pad = 150 pcf

4.4.2 Live Load (L)

The live load (L) considered is the gravitational dead weight of the fully loaded dry cask.

- Weight of each fully-loaded dry cask = 356.5 kips (Ref.2)

Four dry cask storage configurations are considered:

- 2, 4, and 8 casks
- 7 casks with one cask being transported on the pad by cask transporter
- Weight of transporter = 135 kips (Ref. 4)
- An impact factor of 1.0 is conservatively assumed and applied to the total weight of transporter plus one fully- loaded cask, i.e. $(135 + 356.5 =) 491.5$ kips to account for the dynamic effect associated with cask transporting



CALCULATION SHEET

ORIGINATOR W DATE 6/1/10 CALC. NO. REV. NO. 0
PROJECT Private Fuel Storage Facility CHECKED MT DATE 6/17/10
SUBJECT Storage Pad Analysis and Design JOB NO. 1083-000
SHEET NO. 16

4.4.3 Lateral Soil Pressure (H)

The lateral soil pressure (H) acting on the pad's perimeter wall considered is based on the properties of structural backfill soil as follows:

Unit weight of soil = 125 pcf (Ref. 8)

At-rest earth pressure coefficient (K_a) = 0.43 (Ref. 8)

Passive earth pressure coefficient (k_p) = 3.7 (Ref. 8).

4.4.4 Operating and Accident Thermal Loads (T and T_a)

Since the storage pad is supported freely on the ground surface, the loads due to T and T_a are assumed to produce negligible effect for the design of the pad.

4.4.5 Wind Load (W) and Tornado Wind and Missile Load (W_t)

For the design of the pad, the wind load (W) and tornado wind and missile load (W_t) are assumed to affect only the storage casks but not the pad. Thus, its effects are not considered in the design of the pad.

4.4.6 Earthquake Load (E)

The earthquake load (E) considered for the design of the pad is based on the horizontal and vertical design ground motion response spectra (Ref. 8) developed for the site.

For design of the pad, the maximum horizontal (a_h) and vertical (a_v) pad response accelerations based on the Holtec's seismic response analysis results (Ref. 5) coupled with the dry cask seismic response reaction force time histories acting on the pad (Ref. 5) with 2, 4, and 8 cask storage configurations are considered. Values of $a_h = 0.67g$ and $a_v = 0.69g$ are used in the design.



CALCULATION SHEET

CALC. NO. SL(P017)-1 REV. NO. 0
CHECKED hzm DATE 6/17/97
JOB NO. 1083-000
SHEET NO. 17

ORIGINATOR kw
PROJECT Private Fuel Storage Facility
SUBJECT Storage Pad Analysis and Design

For checking seismic sliding stability of the storage pad, the dynamic active soil pressure is computed using the ASCE 4-86 (Ref. 13) procedure.



CALCULATION SHEET

CALC. NO. SC(P017)-1 REV. NO. 0ORIGINATOR W DATE 6/17/97 CHECKED W DATE 6/17/97
PROJECT Private Fuel Storage Facility JOB NO. 1083-000
SUBJECT Storage Pad Analysis and Design SHEET NO. 18

4.5 Load Combinations

Load combinations in accordance with ACI 349-85 (1990) are considered in the pad design as follows:

Loading Condition

Load Combinations

Normal Condition

(1)

 $1.4D + 1.7L$

(2)

 $1.4D + 1.7L + 1.7H$

Off-Normal Condition

(1)

 $0.75 (1.4D + 1.7L + 1.7H + 1.7T)$

(2)

 $0.75 (1.4D + 1.7L + 1.7H + 1.7T + 1.7W)$

Accident-Level Condition (1)

 $D + L + H + T + E$

(2)

 $D + L + H + T_s$

Since T , T_s , W , and W_t are assumed negligible for the design of the pad, the governing load combinations considered in design become:

Loading Condition

Load Combination

Normal condition

 $1.4D + 1.7L + 1.7H$

Accidental-level condition

 $D + L + H + E$



CALCULATION SHEET

ORIGINATOR W DATE 6/17/07 CALC. NO. SC(P017)-4 REV. NO. 0
PROJECT Private Fuel Storage Facility CHECKED W DATE 6/17/07
SUBJECT Storage Pad Analysis and Design JOB NO. 1083-000
SHEET NO. 19

4.6 Acceptance Criteria

4.6.1 Reinforced Concrete Pad

The acceptance criteria for design are in accordance with the strength design (U_c) provisions of ACI-349-85 (1990) as follows:

Loading Condition

Acceptance Criteria

Normal condition

$$U_c > 1.4D + 1.7L + 1.7H$$

Accident-level condition

$$U_c > D + L + H + E$$

~~4.6.2 Soil Bearing and Sliding Stability~~

(a) Vertical Bearing Stability

- Minimum factor of safety for static (dead plus live) loads = 3.0 (Ref. 8).
- Gross allowable static bearing pressure = 4.0 ksf (Ref. 8).
- Minimum factor of safety for static plus design earthquake load = 1.1 (Ref. 8).
- Gross allowable bearing capacity for static plus earthquake load - see Table 3.

(b) Horizontal Sliding and Overturning Stability

- Minimum factor of safety for static (dead plus live) load = 1.5 (Ref. 8).
- Minimum factor of safety for static plus design earthquake load = 1.1 (Ref. 8).



CALCULATION SHEET

CALC. NO. SC(PD177)-1 REV. NO. 0
DATE 6/17/97 CHECKED MJR DATE 6/17/97
JOB NO. 1083-000
SHEET NO. 20

ORIGINATOR W
PROJECT Private Fuel Storage Facility
SUBJECT Storage Pad Analysis and Design

Table 3

Gross Allowable Bearing Capacity for Static Plus Earthquake Loads

Coefficient of Friction Between Casks and Pad μ	Gross Allowable Bearing Pressure $Q_{allowable}$ ksf
0.00	8.97
0.10	8.06
0.20	7.22
0.30	6.47
0.40	5.79
0.50	5.18
0.60	4.64
0.67	4.30



CALCULATION SHEET

CALC. NO. SCCPO17 -1 REV. NO. 0

ORIGINATOR msd DATE 6-17-97 CHECKED W DATE 6/17/97

PROJECT Private Fuel Storage Facility JOB NO. 1083-000

SUBJECT Storage Pad Analysis and Design SHEET NO. 21

5 DESIGN ANALYSIS

5.1 Static and Dynamic Analysis Using CEC SAP

5.1.1 Mathematical Model

5.1.2 Static Analysis

5.1.3 Dynamic Loadings

5.1.4 Dynamic Analysis Output Selection

5.1.5 Static and Dynamic Analysis Inputs and Outputs

5.1.6 Static and Dynamic Analysis Results



CALCULATION SHEET

CALC. NO. CE(2017)-1 REV. NO. 0

ORIGINATOR mg DATE 6-10-97 CHECKED W DATE 6/10/97
PROJECT PFST JOB NO. 1083-002
SUBJECT Storage Pad Analysis SHEET NO. 22

5.1.1. Mathematical model

A mathematical model was developed for the analysis using Program CEC SAP.

Total number of nodes: 299

Elements used:

- 264 plate elements were used to model the pad
- to model soil properties {
 - 299 vertical boundary elements
 - 299 horizontal boundary elements in X-direction
 - 299 horizontal boundary elements in Y-direction

These boundary elements are used to model soil stiffness associated with three motion directions. In other words, each node has three soil springs attached for the three directions of motion.

- Likewise, there are three damper elements assigned to every node to model the soil damping effect. There are a total of 897 damper elements.



CALCULATION SHEET

ORIGINATOR msj DATE 6-10-97 CALC. NO. SC(1017)-1 REV. NO. 1
PROJECT PFST CHECKED W DATE 6/10/97
SUBJECT Storage Pad Analysis JOB NO. 1083-000
SHEET NO. 25

The finite element mesh is shown in the next page with node number plotted. The 299 nodes are arranged in 23 rows of 13 nodes. The distances

between consecutive nodes in each row are, from left to right, 1.98', 2.76', 2.76', 2.76', 2.76', 1.98', 1.98', 2.76', 2.76', 2.76', 2.76', 1.98'. The distances between rows are, from bottom to top, 3.98', 2.76', 2.76',


2.76', 2.76', 3.96', 2.76', 2.76', 2.76', 2.76', 1.98', 1.98', 2.76', 2.76', 2.76', 2.76', 3.96', 2.76', 2.76', 2.76', 2.76', 3.98'.

The mesh is symmetrical with respect to both centerlines. Node No. 150 is at the center of the pad. A

node is assigned to every loading point for each cask. The loading nodes for all cask are

	Quadrant 1	Quadrant 2	Quadrant 3	Quadrant 4
Cask 1	277	249	225	253
Cask 2	283	255	231	259
Cask 3	212	184	160	188
Cask 4	218	190	166	194
Cask 5	134	106	82	110
Cask 6	140	112	88	116
Cask 7	69	41	17	45
Cask 8	75	47	23	51

CECSA.PLOT CEC SAP MODEL



PRIVATE FUEL STORAGE FACILITY, CASK STORAGE PAD

CEC JOB NO. 1083-000

BY msj DATE 6-10-97

CHECK 4 DATE 6/10/97

CALC. NO. 56(P017)-1 REV. NO. 0

SHEET NO. 24


Finite Element Mesh (Plate Element Numbers)

CECSAPLOT

CECSAP MODEL

DYNAMIC ANALYSIS, DRY CASK STORAGE PAD (KIP,F), 2 CASKS

Plate
Element
Numbers:



CEC JOB NO.	1083-000
BY	DATE 6-10-97
CHECK	DATE 6/10/97
CALC. NO.	SC(P017)-1
REV. NO.	0
SHEET NO.	25



CALCULATION SHEET

ORIGINATOR ms7 DATE 6-10-97 CALC. NO. SC(2019)-1 REV. NO. 0
PROJECT PFSF CHECKED W DATE 6/10/97
SUBJECT Rad Analysis JOB NO. 1083-000
SHEET NO. 26

Local axes of plate elements

In The CECSAP model, the local plate coordinate system is in coincidence with the global system.

Thus, the moment M_{xx} of a plate element is for bending about the global Y-axis, and M_{yy} is for bending about global X-axis.



CALCULATION SHEET

CALC. NO. SC(P017)- REV. NO. 0

ORIGINATOR mg DATE 6-10-97 CHECKED W DATE 6/10/97

PROJECT PFST JOB NO. 1083-000

SUBJECT Storage Pad Analysis SHEET NO. 27

Material properties of Pad (Plate Elements)

Young's modulus, E

$$\begin{aligned} E &= 57000 \sqrt{f_c'} \quad f_c' = 4000 \text{ psi (reference)} \\ &= 3605 \text{ ksi} \\ &= 519120 \text{ ksf} \end{aligned}$$

Poisson's Ratio $\nu = 0.17$

Thus, the plane stress material matrix is as follows

$$\begin{Bmatrix} \sigma_{xx} \\ \sigma_{yy} \\ \tau_{xy} \end{Bmatrix} = \frac{E}{1-\nu^2} \begin{bmatrix} 1 & \nu & 0 \\ \nu & 1 & 0 \\ 0 & 0 & (1-\nu)/2 \end{bmatrix} \begin{Bmatrix} \epsilon_{xx} \\ \epsilon_{yy} \\ \epsilon_{xy} \end{Bmatrix} = \begin{bmatrix} 534570 & 90880 & 0 \\ 90880 & 534570 & 0 \\ 0 & 0 & 221850 \end{bmatrix} \begin{Bmatrix} \epsilon_{xx} \\ \epsilon_{yy} \\ \epsilon_{xy} \end{Bmatrix}$$

where $\sigma_{xx}, \sigma_{yy}, \tau_{xy}$ are normal and shear stresses,

and $\epsilon_{xx}, \epsilon_{yy}, \epsilon_{xy}$ are the corresponding strains.

Reference: HOLTZ Report # HI-971631 Appendix C P.C-2
5-19-97

The mass density of the Pad is $0.15/32.2 = 0.0046584 \frac{\text{k}}{\text{ft}^3} \frac{\text{s}^2}{\text{f}}$.

units: k = kip
s = second
f = foot



CALCULATION SHEET

ORIGINATOR mg DATE 6-10-97 CALC. NO. SC(P017)-1 REV. NO. 0
PROJECT PFST CHECKED W DATE 6/10/97
SUBJECT Storage Pad Analysis JOB NO. 1083-000
SHEET NO. 28

Soil Properties: Stiffness, Damping and Mass

Soil stiffness, damping and mass are distributed evenly, according to the tributary area of each node, to all nodes modelling the pad. The values were taken from HOLTec Report NO. HI-971631, Appendix C (Ref. 3)

The values below are the total values for the entire Pad:

Vibration Mode

Vertical

Mass

$$4.766 \times 10^3 \frac{\text{LB-S}^2}{\text{in}} = 57.192 \text{ K-S}^2/\text{f}$$

Stiffness

$$9.679 \times 10^6 \text{ LB/in} = 116148 \text{ K/f}$$

Damping

$$3.949 \times 10^5 \frac{\text{LB-S}}{\text{in}} = 4738.8 \text{ K-S/f}$$

Horizontal (X)

Mass

$$882.512 \frac{\text{LB-S}^2}{\text{in}} = 10.58 \text{ K-S}^2/\text{f}$$

Stiffness

$$6.991 \times 10^6 \text{ LB/in} = 83892 \text{ K/f}$$

Damping

$$1.933 \times 10^5 \frac{\text{LB-S}}{\text{in}} = 2319.6 \text{ K-S/f}$$

Horizontal (Y)

Mass

$$882.512 \frac{\text{LB-S}^2}{\text{in}} = 10.59 \text{ K-S}^2/\text{f}$$

Stiffness

$$6.641 \times 10^6 \text{ LB/in} = 79692 \text{ K/f}$$

Damping

$$1.836 \times 10^5 \frac{\text{LB-S}}{\text{in}} = 2202 \text{ K-S/f}$$



CALCULATION SHEET

CALC. NO. sc(p017)-1 REV. NO. 0ORIGINATOR KL DATE 5/22/97 CHECKED mz DATE 5-24-97PROJECT Private Fuel Storage Facility JOB NO. 1083-000SUBJECT Storage Pad Analysis and Design SHEET NO. 29

MODELING OF SOIL FOUNDATION SUPPORTING THE PAD BY SPRING, DASHPOT AND MASS

SOIL FOUNDATION SUPPORTING THE PAD IS MODELLED BY SOIL SPRING

STIFFNESSES, DASHPOT CONSTANTS AND MASSES DEVELOPED BY

HOLTEC (APP.C, REPORT NO. HI-971631, "MULTI-CASE SEISMIC

RESPONSE AT THE PSF ISFSI) AS LISTED BELOW:

VIBRATION MODE	SOIL PARAMETER	VALUES	Page No.
			(HI-971631) Ref. 3
VERTICAL	M_V	$4.766 \times 10^3 \frac{\text{LB-SEC}^2}{\text{IN}}$	P.C-8
	K_V	$9.679 \times 10^6 \frac{\text{LB}}{\text{IN}}$	P.C-6
	C_V	$3.949 \times 10^5 \frac{\text{LB-SEC}}{\text{IN}}$	P.C-7
HORIZONTAL	M_H	$882.512 \frac{\text{LB-SEC}^2}{\text{IN}}$	P.C-9
	K_{HL}	$4.641 \times 10^6 \frac{\text{LB}}{\text{IN}}$	P.C-5
	C_{HL}	$1.836 \times 10^5 \frac{\text{LB-SEC}}{\text{IN}}$	P.C-7
	K_{HS}	$6.991 \times 10^6 \frac{\text{LB}}{\text{IN}}$	P.C-5
	C_{HS}	$1.933 \times 10^5 \frac{\text{LB-SEC}}{\text{IN}}$	P.C-7


NOTES: M = SOIL MASS, C = SOIL DASHPOT CONSTANT, K = SOIL SPRING STIFFNESS
SUBSCRIPTS H = HORIZONTAL, V = VERTICAL, L AND S = LONG AND SHORT SIDES OF PAD



CALCULATION SHEET

CALC. NO. SC(P017)-1 REV. NO. 0ORIGINATOR KL DATE 5/22/97 CHECKED MSZ DATE 5-24-97PROJECT Private Fuel Storage Facility JOB NO. 1083-000SUBJECT Storage Pad Analysis and Design SHEET NO. 30

THE SOIL PARAMETERS GIVEN IN THE ABOVE TABLE ARE DISTRIBUTED
OVER TRIBUTARY AREA OF EACH NODE ON THE PAD AS SHOWN BELOW:

 ΔA_i = TRIBUTARY AREA AT NODE i A = TOTAL AREA OF THE PAD

$$L = 64' = 64 \times 30 = 1920 \text{ FT}^2$$

(DRY CASK STORAGE FOOTPRINTS ARE
NOT SHOWN ON THE SKETCH)

$$B = 30'$$

LUMPED PARAMETERS FOR SOIL SPRING STIFFNESS, DAMPOT CONSTANT,

AND MASS TO BE ATTACHED TO NODE " i " ON THE PAD ARE

CALCULATED AS

$$M_i = M \times \Delta A_i / A$$

$$K_i = K \times \Delta A_i / A$$

$$C_i = C \times \Delta A_i / A$$



CALCULATION SHEET

CALC. NO. SC(POIN)-1 REV. NO. 0

ORIGINATOR KL DATE 5/22/97 CHECKED ms DATE 5-26-97

PROJECT Private Fuel Storage Facility JOB NO. 1083-000

SUBJECT Storage Pad Analysis and Design SHEET NO. 31

IN THE ABOVE MODELING OF THE VERTICAL SOIL PARAMETERS, THE
VERTICAL RESPONSE OF THE PAD IS ASSUMED TO BE MAINLY
CONTRIBUTED BY VERTICAL VIBRATION MODE AND THAT DUE TO
ROCKING VIBRATION MODE IS ASSUMED TO BE RELATIVELY SMALL.
THUS, THE VERTICAL SOIL PARAMETERS DUE TO VERTICAL VIBRATION
MODE WERE USED IN THE SOIL FOUNDATION MODEL.




CALCULATION SHEET

CALC. NO. SC(2017)-1 REV. NO. 0ORIGINATOR msg DATE 5-10-97 CHECKED rw DATE 6/10/97PROJECT PFST JOB NO. 1083-000SUBJECT Storage Pad Analysis SHEET NO. 32

Proportional Damping for Pad

Stiffness proportional damping $\beta[K]$ was used.



$$[C]_{\text{pad}} = \beta [K]_{\text{pad}}$$

For 7% @ 25 Hz $\rightarrow \beta = \frac{\alpha T}{\pi} = \frac{\alpha}{f \pi} = \frac{0.07}{25 \cdot \pi} = 0.00089127$

$$\lambda_n = \beta \pi f_n, \text{ damping ratio is proportional to freq. } f_n$$

Note: $\beta[K]$ and the soil dampers constitute the damping matrix of the structure(pad)-soil system.



CALCULATION SHEET

ORIGINATOR MSB DATE 6-10-97 CALC. NO. SC(PD19)-1 REV. NO. 0
PROJECT Private Fuel Storage Facility CHECKED W DATE 6/10/97
SUBJECT Storage Pad Analysis and Design JOB NO. 1083-000
SHEET NO. 33

5.1.2 Static Analyses

There are two types of static analysis carried out by CEC SAP

- Dead Load Analysis

The loading is the weight of the pad only

- Live Load Analysis

There are four load cases

1. 2 Casks Nos 1 and 2
2. 4 Casks Nos. 1, 2, 3 and 4
3. 8 Casks all 8 casks
4. 8 Casks plus transporters

The weight of a cask is 356.5 Kips. It is evenly distributed at four loading points of the four quadrants of the cask.

Nodes at which a downward load of 89.125 kip is applied:

Cask NO.	1	2	3	4	5	6	7	8
	225	231	160	166	82	88	17	23
Loaded	249	255	184	190	106	112	41	47
Nodes	253	259	188	194	110	116	45	51
NOS.	277	283	212	218	134	140	69	75



CALCULATION SHEET

ORIGINATOR

m42

DATE

6-13-97

CALC. NO. 51(2017)-1

REV. NO.

2

PROJECT

PFSP

CHECKED

m

DATE

6/13/97

SUBJECT

Pad Analysis and Design

JOB NO.

1083000

SHEET NO.

34

Application of Live loads

For Cases 1, 2 and 3, The weight of each cask was applied evenly @ four loading points of the four quadrants

Case 1 Casks 1 and 2

Case 2 Casks 1, 2, 3, and 4


Case 3 Casks 1, 2, 3, 4, 5, 6, 7, and 8

Case 4* Casks 2, 3, 4, 5, 6, 7, 8 and

transporter carrying cask 1

*Note:

Only half of the transporter weight was used. a dynamic impact factor of 2 was used; i.e. $(0.5 \times 135 + 365.5) 2 = 866 \text{ Kips}$. This 866 kips are applied evenly to Nodes 222 to 227 and Nodes 274 to 279 as shown in the drawing on the left.



□ — Nodes at which the transporter load was applied.



CALCULATION SHEET

ORIGINATOR MSD DATE 6-10-97 CALC. NO. SC/p019)-1 REV. NO. 0
PROJECT Private Fuel Storage Facility CHECKED W DATE 6/10/97
SUBJECT Storage Pad Analysis and Design JOB NO. 1083-000
SHEET NO. 35

Mathematical Model for Static Analysis

The mathematical model used for static analysis is the same as the one used for dynamic analysis with the following changes

1. The vertical soil spring stiffness is 20 kip/ft^3 (Ref. 8).

2. No damper elements were used in static analysis.



CALCULATION SHEET

CALC. NO. SC(P017)-1 REV. NO. 0ORIGINATOR msz DATE 6-10-97 CHECKED W DATE 6/10/97PROJECT PFSF JOB NO. 1083-002SUBJECT Storage Pad Analysis SHEET NO. 36

5.1.3 Dynamic Analysis

Dynamic Loading

The dynamic loading on the pad is defined by force time histories. For each cask, there are six force time histories: 4 vertical force time histories defining the ^{vertical(z)} loading at four quadrants of the cask and two force time histories defining horizontal loadings in the x and y directions.

There are three dynamic load cases:

Case 1 - 2 casks : Casks 1 and 2

Case 2 - 4 casks : Casks 1, 2, 3, and 4

Case 3 - 8 casks : Casks 1, 2, 3, 4, 5, 6, 7, and 8

Therefore, for Case 1, loading is defined by 12 force time histories. Similarly, 24 and 48 time histories were used to define loadings for Case 2 and 3, respectively.



CALCULATION SHEET

CALC. NO. SC(2017)-1 REV. NO. 0ORIGINATOR msg DATE 6-10-97 CHECKED W DATE 6/10/97PROJECT PFSS JOB NO. 1083-00SUBJECT Storage Pad Analysis SHEET NO. 37

Force Time History Assignment


The force time history data provided by Holtec consist of two sets corresponding to two friction values, 0.2 and 0.8, between pad and casks. The time history plots for both set are included in Attachment A-1. By examining the plots, it was determined that the set associated with the friction value of 0.8 was the governing load. Note that the static gravity load was not included in the dynamic loads. In the following, the loading time histories are assigned to proper loading nodes. Note that the horizontal loads for a cask were distributed evenly to the four loading nodes for the four quadrants. This is achieved by assigning each horizontal component to four loading points of the four quadrants of the associated cask and then using a scale factor of 0.25 to return the total effect back to one.



CALCULATION SHEET


ORIGINATOR msz DATE 5-28-97 CALC. NO. SC(2017)-1 REV. NO. 0
 PROJECT PFST CHECKED re DATE 6/10/97
 SUBJECT Storage Pad Analysis JOB NO. 1083-000 SHEET NO. 38

2-Casks nodal force loads time histories



Node # Comp # TH # arrival # Scale f.

5	277	1	5	0	-0.25	TH NO.
6	277	2	6	0	-0.25	
7	277	3	1	0	-1	
8	249	1	5	0	-0.25	
9	249	2	6	0	-0.25	
0	249	3	2	0	-1	
1	225	1	5	0	-0.25	
2	225	2	6	0	-0.25	
3	225	3	3	0	-1	
4	253	1	5	0	-0.25	
5	253	2	6	0	-0.25	
	253	3	4	0	-1	
7	283	1	11	0	-0.25	
8	283	2	12	0	-0.25	
9	283	3	7	0	-1	
0	255	1	11	0	-0.25	
1	255	2	12	0	-0.25	
2	255	3	8	0	-1	
3	231	1	11	0	-0.25	
4	231	2	12	0	-0.25	
5	231	3	9	0	-1	
6	259	1	11	0	-0.25	
7	259	2	12	0	-0.25	
8	259	3	10	0	-1	



Node NO.

Factor of 0.25 ^{was used} to distribute horizontal loads evenly to four loading points. Negative signs imply the loads are acting downward on the pad.



ORIGINATOR msd DATE 5-28-97 CHECKED lu DATE 6/10/97



PROJECT PFSF JOB NO. 1083

SUBJECT Storage Pad Analysis SHEET NO. 39

DATE 5-28-97

DATE 6/10/97
JOB NO. 1083-
SHEET NO. 39

4- Cask model force load time history number assignment



Node Numbers of
Loaded Nodes
for Core 2, 4-Cast Case



CALCULATION SHEET

ORIGINATOR msd DATE 5-28-97 CALC. NO. SC/D017-1 REV. NO. 0
PROJECT PFST CHECKED W DATE 6/10/97
SUBJECT Storage Pad Analysis JOB NO. 1085-000
SHEET NO. 40

4-Cask Nodal Load time history assignment (cont'd)

For Casks 1 & 2, use previous data.

For Casks 3 & 4, use the following assignment.









Node #	Comp #	TH. #	arrival #	Scale f.
160	1	17	0	-0.25
160	2	18	0	-0.25
160	3	15	0	-1
166	1	23	0	-0.25
166	2	24	0	-0.25
166	3	21	0	-1
184	1	17	0	-0.25
184	2	18	0	-0.25
184	3	14	0	-1
188	1	17	0	-0.25
188	2	18	0	-0.25
188	3	16	0	-1
190	1	23	0	-0.25
190	2	24	0	-0.25
190	3	20	0	-1
194	1	23	0	-0.25
194	2	24	0	-0.25
194	3	22	0	-1
212	1	17	0	-0.25
212	2	18	0	-0.25
212	3	13	0	-1
218	1	23	0	-0.25
218	2	24	0	-0.25
218	3	19	0	-1



CALCULATION SHEET

ORIGINATOR msr DATE 5-28-97 CALC. NO. SC(2017)-1 REV. NO. 0
PROJECT PFST CHECKED K DATE 6/10/97
SUBJECT Storage Pool Analysis JOB NO. 1087-000
SHEET NO. 41

8-cask Nodal Force Time History number assignment



Loaded Node Numbers.

T.H. Numbers



CALCULATION SHEET

CALC. NO. SC(2017)-1 REV. NO. 2ORIGINATOR MD DATE 4-28-97 CHECKED W DATE 6/10/97PROJECT PFST JOB NO. 1083-000SUBJECT Storage Pad Analysis SHEET NO. 42

8-Case Nodal Load Time History Assignment (cont'd)

Assignment for Cases 1 to 4 is not repeated here. The assignment used for 4-Case case applies. Only Cases 5 to 8 are assigned here.

Node #	Comp #	TH #	Arrival #	Scale factor	Node #	Comp #	TH #	Arrival #	Scale factor
17	1	41	0	-0.25	82	1	29	0	-0.25
17	2	42	0	-0.25	82	2	30	0	-0.25
17	3	39	0	-1	82	3	27	0	-1
23	1	47	0	-0.25	88	1	35	0	-0.25
23	2	48	0	-0.25	88	2	36	0	-0.25
23	3	45	0	-1	88	3	33	0	-1
41	1	41	0	-0.25	106	1	29	0	-0.25
41	2	42	0	-0.25	106	2	30	0	-0.25
41	3	38	0	-1	106	3	26	0	-1
45	1	41	0	-0.25	110	1	29	0	-0.25
45	2	42	0	-0.25	110	2	30	0	-0.25
45	3	40	0	-1	110	3	28	0	-1
47	1	47	0	-0.25	112	1	35	0	-0.25
47	2	48	0	-0.25	112	2	36	0	-0.25
47	3	44	0	-1	112	3	32	0	-1
51	1	47	0	-0.25	116	1	35	0	-0.25
51	2	48	0	-0.25	116	2	36	0	-0.25
51	3	46	0	-1	116	3	34	0	-1
69	1	41	0	-0.25	134	1	29	0	-0.25
69	2	42	0	-0.25	134	2	30	0	-0.25
69	3	37	0	-1	134	3	25	0	-1
75	1	47	0	-0.25	140	1	35	0	-0.25
75	2	48	0	-0.25	140	2	36	0	-0.25
75	3	43	0	-1	140	3	31	0	-1



CALCULATION SHEET


ORIGINATOR msb DATE 6-10-97 CALC. NO. SC (p017)-1 REV. NO. 0
PROJECT Private Fuel Storage Facility CHECKED W DATE 6/10/97
SUBJECT Storage Pad Analysis and Design JOB NO. 1083-000
SHEET NO. 43

5.1.4 Dynamic Analyses Output Selection

The following response quantities were selected for output for all three cases of dynamic analyses

Displacements : Three components (U_x, U_y, U_z) of displacements for all nodes in the two long side edges of pad, the long center line, the short center line, the top short edge and one section in the short direction (x) between the top edge and ^{short} center line as indicated by the solid lines in

The left figure.






CALCULATION SHEET

ORIGINATOR msj DATE 6-10-97 CALC. NO. SC(2017)-1 REV. NO. 0
PROJECT Private Fuel Storage Facility CHECKED W DATE 6/10/97
SUBJECT Storage Pad Analysis and Design JOB NO. 1083-000
SHEET NO. 44

Dynamic output Selection (cont'd)

Pad stresses output Selection

Plate bending moments (M_{xx} , M_{yy}) and shell membrane forces (S_{xx} , S_{yy}) were selected for output. Plate elements numbered 193 to 264 were selected. These elements represent the pad from the edge of Cask Nos. 3 and 4 to the upper edge of the pad as shown in the following sketch:





CALCULATION SHEET

ORIGINATOR MJD DATE 6-10-97 CALC. NO. SC(2017)-1 REV. NO. 0
PROJECT Private Fuel Storage Facility CHECKED W DATE 6/10/97
SUBJECT Storage Pad Analysis and Design JOB NO. 1083-000
SHEET NO. 45

Dynamic output selection (cont'd)

Soil Spring force output Selection

Forces in vertical soil springs attached to
Nodes numbered from 183 to 299 were
selected for output. The vertical springs
selected are located from the center line
of coaks 3 and 4 to the upper edge
of the pad.

All selected response quantities were output in terms
of maximum values printed in the output file and
in terms of time history data files, which were
used for plating and postprocessing for the
retrieval of concurrent values and shear force
calculations.



CALCULATION SHEET

CALC. NO. SC(P017)-1 REV. NO. 0

ORIGINATOR M4B DATE 6-10-97 CHECKED W DATE 6/10/97

PROJECT Private Fuel Storage Facility JOB NO. 1083-000

SUBJECT Storage Pad Analysis and Design SHEET NO. 46

Dynamic Output Selection (Cont'd)

Shear Force Output

Since the plate element used in CECSAP does not output shear force values. The shear forces in the pad were calculated by moment gradient



CALCULATION SHEET

ORIGINATOR msz DATE 6-13-97 CALC. NO. sc(1017)-1 REV. NO. 0
PROJECT Private Fuel Storage Facility CHECKED vr DATE 6/13/97
SUBJECT Storage Pad Analysis and Design JOB NO. 1083-000
SHEET NO. 47

5.1.5 Inputs and Outputs of Static and Dynamic Analyses

Complete input file listings are provided in Attachment A-2. To avoid lengthy listing, only partial output listings, The first and last four pages of all outputs are provided in Attachment A-3. The complete outputs are provided on computer diskettes.

The filenames used for the input and output files are as follows:

	Input filename	Output filename
Dead Load Analysis	D.INP	D.OUT
Live Load Analysis	LL.INP	LL.OUT
Dynamic Analysis (2 cases)	2.INP	2.OUT
Dynamic Analysis (4 cases)	4.INP	4.OUT
Dynamic Analysis (8 cases)	8.INP	8.OUT



CALCULATION SHEET

ORIGINATOR msj DATE 6-13-97 CALC. NO. SC/PO17)-1 REV. NO. 0
PROJECT PFST CHECKED W DATE 6/13/97
SUBJECT Pad Analysis and Design JOB NO. 1083000
SHEET NO. 48

5.1.6. Static and Dynamic Analysis Results

Static Analysis Results

Maximum static analysis results in Bending are tabulated in the following. The values were taken from Attachment A-4, which contains partial listing of results of Nodal displacements and element forces and bending moments.

Max. Bending Moments (KIP-ft/ft)

		M_{yy}
Dead load		0
Live load:		
Load case 1	2 Casks	-21.8
2.	4 Casks	-57.1
3.	8 Casks	-37.4
4.	8 Cask Transporter	-45.6

M_{yy} values are used. However, ^{max.} The value of M_{yy} for 2 cask case is +52.3, which is generated by artificial soil tension under unloaded portion of Pad



CALCULATION SHEET

ORIGINATOR MSD DATE 6-13-97 CALC. NO. SC(2017)-1 REV. NO. 0
PROJECT Private Fuel Storage Facility CHECKED W DATE 6/13/97
SUBJECT Storage Pad Analysis and Design JOB NO. 1083-000
SHEET NO. 49

Therefore, the maximum negative value of 21.8 is picked instead. The maxima of M_{xx} (bending about y-axis) and M_{yy} (bending about x-axis) are listed in the following table, where the picked values are circled.

CECSAP OUTPUT FILE NAME=LL.OUT
**** MAXIMUM **** BENDING VALUES

LOAD CASE NO.=	1		
ELEM.NO.	MXMAX	ELEM.NO.	MYMAX
150	3.73	133	52.31
LOAD CASE NO.=	2		
ELEM.NO.	MXMAX	ELEM.NO.	MYMAX
258	4.75	73	22.34
LOAD CASE NO.=	3		
ELEM.NO.	MXMAX	ELEM.NO.	MYMAX
6	3.59	0	0.00
LOAD CASE NO.=	4		
ELEM.NO.	MXMAX	ELEM.NO.	MYMAX
260	27.22	133	29.68

**** MINIMUM **** BENDING VALUES

LOAD CASE NO.=	1		
ELEM.NO.	MXMIN	ELEM.NO.	MYMIN
234	-8.71	229	-21.84
LOAD CASE NO.=	2		
ELEM.NO.	MXMIN	ELEM.NO.	MYMIN
196	-12.85	169	-57.12
LOAD CASE NO.=	3		
ELEM.NO.	MXMIN	ELEM.NO.	MYMIN
124	-11.36	97	-37.36
LOAD CASE NO.=	4		
ELEM.NO.	MXMIN	ELEM.NO.	MYMIN
70	-14.73	205	-45.61



CALCULATION SHEET

ORIGINATOR msg DATE 6-13-97 CALC. NO. SC/PO17)-1 REV. NO. 0
PROJECT PFST CHECKED W DATE 6/13/97
SUBJECT Pad Analysis and Design JOB NO. 1085-000
SHEET NO. 50


Max. Static shear force

Dead Load case

The bending moment due to dead load is essentially zero, so, the shear force is also immaterial in dead load case.

Live Load Case

The shear force is calculated using the method of taking moment gradient between two neighboring elements.



"l" is the distance between the centroids, where, the bending moments are calculated.

Shear force V is

$$V = (M_2 - M_1) / l$$



CALCULATION SHEET

CALC. NO. SC(2017)- / REV. NO. 3ORIGINATOR msy DATE 6-13-97 CHECKED W DATE 6/13/97PROJECT PFSF JOB NO. 1023-000SUBJECT Pad Analysis and Design SHEET NO. 51

Max. static shear forces (cont'd)

The shear forces of the four live load cases were obtained by calculating the moment gradients of M_{xx} and M_{yy} . The calculated maximum ^{shear force} values are listed in the following table

CECSAP OUTPUT FILE NAME=LL.OUT
MAXIMUM LIVE LOAD SHEAR..FOR MXX

2 Casks →

LOAD CASE NO.= 1
ELEM1 ELEM2 MAX.SHEAR
255 254 -2.518

4 Casks →

LOAD CASE NO.= 2
ELEM1 ELEM2 MAX.SHEAR
195 196 -3.773

8 Casks →

LOAD CASE NO.= 3
ELEM1 ELEM2 MAX.SHEAR
125 124 3.8558 Casks
+ transporter →LOAD CASE NO.= 4
ELEM1 ELEM2 MAX.SHEAR
129 128 -4.691

MAXIMUM LIVE LOAD SHEAR..FOR MY

2 Casks →

LOAD CASE NO.= 1
ELEM1 ELEM2 MAX.SHEAR
217 205 -6.867

4 Casks →

LOAD CASE NO.= 2
ELEM1 ELEM2 MAX.SHEAR
135 123 -8.358

8 Casks →

LOAD CASE NO.= 3
ELEM1 ELEM2 MAX.SHEAR
25 13 -5.7468 Casks and
Transporter →LOAD CASE NO.= 4
ELEM1 ELEM2 MAX.SHEAR
217 205 11.286

The
circled ones
are the
selected
maximum
values.

The unit of the shear force is kip/ft.



CALCULATION SHEET

ORIGINATOR me DATE 6-13-97 CALC. NO. SC(2019)-1 REV. NO. 0
PROJECT PFSF CHECKED W DATE 6/13/97
SUBJECT Pad Analysis & Design JOB NO. 1083-0000
SHEET NO. 52

5.1.6 Static and Dynamic Analysis Results (Cont'd)

Dynamic Analysis Results

The maximum values of selected dynamic response quantities are listed in Attachment A-5. The time history plots for all selected output quantities are attached in Attachment A-6

In the following sections, dynamic shear force calculation is presented. Maximum bending moments and total soil reaction forces are also presented below.



CALCULATION SHEET

ORIGINATOR

mcb

DATE

6-10-97

CALC. NO. SC(P017)-1

REV. NO. 0

PROJECT

Private Fuel Storage Facility

CHECKED

kr

DATE

6/13/97

SUBJECT

Storage Pad Analysis and Design

JOB NO.


1083-000

SHEET NO.

53

Shear Force Calculation

The shear force is calculated using moment gradient. For example, if M_{yy1} and M_{yy2} are



The bending moments per unit length about the X -axis for two neighboring elements 1 and 2. In CEC-SAP, The plate bending moments are defined at the centroid of the plate element, Thus the shear force between the two elements is calculated by calculating the moment gradient as follows:

$$V = \frac{M_{yy2} - M_{yy1}}{l}$$

where

V : shear force per unit length in X direction (points out from the paper)
 l : distance between two centroids of the two neighboring elements

M_{yy1}, M_{yy2} : Moments per unit length about the X -axis.




CALCULATION SHEET

ORIGINATOR MZ DATE 6-10-97 CALC. NO. SC(2017)-1 REV. NO. 0
PROJECT Private Fuel Storage Facility CHECKED KV DATE 6/13/97
SUBJECT Storage Pad Analysis and Design JOB NO. 1083-000
SHEET NO. 54

Shear Force Calculation For sections in X-direction

By Using moment gradients, the shear forces in 5-
selected sections in the X-direction were calculated
for the three dynamic cases. The 5-
selection sections are indicated in the following
sketch and designated by the beginning node numbers





CALCULATION SHEET

ORIGINATOR MSZ DATE 6-11-97 CALC. NO. SC(P019)-1 REV. NO. 0
PROJECT Private Fuel Storage Facility CHECKED W DATE 6/13/97
SUBJECT Storage Pad Analysis and Design JOB NO. 1083-000
SHEET NO. 55

Total Shear Force in Sections In X-Direction

The total shear forces in the pad were calculated at the five sections in X-direction. The node numbers along the four sections are


Section 1	222 → 234	13 nodes, 12 elements
Section 2	235 → 247	13 nodes, 12 elements
Section 3	248 → 260	13 nodes, 12 elements
Section 4	261 → 273	13 nodes, 12 elements
Section 5	274 → 286	13 nodes, 12 elements

Total shear forces at these five sections were calculated for the three dynamic cases and are listed in the following:

	Case 1 2 Casks	Case 2 4 Casks	Case 3 8 Casks
Section 1	1566 Kips	378 Kips	357 Kips
2	1444	455	438
3	456	295	258
4	1656	482	416
5	1089	355	260

As shown in the above table, the 2-cask case generated the greatest shear force. The time history of the shear forces at the five sections for Case 1 is shown in the following page. The shear forces for each of the 12 elements of the five sections for all three dynamic cases are also included after the plot.

TOTAL SHEAR FORCE (ENTIRE X-SECTION)



CEC JOB NO.	1083-000
BY	DATE 6-11-97
CHECK	DATE 6/13/97
CALC. NO.	SC(P017)-1
REV. NO.	0
SHEET NO.	56

MAXIMUM DYNAMIC SHEAR FORCE (KIPS/FT) IN TRANSVERSE SECTIONS (2-CASK CASE)
GRADIENT OF MY (BENDING ABOUT X-AXIS OR TRANSVERSE AXIS)

SECTION 1 (293-SECTION)

1ST EL.	193-YY	194-YY	195-YY	196-YY	197-YY	198-YY	199-YY	200-YY	201-YY	202-YY	203-YY	204-YY
2ND EL.	205-YY	206-YY	207-YY	208-YY	209-YY	210-YY	211-YY	212-YY	213-YY	214-YY	215-YY	216-YY
MAXIMUM	12.11	9.85	12.65	14.69	13.15	10.36	7.82	6.91	8.37	9.28	10.93	12.54
@TIME	4.885	4.885	4.890	4.890	4.890	4.890	4.890	4.890	4.895	4.895	4.890	4.890
MINIMUM	-93.81	-84.05	-72.00	-60.86	-53.27	-51.19	-50.76	-49.46	-44.77	-33.79	-21.72	-23.99
@TIME	4.875	4.875	4.875	4.875	4.875	4.875	4.875	4.875	4.875	4.875	4.880	5.315

SECTION 2 (205-SECTION)

1ST EL.	205-YY	206-YY	207-YY	208-YY	209-YY	210-YY	211-YY	212-YY	213-YY	214-YY	215-YY	216-YY
2ND EL.	217-YY	218-YY	219-YY	220-YY	221-YY	222-YY	223-YY	224-YY	225-YY	226-YY	227-YY	228-YY
MAXIMUM	15.50	19.22	26.90	26.67	18.70	15.28	15.46	18.98	26.69	26.48	18.26	19.40
@TIME	6.405	6.405	6.405	6.405	6.405	6.405	6.405	6.405	6.405	6.405	6.405	4.890
MINIMUM	-154.26	-110.94	-52.79	-27.61	-37.25	-59.71	-91.67	-72.32	-24.38	-20.80	-34.43	-45.15
@TIME	4.870	4.875	4.875	4.875	4.875	4.875	4.870	4.870	4.875	4.880	5.315	5.315

← Maximum shear
between elements
205 and 217

SECTION 3 (217 SECTION)

1ST EL.	217-YY	218-YY	219-YY	220-YY	221-YY	222-YY	223-YY	224-YY	225-YY	226-YY	227-YY	228-YY
2ND EL.	229-YY	230-YY	231-YY	232-YY	233-YY	234-YY	235-YY	236-YY	237-YY	238-YY	239-YY	240-YY
MAXIMUM	21.13	20.70	20.15	19.13	17.45	15.75	14.25	12.66	11.25	10.69	10.45	10.50
@TIME	4.885	4.885	4.885	4.885	4.885	4.885	4.885	4.885	4.885	6.405	4.890	4.890
MINIMUM	-15.17	-14.17	-13.09	-11.68	-10.45	-9.91	-9.88	-10.31	-10.97	-10.83	-10.07	-9.38
@TIME	4.895	4.895	4.895	4.895	6.570	7.975	7.975	7.975	6.570	6.570	7.975	7.975

SECTION 4 (229-SECTION)

1ST EL.	229-YY	230-YY	231-YY	232-YY	233-YY	234-YY	235-YY	236-YY	237-YY	238-YY	239-YY	240-YY
2ND EL.	241-YY	242-YY	243-YY	244-YY	245-YY	246-YY	247-YY	248-YY	249-YY	250-YY	251-YY	252-YY
MAXIMUM	149.46	111.12	59.53	41.41	40.58	61.45	91.32	77.54	40.69	25.69	31.13	41.88
@TIME	4.875	4.875	4.875	4.880	4.875	4.875	4.870	4.870	4.875	4.880	7.905	5.315
MINIMUM	-16.24	-17.87	-26.53	-26.62	-17.88	-15.70	-15.67	-17.55	-26.37	-26.48	-17.77	-15.36
@TIME	7.945	7.945	6.565	6.565	6.565	7.945	7.975	6.565	6.565	6.565	6.565	7.975

SECTION 5 (241-SECTION)

1ST EL.	241-YY	242-YY	243-YY	244-YY	245-YY	246-YY	247-YY	248-YY	249-YY	250-YY	251-YY	252-YY
2ND EL.	253-YY	254-YY	255-YY	256-YY	257-YY	258-YY	259-YY	260-YY	261-YY	262-YY	263-YY	264-YY
MAXIMUM	64.04	56.67	47.06	42.28	39.79	37.15	36.49	35.31	31.42	27.36	24.64	22.02
@TIME	4.875	4.875	4.875	4.880	4.880	4.880	4.875	4.875	4.875	4.880	4.880	4.880
MINIMUM	-9.41	-8.04	-6.25	-6.32	-6.87	-7.20	-7.13	-6.62	-5.65	-6.57	-7.32	-9.07
@TIME	7.940	7.945	11.960	4.890	7.955	7.955	7.955	7.955	11.960	4.890	4.470	4.895

CEC JOB NO.	1083-000
BY	msb
DATE	6-17-97
CHECK	W
DATE	6/17/97
CALC. NO.	SC(P017)-1
REV. NO.	0
SHEET NO.	57

MAXIMUM DYNAMIC SHEAR FORCE (KIPS/FT) IN TRANSVERSE SECTIONS (4-CASK CASE)
GRADIENT OF MY (BENDING ABOUT X-AXIS OR TRANSVERSE AXIS)

SECTION 1

1STDATA	193-YY	194-YY	195-YY	196-YY	197-YY	198-YY	199-YY	200-YY	201-YY	202-YY	203-YY	204-YY
2NDDATA	205-YY	206-YY	207-YY	208-YY	209-YY	210-YY	211-YY	212-YY	213-YY	214-YY	215-YY	216-YY
MAXIMUM	19.33	16.85	21.11	19.64	12.58	15.49	16.45	15.70	18.20	18.64	15.78	14.16
QTIME	3.010	9.865	9.865	9.865	6.580	6.580	6.580	6.580	8.450	8.450	8.450	8.450
MINIMUM	-20.45	-16.47	-12.93	-13.09	-14.25	-13.48	-12.66	-12.43	-15.36	-19.52	-23.20	-25.88
QTIME	11.505	11.505	9.430	2.990	2.990	2.990	11.475	11.095	11.095	7.015	7.015	7.015

SECTION 2

1STDATA	205-YY	206-YY	207-YY	208-YY	209-YY	210-YY	211-YY	212-YY	213-YY	214-YY	215-YY	216-YY
2NDDATA	217-YY	218-YY	219-YY	220-YY	221-YY	222-YY	223-YY	224-YY	225-YY	226-YY	227-YY	228-YY
MAXIMUM	16.09	16.08	20.21	18.65	16.08	16.57	17.57	18.63	21.37	21.43	19.64	18.44
QTIME	11.965	11.495	11.495	11.495	8.445	6.580	6.580	8.450	8.450	8.450	8.450	8.450
MINIMUM	-42.33	-34.25	-23.36	-17.84	-28.99	-32.29	-32.06	-28.24	-17.56	-19.81	-30.80	-41.92
QTIME	11.505	11.505	11.505	2.990	2.990	2.990	11.475	11.475	11.475	11.095	11.095	7.015

SECTION 3

1STDATA	217-YY	218-YY	219-YY	220-YY	221-YY	222-YY	223-YY	224-YY	225-YY	226-YY	227-YY	228-YY
2NDDATA	229-YY	230-YY	231-YY	232-YY	233-YY	234-YY	235-YY	236-YY	237-YY	238-YY	239-YY	240-YY
MAXIMUM	13.61	11.89	11.35	10.80	9.80	10.20	11.23	12.01	13.72	15.73	16.98	17.97
QTIME	3.015	3.015	8.445	8.445	8.445	8.450	8.450	8.450	3.000	3.000	3.000	3.000
MINIMUM	-12.25	-11.47	-11.30	-10.83	-10.13	-9.57	-9.41	-9.51	-10.69	-11.21	-11.19	-11.09
QTIME	3.005	4.495	4.495	4.495	4.495	4.495	4.495	4.495	4.510	4.510	4.510	4.510

SECTION 4

1STDATA	229-YY	230-YY	231-YY	232-YY	233-YY	234-YY	235-YY	236-YY	237-YY	238-YY	239-YY	240-YY
2NDDATA	241-YY	242-YY	243-YY	244-YY	245-YY	246-YY	247-YY	248-YY	249-YY	250-YY	251-YY	252-YY
MAXIMUM	37.92	28.03	15.99	14.99	26.65	30.56	29.38	22.10	14.12	21.98	34.88	45.74
QTIME	11.505	11.505	4.895	2.990	2.990	2.990	11.475	11.475	7.915	11.095	7.015	7.015
MINIMUM	-17.72	-16.52	-18.79	-18.36	-15.30	-14.18	-14.05	-15.47	-20.18	-21.84	-16.39	-15.51
QTIME	3.005	4.495	4.495	4.495	4.495	4.495	4.495	4.500	6.745	6.745	4.500	4.500

SECTION 5

1STDATA	241-YY	242-YY	243-YY	244-YY	245-YY	246-YY	247-YY	248-YY	249-YY	250-YY	251-YY	252-YY
2NDDATA	253-YY	254-YY	255-YY	256-YY	257-YY	258-YY	259-YY	260-YY	261-YY	262-YY	263-YY	264-YY
MAXIMUM	15.36	13.05	11.77	14.20	15.12	14.57	13.12	12.47	13.55	15.05	16.63	17.28
QTIME	11.505	11.505	2.990	2.990	2.990	2.990	2.990	11.095	11.095	11.095	11.095	11.095
MINIMUM	-9.86	-8.53	-6.85	-6.22	-7.28	-8.45	-8.79	-8.23	-7.10	-8.50	-9.20	-10.27
QTIME	4.500	4.500	4.500	4.500	6.580	6.580	6.580	6.580	11.085	11.085	11.085	4.500

CEC JOB NO.	1083-000
BY <i>ms</i>	DATE 6-17-97
CHECK <i>W</i>	DATE 6/17/97
CALC. NO. SC(P017)-1	REV. NO. 0
SHEET NO.	5Y

MAXIMUM DYNAMIC SHEAR FORCE (KIPS/FT) IN TRANSVERSE SECTIONS (8-CASK CASE)
GRADIENT OF MYY (BENDING ABOUT X-AXIS OR TRANSVERSE AXIS)

SECTION 1

1STDATA	193-YY	194-YY	195-YY	196-YY	197-YY	198-YY	199-YY	200-YY	201-YY	202-YY	203-YY	204-YY
2NDDATA	205-YY	206-YY	207-YY	208-YY	209-YY	210-YY	211-YY	212-YY	213-YY	214-YY	215-YY	216-YY
MAXIMUM	22.76	20.96	18.50	14.44	15.66	17.74	17.59	21.37	25.61	24.43	18.90	15.29
QTIME	9.415	9.415	9.415	9.415	13.340	13.340	13.340	13.335	13.335	13.335	13.335	13.335
MINIMUM	-26.71	-21.28	-13.43	-11.17	-10.88	-11.51	-10.99	-10.06	-13.13	-18.11	-20.73	-22.85
QTIME	9.405	9.405	9.405	13.350	2.980	2.980	2.980	9.395	16.325	16.325	16.325	16.325

SECTION 2

1STDATA	205-YY	206-YY	207-YY	208-YY	209-YY	210-YY	211-YY	212-YY	213-YY	214-YY	215-YY	216-YY
2NDDATA	217-YY	218-YY	219-YY	220-YY	221-YY	222-YY	223-YY	224-YY	225-YY	226-YY	227-YY	228-YY
MAXIMUM	18.82	17.21	17.89	20.91	20.46	18.45	14.35	13.54	19.92	21.98	16.32	19.04
QTIME	9.410	8.485	13.340	13.340	13.340	13.340	13.340	16.120	16.120	15.055	16.120	16.330
MINIMUM	-47.11	-37.23	-23.95	-22.00	-31.11	-30.90	-24.40	-21.97	-15.82	-27.45	-43.55	-55.03
QTIME	9.405	9.405	9.405	7.900	7.900	7.900	2.980	14.785	7.925	7.925	7.925	7.925

SECTION 3

1STDATA	217-YY	218-YY	219-YY	220-YY	221-YY	222-YY	223-YY	224-YY	225-YY	226-YY	227-YY	228-YY
2NDDATA	229-YY	230-YY	231-YY	232-YY	233-YY	234-YY	235-YY	236-YY	237-YY	238-YY	239-YY	240-YY
MAXIMUM	9.11	9.05	10.05	11.08	10.70	11.21	11.31	10.92	9.87	10.37	10.03	9.43
QTIME	14.185	8.490	13.345	13.345	13.345	13.340	13.340	13.340	13.340	16.120	16.120	16.120
MINIMUM	-9.46	-8.51	-8.84	-8.50	-7.95	-8.28	-8.83	-14.18	-18.84	-19.73	-17.21	-16.00
QTIME	7.940	7.940	7.935	7.935	7.930	7.930	15.905	15.890	15.890	15.890	15.890	15.905

SECTION 4

1STDATA	229-YY	230-YY	231-YY	232-YY	233-YY	234-YY	235-YY	236-YY	237-YY	238-YY	239-YY	240-YY
2NDDATA	241-YY	242-YY	243-YY	244-YY	245-YY	246-YY	247-YY	248-YY	249-YY	250-YY	251-YY	252-YY
MAXIMUM	44.87	33.58	17.52	18.34	29.01	30.44	26.29	25.33	17.14	15.50	26.41	38.26
QTIME	9.400	9.400	9.400	7.900	7.900	7.900	14.785	14.785	14.785	16.325	7.925	7.925
MINIMUM	-19.31	-14.96	-17.25	-17.27	-13.53	-12.00	-12.39	-19.47	-42.38	-45.05	-27.78	-20.36
QTIME	9.410	3.385	8.215	8.215	8.215	8.215	15.905	15.890	15.890	15.890	15.890	15.900

SECTION 5

1STDATA	241-YY	242-YY	243-YY	244-YY	245-YY	246-YY	247-YY	248-YY	249-YY	250-YY	251-YY	252-YY
2NDDATA	253-YY	254-YY	255-YY	256-YY	257-YY	258-YY	259-YY	260-YY	261-YY	262-YY	263-YY	264-YY
MAXIMUM	18.43	15.36	10.93	9.96	11.66	12.15	11.79	10.86	13.89	12.02	9.76	13.35
QTIME	9.405	9.405	9.405	13.350	13.350	13.350	13.350	13.350	15.890	15.890	16.325	16.325
MINIMUM	-11.55	-9.51	-6.74	-7.58	-7.71	-7.68	-8.07	-9.21	-9.63	-9.99	-10.14	-9.03
QTIME	9.415	9.415	15.905	13.340	13.340	13.340	15.900	15.900	15.900	15.900	15.900	15.900

CEC JOB NO.	1083-000
BY	DATE 6-17-97
CHECK	DATE 6/17/97
CALC. NO.	REV. NO. 0
SHEET NO.	59




CALCULATION SHEET

ORIGINATOR msz DATE 6-17-97 CALC. NO. SCD0017)-1 REV. NO. 0
PROJECT PFSF CHECKED W DATE 6/17/97
SUBJECT Peak Analysis JOB NO. 1083-000
SHEET NO. 60

Max. Shear Force under Casks in Transverse Direction

2 Casks 4 Casks 8 Casks @ Section 4 (Transverse)

1.98	149.46	37.92	44.87	} Dynamic Analysis
2.76	111.12	28.03	33.58	
2.76	59.53	18.79	17.52	
2.76	41.41	18.36	18.34	
2.76	40.58	26.65	29.01	
average	76.3	25.23	27.69 K/4	



Section 4 has the greatest averaged shear force under the cask.

The max. averaged shear force under cask is used as an estimate of the punching shear.



CALCULATION SHEET


ORIGINATOR msd DATE 6-11-97 CALC. NO. sc(1017)-1 REV. NO. 0
PROJECT Private Fuel Storage Facility CHECKED m DATE 6/17/97
SUBJECT Storage Pad Analysis and Design JOB NO. 1083-000
SHEET NO. 61

Dynamic Analysis Results (cont'd)

Shear Force for Sections in Y-direction

The method of
(Moment gradient of M_{xx} (bending about the y-axis))

is used to calculate the shear force. The 11
sections indicated in the following drawing are used.



The maxima and minima for the six rows of elements
for each section are listed later in this calculation package.
From the table, it is found that the maximum shear forces
occur at Section 6 between the two casks (shaded above).

The shear forces in Section 6 is plotted on the right in the
figure above for the 2-cask case.



CALCULATION SHEET

ORIGINATOR msr DATE 6/11/97 CHECKED W JOB NO. 1083002 SHEET NO. 62
PROJECT PFS
SUBJECT Storage Pad Analysis

Dynamic Analysis Results (cont'd)

Summary of Maximum Shear Forces in Pad

By using the method of Moment Gradients described above,

The shear forces in 11 selected longitudinal (y) and

5 selected transverse (x) sections were calculated

for each analysis time step. The maximum

shear forces were presented in the following table

Maximum Shear Forces (kip/ft)

Longitudinal Sections	Transverse Sections	2 Casks		4 Casks		8 Casks		2 Cask
		#205	#217	#240	#252	#216	#228	
			154	46		55		154
		#234	#235	#222	#223	#262	#263	
								136

Note: The force numbers to the left of a shear force value are the element numbers of the two plate elements between which the moment gradient was calculated



CALCULATION SHEET

ORIGINATOR m² DATE 6-11-97 CALC. NO. SC(P017)-1 REV. NO. 0
 PROJECT PFST CHECKED W DATE 6/13/97
 SUBJECT Storage Pad Analysis (Dynamic) 2 Casks JOB NO. 1083-000
 SHEET NO. 63

Dynamic Analysis Results (cont'd)

Shear Force Calculation From Gradient of Mxx (2-Cask Case)

	Plate El. No.	File No.	col no.	Mxx @ Time 4.880	Max Shear xL = 2.37'
9	205	207.str	3	-16.34	$(17.99 - (-16.34)) / 2.37$ = 14.49
10	206	207.str	7	+17.99	
11				@ 4.875 sec	
12	217	213.str	3	-148.1	+31.89 K/
13	218	213.str	7	-72.52	
14				@ 4.875 sec	
15	229	19.str	3	-148.6	+32.88 K/
16	230	19.str	7	-70.69	
17				@ 4.880 sec	
18	241	25.str	7	-7.05	+23.61 K/
19	242	25.str	3	+48.91	
20				@ 4.880	xL = 2.96'
21	206	7.str	7	+17.99	$(92.28 - 17.99) / 2.76$ = +26.92 K/
22	207	8.str	3	+92.28	
23				@ 4.880	
24	218	13.str	7	-41.07	+66.66 K/
25	219	14.str	3	+142.9	
26				@ 4.880	
27	230	19.str	7	-30.23	+71.71 K/
28	231	20.str	3	+167.7	
29					
30	242	25.str	7	+48.91	+41.95 K/
31	243	26.str	3	+164.7	

The procedure was programmed to process other elements in time history steps. Results are in the following pages. The above hand calculation is used to verify the program.

MAXIMUM DYNAMIC SHEAR FORCE (KIPS/FT) IN LONGITUDINAL SECTIONS (2-CASK CASE)
GRADIENT OF MXX (BENDING ABOUT Y-AXIS OR LONGITUDINAL AXIS)

SECTION 1

1STDATA 193-XX 205-XX 217-XX 229-XX 241-XX 253-XX
 2NDDATA 194-XX 206-XX 218-XX 230-XX 242-XX 254-XX
 MAXIMUM 13.78 14.49 31.89 32.87 23.61 28.63
 @TIME 4.875 4.875 4.870 4.870 4.875 4.875
 MINIMUM -10.74 -11.93 -6.58 -8.04 -12.08 -14.13
 @TIME 4.885 4.885 6.405 11.955 4.885 4.885

SECTION 2

1STDATA 194-XX 206-XX 218-XX 230-XX 242-XX 254-XX
 2NDDATA 195-XX 207-XX 219-XX 231-XX 243-XX 255-XX
 MAXIMUM 17.49 26.92 66.66 71.71 41.95 25.23
 @TIME 4.880 4.875 4.875 4.875 4.875 4.880
 MINIMUM -17.03 -21.07 -12.57 -12.23 -22.81 -22.55
 @TIME 6.405 6.405 6.405 12.995 12.995 12.995

SECTION 3

1STDATA 195-XX 207-XX 219-XX 231-XX 243-XX 255-XX
 2NDDATA 196-XX 208-XX 220-XX 232-XX 244-XX 256-XX
 MAXIMUM 10.18 18.59 23.59 23.08 17.28 8.15
 @TIME 4.875 4.875 4.875 4.875 4.875 4.875
 MINIMUM -5.31 -7.32 -9.45 -9.50 -7.79 -7.28
 @TIME 6.415 6.415 5.315 5.315 13.005 13.005

SECTION 4

1STDATA 196-XX 208-XX 220-XX 232-XX 244-XX 256-XX
 2NDDATA 197-XX 209-XX 221-XX 233-XX 245-XX 257-XX
 MAXIMUM 21.57 25.29 16.14 17.94 29.95 30.67
 @TIME 4.870 6.405 6.405 12.995 12.995 12.995
 MINIMUM -19.86 -19.01 -18.21 -19.09 -21.08 -22.76
 @TIME 4.880 4.880 7.905 4.875 6.575 4.880

SECTION 5

1STDATA 197-XX 209-XX 221-XX 233-XX 245-XX 257-XX
 2NDDATA 198-XX 210-XX 222-XX 234-XX 246-XX 258-XX
 MAXIMUM 10.93 11.59 10.59 11.94 14.84 20.49
 @TIME 4.885 6.405 6.405 11.955 4.885 4.885
 MINIMUM -24.28 -47.86 -64.87 -69.32 -60.11 -43.12
 @TIME 4.875 4.875 4.875 4.875 4.875 4.875

SECTION 6

1STDATA 198-XX 210-XX 222-XX 234-XX 246-XX 258-XX
 2NDDATA 199-XX 211-XX 223-XX 235-XX 247-XX 259-XX
 MAXIMUM 13.49 23.34 42.91 43.64 25.83 23.22
 @TIME 4.885 5.315 5.315 5.315 5.315 4.885
 MINIMUM -37.82 -72.81 -135.81 -136.30 -79.97 -52.53
 @TIME 4.875 4.875 4.870 4.870 4.875 4.875

SECTION 7

1STDATA 199-XX 211-XX 223-XX 235-XX 247-XX 259-XX
 2NDDATA 200-XX 212-XX 224-XX 236-XX 248-XX 260-XX
 MAXIMUM 13.28 17.60 23.43 24.32 20.30 20.05
 @TIME 4.885 5.315 4.885 4.885 4.885 4.885
 MINIMUM -32.53 -35.65 -24.18 -23.59 -35.57 -39.24
 @TIME 4.875 4.875 4.875 4.875 4.875 4.875

SECTION 8

1STDATA 200-XX 212-XX 224-XX 236-XX 248-XX 260-XX
 2NDDATA 201-XX 213-XX 225-XX 237-XX 249-XX 261-XX

VERIFIED by
hand calculation

CEC JOB NO.	1082-001
BY	DATE 6-17-97
CHECK	DATE 6/17/97
CALC. NO.	REV. NO. 0
SHEET NO.	64

Maximum between ELM. 234 & ELM. 235

MAXIMUM	12.26	14.74	59.60	65.66	19.04	20.12
@TIME	6.415	4.885	4.870	4.870	6.575	13.005
MINIMUM	-20.98	-24.44	-15.34	-18.22	-29.03	-29.50
@TIME	4.870	6.405	6.405	4.880	6.565	6.565

SECTION 9

1STDATA	201-XX	213-XX	225-XX	237-XX	249-XX	261-XX
2NDDATA	202-XX	214-XX	226-XX	238-XX	250-XX	262-XX
MAXIMUM	10.58	22.90	30.65	31.34	24.96	14.42
@TIME	4.875	4.875	4.875	4.875	4.875	4.875
MINIMUM	-2.62	-5.29	-6.95	-6.93	-5.43	-5.72
@TIME	5.315	5.315	5.315	5.315	4.885	4.885

SECTION 10

1STDATA	202-XX	214-XX	226-XX	238-XX	250-XX	262-XX
2NDDATA	203-XX	215-XX	227-XX	239-XX	251-XX	263-XX
MAXIMUM	30.42	40.00	34.59	31.67	31.91	28.55
@TIME	4.875	4.875	4.875	4.875	4.875	4.875
MINIMUM	-8.50	-14.97	-23.05	-23.33	-19.62	-19.71
@TIME	7.905	7.905	5.315	5.315	4.885	4.890

SECTION 11

1STDATA	203-XX	215-XX	227-XX	239-XX	251-XX	263-XX
2NDDATA	204-XX	216-XX	228-XX	240-XX	252-XX	264-XX
MAXIMUM	14.31	13.96	13.92	15.37	15.47	21.34
@TIME	4.875	4.875	4.880	4.880	4.875	4.875
MINIMUM	-9.19	-12.94	-14.93	-16.84	-18.64	-19.76
@TIME	4.885	4.885	4.885	4.885	4.885	4.885

DEC JOB NO.	1083-000
BY <u>mcz</u>	DATE <u>6-17-97</u>
CHECK <u>W</u>	DATE <u>6/17/97</u>
CALC. NO. <u>SC(P017)-1</u>	REV. NO. <u>0</u>
SHEET NO. <u>65</u>	

MAXIMUM DYNAMIC SHEAR FORCE (KIPS/FT) IN LONGITUDINAL SECTIONS (4-CASK CASE) GRADIENT OF MXX (BENDING ABOUT Y-AXIS OR LONGITUDINAL AXIS)

SECTION 1

1STDATA 193-XX 205-XX 217-XX 229-XX 241-XX 253-XX
 2NDDATA 194-XX 206-XX 218-XX 230-XX 242-XX 254-XX
 MAXIMUM 8.46 8.63 11.15 11.23 8.87 10.76
 @TIME 4.925 4.925 4.925 8.280 8.280 8.280
 MINIMUM -8.16 -7.52 -7.93 -8.77 -9.01 -10.97
 @TIME 9.865 11.485 2.995 2.995 2.995 9.890

SECTION 2

1STDATA 194-XX 206-XX 218-XX 230-XX 242-XX 254-XX
 2NDDATA 195-XX 207-XX 219-XX 231-XX 243-XX 255-XX
 MAXIMUM 15.58 20.28 25.40 24.14 16.63 16.21
 @TIME 4.925 11.505 11.505 11.505 11.505 11.510
 MINIMUM -17.07 -16.99 -11.83 -12.83 -15.82 -16.22
 @TIME 9.865 6.410 11.485 2.990 9.890 9.890

SECTION 3

1STDATA 195-XX 207-XX 219-XX 231-XX 243-XX 255-XX
 2NDDATA 196-XX 208-XX 220-XX 232-XX 244-XX 256-XX
 MAXIMUM 10.07 10.05 11.51 13.00 13.99 14.92
 @TIME 4.925 14.825 11.510 11.510 11.510 11.510
 MINIMUM -9.53 -11.54 -14.94 -16.11 -14.91 -17.73
 @TIME 14.165 2.990 2.990 2.990 11.480 11.485

SECTION 4

1STDATA 196-XX 208-XX 220-XX 232-XX 244-XX 256-XX
 2NDDATA 197-XX 209-XX 221-XX 233-XX 245-XX 257-XX
 MAXIMUM 18.36 18.14 15.33 15.70 20.50 21.16
 @TIME 8.440 5.420 3.020 7.930 7.930 7.930
 MINIMUM -13.93 -17.38 -26.81 -24.68 -23.05 -22.43
 @TIME 6.420 2.985 2.985 2.985 11.480 11.480

SECTION 5

1STDATA 197-XX 209-XX 221-XX 233-XX 245-XX 257-XX
 2NDDATA 198-XX 210-XX 222-XX 234-XX 246-XX 258-XX
 MAXIMUM 10.80 11.52 11.81 11.35 13.37 14.74
 @TIME 9.865 3.015 3.015 7.930 6.760 6.760
 MINIMUM -14.92 -19.06 -25.51 -26.17 -21.46 -18.09
 @TIME 6.575 11.475 11.475 11.475 11.475 11.480

SECTION 6

1STDATA 198-XX 210-XX 222-XX 234-XX 246-XX 258-XX
 2NDDATA 199-XX 211-XX 223-XX 235-XX 247-XX 259-XX
 MAXIMUM 10.85 16.70 36.22 35.87 18.09 16.61
 @TIME 11.970 7.910 11.085 11.085 11.090 6.760
 MINIMUM -16.01 -16.26 -29.22 -29.73 -19.88 -15.96
 @TIME 6.575 4.900 8.285 8.285 11.475 11.475

SECTION 7

1STDATA 199-XX 211-XX 223-XX 235-XX 247-XX 259-XX
 2NDDATA 200-XX 212-XX 224-XX 236-XX 248-XX 260-XX
 MAXIMUM 12.86 16.03 20.03 21.21 18.21 16.48
 @TIME 11.970 7.910 2.990 2.990 7.910 2.995
 MINIMUM -11.74 -10.85 -11.81 -13.89 -14.35 -14.59
 @TIME 11.255 11.255 11.260 11.260 11.260 11.260

SECTION 8

1STDATA 200-XX 212-XX 224-XX 236-XX 248-XX 260-XX
 2NDDATA 201-XX 213-XX 225-XX 237-XX 249-XX 261-XX

CEC JOB NO.	1083-000
BY	DATE 6-17-97
CHECK	DATE 6/17/97
CALC. NO. SC(P017)-1	REV. NO. 0
SHEET NO.	66

MAXIMUM 15.32 15.46 21.21 19.12 18.41 20.33
 @TIME 2.980 11.485 11.475 11.485 2.995 2.995
 MINIMUM -22.49 -16.79 -12.42 -15.63 -21.28 -22.08
 @TIME 8.445 9.540 11.260 11.260 6.745 11.965

SECTION 9

1STDATA 201-XX 213-XX 225-XX 237-XX 249-XX 261-XX
 2NDDATA 202-XX 214-XX 226-XX 238-XX 250-XX 262-XX
 MAXIMUM 9.42 12.11 15.02 15.39 13.51 14.58
 @TIME 2.980 11.475 11.475 11.475 11.480 11.480
 MINIMUM -9.28 -10.54 -11.01 -11.66 -12.29 -12.96
 @TIME 13.455 14.825 14.825 7.930 7.930 14.830

SECTION 10

1STDATA 202-XX 214-XX 226-XX 238-XX 250-XX 262-XX
 2NDDATA 203-XX 215-XX 227-XX 239-XX 251-XX 263-XX
 MAXIMUM 22.24 14.77 13.50 17.87 26.56 26.74
 @TIME 8.450 6.420 11.475 11.475 6.745 6.745
 MINIMUM -13.33 -14.31 -16.85 -17.68 -15.66 -15.56
 @TIME 14.050 14.050 14.050 7.920 6.755 6.760

SECTION 11

1STDATA 203-XX 215-XX 227-XX 239-XX 251-XX 263-XX
 2NDDATA 204-XX 216-XX 228-XX 240-XX 252-XX 264-XX
 MAXIMUM 10.33 10.11 8.72 10.80 11.43 13.83
 @TIME 8.450 3.000 9.400 9.400 9.400 11.475
 MINIMUM -6.73 -7.02 -9.10 -9.67 -9.16 -11.41
 @TIME 6.760 14.055 7.910 6.760 6.760 6.435

REC JOB NO.	1083-000
BY <u>mm</u>	DATE 6-17-97
CHECK <u>W</u>	DATE 6/17/97
CALC. NO. SC(P019)-1	REV. NO. 0
SHEET NO. 67	

MAXIMUM DYNAMIC SHEAR FORCE (KIPS/FT) IN LONGITUDINAL SECTIONS (8-CASK CASE) GRADIENT OF MXX (BENDING ABOUT Y-AXIS OR LONGITUDINAL AXIS)

SECTION 1

1STDATA 193-XX 205-XX 217-XX 229-XX 241-XX 253-XX
 2NDDATA 194-XX 206-XX 218-XX 230-XX 242-XX 254-XX
 MAXIMUM 11.78 11.48 12.50 12.21 10.73 11.44
 @TIME 6.610 6.610 6.610 6.610 6.610 5.245
 MINIMUM -13.70 -11.73 -10.17 -9.11 -8.99 -9.62
 @TIME 13.345 13.345 13.345 7.910 7.910 7.910

SECTION 2

1STDATA 194-XX 206-XX 218-XX 230-XX 242-XX 254-XX
 2NDDATA 195-XX 207-XX 219-XX 231-XX 243-XX 255-XX
 MAXIMUM 19.28 19.51 20.91 20.43 18.17 16.43
 @TIME 6.605 6.605 6.605 6.605 6.610 6.610
 MINIMUM -21.71 -23.18 -18.42 -13.58 -17.20 -17.58
 @TIME 13.345 13.345 13.345 13.345 7.955 7.955

SECTION 3

1STDATA 195-XX 207-XX 219-XX 231-XX 243-XX 255-XX
 2NDDATA 196-XX 208-XX 220-XX 232-XX 244-XX 256-XX
 MAXIMUM 16.59 17.45 17.61 17.55 18.75 21.39
 @TIME 7.935 7.935 7.935 7.935 7.940 7.940
 MINIMUM -15.92 -13.86 -13.53 -13.49 -12.34 -13.77
 @TIME 13.340 13.345 13.345 7.900 13.350 13.350

SECTION 4

1STDATA 196-XX 208-XX 220-XX 232-XX 244-XX 256-XX
 2NDDATA 197-XX 209-XX 221-XX 233-XX 245-XX 257-XX
 MAXIMUM 20.03 19.57 19.59 23.07 26.55 27.32
 @TIME 7.930 13.305 7.935 7.935 7.935 7.935
 MINIMUM -16.66 -23.12 -31.57 -30.24 -19.04 -15.05
 @TIME 7.900 7.900 7.900 7.900 7.900 15.895

SECTION 5

1STDATA 197-XX 209-XX 221-XX 233-XX 245-XX 257-XX
 2NDDATA 198-XX 210-XX 222-XX 234-XX 246-XX 258-XX
 MAXIMUM 16.96 17.77 18.37 18.21 17.55 19.28
 @TIME 7.930 7.930 7.930 7.930 7.935 7.935
 MINIMUM -23.18 -15.01 -15.08 -14.81 -14.90 -20.74
 @TIME 13.335 9.405 14.785 14.785 15.895 15.895

SECTION 6

1STDATA 198-XX 210-XX 222-XX 234-XX 246-XX 258-XX
 2NDDATA 199-XX 211-XX 223-XX 235-XX 247-XX 259-XX
 MAXIMUM 12.18 17.79 40.14 40.28 18.02 14.72
 @TIME 7.925 7.900 7.900 7.900 7.900 7.930
 MINIMUM -24.48 -16.67 -32.27 -31.69 -21.13 -26.15
 @TIME 13.335 15.060 15.060 15.060 15.890 15.890

SECTION 7

1STDATA 199-XX 211-XX 223-XX 235-XX 247-XX 259-XX
 2NDDATA 200-XX 212-XX 224-XX 236-XX 248-XX 260-XX
 MAXIMUM 12.46 15.93 18.86 18.99 16.23 10.63
 @TIME 13.345 7.900 2.980 7.900 7.900 7.930
 MINIMUM -13.76 -13.65 -13.39 -23.45 -32.95 -40.91
 @TIME 6.610 6.610 15.890 15.890 15.890 15.890

SECTION 8

1STDATA 200-XX 212-XX 224-XX 236-XX 248-XX 260-XX
 2NDDATA 201-XX 213-XX 225-XX 237-XX 249-XX 261-XX

CEC JOB NO.	1083-000
BY	DATE 6-17-97
CHECK	DATE 6/17/97
CALC. NO.	SC(P017)-1 REV. NO. 0
SHEET NO.	68

MAXIMUM 17.14 18.42 22.84 22.74 17.57 15.32
 @TIME 13.340 13.345 14.785 14.785 2.985 13.350
 MINIMUM -20.67 -21.07 -16.45 -25.43 -51.23 -55.65
 @TIME 6.610 15.660 7.935 15.890 15.890 15.890

SECTION 9

1STDATA 201-XX 213-XX 225-XX 237-XX 249-XX 261-XX
 2NDDATA 202-XX 214-XX 226-XX 238-XX 250-XX 262-XX
 MAXIMUM 17.25 13.21 14.10 14.37 12.98 12.54
 @TIME 13.335 13.340 13.345 13.345 13.345 2.990
 MINIMUM -17.48 -18.03 -18.24 -18.21 -17.94 -17.57
 @TIME 7.930 7.935 7.935 7.935 7.935 7.935

SECTION 10

1STDATA 202-XX 214-XX 226-XX 238-XX 250-XX 262-XX
 2NDDATA 203-XX 215-XX 227-XX 239-XX 251-XX 263-XX
 MAXIMUM 23.91 19.31 21.08 38.63 62.83 66.22
 @TIME 13.335 15.055 15.890 15.890 15.890 15.890
 MINIMUM -22.10 -24.32 -29.39 -27.34 -20.88 -16.76
 @TIME 9.420 7.930 7.925 7.930 7.930 3.020

SECTION 11

1STDATA 203-XX 215-XX 227-XX 239-XX 251-XX 263-XX
 2NDDATA 204-XX 216-XX 228-XX 240-XX 252-XX 264-XX
 MAXIMUM 12.82 12.35 15.93 22.96 28.17 33.40
 @TIME 13.335 13.335 15.890 15.890 15.890 15.890
 MINIMUM -13.58 -13.67 -17.43 -18.13 -16.74 -19.81
 @TIME 7.925 7.930 7.925 7.930 7.930 7.930

CEC JOB NO.	1083-0000
BY <u> </u>	DATE 6-17-97
CHECK <u> </u>	DATE 6/17/97
CALC. NO. <u>SC(P017)-1</u>	REV. NO. 0
SHEET NO.	69



CALCULATION SHEET

ORIGINATOR M. Z

DATE 6-5-97

CALC. NO. SC(P017)-1

REV. NO. 2

PROJECT PFSF

JOB NO. 1083-000

SUBJECT Pad Dynamic Analysis

SHEET NO. 70

Maximum Dynamic Response

By examining the maximum values in Attachment A-3 and time history plots in Attachment A-4, the maximum response was found to occur in 2-case case @ time = 4.88 seconds:



Zlem. no	(KIP/FT) Sxx	(KIP-FT/FT) Mxx	(KIP/FT) Syy	(KIP-FT/FT) Myy	
217	-6.06	-109.2	23.04	-695.0	← Local max.
218	38.89	-41.07	-4.44	-571.3	
219	19.27	142.9	-12.42	-408.8	
220	-2.08	208.0	-8.74	-311.4	
221	-23.67	171.9	-15.79	-303.5	
222	12.83	18.16	-14.80	-353.4	
223	-13.12	-242.7	-22.97	-419.8	
224	23.85	-300.0	-19.34	-398.6	
225	0.99	-203.0	-13.52	-295.9	
226	-20.30	-118.4	-9.31	-201.1	
227	-38.48	-22.92	-29.14	-131.9	
228	6.31	9.12	-57.86	-92.33	

$QVE = 344.3 \text{ K-ft/f}$

2-case case @ time = 4.88 seconds

Note: Sxx, Syy: in plane membrane forces in the x- and y- directions, respectively

Mxx, Myy: bending moments per unit length about y- and x- axes, respectively





CALCULATION SHEET

ORIGINATOR msy DATE 6-5-97 CALC. NO. SC(P017)-1 REV. NO. 0
PROJECT PFSF CHECKED W DATE 6/17/97
SUBJECT Pool Dynamic Analysis JOB NO. 1083-000
SHEET NO. 71

Dynamic Analysis Results (cont'd)

Average max. bending moments in transverse section, M_{yy} (K-ft/s)
(Section No. 4)

Plate Element		4 cases	8 cases
Length	No.	max. M (K-ft/s)	max. M (K-ft/s)
1.98	217	161.6	173.1
2.76	218	123.9	132.4
2.76	219	91.89	78.45
2.76	220	111.7	83.17
2.76	221	142.6	117.3
1.98	222	147.7	122.1
1.98	223	126.5	108.5
2.76	224	116.3	106.8
2.76	225	107.4	100.7
2.76	226	132.1	109.8
2.76	227	166.0	116.6
1.98	228	191.0	145.0
average →		132.6	114.0



CALCULATION SHEET

ORIGINATOR mcg DATE 6-5-97 CALC. NO. SC(P017)-1 REV. NO. 0
 PROJECT Private Fuel Storage Facility CHECKED K DATE 5/17/07
 SUBJECT Storage Pad Analysis and Design JOB NO. 1083-000
 SHEET NO. 72

Total Maximum Horizontal Soil Reactions of Dynamic Analyses

Maximum total shear forces between pad and soil were calculated by the following equation

$$F_x = K_{s,x} * d_{max,x}$$

where F_x is the shear force in kips in the x-direction

$K_{s,x}$ is the total shear stiffness in x-direction

$d_{max,x}$ = averaged maximum displacement of pad in x-direction

The equation was also applied to y-shear force calculation with appropriate values associated with motions in y direction.

		$K_s (k/in)$	$d_x (in)$	$F_x (k)$	
X-direction	2 Casks	6991	0.104	727K	Note: dx and dy values are taken from the maximum values in attachment A-3,
	4 Casks	6991	0.13	909K	
	8 Casks	6991	0.29	2027K ←	
		$K_{s,y} (k/in)$	$d_y (in)$	F_y	
y-direction	2 Casks	6641	0.10	664K	
	4 Casks	6641	0.18	1195K	
	8 Casks	6641	0.20	1328K ←	




CALCULATION SHEET


ORIGINATOR DATE 6-5-97 CALC. NO. SC(PO17)-1 REV. NO. 0
PROJECT Private Fuel Storage Facility CHECKED KL DATE 6/17/97
SUBJECT Storage Pad Analysis and Design JOB NO. 1083-000
SHEET NO. 73

Estimation of Pad Averaged Displacements (Dynamic)

2-Cask Case




4-Cask Case





CALCULATION SHEET

ORIGINATOR msjDATE 6-5-97CALC. NO. SC(P017)-1REV. NO. 0PROJECT Private Fuel Storage FacilityDATE 6/17/97SUBJECT Storage Pad Analysis and DesignJOB NO. 1083-000SHEET NO. 748-Case Case

$$dx = (0.02373 + 0.02418 + 0.02424) / 3 = 0.0241' \\ = 0.289"$$

$$dy = (0.01683 + 0.01682) / 2 = 0.0168' \\ = 0.202"$$

The displacements used here were extracted from response time history plots in Attachment A-6.




CALCULATION SHEET

ORIGINATOR MSJDATE 6-5-97CALC. NO. SC(P017)-1REV. NO. 0PROJECT PF5FDATE 6/17/97SUBJECT Storage Pad AnalysisJOB NO. 1083-000SHEET NO. 75

Dynamic Analysis Results

Total Vertical Soil Pressure was estimated by multiplying the averaged vertical displacement and total vertical soil stiffness, which is 1161.48 K/ft.

Node No.	Max. Displ. (Vertical) (ft)		
	2 Cais	4 Cais	8 Cais
1	-0.00711	-0.00742**	0.03139
7	-0.00455	-0.00360	0.01733
13	-0.00697	-0.00786	0.04200
144	0.01230	0.01082	0.03869
150	0.00532	0.00742	0.01106
156	0.00681	0.01832	0.04559
287	0.05525	0.03156	0.03410
293	0.03314	0.02408	0.01831
299	0.02391	0.03466	0.04046
Average*	0.01726	0.01619	0.03099
Total Force	2005 K	1881 K	3600 K



Note: The displacement values were taken from maximum value listings in Attachment A-5

* Averages were taken by ignoring signs for conservatism

** positive displacements imply downward movements



CALCULATION SHEET

CALC. NO. SC(P017)-1 REV. NO. 0ORIGINATOR msg DATE 6-10-97 CHECKED W DATE 6/17/97PROJECT PFSF JOB NO. 1083-000SUBJECT Storage Pad Analysis SHEET NO. 76

Maximum Soil Pressure (Static and Dynamic Analysis)

$$\text{Dead load Analysis} = (20 \text{ K/f/f}^2) \times \delta_{z \text{ max}}$$

$$\delta_{z \text{ max}} : \text{max. vertical displ.} = 0.0225'$$

$$\text{Thus max. soil pressure } P = 0.45 \text{ K/f}^2$$

Live Load Analysis

Similar equation was used

	$\delta_{z \text{ max}}$		P_{max}
2 Casks	0.06530'	@ Node 294	1.31 Ksf
4 Casks	0.08254'	@ Node 289	1.65 Ksf
8 Casks	0.07842'	@ Node 147	1.57 Ksf
8 Casks + transporter	0.1525'	@ Node 287	3.05 Ksf

Dynamic Load Analysis

$$P = 60.5 \text{ K/f/f}^2 \times \delta_{z \text{ max}}$$

	$\delta_{z \text{ max}}$		P_{max}
2 Casks	0.05525'	@ Node 287	3.34 Ksf
4 Casks	0.03466'	@ Node 299	2.10 Ksf
8 Casks	0.04625'	@ Node 117	2.80 Ksf



CALCULATION SHEET

ORIGINATOR 2027 DATE 6-17-97 CALC. NO. SC(2017)- REV. NO. 0
PROJECT PEST CHECKED W DATE 6/17/97
SUBJECT Pad Analysis and Design JOB NO. 1083-000
SHEET NO. 77

Summary of CEC SAP Analysis Results

Static Analysis Results				
		(K-FT/FT)	(K/FT)	(KSF)
		Max. Moment _A	Max. Shear _A	Max. Soil Pressure _A
Dead Load		0	0	0.45
Live Load	2 Casks	21.8	6.9	1.31
	4 Casks	57.1	8.4	1.65
	8 Casks	37.4	5.7	1.57
	8 Casks and Transporter	45.6	11.3	3.05

Dynamic Analysis Results

		Max. Moment	Max. Shear	Max. Soil Pressure	Total Max. Horizontal Soil Reaction (KIPS)	
		(KIP-FT/FT)	(KIP/FT)	(KSF)	Longit.	Transv.
Earthquake Load	2 Casks	344.3	76.3	3.34	727	664
	4 Casks	132.6	25.2	2.70	1195	909
	8 Casks	114.0	27.7	2.80	1328	2027



CALCULATION SHEET

ORIGINATOR DH DATE 6/6/97 CALC. NO. SC(P017)-1 REV. NO. 0
PROJECT Private Fuel Storage Facility CHECKED W DATE 6/17/97
SUBJECT Storage Pad Analysis and Design JOB NO. 1083-000
SHEET NO. 78

5.2 DYNAMIC ANALYSIS USING SASSI MODEL

THIS SECTION DOCUMENTS A SASSI DYNAMIC ANALYSIS OF THE PAD. THIS ANALYSIS WAS PERFORMED AS A CHECK OF THE CEC-SAP ANALYSIS.

THE ANALYSIS WAS PERFORMED FOR ONE LOAD CASE, CONSISTING OF A SINGLE VERTICAL FORCE, APPLIED TO QUADRANT 2 OF CASK 1. THE 2 CASK CONFIGURATION WAS USED, WITH A FRICTION COEFFICIENT OF 0.8.

RESULTS IN THE FORM OF VERTICAL DISPLACEMENTS AND BENDING MOMENTS IN THE PAD WILL BE CALCULATED AND COMPARED TO CEC-SAP RESULTS.



CALCULATION SHEET

ORIGINATOR M. Tsay DATE 5/22/97 CALC. NO. SC (2017)-1 REV. NO. 0
PROJECT Private Fuel Storage Facility CHECKED DH DATE 6/2/97
SUBJECT Storage Pad Analysis and Design JOB NO. 1083-000
SHEET NO. 79

5.2.1 SASSI MODEL

From dynamic soil parameters for SASSI model,
the average ^{strain-compatible} shear wave velocity for the first
6 layers, $V_s = (637 + 520 + 469 + 353 + 327 + 280) / 6$
 $= 431 \text{ fps}$

Applying $f_{max} = V_s / 5 H_{max} = 431 / 5 \times 3.98 = 21.66 \text{ cps}$
where $H_{max} = 3.98'$ is the max. FE model dimension. Say 22 cps

For $V_s = 1809 \text{ fps}$, $H_{max} = V_s / 5 f_{max} = 1809 / 5 \times 22 = 16 \text{ ft}$ use 15

$V_s = 1861$, $H_{max} = V_s / 5 f_{max} = 1861 / 5 \times 22 = 16.9 \text{ ft}$ use 15

$V_s = 2080$, $H_{max} = 2080 / 5 \times 22 = 18.9 \text{ ft}$ use 20'

$V_s = 2440$, $H_{max} = 2440 / 5 \times 22 = 22.2 \text{ ft}$ use 20'

$V_s = 637$, $H_{max} = 637 / 5 \times 22 = 5.79'$ use 5'

$V_s = 520$, $H_{max} = 520 / 5 \times 22 = 4.73'$ use 5'

$V_s = 469$, $H_{max} = 469 / 5 \times 22 = 4.26'$ use 2.5'

$V_s = 353$, $H_{max} = 353 / 5 \times 22 = 3.2'$ use 2.5'



CALCULATION SHEET

ORIGINATOR M. T. Say DATE 5/22/07 CALC. NO. SC(P017)-1 REV. NO. 0
PROJECT Private Fuel Storage Facility CHECKED DJ DATE 6/2/97
SUBJECT Storage Pad Analysis and Design JOB NO. 1083-000
SHEET NO. 80

$$V_s = 327 \text{ fps} \quad H_{max} = 327 / 5.122 = 2.97' \text{ use } 2.5'$$

$$V_s = 280 \text{ fps} \quad H_{max} = 280 / 5.122 = 2.56' \text{ use } 2.5'$$

The soil layers to be used in SITE module for
SASSI will be:

$$V_s = 637 \text{ fps}, H = 5'; \quad 1 \text{ layer @ } 5' \leftarrow (\text{MAKE } 2' \text{ THICK BECAUSE THE PAD IS } 3' \text{ THICK})$$

$$V_s = 520 \text{ fps}, H = 5'; \quad 1 \text{ layer @ } 5'$$

$$V_s = 469 \text{ fps}, H = 5'; \quad 2 \text{ layers @ } 2.5'$$

$$V_s = 353 \text{ fps}, H = 5'; \quad 2 \text{ layers @ } 2.5'$$

$$V_s = 327 \text{ fps}, H = 5'; \quad 2 \text{ layers @ } 2.5'$$

$$V_s = 280 \text{ fps}, H = 5'; \quad 2 \text{ layers @ } 2.5'$$

$$V_s = 1809 \text{ fps}, H = 30'; \quad 2 \text{ layers @ } 15'$$

$$V_s = 1861 \text{ fps}, H = 60'; \quad 4 \text{ layers @ } 15'$$

$$V_s = 2080 \text{ fps}, H = 180'; \quad 9 \text{ layers @ } 20'$$

$$V_s = 2440 \text{ fps}, H = 300'; \quad 15 \text{ layers @ } 20'$$



CALCULATION SHEET

CALC. NO. SCC P0177-1 REV. NO. 0
CHECKED DF DATE 6/2/97
JOB NO. 1082-000
SHEET NO. 83

ORIGINATOR M. Teau DATE 5/20/97
PROJECT Private Fuel Storage Facility
SUBJECT Storage Pad Analysis and Design

↑ Y

$1.98' \times 4 @ 2.76' = 11.04' \quad 3.96' \times 4 @ 2.76' = 11.04' \quad 1.98'$

FIG. 5.2.1-3

BRICK NODES

EXCAVATE
NODES

EL. D.O.

$3.98' \times 4 @ 2.76' = 11.04' \quad 3.96' \times 4 @ 2.76' = 11.04' \quad 1.98'$

885

872

859

846

833

820

807

794

781

768

755

742

729

716

703

690

677

664

651

638

625

612

857 Center

884 Outer Diameter

571 $132.5" = 11.04'$

858

845

832

819

806

793

780

767

754

741

728

715

702

689

676

663

650

637

624

→ X

599 600 601 602 603 604 605 606 607 608 609 610 611



CALCULATION SHEET

0

ORIGINATOR

m

T. Sav

DATE

5/20/97

CALC. NO. SC (P0172)-1 REV. NO.

CHECKED

DIT

DATE

6/2/97

PROJECT

Storage Pad Analysis and Design

JOB NO.

1083-000

SUBJECT

SHEET NO.

24

Y

 $1.98' \quad 1 @ 2.76' = 11.04' \quad 3.96' \quad 4 @ 2.76' = 11.04' \quad 1.98'$

FIG. 5.2.1-4

BRICK NODES

EXCAVATE,

PUT BACK

NODES

E.L. -2.0'

 $1.98' \quad 4 @ 2.76' = 11.04' \quad 3.96' \quad 4 @ 2.76' = 11.04' \quad 1.98'$

586

573

560

547

534

521

508

495

482

469

456

443

430

417

404

391

378

365

352

339

326

313

598 Canister

585 Outer Diameter

 $132.5" = 11.04'$

572

559

546

533

520

507

494

481

468

455

442

429

416

403

390

377

364

351



338

325

X

300 301 302 303 304 305 306 307 308 309 310 311 312



CEC JOB NO.	1083-000
BY <u>DH</u>	DATE <u>6/6/97</u>
CHECK <u>K</u>	DATE <u>6/10/97</u>
CALC. NO. <u>SC(POM)-1</u>	REV. NO. <u>0</u>
SHEET NO. <u>85</u>	



3-D PLATE

FIG. 5.2.1-5



CEC JOB NO.	1083-000		
BY	DP	DATE	6/6/97
CHECK	KV	DATE	6/10/97
CALC. NO.	SC(P017)-1	REV. NO.	0
SHEET NO.	86		



3-D SOLID (PUT BACK SOIL)


FIG 5.2.1-6

CEC JOB NO.	1083-000		
BY	DH	DATE	6/6/97
CHECK	KW	DATE	6/10/97
CALC. NO.	SC(P017)-1	REV. NO.	0
SHEET NO.	87		




3-D SOLID (EXCAVATE SOIL)

FIG. 5.2.1-7



$$\frac{22 \times 12}{44} = \frac{22}{2} = 11 \text{ ELEM}$$



287	288	289	290	291	292	293	294	295	296	297	298	299
274	275	276	277	278	279	280	281	282	283	284	285	286
262	263	264	265	266	267	268	269	270	271	272	273	
248	249	250	251	252	253	254	255	256	257	258	259	260
235	236	237	238	239	240	241	242	243	244	245	246	247
222	223	224	225	226	227	228	229	230	231	232	233	234
209	210	211	212	213	214	215	216	217	218	219	220	221
196	197	198	199	200	201	202	203	204	205	206	207	208
183	184	185	186	187	188	189	190	191	192	193	194	195
170	171	172	173	174	175	176	177	178	179	180	181	182
157	158	159	160	161	162	163	164	165	166	167	168	169
144	145	146	147	148	149	150	151	152	153	154	155	156
131	132	133	134	135	136	137	138	139	140	141	142	143
118	119	120	121	122	123	124	125	126	127	128	129	130
105	106	107	108	109	110	111	112	113	114	115	116	117
92	93	94	95	96	97	98	99	100	101	102	103	104
79	80	81	82	83	84	85	86	87	88	89	90	91
66	67	68	69	70	71	72	73	74	75	76	77	78
53	54	55	56	57	58	59	60	61	62	63	64	65
40	41	42	43	44	45	46	47	48	49	50	51	52
27	28	29	30	31	32	33	34	35	36	37	38	39
14	15	16	17	18	19	20	21	22	23	24	25	26
1	2	3	4	5	6	7	8	9	10	11	12	13

CEC JOB NO.	1083-000
BY	PH
DATE	6/6/97
CHECK	W
DATE	6/10/97
CALC. NO.	50 (P017) - 1
REV. NO.	0
SHEET NO.	88

← ELEM NO.
— NODE NO.

FIG. 5.2.1-8





FIG. 5.2.1-9

CEC JOB NO.	1083-000
BY	DH
DATE	6/6/97
CHECK	✓
DATE	6/10/97
CALC. NO.	SC(P017)-1
REV. NO.	0
SHEET NO.	89



CALCULATION SHEET

ORIGINATOR

DH

DATE

6/6/97

CALC. NO. SCCP0177-1

REV. NO. 0

PROJECT

Private Fuel Storage Facility

CHECKED

W

DATE

6/12/97

SUBJECT

Storage Pad Analysis and Design

JOB NO.

1083-000

SHEET NO.

90

5.2.2 DYNAMIC LOADING

THE LOADING CONSISTS OF A VERTICAL FORCE

APPLIED TO NODE 249. THE INPUT TIME HISTORY

IS DESIGNATED "V20812" WHICH STANDS FOR

VERTICAL FORCE, 2 CASK CONFIGURATION, FRICTION

COEFFICIENT = 0.08, LOADING ON CASK 1, QUADRANT 2.

THE TIME HISTORY IS SHOWN IN FIGURE 5.2.2-2.




FIG. 5.2.2-1




FIG. 5.2.2-2 INPUT TIME HISTORY
APPLIED TO NODE 249.

CEC JOB NO.	1083-000
BY	DH
CHECK	W
CALC. NO.	SC(107)-JREV. NO. 0
SHEET NO.	91
DATE	6/6/97
DATE	6/12/97

TIME HISTORY FILE = V20812.TH2



CALCULATION SHEET

ORIGINATOR DH DATE 6/5/92 CALC. NO. SCCP017)-1 REV. NO. 0
PROJECT Private Fuel Storage Facility CHECKED W DATE 6/12/97
SUBJECT Storage Pad Analysis and Design JOB NO. 1083-000
SHEET NO. 92

5.2.3 ANALYSIS PROCEDURE

THE SASSI ANALYSIS PROCEDURES IS SHOWN
IN FIGURES 5.2.3-1 THROUGH 5.2.3-4.

THE STEPS ARE AS FOLLOWS:

STEP 1. CALCULATE IMPEDANCE FOR FREQUENCIES
1-8. SEE FIG. 5.2.3-1.

STEP 2. CALCULATE IMPEDANCE FOR FREQUENCIES
9-16. SEE FIG. 5.2.3-2.

STEP 3. CALCULATE IMPEDANCE FOR FREQUENCIES
17-23. SEE FIG. 5.2.3-3.

STEP 4. COMBINE IMPEDANCES CALCULATED IN
STEPS 1-3. RUN MOTION AND STRESS TO CALCULATE
DISPLACEMENTS AND BENDING MOMENTS. SEE FIG. 5.2.3-4.




CALCULATION SHEET

CALC. NO. SC(P017)-1 REV. NO. 0

ORIGINATOR DH DATE 6/7/97 CHECKED W DATE 6/12/97
PROJECT Private Fuel Storage Facility JOB NO. 1083-000
SUBJECT Storage Pad Analysis and Design SHEET NO. 93

SASSI Analysis Procedure:



Step 1. Run the SITE module.

INPUT = svlasd

Step 2. Run the POINT3 module.

INPUT = svlapd

Step 3. Run the HOUSE module.

INPUT = svlahd

Step 4. Run the ANALYS module.

INPUT = svlaad

Step 5. Run the MOTOR module.

INPUT = f2492amd

Step 6. Run the ANALYS module.

INPUT = f2492aad

FIG. 5.2.3-1. IMPEDANCE FOR FREQUENCIES 1-8

sassiv3c.drw



CALCULATION SHEET

ORIGINATOR DH DATE 6/3/97 CALC. NO. SC(P017)-1 REV. NO. 0
PROJECT Private Fuel Storage Facility CHECKED KV DATE 6/12/97
SUBJECT Storage Pad Analysis and Design JOB NO. 1083-000
SHEET NO. 94

SASSI Analysis Procedure




FIG. 5.2.3-2 IMPEDANCE FOR FREQUENCIES 9-16

sassiv3c.drw



CALCULATION SHEET

ORIGINATOR

DH

DATE

6/7/97

CALC. NO. SC(P017)-1

REV. NO. 0

PROJECT

Private Fuel Storage Facility

JOB NO.

1083-000


SUBJECT

Storage Pad Analysis and Design

SHEET NO.

95

SASSI Analysis Procedure



Step 1. Run the SITE module.

INPUT= sv/csd (same as sv/asd)

Step 2. Run the POINT3 module.

INPUT= sv/cpd (same as sv/apd)

Step 3. Run the HOUSE module.

INPUT= sv/chd (same as sv/ahd)

Step 4. Run the ANALYS module.

INPUT= sv/cad

Step 5. Run the MOTOR module.

INPUT= f249zcmd

Step 6. Run the ANALYS module.

INPUT= f249zcad

FIG. 5.2.3-3 IMPEDANCE FOR FREQUENCIES 17-23

sassiv3c.drw



CALCULATION SHEET

ORIGINATOR

PROJECT

SUBJECT

Private Fuel Storage Facility

Storage Pad Analysis and Design

Dt

DATE

6/5/92

CALC. NO. SC(PO.177)-1

REV. NO. 0

CHECKED

✓

DATE 6/12/97

JOB NO.

1083-000

SHEET NO.

96

SASSI Analysis Procedure




FIG. 3.2.3-4 COMBINE TAPE 8'S, RUN MOTION AND STRESS

sassy1e.dsf



CALCULATION SHEET

CALC. NO. SCCF0172-1 REV. NO. 0

ORIGINATOR DH DATE 6/7/97 CHECKED W DATE 6/12/97
PROJECT Private Fuel Storage Facility
SUBJECT Storage Pad Analysis and Design JOB NO. 1083-000
SHEET NO. 97

5.2.4 SASSI ANALYSIS RESULTS

THIS SECTION PRESENTS RESULTS DUE TO THE VERTICAL

FORCE ON NODE 249. FIGURES 5.2.4-1 THROUGH 5.2.4-5

SHOW FORCE-TO-DISPLACEMENT TRANSFER FUNCTIONS FOR

SELECTED NODES. FIGURES 5.2.4-6 THROUGH 5.2.4-13 SHOW

FORCE-TO-MOMENT TRANSFER FUNCTIONS FOR SELECTED

ELEMENT COMPONENTS.

THE MAXIMUM DISPLACEMENTS AT SELECTED NODES ARE

SHOWN IN TABLE 5.2.4-1, AND FIG. 5.2.4-14.

THE TIME HISTORIES ARE SHOWN IN FIGS. 5.2.4-15

THROUGH 5.2.4-26.



CALCULATION SHEET

CALC. NO. SC(P017)-1 REV. NO. 0ORIGINATOR DHDATE 6/2/97CHECKED WDATE 6/12/97PROJECT Private Fuel Storage FacilityJOB NO. 1083-000SUBJECT Storage Pad Analysis and DesignSHEET NO. 98

THE MAXIMUM BENDING MOMENTS IN SELECTED PLATE

ELEMENTS ARE SHOWN IN TABLE 5.2.4-2. THE TIME

HISTORIES ARE SHOWN IN FIGS. 5.2.4-27 THROUGH

5.2.4-30.

THE MAXIMUM BENDING MOMENTS OF SELECTED PLATE ELEMENTS

ARE SHOWN IN FIG. 5.4.2-31. THE MAXIMUM TRANSVERSE

SHEAR BETWEEN THESE ELEMENTS, BASED ON THE

MAXIMUM MOMENTS, IS CALCULATED ON THE

FOLLOWING TWO PAGES.



CALCULATION SHEET

ORIGINATOR DH DATE 6/13/97 CALC. NO. SCCP0172-1 REV. NO. 3
PROJECT PRIVATE FUEL STORAGE FACILITY CHECKED ✓ DATE 6/16/97
SUBJECT STORAGE PAD ANALYSIS AND DESIGN JOB NO. 1083-000
SHEET NO. 99

LOADING V20812 (SEE FIG. 5.2.4-31)

<u>X-DIR</u>		
<u>ELEMENTS</u>	L_x [FT]	$V = \frac{\Delta M_y}{L_x}$ [K/FT OF ELEMENT LENGTH]
205-206	2.37	$(-18.8 + 15.8) / 2.37 = -1.69$
217-218	2.37	$(-82.6 + 6.1) / 2.37 = -15.40$



CALCULATION SHEET

ORIGINATOR DT DATE 6/13/97 CALC. NO. SCC(P017)-1 REV. NO. 0
PROJECT PRIVATE FUEL STORAGE FACILITY CHECKED W DATE 6/16/97
SUBJECT STORAGE PAD ANALYSIS AND DESIGN JOB NO. 1083-000
SHEET NO. 100

LOADING V20812 (SEE FIG. 5.2.1-31)

Y-DIR

ELEMENTS	L_y [FT]	$V = \frac{\Delta M_{xx}}{L_y}$
		[K/FT OF ELEM LENGTH]
205-217	2.76	$(-163.6 + 11.5) / 2.76 = 89.82$
206-218	2.76	$(-147.9 + 336.0) / 2.76 = 68.15$

TABLE 5.2.4-1

1MOTION - V20812AOD, PFSF, 3' PAD, 2 CASKS, MU=0.8, FZ ON NODE 249 (K-FT)

MAXIMUM ABSOLUTE DISPL.

N.P.	X-DIS	AT TIME	Y-DIS	AT TIME	Z-DIS	AT TIME
144					.0087	4.9200
157					.0099	4.9200
170					.0116	4.9200
183					.0136	4.9200
196					.0156	4.9150
209					.0184	4.8900
222					.0234	4.8850
235					.0267	4.8850
248					.0285	4.8850
249					.0245	4.8850
250					.0194	4.8900
251					.0154	4.8900
252					.0124	4.8950
253					.0097	4.9000
254					.0081	4.9000
255					.0063	4.9300
256					.0045	4.9350
257					.0031	4.9450
258					.0039	4.8950
259					.0068	4.8950
260					.0089	4.8950
261					.0280	4.8850
274					.0259	4.8900
287					.0240	4.8900
288					.0209	4.8900
289					.0169	4.8950
290					.0143	4.8950
291					.0116	4.8950
292					.0095	4.9300
293					.0080	4.9300
294					.0065	4.9350
295					.0051	4.8800
296					.0049	4.8850
297					.0064	4.8900

CEC JOB NO.	1083-000
BY	DH
DATE	6/7/97
CHECK	WV
DATE	6/12/97
CALC NO.	SC(0017)-1
REV NO.	0
NO	101

TABLE 5.2.4-1 (CONT'D)

298	.0089	4.8950
299	.0112	4.8950

BLANKS IN THE ABOVE TABLES ARE DOFS WHERE OUTPUT HAS NOT BEEN REQUESTED

CEC JOB NO.	1083-060		
BY	DH	DATE	6/7/97
CHECK	K	DATE	6/12/97
CALC. NO.	SC(P017)-1	REV. NO.	0
SHEET NO.	102		

1STRESS - V20812BTD, PFSF, 3' PAD, 2 CASKS, MU=0.8, FZ ON NODE 249 (K-FT)

COMPUTED STRESSES / FORCES / MOMENTS

3D PLATE/SHELL ELEMENTS

[K-FT/FT]

GROUP	ELEMENT	SIX(MAX) (F/L)	SYI(MAX) (F/L)	SXY(MAX) (F/L)	MXI(MAX) (F-L/L)	MYI(MAX) (F-L/L)	MXI(MAX) (F-L/L)
1	169				.1002E+03	.1028E+02	
1	170				.8597E+02	.3087E+02	
1	171				.7029E+02	.5315E+02	
1	172				.5603E+02	.7175E+02	
1	173				.4357E+02	.8232E+02	
1	174				.3427E+02	.8348E+02	
1	175				.2748E+02	.7808E+02	
1	176				.2022E+02	.6532E+02	
1	177				-.1288E+02	.4867E+02	
1	178				-.8345E+01	.2954E+02	
1	179				-.9626E+01	.1210E+02	
1	180				-.1024E+02	.2240E+01	
1	181				.8198E+02	.1118E+02	
1	182				.6776E+02	.3049E+02	
1	183				.5149E+02	.5684E+02	
1	184				.3748E+02	.8189E+02	
1	185				-.3360E+02	.9698E+02	
1	186				-.3113E+02	.9985E+02	
1	187				-.2776E+02	.9400E+02	
1	188				-.2283E+02	.7915E+02	
1	189				-.1666E+02	.5765E+02	
1	190				-.1301E+02	.3629E+02	
1	191				-.1423E+02	.1603E+02	
1	192				-.1461E+02	.3509E+01	
1	193				-.6062E+02	.4952E+01	
1	194				-.5881E+02	.2268E+02	
1	195				-.5549E+02	.6154E+02	
1	196				-.5017E+02	.9868E+02	
1	197				-.4355E+02	.1189E+03	
1	198				-.3858E+02	.1222E+03	
1	199				-.3390E+02	.1146E+03	
1	200				-.2761E+02	.9643E+02	
1	201				-.2031E+02	.6960E+02	
1	202				-.1872E+02	.4422E+02	
1	203				-.1885E+02	.2060E+02	
1	204				-.1884E+02	.4792E+01	
1	205				-.1636E+03	-.1876E+02	
1	206				-.1479E+03	-.1475E+02	
1	207				-.1230E+03	.7318E+02	
1	208				-.9769E+02	.1205E+03	
1	209				-.7267E+02	.1428E+03	
1	210				-.5402E+02	.1449E+03	
1	211				-.4387E+02	.1350E+03	
1	212				-.3382E+02	.1129E+03	
1	213				-.2435E+02	.8126E+02	
1	214				-.2337E+02	.5131E+02	

TABLE 5.2.4-2

CEC JOB NO.	1083-000
BY	PH
DATE	6/14/97
CHECK	W
DATE	6/17/97
CALC. NO.	366017
REV. NO.	0
SHEET NO.	103



1	215	-.2350E+02	.2441E+02
1	216	-.2306E+02	.5848E+01
1	217	-.4115E+03	-.8256E+02
1	218	-.3360E+03	-.4609E+02
1	219	-.2255E+03	.8727E+02
1	220	-.1459E+03	.1394E+03
1	221	-.9456E+02	.1603E+03
1	222	-.6827E+02	.1604E+03
1	223	-.5181E+02	.1480E+03
1	224	-.3736E+02	.1226E+03
1	225	-.2592E+02	.8755E+02
1	226	-.2516E+02	.5518E+02
1	227	-.2550E+02	.2635E+02
1	228	-.2542E+02	.6421E+01
1	229	-.4144E+03	-.8102E+02
1	230	-.3410E+03	-.4159E+02
1	231	-.2319E+03	.9530E+02
1	232	-.1525E+03	.1496E+03
1	233	-.9941E+02	.1706E+03
1	234	-.6940E+02	.1695E+03
1	235	-.5174E+02	.1554E+03
1	236	-.3610E+02	.1274E+03
1	237	-.2457E+02	.8962E+02
1	238	-.2471E+02	.5658E+02
1	239	-.2524E+02	.2673E+02
1	240	-.2531E+02	.6471E+01
1	241	-.1739E+03	-.1425E+02
1	242	-.1648E+03	-.1520E+02
1	243	-.1445E+03	.9884E+02
1	244	-.1146E+03	.1525E+03
1	245	-.8100E+02	.1749E+03
1	246	-.5690E+02	.1725E+03
1	247	-.4097E+02	.1568E+03
1	248	-.2688E+02	.1267E+03
1	249	-.2179E+02	.8676E+02
1	250	-.2162E+02	.5487E+02
1	251	-.2185E+02	.2496E+02
1	252	-.2131E+02	.6054E+01
1	253	-.4791E+02	.1774E+02
1	254	-.5003E+02	.5847E+02
1	255	-.4951E+02	.1192E+03
1	256	-.4338E+02	.1679E+03
1	257	-.3254E+02	.1833E+03
1	258	-.2366E+02	.1738E+03
1	259	-.1778E+02	.1529E+03
1	260	-.1176E+02	.1194E+03
1	261	-.9830E+01	.8009E+02
1	262	-.9770E+01	.4618E+02
1	263	-.9551E+01	.1787E+02
1	264	-.9246E+01	-.5682E+01

TABLE 5.2.4-2 (CONT'D)

CEC JOB NO.	1083-000
BY	DH
DATE	6/14/97
CHECK	W
DATE	6/17/97
CALC. NO. SC (P017)-1	REV. NO. 0
SHEET NO.	104


BLANKS IN THE ABOVE TABLES ARE COMPONENTS WHERE OUTPUT HAS NOT BEEN REQUESTED.

V20812A00, PFSF, 3' PAD, 2 CASKS, MU=0.8, FZ ON NODE 249 (K-FT)





CEC JOB NO.	1083-000		
BY	DH	DATE	6/7/97
CHECK	W	DATE	6/12/97
CALC. NO.	SCCP017-1	REV. NO.	0
EET NO.	105		

FIG. 5.2.4-1



CEC JOB NO.	1083-000		
BY	DK	DATE	6/7/97
CHECK	W	DATE	6/12/97
CALC. NO.	SC(P017)-1	REV. NO.	0
SHEET NO.	106		



FIG. 5.2,4-2



CEC JOB NO.	1083-DDD		
BY	DH	DATE	6/7/97
CHECK	K	DATE	6/12/97
CALC. NO.	SCCP017-1	REV. NO.	0
SHEET NO.	107		

FIG. 5.2.4-3



V20812A00, PFSF, 3' PAD, 2 CASKS, MU=0.8, FZ ON NODE 249 (K-FT)



CEC JOB NO.	1083-000
BY	DLT
DATE	6/7/97
CHECK	W
DATE	6/12/97
CALC. NO.	SC(P017)-1
REV. NO.	0
SHEET NO.	108


FIG. 5.2.4-4

V20812A0D, PFSF, 3' PAD, 2 CASKS, MU=0.8, FZ ON NODE 249 (K-FT)



CEC JOB NO.	1083-000
BY	DH
DATE	6/7/97
CHECK	✓
DATE	6/12/97
CALC. NO.	SC(P017)-
REV. NO.	0
SHEET NO.	109



FIG. 5.2.4-5.



CEC JOB NO.	1083-000		
BY	DU	DATE	6/7/97
CHECK	K	DATE	6/12/97
CALC. NO.	SC(P017)-1	REV. NO.	0
SHEET NO.	110		

FIG. 5.2.4 - 6



V20812ATD, PFSF, 3' PAD, 2 CASKS, MU=0.8, FZ ON NODE 249 (K-FT)



CEC JOB NO.	1083-000		
BY	DH	DATE	6/7/97
CHECK	W	DATE	6/12/97
CALC. NO.	SC(P017)-1	REV. NO.	0
SHEET NO.	111		

FIG. 5.2.4 - 7



V20812ATD, PFSF, 3' PAD, 2 CASKS, MU=0.8, FZ ON NODE 249 (K-FT)



CEC JOB NO.	1083-000	
BY	DB	DATE 6/7/97
CHECK	KV	DATE 6/12/97
CALC. NO.	SC(P017)-1	REV. NO. 0
SHEET NO.	112	

FIG. 5.2.4-8



V20812ATD, PFSF, 3' PAD, 2 CASKS, MU=0.8, FZ ON NODE 249 (K-FT)



CEC JOB NO.	1083-060
BY	DK
DATE	6/7/97
CHECK	W
DATE	6/12/97
CALC. NO.	SC(P017)-1
REV. NO.	0
SHEET NO.	113


FIG. 5.2.4-9

V208128TD, PFSF, 3' PAD, 2 CASKS, MU=0.8, FZ ON NODE 249 (K-FT)



CEC JOB NO.	1083-000
BY	DH
DATE	6/13/97
CHECK	KV
DATE	6/13/97
CALC. NO.	SC(P017)-1
REV. NO.	0
SHEET NO.	114


FIG. 5.2.4-10



CEC JOB NO.	1083-000		
BY	1214	DATE	6/13/97
CHECK	K	DATE	6/13/97
CALC. NO.	SC(P017)-1	REV. NO.	6
SHEET NO.	115		

FIG. 5.2.4-11



V208128TD, PF5F, 3' PAD, 2 CASKS, MU=0.8, FZ ON NODE 249 (K-FT)



CEC JOB NO.	1083-000
BY	DLT
DATE	6/13/97
CHECK	✓
DATE	6/13/97
CALC. NO.	SC(P017)-1
REV. NO.	0
SHEET NO.	116

FIG 5.2.4-112

V20812BTD, PFSF, 3' PAD, 2 CASKS, MU=0.8, FZ ON NODE 249 (K-FT)




CEC JOB NO.	1083-000
BY	124
DATE	6/13/97
CHECK	✓
DATE	6/13/97
CALC. NO.	SC(P017)-1
REV. NO.	0
SHEET NO.	117


FIG. 5.2.4- F3

SASSI- MAX/MIN Z-DISPL. DUE TO F2 ON NODE 249 (REF. OUTPUT f249za001bm)

FIG. 5.2.4-14



CEC JOB NO.	1083-000		
BY	DT	DATE	6/7/97
CHECK	KK	DATE	6/12/97
CALC. NO.	SC (P017)	REV. NO.	0
SHEET NO.	118		






CEC JOB NO. 1083-000
 BY DH DATE 6/7/97
 CHECK M(LF) STD DATE 6/12/97
 CALC. NO. SC(9017)-1 REV. NO. 0
 SHEET NO. 119

SASSI TAPE 12 = V20B12A.12
 INPUT TIME HISTORY = VERTICAL, 2 CASKS, FR=0.8, 1ST CASK, QUAD NO.2 (KIPS)
 UNITS OF FORCE ARE K, UNITS OF LENGTH ARE FT AND RADIANS

FIG. 5.2.4-15

V20812A00, PFSF, 3' PAD, 2 CASKS, MU=0.8, FZ ON NODE 249 (K-FT)






CEC JOB NO. 1083-000
 BY DH DATE 6/7/97
 CHECK (K&L) STD DATE 6/12/97
 CALC. NO. SC (R07)-1 REV. NO. 0
 SHEET NO. 126

SASSI TAPE 12 = V20812A.12

INPUT TIME HISTORY = VERTICAL, 2 CASKS, FR=0.8, 1ST CASK, QUAD NO.2 (KIPS)
 UNITS OF FORCE ARE K, UNITS OF LENGTH ARE FT AND RADIANS

FIG. 5.2.4-16

V20812A00, PFSF, 3' PAD, 2 CASKS, MU=0.8, FZ ON NODE 249 (K-FT)






CEC JOB NO. 1083-060
 BY DH DATE 6/7/97
 CHECK W (1) STD DATE 6/12/97
 CALC. NO. SC (P17)-1 REV. NO. 0
 SHEET NO. 1A1

SASSI TAPE 12 = V20812A.12

INPUT TIME HISTORY = VERTICAL, 2 CASKS, FR=0.8, 1ST CASK, QUAD NO.2 (KIPS)
 UNITS OF FORCE ARE K, UNITS OF LENGTH ARE FT AND RADIANS

FIG. 5.2.4-17

V20812A00, PFSF, 3' PAD, 2 CASKS, MU=0.8, FZ ON NODE 249 (K-FT)






CEC JOB NO. 1083-000
 BY DH DATE 6/7/97
 CHECK W (L) SID DATE 6/12/97
 CALC. NO. SC(P17)-1 REV. NO. 0
 SHEET NO. 122

SASSI TAPE 12 = V20812A.12

INPUT TIME HISTORY = VERTICAL, 2 CASKS, FR=0.8, 1ST CASK, QUAD NO.2 (KIPS)
 UNITS OF FORCE ARE K, UNITS OF LENGTH ARE FT AND RADIANS

FIG. 5.2.4-18

V20812A0D, PFSF, 3' PAD, 2 CASKS, MU=0.8, FZ ON NODE 249 (K-FT)






CEC JOB NO. 1083-000
 BY DH DATE 6/7/97
 CHECK K (LF) SITE DATE 6/12/97
 CALC. NO. SC(R017)-1 REV. NO. 0
 SHEET NO. 123

SASSI TAPE 12 = V20812A.12

INPUT TIME HISTORY = VERTICAL, 2 CASKS, FR=0.8, 1ST CASK, QUAD NO.2 (KIPS)
 UNITS OF FORCE ARE K, UNITS OF LENGTH ARE FT AND RADIANS

FIG. 5.2.4-19

V20812ADD, PFSF, 3' PAD, 2 CASKS, MU=0.8, FZ ON NODE 249 (K-FT)






CEC JOB NO. 1083-060
 BY BH DATE 6/7/97
 CHECK M (LF) SD DATE 6/12/97
 CALC. NO. SC (P017)-1 REV. NO. 0
 SHEET NO. 124

SASSI TAPE 12 = V20812A.12

INPUT TIME HISTORY = VERTICAL, 2 CASKS, FR=0.8, 1ST CASK, QUAD NO.2 (KIPS) Fig. 5.2.4-20
 UNITS OF FORCE ARE K, UNITS OF LENGTH ARE FT AND RADIANS

V20812A00, PFSF, 3' PAD, 2 CASKS, MU=0.8, FZ ON NODE 249 (K-FT)






CEC JOB NO. 1083-000
 BY DH DATE 6/7/97
 CHECK W (L) SID DATE 6/12/97
 CALC. NO. SC(P017)-1 REV. NO. 0
 SHEET NO. 125

SASSI TAPE 12 = V20812A.12

INPUT TIME HISTORY = VERTICAL, 2 CASKS, FR=0.8, 1ST CASK, QUAD NO.2 (KIPS)
 UNITS OF FORCE ARE K, UNITS OF LENGTH ARE FT AND RADIANS

FIG. 5.2.4-21

V20812ADD, PFSF, 3' PAD, 2 CASKS, MU=0.8, FZ ON NODE 249 (K-FT)



CEC JOB NO.	1083-000
BY	DH
CHECK	W (LF) STD
CALC. NO.	SC (P017)-1 REV. NO. 0
SHEET NO.	126
DATE	6/7/97
DATE	6/12/97


SASSI TAPE 12 = V20812A.12

INPUT TIME HISTORY = VERTICAL, 2 CASKS, FR=0.8, 1ST CASK, QUAD NO.2 (KIPS)

UNITS OF FORCE ARE K, UNITS OF LENGTH ARE FT AND RADIANS

FIG. 5.2.4-22

V20812A00, PFSF, 3' PAD, 2 CASKS, MU=0.8, FZ ON NODE 249 (K-FT)




CEC JOB NO. 1083-000
 BY CH DATE 6/7/97
 CHECK W (LF) DATE 6/12/97
 CALC. NO. SC(P17)-1 REV. NO. 0
 SHEET NO. 27

SASSI TAPE 12 = V20812A.12

INPUT TIME HISTORY = VERTICAL, 2 CASKS, FR=0.8, 1ST CASK, QUAD NO.2 (KIPS)
 UNITS OF FORCE ARE K, UNITS OF LENGTH ARE FT AND RADIANS

Fig. 5.2.4- 23

V20812A00, PFSF, 3' PAD, 2 CASKS, MU=0.8, FZ ON NODE 249 (K-FT)



CEC JOB NO. 1083-003
 BY DH DATE 6/3/97
 CHECK W (LF) DATE 6/19/97
 CALC. NO. SC(P017)-1 REV. NO. 0
 SHEET NO. 12-8




SASSI TAPE 12 = V20812A.12

INPUT TIME HISTORY = VERTICAL, 2 CASKS, FR=0.8, 1ST CASK, QUAD NO.2 (KIPS)

UNITS OF FORCE ARE K, UNITS OF LENGTH ARE FT AND RADIANS

FIG. 5.2.4-24

V20812A00, PFSF, 3' PAD, 2 CASKS, MU=0.8, FZ ON NODE 249 (K-FT)



CEC JOB NO. 1083-000
 BY dh (H) DATE 6/7/97
 CHECK W DATE 6/12/97
 CALC. NO. SC(P017)-1 REV. NO. 0
 SHEET NO. 129




SASSI TAPE 12 = V20812A.12

INPUT TIME HISTORY = VERTICAL, 2 CASKS, FR=0.8, 1ST CASK, QUAD NO.2 (KIPS)

UNITS OF FORCE ARE K, UNITS OF LENGTH ARE FT AND RADIANS

FIG. S.2.4-25

V20812ADD, PFSF, 3' PAD, 2 CASKS, MU=0.8, FZ ON NODE 249 (K-FT)






CEC JOB NO. 1083-060
 BY DH
 CHECK W (L) SID DATE 6/2/97
 CALC. NO. SC(P017)-1 REV. NO. 0
 SHEET NO. 130

SASSI TAPE 12 = V20812A.12

INPUT TIME HISTORY = VERTICAL, 2 CASKS, FR=0.8, 1ST CASK, QUAD NO.2 (KIPS)
 UNITS OF FORCE ARE K, UNITS OF LENGTH ARE FT AND RADIANS

FIG. 5.2.4-26

V208128TD, PFSF, 3' PAD, 2 CASKS, MU=0.8, FZ ON NODE 249 (K-FT)




CEC JOB NO. 1083-000
 BY DH 95019-5005 6/13/97
 CHECK K DATE 6/16/97
 CALC. NO. SC(0017)-1 REV. NO. 6
 SHEET NO. 131

SASSI TAPE 14 = v20812b.14
 INPUT TIME HISTORY = VERTICAL, 2 CASKS, FR=0.8, 1ST CASK, QUAD NO.2 (KIPS)
 UNITS OF FORCE ARE K, UNITS OF LENGTH ARE FT AND RADIANS

F16, 5.2.4-27




CEC JOB NO.	1023-b00
BY	DH
CHECK	SSRIS/DRG
CALC. NO.	SC(P017)-1
DATE	6/16/97
REV. NO.	0
SHEET NO.	132



SASSI TAPE 14 = v20812b.14
 INPUT TIME HISTORY = VERTICAL, 2 CASKS, FR=0.8, 1ST CASK, QUAD NO.2 (KIPS)
 UNITS OF FORCE ARE K, UNITS OF LENGTH ARE FT AND RADIANS

FIG. 5.2.4-28

V20812BTD, PFSF, 3' PAD, 2 CASKS, MU=0.8, FZ ON NODE 249 (K-FT)






CEC JOB NO. 1083-000
 BY DH
 CHECK W
 CALC. NO. 5(1017)-1 REV. NO. 0
 SHEET NO. 133

SASSI TAPE 14 = v20812b.14

INPUT TIME HISTORY = VERTICAL, 2 CASKS, FR=0.8, 1ST CASK, QUAD NO.2 (KIPS)
 UNITS OF FORCE ARE K, UNITS OF LENGTH ARE FT AND RADIANS

FIG. 5.2.4-29

V208128TD, PFSF, 3' PAD, 2 CASKS, MU=0.8, FZ ON NODE 249 (K-FT)




CEC JOB NO. 1083-005
 BY DH
 CHECK W. SERRIS/3/2001
 DATE 6/13/97
 CALC. NO. SC(P97D)-1 REV. NO. 0
 SHEET NO. 134

SASSI TAPE 14 = v20812b.14
 INPUT TIME HISTORY = VERTICAL, 2 CASKS, FR=0.8, 1ST CASK, QUAD NO.2 (KIPS)
 UNITS OF FORCE ARE K, UNITS OF LENGTH ARE FT AND RADIANS


FIG. 5.2.4-30

FIG. 5.2.4-31

SASSI RESULTS (REF. V20812 bto. ibm)
(SEE ALSO TABLE 5.2.4-2)



CEC JOB NO.	1083-000
BY	DH
DATE	6/14/97
CHECK	W
DATE	6/16/97
CALC. NO.	SC(P017)-1
REV. NO.	0
SHEET NO.	135





CALCULATION SHEET

ORIGINATOR DH CALC. NO. SC(P017)-1 REV. NO. 0
PROJECT Private Fuel Storage Facility DATE 6/9/97 CHECKED W DATE 6/16/97
SUBJECT Storage Pad Analysis and Design JOB NO. 1083-000
SHEET NO. 136

5.2.5 COMPARISON OF CECSAP AND SASSI RESULTS

RESULTS OF THE CECSAP AND SASSI ANALYSES, IN TERMS OF MAXIMUM DISPLACEMENTS AND BENDING MOMENTS, ARE COMPARED IN TABLES 5.2.5-1 AND 5.2.5-2.

THE DISPLACEMENT TIME HISTORIES AT SELECTED NODES ARE PLOTTED TOGETHER FOR COMPARISON ON FIG. 5.2.5-1.

THE MOMENT TIME HISTORIES FOR ELEMENT 217 HAVE BEEN PLOTTED TOGETHER FOR COMPARISON IN FIGS. 5.2.5-2 THROUGH 5.2.5-4.

MAXIMUM SHEARS ARE COMPARED IN TABLE 5.2.5-3.

THE CECSAP RESULTS ARE CONSISTENTLY HIGHER THAN THE SASSI RESULTS. THUS, DESIGNING THE PAD USING THE CECSAP RESULTS WILL RESULT IN A MORE CONSERVATIVE DESIGN.



CALCULATION SHEET

ORIGINATOR MSD DATE 8-6-97 CALC. NO. SC(P017)-1 REV. NO. 0
PROJECT PFSF CHECKED DH DATE 6/9/97
SUBJECT _____ JOB NO. 1083-000
SHEET NO. 137

TABLE 5.2.5-1

Comparison between CEC SAP and SASSI

Loading : a single force time history for the 2nd quadrant of the 1st Cast for the 2 cast case was applied at Node 249, Node for the center of the 2nd quadrant of the 1st cast

Displacement Comparison

Left edge (A) (B) (B)/(A)-1) 100%

Node No. SASSI CEC SAP

144 0.0087' 0.0121' +39

157 0.0099' 0.0135' +36

170 0.0116 0.0158 +36

183 0.0136 0.0182 +34

196 0.0156 0.0208 +33

209 0.0184 0.0237 +29

222 0.0234 0.0279 +19

235 0.0267 0.0307 +15

248 0.0285 0.0332 +16

261 0.0280 0.0352 +26

274 0.0259 0.0367 +42

287 0.0240 0.0385 +60

Top Edge

287 0.0240 0.0385 +60

288 0.0209 0.0350 +67

289 0.0169 0.0305 +80

290 0.0143 0.0266 +86

291 0.0116 0.0226 +95

292 0.0095 0.0183 +93

293 0.0080 0.0151 +89

294 0.0065 0.0116 +78



CALCULATION SHEET

ORIGINATOR MSZ DATE 6-6-97 CALC. NO. SC(P017)-1 REV. NO. 0
PROJECT Private Fuel Storage Facility CHECKED DH DATE 6/9/97
SUBJECT Storage Pad Analysis and Design JOB NO. 108J-000
SHEET NO. 138

TABLE 5.2.5-2

Pad Bending Moment Comparison

Four elements around the loading point (Node 249) were chosen for comparison between CECSAP and SASSI in plate bending maximum values

Element No.	(A) * SASSI M_{yy}	(B) CECSAP M_{xx}	% $[(B)/(A)-1]100$
217	-82.56	-152.8	+85
218	-46.09	-79.78	+73
229	-81.02	-151.8	+87
230	-41.59	-77.78	+87
	M_{xx}	M_{yy}	
217	-411.5	-638.0	+55
218	-336.0	-498.1	+48
229	-414.4	-651.5	+57
230	-341.0	-514.2	+51

Conclusions

CECSAP calculates higher peak values. Especially the moment peaks by CECSAP are much higher than those by SASSI.

* NOTE = THE PLATE LOCAL X AND Y AXES IN THE SASSI MODEL CORRESPOND TO THE PLATE LOCAL Y AND X AXES IN THE CECSAP MODEL.



CALCULATION SHEET

ORIGINATOR PH DATE 6/14/97 CALC. NO. SC(P017)-1 REV. NO. 0
PROJECT Private Fuel Storage Facility CHECKED W DATE 6/16/97
SUBJECT Storage Pad Analysis and Design JOB NO. 1083-000
SHEET NO. 139

TABLE 5.2.5-3

PAD SHEAR COMPARISON

X-DIR

(A)

$$SASSI = \Delta M_{xx} / L$$

(B)

$$CECSAP = \Delta M_{xx} / L$$

$$\left(\frac{B}{A} - 1 \right) \times 100$$

ELEMENTS

[K-FT/FT]

[K-FT/FT]

205-206

1.69

217-218

15.40

30.81⁽¹⁾

100%

Y-DIR

(A)

$$SASSI = \Delta M_{yy} / L$$

(B)

$$CECSAP = \Delta M_{yy} / L$$

$$\left(\frac{B}{A} - 1 \right) \times 100$$

ELEMENTS

[K-FT/FT]

[K-FT/FT]

205-217

89.82

206-218

68.15

(1) FROM TABLE 5.2.5-2

$$(152.8 - 79.78) / 2.37 = 30.81$$

DISPLACEMENT TIME HISTORIES (CECSAP vs SASSI)









FIG. S.2.5-1-

SHEET NO. 140	
CALC. NO. SC (R017)-1 REV. NO. 0	
CHECK OH	DATE 6/9/97
BY M. J. R.	DATE 6-9-97
CEC JOB NO. 181083-00018	



CEC JOB NO.	1083-000
BY	ST-818
DATE	6-9-97
CHECK	PH
DATE	6/9/97
CALC. NO.	SC(P017)-1
REV. NO.	0
SHEET NO.	141

FIG. 5.2.5-2




FIG. 5.2.5-3

CEC JOB NO. 1083-006	
BY <u>mm</u>	DATE 6-9-97
CHECK <u>DH</u>	DATE 6/9/97
CALC. NO. <u>SC(P017)-1</u>	REV. NO. 0
SHEET NO. 142	

MOMENT TIME HISTORIES (CECSAP vs SASSI)




FIG 5.2.5-4

CEC JOB NO.	161083-00018
BY	DATE 6-9-97
CHECK DH	DATE 6/9/97
CALC. NO. SC(P017)-1	REV. NO. 0
SHEET NO.	143




CALCULATION SHEET

CALC. NO. SC(PO17)-1 REV. NO. 0

ORIGINATOR M. T. Egan DATE 5/28/07 CHECKED W DATE 6/2/07
PROJECT Private Fuel Storage Facility JOB NO. 1083-000
SUBJECT Storage Pad Analysis and Design SHEET NO. 144

5.3 SOIL PRESSURE


5.3.1 static soil pressure



L : Live Load
D : Dead Load


Load Case 1

2 tanks




Load Case 2

4 tanks



Load Case 3


8 tanks



Load Case 4

7 tanks +

one transporter with one tank





CALCULATION SHEET


ORIGINATOR M. Tsay DATE 5/28/97 CALC. NO. SC(P017)-1 REV. NO. 0
 PROJECT Private Fuel Storage Facility CHECKED W DATE 6/2/97
 SUBJECT Storage Pad Analysis and Design JOB NO. 1083-000
 SHEET NO. 145

The soil pressure under dead load and live load are to be checked with simplified procedure and later compare to computer analysis results.

Load case 1 with 2 casks acting

a. Soil pressure due to dead load $p_a = 0.150 \times 3 = 0.450 \text{ Ksf}$

b. Soil pressure due to live load of 2 casks



$$e = \text{eccentricity} = 22.5' > L/6 = 64/6 = 10.67'$$

$$\text{Let } L'/3 = L/2 - e; P = 8L'B/2, L' = 3 \times (64/2 - 22.5) = 28.5'$$

$$q = \frac{2P}{3B(L/2 - e)}; P = 2 \times 356.521, B = 30', L = 64'$$

$$q = 2 \times (2 \times 356.521) / (3 \times 30 (64/2 - 22.5)) = 1.668 \text{ Ksf}$$

$$P = p_a + q = 0.450 + 1.668 = 2.12 \text{ Ksf} < 4 \text{ Ksf (Ref. 8, P. 4-5)}$$



CALCULATION SHEET

CALC. NO. SC(PD17)-1 REV. NO. 0

ORIGINATOR M. Tsay DATE 5/28/97 CHECKED W DATE 6/2/97
PROJECT Private Fuel Storage Facility JOB NO. 1083-000
SUBJECT Storage Pad Analysis and Design SHEET NO. 146

Under the dead load, there will be no bending moment, since the downward concrete load always equal upward soil bearing pressure.

Sections A, B, C are to be checked for the bending moment due to live load.

$$\begin{aligned} f_A &= 1.668 \times (28.5 - 3.98) / 28.5 \\ &= 1.435 \text{ KSF} \end{aligned}$$

$$\begin{aligned} f_B &= 1.668 \times (28.5 - 3.98 - 11.04/2) / 28.5 \\ &= 1.112 \text{ KSF} \end{aligned}$$

$$\begin{aligned} f_C &= 1.668 \times (28.5 - 3.98 - 11.04) / 28.5 \\ &= 0.789 \end{aligned}$$

The bending moment at section A

$$\begin{aligned} M_{/30} &= 1.7 \times (1.435 \times \frac{1}{2} \times 3.98^2 + \frac{2}{3} \times \frac{1}{2} \times 3.98^2 \times (1.668 - 1.435)) \\ &= 1.7 \times (11.365 + 1.230) \\ &= 1.7 \times 12.595 \\ &= 21.412 \text{ K-ft} \end{aligned}$$



CALCULATION SHEET

CALC. NO. SC(PD17)-1 REV. NO. 0

ORIGINATOR M. Saw DATE 5/28/97 CHECKED W DATE 6/2/97
PROJECT Private Fuel Storage Facility JOB NO. 1083-000
SUBJECT Storage Pad Analysis and Design SHEET NO. 147

The bending moment at section B

$$\begin{aligned} M_{/30} &= 1.7 \times (1.112 \times \frac{1}{2} \times 9.5^2 + \frac{1}{3} \times 9.5^2 \times (1.668 - 1.112) \\ &\quad - \frac{1}{2} \times 2 \times 356.521 \times 0.4244 \times 5.52/30) \\ &= 1.7 \times (50.179 + 16.726 - 27.841) \\ &= 1.7 \times 39.064 \\ &= 66.409 \text{ K-ft/ft} \end{aligned}$$

The bending moment at section C

$$\begin{aligned} M_{/30} &= 1.7 \times (0.789 \times \frac{1}{2} \times (11.04 + 3.98)^2 + \frac{1}{3} \times (11.04 + 3.98)^2 \times \\ &\quad (1.668 - 0.789) - 2 \times 356.521 \times 5.52/30) \\ &= 1.7 \times (88.999 + 66.101 - 131.2) \\ &= 1.7 \times 23.90 \\ &= 40.63 \text{ K-ft/ft} \end{aligned}$$

Section B has the max. moment of 66.41 K-ft/ft.



CALCULATION SHEET

CALC. NO. SC(PD17)-1 REV. NO. 0


ORIGINATOR M. Tsay DATE 5/29/97
 PROJECT Private Fuel Storage Facility
 SUBJECT Storage Pad Analysis and Design

CHECKED W DATE 6/2/97
 JOB NO. 1083-000
 SHEET NO. 148

Load Case 2 with 4 casks

a. Soil pressure due to dead load $p_d = 0.150 \times 3 = 0.450$ ksf

b. Soil pressure due to live load of 4 casks



$$e = \text{eccentricity} = 15' > \frac{L}{6} = \frac{64}{6} = 10.67'$$

$$\text{Let } \frac{L'}{3} = \frac{L}{2} - e, \quad P = \frac{3LB}{2}; \quad L' = (64/2 - 15) \times 3 = 51'$$

$$g = \frac{2P}{3B(\frac{L}{2} - e)}; \quad P = 4 \times 356.521, \quad B = 30$$

$$g = \frac{2 \times 4 \times 356.521}{3 \times 30 \times (32 - 15)} = 1.864 \text{ ksf}$$

$$p = p_d + g = 0.450 + 1.864 = 2.31 \text{ ksf} < 4 \text{ ksf}$$

Soil pressure under section A, B, C, D, E, F

$$g_A = 1.864 \times (51 - 3.98) / 51 = 1.719$$

$$g_B = 1.864 \times (51 - 3.98 - 5.52) / 51 = 1.517$$



CALCULATION SHEET

ORIGINATOR M. Tsay DATE 5/5/97 CALC. NO. SC(P017)-1 REV. NO. 0
PROJECT Private Fuel Storage Facility CHECKED W DATE 6/2/97
SUBJECT Storage Pad Analysis and Design JOB NO. 1083-000
SHEET NO. 149

$$g_c = 1.864 \times (51 - 3.98 - 11.04) / 51 = 1.315$$

$$g_D = 1.864 \times (51 - 3.98 - 11.04 - 3.96) / 51 = 1.170$$

$$g_E = 1.864 \times (51 - 3.98 - 11.04 - 3.96 - 11.04/2) / 51 = 0.969$$

$$g_F = 1.864 \times (51 - 3.98 - 11.04 \times 2 - 3.96) / 51 = 0.767$$

Moment at section A

$$M_{A/30} = 1.7 \times \left(\frac{1}{2} \times 3.98^2 \times 1.719 + \frac{1}{2} \times 3.98^2 \times (1.864 - 1.719) \right)$$

$$= 1.7 \times (13.615 + 0.766)$$

$$= 1.7 \times 14.381$$

$$= 24.447 \text{ K-ft/ft}$$

Moment at section B

$$M_{B/30} = 1.7 \times \left(\frac{1}{2} \times (3.98 + 5.52)^2 \times 1.517 + \frac{1}{2} \times 9.5^2 \times (1.864 - 1.517) \right)$$

$$- \frac{1}{2} \times 2 \times 356.521 \times 0.4244 \times 5.52/30$$

$$= 1.7 \times (68.455 + 10.439 - 27.841)$$

$$= 1.7 \times 51.053$$

$$= 86.791 \text{ K-ft/ft}$$



CALCULATION SHEET

CALC. NO. SC(D017)-1 REV. NO. 0

ORIGINATOR M. Tsang DATE 5/25/27 CHECKED KW DATE 6/2/97
PROJECT Private Fuel Storage Facility JOB NO. 1083-000
SUBJECT Storage Pad Analysis and Design SHEET NO. 150

Moment at section C

$$\begin{aligned} M_{C/30} &= 1.7 \times \left(\frac{1}{2} \times (9.5 + 5.52)^2 \times 1.315 + \frac{1}{3} \times (1.864 - 1.315) \times 15.02^2 \right. \\ &\quad \left. - 2 \times 356.521 \times 5.52/30 \right) \\ &= 1.7 \times (148.332 + 41.285 - 131.20) \\ &= 1.7 \times 58.417 \\ &= 99.31 \text{ K-ft/ft} \end{aligned}$$

Moment at section D

$$\begin{aligned} M_{D/30} &= 1.7 \times \left(\frac{1}{2} \times (15.02 + 3.96)^2 \times 1.17 + \frac{1}{3} \times (1.864 - 1.17) \times 18.98^2 \right. \\ &\quad \left. - 2 \times 356.521 \times (5.52 + 3.96)/30 \right) \\ &= 1.7 \times (210.741 + 83.336 - 225.321) \\ &= 1.7 \times 68.756 \\ &= 116.885 \text{ K-ft/ft} \end{aligned}$$

Moment at section E

$$\begin{aligned} M_{E/30} &= 1.7 \times \left(\frac{1}{2} \times (18.98 + 5.52)^2 \times 0.969 + \frac{1}{3} \times (1.864 - 0.969) \times 24.5 \right. \\ &\quad \left. - 2 \times 356.521 \times (5.52 \times 2 + 3.96)/30 - \frac{1}{2} \times 2 \times 356.521 \times 0.4244 \right. \\ &\quad \left. \times 5.52/30 \right) \end{aligned}$$



CALCULATION SHEET

ORIGINATOR M. Teany DATE 5/25/97 CALC. NO. SC(P017)-1 REV. NO. 0
PROJECT Private Fuel Storage Facility CHECKED W DATE 6/2/97
SUBJECT Storage Pad Analysis and Design JOB NO. 1083-000
SHEET NO. 151

$$= 1.7 \times (290.821 + 179.075 - 356.521 - 27.841)$$

$$= 1.7 \times 85.534$$

$$= 145.408 \text{ K-ft/ft}$$

Moment at section F

$$M_{F/30} = 1.7 \times \frac{1}{2} \times 0.767 \times (51 - 2 \times 11.04 - 3.98 - 3.96)^2 \times \frac{1}{3}$$

$$= 1.7 \times 56.267$$

$$= 95.654 \text{ K-ft/ft}$$

Max. moment occur under section E

$$M_{max} = 1.7 \times 85.534 = 145.41 \text{ K-ft/ft}$$




CALCULATION SHEET

ORIGINATOR M. Tsav DATE 5/29/17 CALC. NO. SC(P017)-1 REV. NO. 0
 PROJECT Private Fuel Storage Facility CHECKED W DATE 6/2/17
 SUBJECT Storage Pad Analysis and Design JOB NO. 1083-000
 SHEET NO. 152

Load case 3 with 8 casks

a. Soil pressure due to dead load $p_d = 0.150 \times 3 = 0.450 \text{ ksf}$

b. Soil pressure due to live load of 8 casks



$$p_b = \frac{8 \times 356.521}{64 \times 30} = 1.486 \text{ ksf}$$

$$p = p_a + p_b = 0.450 + 1.486 = 1.94 \text{ ksf} < 4 \text{ ksf}$$

It is obvious that the shear equal zero occurs at center and 16' away from center

Bending moment at section A (16' from center)

$$\begin{aligned}
 M_{A/30} &= 1.7 \times (1.486 \times \frac{1}{2} \times 16^2 - 2 \times 356.521 \times (16 - 398 - 552)/30) \\
 &= 1.7 \times (190.208 - 154.492) \\
 &= 1.7 \times 35.716 = 60.717 \text{ k-ft/ft}
 \end{aligned}$$



CALCULATION SHEET

ORIGINATOR M. Tsay DATE 5/5/97 CALC. NO. SC(PD17)-1 REV. NO. 0
PROJECT Private Fuel Storage Facility CHECKED W DATE 6/2/97
SUBJECT Storage Pad Analysis and Design JOB NO. 1083-000
SHEET NO. 153

Bending moment at section B (at center)

$$M_{B/30} = 1.7 \times (1.486 \times \frac{1}{2} \times 32^2 - 2 \times 356.52) \times (22.5 + 7.5) / 30$$

$$= 1.7 \times (760.832 - 713.042)$$

$$= 1.7 \times 47.79$$

$$= 81.243 \text{ K-ft/ft}$$


Max. moment at section B = 81.243 K-ft/ft



CALCULATION SHEET

ORIGINATOR M. Tsai DATE 5/29/97 CALC. NO. SC(PD17)-1 REV. NO. 0
 PROJECT Private Fuel Storage Facility CHECKED KV DATE 6/2/97
 SUBJECT Storage Pad Analysis and Design JOB NO. 1083-000
 SHEET NO. 154

Load case 4 with 7 casks and one transporter loaded with one cask



In this load case, half of the transporter weight with one cask will be assumed at location where the last cask is supposed to be positioned.

This case is load case 3 plus 67.5 kips at

$$Y = -22.5' \text{ and } X = 7.5'$$

$$\begin{aligned} \text{Additional soil pressure } p_i &= \frac{67.5}{64 \times 30} + \frac{67.5 \times 22.5}{30 \times 64^{3/2}} + \frac{67.5 \times 7.5}{64 \times 30^{3/2}} \\ &= 0.035 + 0.074 + 0.053 \\ &= 0.162 \text{ ksf} \end{aligned}$$

$$\begin{aligned} \text{total soil pressure } p &= 0.450 + 1.486 + 0.162 = 2.1 \text{ ksf} \\ &< 4.0 \text{ ksf} \end{aligned}$$



CALCULATION SHEET

CALC. NO. SC(P017)-1 REV. NO. 0

ORIGINATOR M Tsay DATE 5/29/97 CHECKED W DATE 6/2/97

PROJECT Private Fuel Storage Facility JOB NO. 1083-000

SUBJECT Storage Pad Analysis and Design SHEET NO. 155

Soil pressure at section A, B with 67.5 kips transporter wt

$$P_A = \frac{67.5}{64 \times 30} + \frac{67.5 \times 22.5 \times 16}{30 \times 64^3 / 12} = 0.035 + 0.037 = 0.072 \text{ RSF}$$

$$P_B = \frac{67.5}{64 \times 30} + \frac{67.5 \times 22.5 \times 0}{30 \times 64^3 / 12} = 0.035 \text{ RSF}$$

Bending moment at A, B due to 67.5 kips transporter wt.

$$M_{A/30} = 1.7 \times (0.072 \times \frac{1}{2} \times 16^2 + \frac{1}{3} \times (0.035 + 0.072 - 0.072) \times 16^2 - 67.5 \times (22.5 - 16) / 30)$$

$$= 1.7 \times (9.216 + 3.157 - 14.625)$$

$$= 1.7 \times (-2.252)$$

$$= -3.828 \text{ K-ft/ft}$$

$$M_{B/30} = 1.7 \times (0.035 \times \frac{1}{2} \times 32^2 + \frac{1}{3} \times 0.074 \times 32^2 - 67.5 \times 22.5 / 30)$$

$$= 1.7 \times (17.92 + 25.259 - 52.625)$$

$$= 1.7 \times (-7.446)$$

$$= -12.658 \text{ K-ft/ft}$$

$$\text{moment at A} = 60.717 - 3.828 = 56.889 \text{ K-ft/ft}$$

$$\text{moment at B} = 81.243 - 12.658 = 68.585 \text{ K-ft/ft}$$



CALCULATION SHEET

ORIGINATOR M. Tsau DATE 6/10/97 CALC. NO. SC(P017)-1 REV. NO. 0
 PROJECT Private Fuel Storage Facility CHECKED KL DATE 6/10/97
 SUBJECT Storage Pad Analysis and Design JOB NO. 1083-000
 SHEET NO. 156

If 100% impact is assumed for the operating transporter lifting one cask

$$W_i = 2 \times \frac{1}{2} \times 135 + 356.5 = 491.5 \text{ kips}$$

Additional soil pressure $p_t = \frac{491.5}{64 \times 30} + \frac{491.5 \times 22.5}{30 \times 64^2/6} + \frac{491.5 \times 7.5}{64 \times 30^2/6}$
 $= 0.256 + 0.540 + 0.384$
 $= 1.180 \text{ Ksf}$

total soil pressure $p = 0.450 + 1.486 + 1.180$

$$= 3.12 \text{ ksf} < 4.0 \text{ ksf} \quad \text{O.K.}$$

Soil pressure at section A, B with 491.5 kips load

$$p_A = \frac{491.5}{64 \times 30} + \frac{491.5 \times 22.5 \times 16}{30 \times 64^2/12} = 0.256 + 0.270 = 0.526 \text{ ksf}$$

$$p_B = \frac{491.5}{64 \times 30} + \frac{135 \times 22.5 \times 0}{30 \times 64^2/12} = 0.256 \text{ ksf}$$

Bending moment at A, B due to 491.5 kips load

$$M_{A/B0} = 1.7 \times (0.526 \times \frac{1}{2} \times 16^2 + \frac{1}{3} \times (0.256 + 0.540 - 0.526) \times 16^2 - 491.5 \times (22.5 - 16)/30$$

$$= 1.7 \times (67.328 + 23.04 - 106.492)$$

$$= 1.7 \times (-16.124) = -27.410 \text{ K-ft/ft}$$



CALCULATION SHEET

CALC. NO. SC(PD17)-1 REV. NO. 0ORIGINATOR M. Tsay DATE 6/10/97 CHECKED W DATE 6/10/97PROJECT Private Fuel Storage Facility JOB NO. 1083-000SUBJECT Storage Pad Analysis and Design SHEET NO. 157

$$\begin{aligned} M_{B/30} &= 1.7 \times (0.256 \times \frac{1}{2} \times 32^2 + \frac{1}{3} \times 0.540 \times 32^2 - 49.5 \times \frac{22.5}{30}) \\ &= 1.7 \times (131.072 + 184.32 - 368.625) \\ &= 1.7 \times (-53.233) \\ &= -90.496 \text{ k-ft/ft} \end{aligned}$$

$$\text{Moment at A } M_A = 60.717 - 27.410 = 33.307 \text{ k-ft/ft}$$

$$\text{Moment at B } M_B = 81.243 - 90.496 = -9.253 \text{ k-ft/ft}$$



CALCULATION SHEET

CALC. NO. SC(2017-1) REV. NO. 0

ORIGINATOR M. Tsay DATE 6/10/97 CHECKED W DATE 6/10/97
PROJECT Private Fuel Storage Facility JOB NO. 1083-000
SUBJECT Storage Pad Analysis and Design SHEET NO. 158

In comparison, the static analysis using CEC SAP computer program has the following results:

Under Dead Load, soil pressure = $\frac{4.186}{(3.98+2.76) \times 2 \times 2.76} / 4$
= 0.45 ksf
(slit no 76)

Bending moment $M_{yy} = -4.703 \times 10^{-5}$ k-ft/ft
 ≈ 0 negligible

Live Load,

2 cars: Soil pressure, $P_{max} = 6.530E-02 \times 20$
= 1.31 ksf at node 294
(slit. no. 76)

$M_{yy, max} = -21.8$ k-ft/ft at element 229
(slit. no. 49)

4 cars: $P_{max} = 8.254E-02 \times 20$
= 1.65 ksf at node 289
(slit. no. 76)

$M_{yy, max} = -57.1$ k-ft/ft at element 169
(slit. no. 49)

8 cars: $P_{max} = 1.842E-02 \times 20$
= 1.57 ksf at node 147
(slit. no. 76)



CALCULATION SHEET

ORIGINATOR M. Tsay DATE 2/10/27 CALC. NO. SC(DD17)-1 REV. NO. 0
 PROJECT Private Fuel Storage Facility CHECKED W DATE 6/10/07
 SUBJECT Storage Pad Analysis and Design JOB NO. 1083-000
 SHEET NO. 159

$$M_{yy, max} = -37.4 \text{ k-ft/ft at element 97}$$

(Sht. No. 29)

For dead load, hand calculations and computer analysis have same results of soil pressure 0.45 ksf with no bending moment.

For live load, hand calculation computer analysis (Sht. No. 77)

2 casks,	soil pressure	1.67 ksf	1.31 ksf
	bending moment	39.06 k-ft/ft	21.8 k-ft/ft

4 casks,	soil pressure	1.86 ksf	1.65 ksf
	bending moment	85.53 k-ft/ft	57.1 k-ft/ft

8 casks,	soil pressure	1.486 ksf	1.57 ksf
	bending moment	47.79 k-ft/ft	37.4 k-ft/ft

8 casks with	soil pressure	2.67 ksf	3.05 ksf
one transporter	bending moment	33.31/1.7 = 19.59 k-ft/ft	45.6 k-ft/ft

(3.05 + 0.45 = 3.5 < 4.0)


It is concluded that the hand calculations are generally more conservative. Conservative values are used for static loading in design.



CALCULATION SHEET

CALC. NO. SC(P017)-1 REV. NO. 0ORIGINATOR M. Tsay DATE 6/17/97CHECKED W DATE 6/17/97PROJECT Private Fuel Storage FacilityJOB NO. 1083-000SUBJECT Storage Pad Analysis and DesignSHEET NO. 160

5.3.2 Dynamic Lateral soil pressure



For dynamic lateral soil pressure considered, there will have at rest pressure P_0 , earthquake active pressure P_{AE} and passive soil pressure P_P

$$P_0 = \frac{1}{2} K_0 \gamma H^2$$

where $K_0 = 0.43$, $\gamma = 0.125$ (backfill soil) Ref. 8

$$P_0 = \frac{1}{2} \times 0.43 \times 0.125 \times 3^2 = 0.24 \text{ K/ft}$$

$$P_{AE} = \frac{1}{2} \Delta K_{AE} \gamma H^2$$

where $\Delta K_{AE} = \frac{3}{4} \alpha_h$, $\alpha_h = 0.67$ and $\gamma = 0.125$ Ref. 8

$$P_{AE} = \frac{1}{2} \times \frac{3}{4} \times 0.67 \times 0.125 \times 3^2 = 0.28 \text{ K/ft}$$

$$P_P = \frac{1}{2} K_P \gamma H^2$$

where $K_P = 3.7$, $\gamma = 0.125$, Ref. 8

$$P_P = \frac{1}{2} \times 3.7 \times 0.125 \times 3^2 = 2.08 \text{ K/ft}$$



CALCULATION SHEET

ORIGINATOR M. Teay DATE 5/21/97 CALC. NO. SC(0017)-1 REV. NO. 0
PROJECT Private Fuel Storage Facility CHECKED DH DATE 6/2/97
SUBJECT Storage Pad Analysis and Design JOB NO. 1083-000
SHEET NO. 161

6. DESIGN CALCULATIONS

6.1 Design of Reinforced Concrete Pad

The cask storage pad individual dimensions are taken from Stone & Webster drawing No. 0599601-EC-1-B.

The center diameter used is in accordance with Holtec TSAR submittal for Docket Number 72-1008, outer diameter = 132.5" = 11.04'

Concrete properties:

$$f'_c = 4000 \text{ psi}, E_c = 57,000 \sqrt{f'_c} = 57,000 \sqrt{4000} \\ = 3.605 \times 10^6 \text{ psi} = 5.19 \times 10^5 \text{ KSF}$$

$$\nu = 0.17$$

$$f_y = 60,000 \text{ psi for ASTM A615 Grade 60}$$



CALCULATION SHEET

CALC. NO. SC(P017)-1REV. NO. 0ORIGINATOR M. Tsai DATE 6/6/97CHECKED WDATE 6/10/97PROJECT Private Fuel Storage FacilityJOB NO. 1083-000SUBJECT Storage Pad Analysis and DesignSHEET NO. 162

The following axial forces and bending moments per unit length are extracted from the computer dynamic analysis for maximum response case across 30 ft. section for 2 casks acting case @ time = 4.880 seconds

Element No.	Syy (k-ft/ft)	Myy (k-ft/ft)	Width (ft)	Syy*Width	Myy*Width
217	23.04	-695.00	1.98	45.62	-1376.10
218	-4.44	-571.30	2.76	-12.25	-1576.79
219	-12.42	-408.80	2.76	-34.28	-1128.29
220	-8.74	-311.40	2.76	-24.12	-859.46
221	-15.79	-303.50	2.76	-43.58	-837.66
222	-14.80	-353.40	1.98	-29.30	-699.73
223	-22.97	-419.80	1.98	-45.48	-831.20
224	-19.34	-398.60	2.76	-53.38	-1100.14
225	-13.52	-295.90	2.76	-37.32	-816.68
226	-9.35	-201.10	2.76	-25.81	-555.04
227	-29.14	-131.90	2.76	-80.43	-364.04
228	-57.86	-92.33	1.98	-114.56	-182.81

SUM	30	454.89	-10327.95
-----	----	--------	-----------

Weighted Ave.	-15.16	-344.26
---------------	--------	---------

The weighted average of axial force and bending moment are to be used for design


This calculation is same as sheet no. 70



CALCULATION SHEET

ORIGINATOR M. Tsay DATE 6/6/97 CALC. NO. SC(P017)-1 REV. NO. 0
 PROJECT Private Fuel Storage Facility CHECKED KL DATE 6/10/97
 SUBJECT Storage Pad Analysis and Design JOB NO. 1083-000
 SHEET NO. 163

Moment capacity per unit length (about X-X)



Using 2 #10 Each way at bottom per foot,
 1 #10 each way at top per foot

$$A_s = 2 \times 1.27 = 2.54 \text{ in}^2 \quad (\text{ACI 349-85(90) section 10.5})$$

$$A_s' = 1.27 \text{ in}^2$$

$$\text{require } \rho_{min} = 200/f_y = 200/60,000 = 0.0033$$

$$1 \#10 \text{ provide } \rho = 1.27 / (12 \times 32.34) = 0.0033$$

For $f_c' = 4000$ psi, $\beta_1 = 0.85$

$$f_y = 60,000 \text{ psi}$$

$$d = 36 - 3 - 1.27/2 - 0.875 = 31.49 \text{ inches} \quad (\#7 \text{ cross tie})$$

$$d' = 2 + 1.27/2 + 0.875 = 3.51 \text{ inches}$$



CALCULATION SHEET

ORIGINATOR

M. Tsang

DATE

6/6/97

CALC. NO. SC(P017)-1

REV. NO. 0

PROJECT

Private Fuel Storage Facility

CHECKED

KL

DATE

6/10/97

SUBJECT

Storage Pad Analysis and Design

JOB NO.

1083-000

SHEET NO.

164

$$a = \frac{A_s f_y}{0.85 f_c' b} = \frac{2 \times 1.27 \times 60}{0.85 \times 4 \times 12} = 3.74"$$

(Neglecting compressive rebar)

$$M_u = \phi M_n = \phi [A_s f_y (d - a/2)] = \phi [2 \times 1.27 \times 60 \times (31.49 - 3.74/2)]$$
$$= \phi \times 4,514.1 \text{ k-in}$$

$$= \phi \times 376.2 \text{ k-ft}$$

$$\text{Use } \phi = 0.9; \text{ DIF} = 1.25 \text{ (ACI 349-85, sec. C.2.1)}$$

$$M_u = 0.9 \times 376.2 = 338.6 \text{ k-ft}$$

$$(M_u)_{\text{DIF}} = 1.25 \times 0.9 \times 376.2 = 1.125 \times 376.2 = 423.2 \text{ k-ft}$$

The required strength

$$U_L > D + L + H + T + E$$

For bending moment, $M_D = M_H = M_T = 0$

$$M_U = M_L + M_E = 39.06 + 344.26 = 383.3 \text{ k-ft}$$

$$< 423.2 \text{ k-ft}$$

$$(M_L = 39.06 \text{ from sheet NO. 156, } M_E = 344.26 \text{ sheet NO. 162})$$



CALCULATION SHEET

ORIGINATOR M. Tsay DATE 6/6/97 CALC. NO. SC(P017)-1 REV. NO. 0
PROJECT Private Fuel Storage Facility CHECKED lv DATE 6/10/97
SUBJECT Storage Pad Analysis and Design JOB NO. 1083-000
SHEET NO. 165

moment capacity per unit length (about Y-Y)

$$d = 36" - 3" - 1.5 \times 1.27" - 0.875" = 30.22"$$

$$d' = 2" + 1.5 \times 1.27" + 0.875" = 4.78"$$

$$a = \frac{A_s f_y}{0.85 f_c' b} = \frac{2 \times 1.27 \times 60}{0.85 \times 4 \times 12} = 3.74"$$

(neglecting compressive rebar)

$$M_u = \phi M_o = \phi [A_s f_y (d - a/2)] = \phi [2 \times 1.27 \times 60 \times (30.22 - 4.78/2)]$$

$$= \phi \times 4,241.3 \text{ k-in.}$$

$$= \phi \times 353.4 \text{ k-ft}$$

use $\phi = 0.9$, DIF = 1.25 (ACI 349-85, sec. C.2.1)

$$M_u = 0.9 \times 353.4 = 318.1 \text{ k-ft}$$

$$(M_u)_{DIF} = 0.9 \times 1.25 \times 353.4 = 397.6 \text{ k-ft}$$

the required strength

$$U_c > D + L + H + T + E$$

For bending moment, $M_D = M_H = M_T = 0$

$$M_u = M_L + M_E = 8.7 + 300 = 308.7 \text{ ft-kips} < 397.6 \text{ ft-kips}$$

($M_L = 8.7$, $M_E = 300$ from computer output sheet Nos. 49 & 70)



CALCULATION SHEET

CALC. NO. SC(P017) REV. NO. 0

ORIGINATOR M. Tsay DATE 6/2/97 CHECKED W DATE 6/13/97

PROJECT Private Fuel Storage Facility JOB NO. 1083-000

SUBJECT Storage Pad Analysis and Design SHEET NO. 166

Shear stress across the section

Maximum shear stresses over the width of one tank

$$V_E = (149.457 \times 1.58 + (111.123 + 59.529 + 41.413 + 40.58) \times 2.76) / (1.98 + 4 \times 2.76)$$

(see calculation sheet No. 60)

$$= (295.92 + 697.3) / 13.02$$

$$= 76.3 \text{ k/ft}$$

$$V_c = \phi 2 \sqrt{f'_c} d = 0.85 \times 2 \times \sqrt{4000} \times 32.0 = 0.85 \times 4,048.0 \text{ lb/in}$$

$$= 0.85 \times 49.0 \text{ k/ft} = 41.7 \text{ k/ft}$$

Shear force at section for 2 tanks

$$V_a = 6.9 \text{ kips/ft} \quad (\text{slab. NO. 77})$$

$$V = V_E + V_a = 76.3 + 6.9 = 83.2 \text{ k/ft}$$

$$V_s = V - V_c = 83.2 - 41.7 = 41.5 \text{ k/ft}$$

$$V_s = A_v f_y d / s \quad \text{ACI 349-85 (9.0) eqn. (11-17)}$$

$$S = 12"; \quad f_y = 60 \text{ ksi}; \quad d = 32.0"$$

$$A_v = V_s s / (f_y d) = 41.5 \times 12 / (60 \times 32.0) = 0.31 \text{ in}^2/\text{ft}$$

1-#5 provide 0.31 in²


USE 1-#7 provide 0.6 in²



CALCULATION SHEET

ORIGINATOR M. Tsai DATE 5/12/17 CALC. NO. SC(P017)-1 REV. NO. 0
 PROJECT Private Fuel Storage Facility CHECKED W DATE 6/13/17
 SUBJECT Storage Pad Analysis and Design JOB NO. 1083-000
 SHEET NO. 167

Punching Shear



Punching shear failure
critical perimeter

$$b_o = \pi (5.02 + d/2) + d + (5.02 + d/2) \times 2$$


for $d = 32.0'' = 2.7'$

$$b_o = \pi (5.02 + 1.35) + 2.7 + (5.02 + 1.35) \times 2$$

$$= 20.02 + 2.7 + 12.74$$

$$= 35.46'$$

Critical Perimeter



$$V_u = \phi V_c = \phi 4\sqrt{4000} \times b_o d$$

$$= 0.85 \times 4 \times \sqrt{4000} \times (35.46 \times 12) \times 32.0$$

$$= 0.85 \times 3,445,000 \text{ lbs}$$

$$= 2,928 \text{ kips}$$

Holden, 2-catch can (Ref. 3)

$$V = 4503 + \frac{1}{2} (1800.2 + 1236) = 6021.1 \text{ kips}$$

Dynamic Demand $V = 6,021.1 - 356.5 = 5,664.6 \text{ kips}$



CALCULATION SHEET

ORIGINATOR M. Sav DATE 6/12/07 CALC. NO. SC(P017)-1 REV. NO. 0
 PROJECT Private Fuel Storage Facility CHECKED K DATE 6/13/07
 SUBJECT Storage Pad Analysis and Design JOB NO. 1083-000
 SHEET NO. 168

ACI 349-85, sect. C.3.7(b), $\mu = 1.6$ (μ = ductility ratio)

$$R_m = R_e / \sqrt{2\mu} \quad (\text{See following sheets for derivation})$$

$$R_m = V_m = 5843 / \sqrt{3.2-1} = 3939 \text{ kips}$$

ACI 349-85, sect. 11.11.3.2,

$$V_u \leq \phi V_n = \phi 6 \sqrt{f_c'} b_o d = 0.85 \times 6 \times \sqrt{4000} \times (35.46 \times 12) \times 32.34 \\ = 0.85 \times 5,222 \text{ kips} = 4439 \text{ kips} > 3,939 \text{ kips}$$

Shear force required by rebar (ACI 349-85, sect. 11.11.3.4, & (ACI 349-85, sect. C.2.1))

$$3,939 - \phi \text{ DIF} \times 2 \sqrt{4000} b_o d / 1000 = 3939 - 1.1 \times 0.85 \times 2 \times \sqrt{4000} \times 35.46 \times 12 \times 32 / 1000 \\ = 3939 - 1610 = 2329 \text{ kips}$$

$$V_s = 2329 / 35.46 = 65.7 \text{ kips/ft}$$

$$A_v = \frac{V_s \cdot s}{\phi f_y d}$$

$$s = 12", f_y = 60, d = 32.34$$

$$A_v = 65.7 \times 12 / (0.85 \times 60 \times 32.34) = 0.48 \text{ in}^2/\text{ft}$$

1-#7 provide 0.6 in²

or 2-#5 provide 0.62 in²

$$\text{Shear capacity} = V_c + V_s = \phi 2 \sqrt{4000} d \times 12 + \phi f_y d \cdot A_v / s$$

$$= 0.85 \times 2 \times \sqrt{4000} \times 32.0 \times 12 + 0.85 \times 60,000 \times 32.0 \times 0.6 / 12$$

$$= 41,300 + 81,600 \text{ lb/ft}$$

$$= 123.0 \text{ K/ft} > 3939 / 35.46 = 111.1 \text{ k/ft} \Rightarrow \text{O.K.}$$




CALCULATION SHEET

ORIGINATOR W.S. Tseng DATE 6/13/97 CALC. NO. SC(P017)-1 REV. NO.
PROJECT PRIVATE FUEL STORAGE FACILITY (PFSF) CHECKED MMT DATE 6/12/97
SUBJECT STORAGE PAD ANALYSIS AND DESIGN JOB NO. 1083-000
SHEET NO. 169

DERIVATION OF REDUCED CAPACITY TAKING CREDIT OF PERMISSIBLE
DUCTILITY RATIO (μ) AS PER ACI 349-85 (1990) SECTION C.3.7 (6)

DEFINITION :



$$\mu = \frac{x_m}{x_y} = \text{Ductility Ratio} ; x_m = \mu x_y$$

R_e = Elastic Resistance Capacity Required

R_m = Inelastic Resistance Capacity Required

K = Equivalent Stiffness



CALCULATION SHEET

ORIGINATOR W.S. / sang DATE 6/13/97 CALC. NO. SC(D017)-1 REV. NO. 6/2/97
PROJECT PRIVATE FUEL STORAGE FACILITY (PFSF) CHECKED mt JOB NO. 1083-000
SUBJECT STORAGE PAD ANALYSIS AND DESIGN SHEET NO. 170

$$x_y = \frac{R_m}{K} ; x_e = \frac{R_e}{K}$$

Use "Energy Balance Principle" $\Rightarrow$ Area ① = Area ②

$$\text{Area ①} = \frac{1}{2} (R_e - R_m) (x_e - x_y)$$

$$= \frac{1}{2} (R_e - R_m) (R_e - R_m) / K$$

$$= \frac{1}{2K} (R_e - R_m)^2$$

$$\text{Area ②} = R_m (x_m - x_e) = R_m \left(u \frac{R_m}{K} - \frac{R_e}{K} \right)$$

$$= \frac{1}{K} (u R_m^2 - R_e R_m)$$

Area ① = Area ② leads to :

$$\frac{1}{2K} (R_e - R_m)^2 = \frac{1}{K} (u R_m^2 - R_e R_m)$$

$$R_e^2 + R_m^2 - 2R_e R_m = 2u R_m^2 - 2R_e R_m$$

$$R_e^2 = (2u - 1) R_m^2$$

$$\therefore R_m = \frac{R_e}{\sqrt{2u - 1}}$$



CALCULATION SHEET

ORIGINATOR CO. S. Tseng DATE 6/13/97 CALC. NO. 3C(2017)-1 REV. NO. 6/13/97
PROJECT PRIVATE FUEL STORAGE FACILITY (PFSE) CHECKED mmr JOB NO. 1083-000
SUBJECT STORAGE PAD ANALYSIS & DESIGN SHEET NO. 171

As per ACI 349-85 (1990), Section C.3.7 (b): $\mu = 1.6$

$$\therefore R_m = \frac{R_e}{\sqrt{2 \times 1.6 - 1}} = \frac{R_e}{\sqrt{2.2}} = 0.674 R_e$$

$$R_m = 0.674 R_e \text{ for } \mu = 1.6$$




CALCULATION SHEET

ORIGINATOR M. Teady DATE 6/17/97 CALC. NO. SC(P017)-1 REV. NO. 0
PROJECT Private Fuel Storage Facility CHECKED W DATE 6/17/97
SUBJECT Storage Pad Analysis and Design JOB NO. 1083-000
SHEET NO. 172

Shear reinforcement area for punching shear

From Holtec Report HI-971631, Ref. 3, the cask will move about 10" radially. With semicircle punching





shear failure mode assumed, the shear reinforcement area to be covered thus become $R = 11.04\frac{1}{2} + 10" + d$
 $= 5.02 + 0.83 + 3\frac{3}{4} = 8.5'$

Required shear reinforcement will be placed equally everywhere.




CALCULATION SHEET

ORIGINATOR M. Tsay DATE 6/11/97 CALC. NO. SC(P017)-1 REV. NO. 0
PROJECT Private Fuel Storage Facility CHECKED KL DATE 6/17/97
SUBJECT Storage Pad Analysis and Design JOB NO. 1083-000
SHEET NO. 173



2-2
SCALE: 1/2" = 1'-0"

PLAN
CASK STORAGE PAD
(500 RECD)





CALCULATION SHEET

ORIGINATOR M. T. S. S. DATE 6/20/97 CALC. NO. SC(0017)-1 REV. NO. 0
PROJECT Private Fuel Storage Facility CHECKED K DATE 6/20/97
SUBJECT Storage Pad Analysis and Design JOB NO. 1083-000
SHEET NO. 174

6.2 Site Bearing Stability checks

6.2.1 Vertical soil bearing pressure and horizontal soil shear stresses

The soil pressures due to 7 casks with one transporter plus one cask and 100% impact from LECSAP (Attachment A) :


nodes	displacement (ft)	K_s (subgrade modulus)	P_s (k/ft)
287	-1.525E-01	20 k/ft^3	3.05
293	-1.135E-01	20	2.27
299	-7.743E-02	20	1.55
157	-1.141E-01	20	2.28
163	-8.931E-02	20	1.77
169	-6.477E-02	20	1.30
1	-2.444E-02	20	1.49
7	-4.836E-02	20	1.17
3	-4.20E-02	20	0.84



CALCULATION SHEET

CALC. NO. SC(PO17)-1 REV. NO. 0
CHECKED ms DATE 6-20-97
JOB NO. 1083-000
SHEET NO. 175

ORIGINATOR M. Tsay DATE 6/20/97
PROJECT Private Fuel Storage Facility
SUBJECT Storage Pad Analysis and Design



Vertical soil pressure for live load of 7 casks
plus one cask on Transporter with a dynamic
impact factor of 1.0

FIG. P-1



CALCULATION SHEET

CALC. NO. SC(P017)-REV. NO. 0

ORIGINATOR W DATE 6/20/97 CHECKED W DATE 6-20-97

PROJECT Private Fuel Storage Facility JOB NO. 1083-000

SUBJECT Storage Pad Analysis and Design SHEET NO. 176

SUMMARY OF DYNAMIC VERTICAL SOIL BEARING PRESSURES

Node No.	2 CASKS		4 CASKS		8 CASKS	
	$\Delta_{max}^{(1)}$ (ft)	$P^{(2)}$ (k/ft ²)	$\Delta_{max}^{(1)}$ (ft)	$P^{(2)}$ (k/ft ²)	$\Delta_{max}^{(1)}$ (ft)	$P^{(2)}$ (k/ft ²)
1	NA	0.	NA	0.	.03139	1.899
7	NA	0.	NA	0.	.01733	1.048
13	NA	0.	NA	0.	.04200	2.541
144	.01230	0.744	.01082	0.655	.03868	2.340
150	.00532	0.322	.00742	0.449	.01106	0.669
156	.00681	0.412	.01832	1.108	.04559	2.758
287	.05525	3.342	.03156	1.909	.03410	2.063
293	.03314	2.005	.02408	1.457	.01831	1.108
299	.02391	1.446	.03466	2.097	.04046	2.448

Notes : (1) - Δ_{max} obtained from CEC SAP shown on p. 75

$$(2) \quad P = \Delta_{max} \cdot K_v' = 60.494 \text{ K/FT/FT}^2$$

where $K_v' = \frac{K_v}{30' \times 64'}$, and $K_v = 9.679 \times 10^6 \frac{\text{LB}}{\text{IN}} = 1.1615 \times 10^5 \frac{\text{K}}{\text{FT}}$
(REF. 3, p. C-6)



CALCULATION SHEET

ORIGINATOR MSB DATE 6-20-97 CALC. NO. SC(P017)-1 REV. NO. 0
PROJECT Private Fuel Storage Facility CHECKED W DATE 6/20/97
SUBJECT Storage Pad Analysis and Design JOB NO. 1083-000
SHEET NO. 177






FIG. P-2

Maximum Vertical Soil Pressure (P_v) Due To Design Earthquake
(Excluding Pad Inertial Force)



CALCULATION SHEET


CALC. NO. SC(PD)177-1 REV. NO. 0

ORIGINATOR KW DATE 6/17/97 CHECKED 12/21 DATE 6/17/97

PROJECT Private Fuel Storage Facility JOB NO. 1083-000

SUBJECT Storage Pad Analysis and Design SHEET NO. 179

6.2.2 Horizontal Sliding Stability Check



To be conservative in lateral soil pressures, backfill soil is used as side soil at abutment.

Total at-rest pressure: $P_o = \frac{1}{2} K_o \gamma H^2$

where $K_o = 0.43$ and $\gamma = 0.125$ KCF (Backfill soil, see Ref. 8)

Total earthquake active pressure: $P_{AE} = \frac{1}{2} \Delta K_{AE} \gamma H^2$

where $\Delta K_{AE} = \frac{3}{4} \alpha_h$, $\alpha_h = 0.67$, and $\gamma = 0.125$ KCF (Ref. 8)

Total dynamic force acting on the pad:

$$P_B = (P_o^2 + P_{AE}^2)^{1/2}$$

where P_o = dynamic force acting on the pad resulting from applying dynamic loads exerted by the cranes on top of the pad as obtained from CECSAP analyses on p. 72, and $P_{AE} = W_{pad} \times \alpha_h = W_{pad} \times 0.67$

Allowable passive pressure: $P_p = \frac{1}{2} K_p \gamma H^2$

where $K_p = 3.7$, $\gamma = 0.125$ KCF (Ref. 8)

Allowable cohesive force: $P_f = c \times l \times w$

where $c = 2.2$ ksf, l = length of the pad in y-direction = $64'$,

and w = width of the pad = $30'$ (Ref. 8)



CALCULATION SHEET

ORIGINATOR K DATE 6/17/97 CALC. NO. SC(D017)-1 REV. NO. 0
PROJECT Private Fuel Storage Pad CHECKED MMT DATE 6/17/97
SUBJECT Storage Pad Analysis and Design JOB NO. 1083-000
SHEET NO. 180

Forces acting in the x-direction (short direction of the pad, 30') are calculated as follows:

$$P_o = \frac{1}{2} \times 0.43 \times 0.125 \times 3^2 \times 64 = 15.5 \text{ kips}$$

$$P_{AE} = \frac{1}{2} \times \left(\frac{3}{4} \times 0.67 \right) \times 0.125 \times 3^2 \times 64 = 18.1 \text{ kips}$$

$$P_c = F_x = 2030 \text{ kips (from CECSAP, 8 cases, see p. 72)}$$

$$P_I = .150 \times 30 \times 64 \times 3 \times 0.67 = 579 \text{ kips}$$

$$P_B = (2030^2 + 579^2)^{1/2} = 2111 \text{ kips}$$

$$P_p = \frac{1}{2} \times 3.7 \times .125 \times 3^2 \times 64 = 133 \text{ kips}$$

$$P_f = 2.2 \times 64 \times 30 = 4224 \text{ kips}$$

Forces acting in the y-direction (long direction of the pad, 64') are calculated as follows:

$$P_o = \frac{1}{2} \times 0.43 \times .125 \times 3^2 \times 30 = 7.3 \text{ kips}$$

$$P_{AE} = \frac{1}{2} \times \left(\frac{3}{4} \times 0.67 \right) \times .125 \times 3^2 \times 30 = 8.5 \text{ kips}$$

$$P_c = F_y = 1330 \text{ kips (from CECSAP, 8 cases, see p. 72)}$$

$$P_I = .150 \times 30 \times 64 \times 3 \times 0.67 = 579 \text{ kips}$$

$$P_B = (1330^2 + 579^2)^{1/2} = 1451 \text{ kips}$$

$$P_p = \frac{1}{2} \times 3.7 \times .125 \times 3^2 \times 30 = 62 \text{ kips}$$

$$P_f = 2.2 \times 64 \times 30 = 4224 \text{ kips}$$



CALCULATION SHEET

ORIGINATOR KV DATE 6/17/97 CALC. NO. SC(D0177)-1 REV. NO. 0
PROJECT Private Fuel Storage Pad CHECKED MTT DATE 6/17/97
SUBJECT Storage Pad Analysis and Design JOB NO. 1083-000
SHEET NO. 181

X-direction

Y-direction

P_0 15.5 kips 7.3 kips

P_{AE} 18.1 kips 8.5 kips

P_B 211.4 kips 145.1 kips

Total Lateral Force = P_D = 2145 kips 1467 kips

P_p 133 kips 62 kips

P_g 4224 kips 4224 kips

Total resistance = P_R = 4357 kips 4286 kips

Factor of safety against sliding ($FS_{sliding}$) in the X-direction can be calculated as:

$$FS_{sliding, x} = \frac{P_R}{P_D} = \frac{4357}{2145} = 2.03 > 1.1 \Rightarrow \text{no sliding (allowable, Ref. 8)}$$

$FS_{sliding}$ in the y-direction can be calculated as:

$$FS_{sliding, y} = \frac{P_R}{P_D} = \frac{4286}{1467} = 2.92 > 1.1 \Rightarrow \text{no sliding}$$

Appendix A and B
available upon request