

## SURVEILLANCE REQUIREMENTS

-----NOTE-----  
These SRs apply to each PAMI Function in Table 3.3.11-1, with exceptions noted.  
-----

SURVEILLANCE		FREQUENCY
SR 3.3.11.1	Perform CHANNEL CHECK for Function 9.	12 hours
SR 3.3.11.2	Perform CHANNEL CHECK for each required instrumentation channel, except Function 9, that is normally energized.	31 days
SR 3.3.11.3	Perform CHANNEL FUNCTIONAL TEST for function 9.	31 days
SR 3.3.11.4	Perform CHANNEL CALIBRATION, for functions 2,3,14,15,16,17, and 20.	18 months
SR 3.3.11.5	Perform CHANNEL CALIBRATION for functions 1,4,5,6,7,8,9,10,11,12,13,18, 19,21,22,23,24,25,26, and 27.	24 months