

Exelon Nuclear  
200 Exelon Way  
KSA 3-E  
Kennett Square, PA 19348

Telephone 610.765.5520  
www.exeloncorp.com

January 25, 2001

Docket Nos. 50-352  
50-353

License Nos. NPF-39  
NPF-85

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, DC 20555


Subject: Limerick Generating Station, Units 1 and 2  
NPDES Permit No. PA0051926

Dear Sir/Madam:

In accordance with Appendix B, Section 3.2 of the Limerick Generating Station Units 1 and 2 Operating Licenses, this letter is being submitted to provide copies of the approval by the Pennsylvania Department of Environmental Protection (PADEP) for change to NPDES permit No. PA0051926 to allow the use of Depositrol PY5200 as an alternate to Depositrol PY5204 in the cooling tower for both Units 1 and 2. Enclosed is a copy of the approval letter from the PADEP.

If you have any questions or require additional information, please do not hesitate to contact us.

Very truly yours,



James A. Hutton  
Director - Licensing

cc: H. J. Miller, Administrator, Region I, USNRC  
A. L. Burritt, USNRC Senior Resident Inspector, LGS  
C. Gratton, USNRC Senior Project Manager

cool



Pennsylvania Department of Environmental Protection

Lee Park, Suite 6010  
555 North Lane  
Conshohocken, PA 19428  
January 5, 2001

Southeast Regional Office

Ms. Karen L. Ferich  
Environmental Physicist  
PECO Energy Company  
200 Exelon Way  
Kennett Square, PA 19348

**RECEIVED**

610-832-6130  
Fax 610-832-6133

**JAN 17 2001**

**ENVIRONMENTAL DEPT.**

Re: Chemical Additives  
Limerick Generating Station  
NPDES Permit No. PA0051926  
Limerick Township  
Montgomery County

Dear Ms. Ferich:

We have reviewed your submittal dated December 8, 2000 regarding information on chemical additives currently in use, or proposed for use at this facility, which was submitted pursuant to Part C of the referenced NPDES permit. The use of these additives is hereby approved.

The usage rate of the chemical additive shall not exceed the following, pursuant to your submittal:

<u>Outfall</u>	<u>Additive</u>	<u>Maximum Allowable Rate (lb/day)</u>
001	Depositrol PY5200	4,000

The permittee shall be responsible for any impairment to water uses or NPDES permit violations that may occur as a result of the use of any chemical additive. The Department reserves the right to require that the use of these additives be discontinued if any adverse effect results from the discharge. The permittee shall notify the appropriate public authorities in the event of any overfeed as soon as it is discovered. Any violations of the conditions contained herein will be considered violations of the Clean Streams Law, 35 P.S. Section 691.1 et seq., June 22, 1937, P.L. 1987.

Please note that the enclosed chemical additives reporting form is to be completed for all chemical additives used at the facility. These forms are to be maintained in your records for a period of at least three years.


Ms. Karen L. Ferich

- 2 -

January 5, 2001

If you should have any questions, please call Mr. Sohan L. Garg at 610-832-6091.

Sincerely,

  
James Newbold, P.E.  
Regional Manager  
Water Management

Enclosure

cc: Delaware River Basin Commission  
Montgomery County Health Department  
Limerick Township  
Chief, Permits Section  
Operations Section  
File  
Re 30 (GJE01)005-2

## DATA REPORTING FORM - CHEMICAL ADDITIVES

Company Name: PECO Energy Company

NPDES Permit No. PA0051926

Outfall No.: 001 Limerick Generating Station

Month/Year: \_\_\_\_\_

Day	Discharge Rate (MGD)	Allowable Usage Rate (lbs/day)	Actual Usage Rate (lbs/day)	Effluent Concentration (mg/l)*	Additive Name
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					
31					

NOTE: The discharge rate is to be measured at the final outfall.

\* If chemical analysis of the outfall is performed, report results in this column.