

DISTRIBUTION
 Docket
 NRC PDR
 Local PDR
 ORB #2 Reading
 KR Goller
 TJCarter
 JMcGough
 DLZiemann
 EAReeves
 RMDiggs
 SVarga
 DEisenhut
 OI&E (3)
 Attorney, OELD
 BJones
 TBAbernathy, DTIE
 ACRS (16)
N. Reed

September 26, 1975

Docket No. 50-317

Baltimore Gas & Electric Company
 ATTN: Mr. A. E. Lundvall, Jr.
 Vice President - Supply
 Gas & Electric Building
 Charles Center
 Baltimore, Maryland 21203

Gentlemen:

This confirms our telephoned authorization given today, September 26, 1975, for a change in Technical Specifications for the Calvert Cliffs Nuclear Power Plant Unit 1 facility as requested by your telecopied letter dated and received on September 26, 1975. Facility Operating License No. DPR-53 is amended, effective immediately, by making the following technical specification change:

Paragraph 3.3.A.9 is amended to add the following to the end of the existing sentence:

Note: Valve CV-306 may be removed from service starting on September 26, 1975, for a period up to six hours for repair while the plant is maintained at temperatures below 300°F. Decay heat removal will be by the steam generator systems. Following repair to CV-306 this Note is void.

Copies of the license amendment, Federal Register Notice and Safety Evaluation for this technical specification change will be sent to you when completed.

B.G. (Douglas) was advised by telecon at 6:05 AM 9/26/75 of this action. EAReeves, OAS #2, Telecopier transmitted 6:10 PM, Sept 26, 1975 BCB
 cc: See next page

Sincerely,

Original signed by:
 Karl R. Goller

Karl R. Goller, Assistant Director
 for Operating Reactors
 Division of Reactor Licensing

Const 2

need final concurrence on final package

KRG

OFFICE →	RL:ORB #2	TR	OELD	RL:ORB #2	RL:AD/ORs
SURNAME →	EAReeves,ah	/	/	DLZiemann <i>(Bucley)</i>	KRGoller
DATE →	9/26/75	9/ /75	9/ /75	9/26/75	9/26/75

September 26, 1975

cc

Mr. James A. Biddison, Jr.
General Counsel
Gas and Electric Building
Charles Center
Baltimore, Maryland 21203

James C. Cawood, Jr., Esquire
Vice President
Chesapeake Environmental
Protection Association
4700 Auth Place
Camp Springs, Maryland 20023

George F. Trowbridge, Esquire
Shaw, Pittman, Potts and
Trowbridge
910 17th Street, N. W.
Washington, D. C. 20006

Bechtel Power Corporation
ATTN: Mr. R. L. Ashley
Chief Nuclear Engineer
P. O. Box 607
Gaithersburg, Maryland 20760

Combustion Engineering, Inc.
ATTN: Mr. J. A. Honey
Project Manager
P. O. Box 500
Windsor, Connecticut 06095

Calvert County Library
Prince Frederick, Maryland 20678

Mr. Bernard Fowler
President, Board of County
Commissioners
Prince Frederick, Maryland 20678

cc w/copy of BG&E's filing
dtd. 9/26/75:

Mr. Warren D. Hodges, Director
Department of State Planning
301 West Preston Street
Baltimore, Maryland 21201

Mr. Robert Blanco
Environmental Protection Agency
Curtis Building -
6th and Walnut Street
Philadelphia, Pennsylvania 19106