

MAY 28 1981

DISTRIBUTION

Docket File


NRC PDR
L PDR
TERA
NSIC
ORB#3 Rdg
Deisenhut
OELD
IE-4
GDeegan-4
OGC
BScharf=10
ACRS-10
OPA
RDiggs

MConner
PKreutzer
Gray File
ASLAB
TNovak

Docket No. 50-317

Mr. A. E. Lundvall, Jr.
Vice President, - Supply
Baltimore Gas & Electric Company
P. O. Box 1475
Baltimore, Maryland 21203

Dear Mr. Lundvall:



This confirms our oral authorization (telephone call from T. Novak and E. Conner, NRC to D. Zyrick, BG&E at 7:20pm on May 27, 1981) to change Technical Specification 3.3.3.6, Table 3.3-10 for Calvert Cliffs, Unit No. 1 in response to your telecopied request dated May 27, 1981. The change involves adding the following footnote, keyed to Item 13. (PORV/Safety Valve Acoustic Flow Monitor), to Table 3.3-10.

"Until June 1, 1981, the inoperable acoustic flow monitor for pressurizer safety valve RV-201 may be replaced by observation of quench tank temperature, level and pressure and the safety valve tail pipe temperatures once per shift."

Copies of the license amendment, our evaluation, and the Federal Register Notice for this Technical Specification change will be forwarded when completed.

Sincerely,

Thomas M. Novak, Assistant Director
for Operating Reactors
Division of Licensing

cc: See next page

810603 0013
p

CP
2

OFFICE	ORB#3:DL	ORB#3:DL	C-ORB#3:DL	AD:OR:DL		
SURNAME	PKreutzer	MConner	RAGlan	TNovak		
DATE	5/28/81	5/28/81	5/28/81	5/28/81		



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

Docket file

May 28, 1981

Docket No. 50-317

Mr. A. E. Lundvall, Jr.
Vice President - Supply
Baltimore Gas & Electric Company
P. O. Box 1475
Baltimore, Maryland 21203

Dear Mr. Lundvall:

This confirms our oral authorization (telephone call from T. Novak and E. Conner, NRC to D. Zyrick, BG&E at 7:20pm on May 27, 1981) to change Technical Specification 3.3.3.6, Table 3.3-10 for Calvert Cliffs, Unit No. 1 in response to your telecopied request dated May 27, 1981. The change involves adding the following footnote, keyed to Item 13. (PORV/Safety Valve Acoustic Flow Monitor), to Table 3.3-10.

"Until June 1, 1981, the inoperable acoustic flow monitor for pressurizer safety valve RV-201 may be replaced by observation of quench tank temperature, level and pressure and the safety valve tail pipe temperatures once per shift."

Copies of the license amendment, our evaluation, and the Federal Register Notice for this Technical Specification change will be forwarded when completed.

Sincerely,

Thomas M. Novak, Assistant Director
for Operating Reactors
Division of Licensing

cc: See next page

Baltimore Gas and Electric Company

cc:

James A. Biddison, Jr.
General Counsel
Baltimore Gas and Electric Company
P. O. Box 1475
Baltimore, MD 21203

George F. Trowbridge, Esquire
Shaw, Pittman, Potts and Trowbridge
1800 M Street, N. W.
Washington, D. C. 20036

Mr. R. C. L. Olson, Principal Engineer
Nuclear Licensing Analysis Unit
Baltimore Gas and Electric Company
Room 922 - G&E Building
P. O. Box 1475
Baltimore, MD 21203

Mr. Leon B. Russell
Plant Superintendent
Calvert Cliffs Nuclear Power Plant
Maryland Routes 2 & 4
Lusby, MD 20657

Bechtel Power Corporation
Attn: Mr. J. C. Judd
Chief Nuclear Engineer
15740 Shady Grove Road
Gaithersburg, MD 20760

Combustion Engineering, Inc.
Attn: Mr. P. W. Kruse, Manager
Engineering Services
P. O. Box 500
Windsor, CT 06095

Public Document Room
Calvert County Library
Prince Frederick, MD 20678

Director, Department of State Planning
301 West Preston Street
Baltimore, MD 21201

Mr. R. M. Douglass, Manager
Quality Assurance Department
Fort Smallwood Road Complex
P. O. Box 1475
Baltimore, MD 21203

Mr. T. L. Syndor, General Supervisor
Operations Quality Assurance
Calvert Cliffs Nuclear Power Plant
Maryland Routes 2 & 4
Lusby, MD 20657

Ms. Mary Harrison, President
Calvert County Board of County Commissioners
Prince Frederick, MD 20768

U. S. Environmental Protection Agency
Region III Office
Attn: EIS Coordinator
Curtis Building (Sixth Floor)
Sixth and Walnut Streets
Philadelphia, PA 19106

Mr. Ralph E. Architzel
Resident Reactor Inspector
NRC Inspection and Enforcement
P. O. Box 437
Lusby, MD 20657

Mr. Charles B. Brinkman
Manager - Washington Nuclear Operations
Combustion Engineering, Inc.
4853 Cordell Avenue, Suite A-1
Bethesda, MD 20014

Mr. J. A. Tierman, Manager
Nuclear Power Department
Calvert Cliffs Nuclear Power Plant
Maryland Routes 2 & 4
Lusby, MD 20657

Director, Criteria and Standards Division
Office of Radiation Programs (ANR-460)
U. S. Environmental Protection Agency
Washington, D. C. 20460

Mr. W. J. Lippold, Supervisor
Nuclear Fuel Management
Baltimore Gas and Electric Company
Calvert Cliffs Nuclear Power Plant
P. O. Box 1475
Baltimore, Maryland 21203

Mr. R. E. Denton, General Supervisor
Training & Technical Services
Calvert Cliffs Nuclear Power Plant
Maryland Routes 2 & 4
Lusby, MD 20657

Administrator, Power Plant Siting Program
Energy and Coastal Zone Administration
Department of Natural Resources
Tawes State Office Building
Annapolis, MD 21204